

ภาคผนวกที่ 7

แบบบันทึกการตรวจสอบระบบป้องกันอัคคีภัย


## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: August July Year: 2023

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)								Checked by	Date	Remark
				Section	Location	Type of Chemical			Physical		Gauge			
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure				
1	ACP-PFE-093	Ocean Wing 1	6000	/			/			/		mb	29/7/68	
2	ACP-PFE-094		6002	/			/			/		mb	29/7/68	
3	ACP-PFE-095		6004	/			/			/		mb	29/7/68	
4	ACP-PFE-096	Ocean Wing 2	6006	/			/			/		mb	29/7/68	
5	ACP-PFE-097		6008	/			/			/		mb	29/7/68	
6	ACP-PFE-098		6010	/			/			/		mb	29/7/68	
7	ACP-PFE-099	Ocean Wing 3	6012	/			/			/		mb	29/7/68	
8	ACP-PFE-100		6015	/			/			/		mb	29/7/68	
9	ACP-PFE-101		6016	/			/			/		mb	29/7/68	
10	ACP-PFE-102	Ocean Wing 4	6017	/			/			/		mb	29/7/68	
11	ACP-PFE-103		6020	/			/			/		mb	29/7/68	
12	ACP-PFE-104		6021	/			/			/		mb	29/7/68	
13	ACP-PFE-105	Ocean Wing 5	6023	/			/			/		mb	29/7/68	
14	ACP-PFE-106		6024	/			/			/		mb	29/7/68	
15	ACP-PFE-107		6026	/			/			/		mb	29/7/68	
16	ACP-PFE-108	Ocean Wing 7	6028	/			/			/		mb	29/7/68	
17	ACP-PFE-109		6031	/			/			/		mb	29/7/68	
18	ACP-PFE-110		6032	/			/			/		mb	29/7/68	
19	ACP-PFE-111	Ocean Wing 8	6035	/			/			/		mb	29/7/68	
20	ACP-PFE-112		6036	/			/			/		mb	29/7/68	
21	ACP-PFE-113		6038	/			/			/		mb	29/7/68	
22	ACP-PFE-114	Ocean Wing 9	6040	/			/			/		mb	29/7/68	
23	ACP-PFE-0115		6042	/			/			/		mb	29/7/68	
24	ACP-PFE-0116		6044	/			/			/		mb	29/7/68	


  
 AMARI PHUKET

CHIEF ENGINEER



# Engineering Department

## FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: July Year: 2025

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)						Checked by	Date	Remark			
				Section	Location	Type of Chemical			Physical				Gauge		
						Dry	Halotron	Wet chemical	Normal				Abnormal	Status	Pressure
25	ACP-PFE-0117		6046		/		/			Jame	29/9/68				
26	ACP-PFE-0118	Ocean Wing 11	6048		/		/								
27	ACP-PFE-0119		6050		/		/								
28	ACP-PFE-0120		6052		/		/								
29	ACP-PFE-0121		6053		/		/								
30	ACP-PFE-0122	Ocean Wing 12	6055		/		/								
31	ACP-PFE-0123		6057		/		/								
32	ACP-PFE-0124		6058		/		/								
33	ACP-PFE-0125		6060		/		/								
34	ACP-PFE-0126	Ocean Wing 13	6062		/		/								
35	ACP-PFE-0127		6063		/		/				Jame	29/9/68			
36	ACP-PFE-0128		6066		/		/								
37	ACP-PFE-0129		6067		/		/								
38	ACP-PFE-0130	Ocean Wing 15	6069		/		/								
39	ACP-PFE-0131		6071		/		/								
40	ACP-PFE-0132		6073		/		/								
41	ACP-PFE-0133		6075		/		/								
42	ACP-PFE-0134	Ocean Wing 17	6077		/		/								
43	ACP-PFE-0135		6079		/		/								
44	ACP-PFE-0136		6081		/		/								
45	ACP-PFE-0137		6083		/		/								
46	ACP-PFE-0138	Ocean Wing 19	6085		/		/								
47	ACP-PFE-0139		6086		/		/								
48	ACP-PFE-0140		6087		/		/								
49	ACP-PFE-0141		Ocean Wing 20	6089		/		/			Jame	29/9/68			

## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: July Year: 2025

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark		
				Section	Location	Type of Chemical			Physical					Gauge	
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure					
50	ACP-PFE-0142		6090		/		/			/		Jane	29/9/68		
51	ACP-PFE-143	Ocean Wing 21	6091		/		/			/					
52	ACP-PFE-144		6093		/		/			/					
53	ACP-PFE-145		6096		/		/			/					
54	ACP-PFE-146		6097		/		/			/					
55	ACP-PFE-147	Ocean Wing 22	6099		/		/			/					
56	ACP-PFE-148		6101		/		/			/					
57	ACP-PFE-149		6103		/		/			/					
58	ACP-PFE-150		6105		/		/			/					
59	ACP-PFE-151	Ocean Wing 23	6107		/		/			/		Jane	29/9/68		
60	ACP-PFE-152		6109		/		/			/					
61	ACP-PFE-153		6112		/		/			/					
62	ACP-PFE-154		6114		/		/			/					
63	ACP-PFE-155	Ocean Wing 25	6116		/		/			/					
64	ACP-PFE-156		6118		/		/			/					
65	ACP-PFE-157		6120		/		/			/					
66	ACP-PFE-158		6121		/		/			/					
67	ACP-PFE-159	Ocean Wing 27	6123		/		/			/					
68	ACP-PFE-160		6124		/		/			/					
69	ACP-PFE-161		6126		/		/			/					
70	ACP-PFE-162		6127		/		/			/					
71	ACP-PFE-163	Ocean Wing 29	6128		/		/			/					
72	ACP-PFE-164		6129		/		/			/					
73	ACP-PFE-165		6130		/		/			/			Jane	29/9/68	



## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: July 2025 Year: 2025

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)						Checked by	Date	Remark
				Type of Chemical	Physical		Gauge					
					Dry	Halotron	Wet chemical	Normal	Abnormal			
74	ACP-PFE-166	Ocean Wing 31	6131	/			/			Jame	29/7/68	
75	ACP-PFE-167		6132	/			/					
76	ACP-PFE-168	Ocean Wing 32	6133	/			/					
77	ACP-PFE-169		6134	/			/					
78	ACP-PFE-170	Ocean Wing 33	6135	/			/					
79	ACP-PFE-171		6136	/			/				n	n
80	ACP-PFE-172	Ocean Wing 34	6137	/			/					
81	ACP-PFE-173		6138	/			/					
82	ACP-PFE-174	Ocean Wing 35	6139	/			/					
83	ACP-PFE-175		6141	/			/					
84	ACP-PFE-176	Ocean Wing 36	6142	/			/			Jame	29/7/64	
85	ACP-PFE-177		6144	/			/					
86	ACP-PFE-178	Ocean Wing 37	6145	/			/					
87	ACP-PFE-179		6147	/			/					
88	ACP-PFE-180	Ocean Wing 38	6148	/			/					
89	ACP-PFE-181		6149	/			/					
90	ACP-PFE-182	Ocean Wing 39	6200	/			/			n	n	
91	ACP-PFE-183		6202	/			/					
92	ACP-PFE-184	Ocean Wing 40	6203	/			/					
93	ACP-PFE-185		6205	/			/					
94	ACP-PFE-186	Ocean Wing 41	6206	/			/					
95	ACP-PFE-187		6208	/			/					
96	ACP-PFE-188	Ocean Wing 42	6209	/			/					
97	ACP-PFE-189		6211	/			/				Jame	29/7/68

## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: July Year: 2023

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark		
				Type of Chemical	Physical		Gauge								
					Dry	Halotron	Wet chemical	Normal	Abnormal	Status				Pressure	
98	ACP-PFE-190	Ocean Wing 43	6212	/			/			/		Same	29/9/68		
99	ACP-PFE-191		6215	/			/				/				
100	ACP-PFE-192	Ocean Wing 44	6216	/			/			/					
101	ACP-PFE-193		6218	/			/				/				
102	ACP-PFE-194	Ocean Wing 45	6219	/			/			/					
103	ACP-PFE-195		6221	/			/				/		n		
104	ACP-PFE-196	Ocean Wing 46	6222	/			/			/					
105	ACP-PFE-197		6224	/			/				/				
106	ACP-PFE-198	Ocean Wing 47	6225	/			/			/					
107	ACP-PFE-199		6227	/			/				/				
108	ACP-PFE-200	Ocean Wing 48	6228	/			/			/			Same	29/9/68	
109	ACP-PFE-201		6230	/			/				/				
110	ACP-PFE-202	Ocean Wing 49	6231	/			/			/					165 Tony.
111	ACP-PFE-203		6233	/			/				/				
112	ACP-PFE-204	Ocean Wing 50	6234	/			/			/					
113	ACP-PFE-205		6236	/			/				/				
114	ACP-PFE-206	ARP	Club Pakarang	/			/			/					
115	ACP-PFE-207	ARP	MDB 4				/			/			n		
116	ACP-PFE-208	ARP	Club Pakarang 1	/			/			/					
117	ACP-PFE-209	ARP	Club Pakarang 2	/			/			/					
118	ACP-PFE-210	ARP	C/P Kitchen	/			/			/					
119	ACP-PFE-211	ARP	C/P Kitchen	/			/			/					
120	ACP-PFE-212	ARP	EE-Pakarang	/			/			/					
121	ACP-PFE-213	ARP	H/K 2	/			/			/					
122	ACP-PFE-214	ARP	Fire pump1	/			/			/			Same	29/9/68	

123 Tany.



# Engineering Department

## FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: July Year: 2023

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)					Checked by	Date	Remark
				Type of Chemical		Physical		Gauge			
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure	
123	ACP-PFE-215	ARP	Fire pump2		/		/		/		29/9/68
124	ACP-PFE-216	ARP	Generator2		/		/		/		
125	ACP-PFE-217	ARP	MDB3		/		/		/		
126	ACP-PFE-218	ARP	Staff toilet A7	/			/		/		
127	ACP-PFE-219	ARP	Transformer 4	/			/		/		
128	ACP-PFE-220	ARP	Coral Kitchen				/		/		
129	ACP-PFE-221	ARP	H/K1		/		/		/		
130	ACP-PFE-222	ARP	H/K3				/		/		
131	ACP-PFE-223	ARP	H/K4		/		/		/		29/9/68
132	ACP-PFE-224	ARP	Fire Pump3			/	/		/		

Acknowledge by: Kady as it

Fire-Life Safety Teamleader

Approved by:

Heads of Department





AMARI PHUKET  
DATE: 29/9/68  
MANAGER  
CHIEF ENGINEER

# Engineering Department

## FLS - 10 : Portable Fire Extinguishers

10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: July ..... Year: 2023 .....

Ite m no.	FLS CODE	Area		Fire Extinguisher						Checked by	Date	Remark	
		Section	Location	Type of Chemical		Physical		Gauge					
				Dry	Halotron	Wet chemical	Normal	Abnormal	Status				Pressure
1	ACP-PFE-001	Floor 1/1	1101		/		/		/		Kan	29/9/68	
2	ACP-PFE-002	Floor 1/2	1206		/		/		/				
3	ACP-PFE-003	Floor 2/1	2101		/		/		/				
4	ACP-PFE-004	Floor 2/2	2204		/		/		/				
5	ACP-PFE-005	Floor 3/1	3101		/		/		/				
6	ACP-PFE-006	Floor 3/2	3201		/		/		/		h		
7	ACP-PFE-007 	Floor 4/1	4101		/		/		/				
8	ACP-PFE-008	Floor 4/2	4205		/		/		/				
9	ACP-PFE-009	Floor 4/3	4305		/		/		/				
10	ACP-PFE-010	Building4	EE Room		/		/		/				
11	ACP-PFE-011	Building5	5105		/		/		/				
12	ACP-PFE-012	Building5	5205		/		/		/		Kan	29/9/68	
13	ACP-PFE-013	Building5	5305		/		/		/				
14	ACP-PFE-014	Building7	Coridor B7FL1		/		/		/				
15	ACP-PFE-015	Building7	Store B7FL 2		/		/		/				
16	ACP-PFE-016 	Building7	Store B7FL 3		/		/		/				
17	ACP-PFE-017	Building7	7107		/		/		/				
18	ACP-PFE-018	Building7	7123		/		/		/				
19	ACP-PFE-019	Building7	7207		/		/		/		h		
20	ACP-PFE-020	Building7	7223		/		/		/				
21	ACP-PFE-021 	Building7	7307		/		/		/				
22	ACP-PFE-022	Building7	7323		/		/		/				
23	ACP-PFE-023	Lagritta	La Gritta Kitchen		/	/	/		/				
24	ACP-PFE-024	Lagritta	La Gritta Kitchen		/		/		/				
25	ACP-PFE-025	Lagritta Bar	La Gritta bar		/		/		/				
26	ACP-PFE-026 	Main Store	Main Store		/		/		/		Kan	29/9/68	



Item no.	FLS CODE	Area		Fire Extinguisher								Checked by	Date	Remark
				Type of Chemical			Physical		Gauge					
		Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure						
27	ACP-PFE-027	Building 1	In Garden Room	/			/			/		Kal	27/9/68	
28	ACP-PFE-028	Building 1	In Florist Room	/			/			/				
29	ACP-PFE-029	Garbage	The Room	/			/			/				
30	ACP-PFE-030	Garbage	The Room	/			/			/				
31	ACP-PFE-031	Staff Canteen	In The Kitchen	/			/			/				
32	ACP-PFE-032	Staff Canteen	In The Kitchen	/			/			/				
33	ACP-PFE-033	Staff Canteen	In The Kitchen			/				/				
34	ACP-PFE-034	Staff Canteen	Station Gas	/			/			/				
35	ACP-PFE-035	Male Locker	In Staff Toilets	/			/			/		Kal	27/9/68	
36	ACP-PFE-036	Female Locker *	In Staff Toilets	/			/			/				
37	ACP-PFE-037	HR. Room	In HR. Room	/			/			/				
38	ACP-PFE-038	MDB3	Out HR. Room	/			/			/				
39	ACP-PFE-039	Lagritta Pool	Lagritta Pool	/			/			/				
40	ACP-PFE-040	Lobby	Entrance (OPR)	/			/			/				
41	ACP-PFE-041	Store bell	In The Room	/			/			/				
42	ACP-PFE-042	Executive Offices	Door Offices	/			/			/				
43	ACP-PFE-043	Lagittta Station Gas	Lobby	/			/			/				
44	ACP-PFE-044	Lagittta Station Gas	Lobby	/			/			/				
45	ACP-PFE-045	Security No.1	Enteance	/			/			/		Kal	27/9/68	
46	ACP-PFE-046	Security No.2	Lobby	/			/			/				
47	ACP-PFE-047	Security No.3 *	Old Time Kepper	/			/			/				
48	ACP-PFE-048	Accounting	In The Room	/			/			/				
49	ACP-PFE-049	Main Kitchen	Entrance	/			/			/				
50	ACP-PFE-050	Main Kitchen	Entrance	/			/			/				
51	ACP-PFE-051	Main Kitchen	Out The Room	/		/	/			/				
52	ACP-PFE-052	Main Kitchen	In The Room	/		/	/			/				
53	ACP-PFE-053	House Keeping	In The Room	/			/			/				
54	ACP-PFE-054	Generator MDB 1	Entrance			/	/			/				
55	ACP-PFE-055	Generator MDB 1	In The Room	/			/			/				
56	ACP-PFE-056	Laundry	Up The Stairs	/			/			/				
57	ACP-PFE-057	Laundry	Laundry	/			/			/				
58	ACP-PFE-058	Laundry	Laundry	/			/			/				
59	ACP-PFE-059	Laundry	Laundry	/			/			/		Kal	27/9/68	

Ite m no.	FLS CODE	Area		Fire Extinguisher							Checked by	Date	Remark	
				Section		Location		Type of Chemical						Physical
		Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure						
60	ACP-PFE-060	Laundry		Laundry	*	/			/			Kal	29/9/68	
61	ACP-PFE-061	Boiler room		Boiler room		/			/			/		
62	ACP-PFE-062	Eng. Work Shop		Tools Room		/			/			/		
63	ACP-PFE-063	Eng. Work Shop		MDB Room		/			/			/		
64	ACP-PFE-064	Eng. Work Shop		Painter Room		/			/			u		
65	ACP-PFE-065	Oil Station		Desel Tank			/		/			/		
66	ACP-PFE-066	Walkway Rim talay				/			/			/		
67	ACP-PFE-067	Voyagerlounge				/			/			/		
68	ACP-PFE-068	Gas Station		Laundry		/			/			Kal	29/9/68	
69	ACP-PFE-069	Mortorbike Garage1				/			/			/		
70	ACP-PFE-070	Mortorbike Garage2				/			/			/		
71	ACP-PFE-071	Rimtalay pump room				/			/			/		
72	ACP-PFE-072	Kid club				/			/			/		
73	ACP-PFE-073	Fire Training	*	HR.		/			/			h		-
74	ACP-PFE-074	PABX room				/			/			/		*
75	ACP-PFE-075	EE room B.2				/			/			/		
76	ACP-PFE-076	Pantry samurt bar 1		Samut Bar		/			/			/		
77	ACP-PFE-077	Pantry samurt bar 2		Samut Bar		/			/			Kal	29/9/68	
78	ACP-PFE-078	Idea Station Gas		Idea Room		/			/			/		
79	ACP-PFE-079	Sport Center				/			/			/		
80	ACP-PFE-080	Sport Center				/			/			/		
81	ACP-PFE-081	Server Room	*			/			/			/		
82	ACP-PFE-082			Front Spa		/			/			u		
83	ACP-PFE-083			Spa Reception		/			/			/		
84	ACP-PFE-084			Spa Sala 1		/			/			/		
85	ACP-PFE-085			Spa Sala 2		/			/			/		
86	ACP-PFE-086	*		Spa Sala 3		/			/			/		
87	ACP-PFE-087			Spa Sala 4		/			/			/		
88	ACP-PFE-088	Fitness				/			/			Kal	29/9/68	



Item no.	FLS CODE	Area		Fire Extinguisher							Checked by	Date	Remark
				Type of Chemical			Physical		Gauge				
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure			
89	ACP-PFE-089	Lift			/		✓		✓		Kol	29/7/65	
90	ACP-PFE-090	GM House			/		✓		/		Kol	29/7/65	
91	ACP-PFE-091	Jetty 1			/		/		/		Kol	29/7/65	
92	ACP-PFE-092	Jetty 2			/		✓		/		Kol	29/7/65	
93	ACP-PFE-093	Gas Station ✖	Laundry		/		/		/		Kol	29/7/65	

Acknowledge by: Kalyasit .....

Fire-Life Safety Teamleader

Approved by: .....

Heads of Department



# Engineering Department

## FLS - 10 : Portable Fire Extinguishers

10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: August Year: 2023

Ite m no.	FLS CODE	Area		Fire Extinguisher								Checked by	Date	Remark
		Section	Location	Type of		Chemical		Physical		Gauge				
				Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure				
1	ACP-PFE-001	Floor 1/1	1101	/	/		/		/	195 Psi	Janne	9/4/25		
2	ACP-PFE-002	Floor 1/2	1206	/	/		/		/	195 Psi	Janne	9/4/25		
3	ACP-PFE-003	Floor 2/1	2101	/	/		/		/	195 Psi	Janne	9/4/25		
4	ACP-PFE-004	Floor 2/2	2204	/	/		/		/	195 Psi	Janne	9/4/25		
5	ACP-PFE-005	Floor 3/1	3101	/	/		/		/	195 Psi	Janne	9/4/25		
6	ACP-PFE-006	Floor 3/2	3201	/	/		/		/	195 Psi	Janne	9/4/25		
7	ACP-PFE-007	Floor 4/1	4101	/	/		/		/	195 Psi	Janne	9/4/25		
8	ACP-PFE-008	Floor 4/2	4205	/	/		/		/	195 Psi	Janne	9/4/25		
9	ACP-PFE-009	Floor 4/3	4305	/	/		/		/	195 Psi	Janne	9/4/25		
10	ACP-PFE-010	Building4	EE Room	/	/		/		/	195 Psi	Janne	9/4/25		
11	ACP-PFE-011	Building5	5105	/	/		/		/	195 Psi	Janne	9/4/25		
12	ACP-PFE-012	Building5	5205	/	/		/		/	195 Psi	Janne	9/4/25		
13	ACP-PFE-013	Building5	5305	/	/		/		/	195 Psi	Janne	9/4/25		
14	ACP-PFE-014	Building7	Coridor B7FL1	/	/		/		/	195 Psi	Janne	9/4/25		
15	ACP-PFE-015	Building7	Store B7FL 2	/	/		/		/	195 Psi	Janne	9/4/25		
16	ACP-PFE-016	Building7	Store B7FL 3	/	/		/		/	195 Psi	Janne	9/4/25		
17	ACP-PFE-017	Building7	7107	/	/		/		/	195 Psi	Janne	9/4/25		
18	ACP-PFE-018	Building7	7123	/	/		/		/	195 Psi	Janne	9/4/25		
19	ACP-PFE-019	Building7	7207	/	/		/		/	195 Psi	Janne	9/4/25		
20	ACP-PFE-020	Building7	7223	/	/		/		/	195 Psi	Janne	9/4/25		
21	ACP-PFE-021	Building7	7307	/	/		/		/	195 Psi	Janne	9/4/25		
22	ACP-PFE-022	Building7	7323	/	/		/		/	195 Psi	Janne	9/4/25		
23	ACP-PFE-023	Lagritta	La Gritta Kitchen	/	/		/		/	195 Psi	Janne	9/4/25		
24	ACP-PFE-024	Lagritta	La Gritta Kitchen	/	/		/		/	195 Psi	Janne	9/4/25		
25	ACP-PFE-025	Lagritta Bar	La Gritta bar	/	/		/		/	195 Psi	Janne	9/4/25		
26	ACP-PFE-026	Main Store	Main Store	/	/		/		/	195 Psi	Janne	9/4/25		



45, 54, 55

Item no.	FLS CODE	Area		Fire Extinguisher							Checked by	Date	Remark
				Type of Chemical			Physical		Gauge				
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure			
27	ACP-PFE-027	Building 1	In Garden Room	/	/		/		/	195 Psi	Jane	9/4/25	
28	ACP-PFE-028	Building 1	In Florist Room	/			/		/	195 Psi	Jane	9/4/25	
29	ACP-PFE-029	Garbage	The Room	/			/		/	195 Psi	Jane	9/4/25	
30	ACP-PFE-030	Garbage	The Room	/			/		/	195 Psi	Jane	9/4/25	
31	ACP-PFE-031	Staff Canteen	In The Kitchen	/			/		/	195 Psi	Jane	9/4/25	
32	ACP-PFE-032	Staff Canteen	In The Kitchen	/			/		/	195 Psi	Jane	9/4/25	
33	ACP-PFE-033	Staff Canteen	In The Kitchen		/		/		/	195 Psi	Jane	9/4/25	
34	ACP-PFE-034	Staff Canteen	Station Gas	/			/		/	195 Psi	Jane	9/4/25	
35	ACP-PFE-035	Male Locker	In Staff Toilets	/			/		/	195 Psi	Jane	9/4/25	
36	ACP-PFE-036	Female Locker	In Staff Toilets	/			/		/	195 Psi	Jane	9/4/25	
37	ACP-PFE-037	HR. Room	In HR. Room	/			/		/	195 Psi	Jane	9/4/25	
38	ACP-PFE-038	MDB3	Out HR. Room	/			/		/	195 Psi	Jane	9/4/25	
39	ACP-PFE-039	Lagritta Pool	Lagritta Pool	/			/		/	195 Psi	Jane	9/4/25	
40	ACP-PFE-040	Lobby	Entrance (OPR)	/			/		/	195 Psi	Jane	9/4/25	
41	ACP-PFE-041	Store bell	In The Room	/			/		/	195 Psi	Jane	9/4/25	
42	ACP-PFE-042	Executive Offices	Door Offices	/			/		/	195 Psi	Jane	9/4/25	
43	ACP-PFE-043	Lagritta Station Gas	Lobby	/			/		/	195 Psi	Jane	9/4/25	
44	ACP-PFE-044	Lagritta Station Gas	Lobby	/			/		/	195 Psi	Jane	9/4/25	
45	ACP-PFE-045	Security No.1	Enteance	/			/		/	195 Psi	Jane	9/4/25	
46	ACP-PFE-046	Security No.2	Lobby	/			/		/	195 Psi	Jane	9/4/25	
47	ACP-PFE-047	Security No.3	Old Time Kepper	/			/		/	195 Psi	Jane	9/4/25	
48	ACP-PFE-048	Accounting	In The Room	/			/		/	195 Psi	Jane	9/4/25	
49	ACP-PFE-049	Main Kitchen	Entrance	/			/		/	195 Psi	Jane	9/4/25	
50	ACP-PFE-050	Main Kitchen	Entrance	/			/		/	195 Psi	Jane	9/4/25	
51	ACP-PFE-051	Main Kitchen	Out The Room		/		/		/	195 Psi	Jane	9/4/25	
52	ACP-PFE-052	Main Kitchen	In The Room		/		/		/	195 Psi	Jane	9/4/25	
53	ACP-PFE-053	House Keeping	In The Room	/			/		/	195 Psi	Jane	9/4/25	
54	ACP-PFE-054	Generator MDB 1	Entrance	/			/		/	195 Psi	Jane	9/4/25	
55	ACP-PFE-055	Generator MDB 1	In The Room	/			/		/	195 Psi	Jane	9/4/25	
56	ACP-PFE-056	Laundry	Up The Stairs	/			/		/	195 Psi	Jane	9/4/25	
57	ACP-PFE-057	Laundry	Laundry	/			/		/	195 Psi	Jane	9/4/25	
58	ACP-PFE-058	Laundry	Laundry	/			/		/	195 Psi	Jane	9/4/25	
59	ACP-PFE-059	Laundry	Laundry	/			/		/	195 Psi	Jane	9/4/25	



Ite m no.	FLS CODE	Area		Fire Extinguisher							Checked by	Date	Remark
				Type of Chemical			Physical		Gauge				
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure			
60	ACP-PFE-060	Laundry	Laundry		/		/		/	193 Psi	Jame	9/4/23	
61	ACP-PFE-061	Boiler room	Boiler room		/		/		/	193 Psi	Jame	9/4/23	
62	ACP-PFE-062	Eng. Work Shop	Tools Room		/		/		/	193 Psi	Jame	9/4/23	
63	ACP-PFE-063	Eng. Work Shop	MDB Room		/		/		/	193 Psi	Jame	9/4/23	
64	ACP-PFE-064	Eng. Work Shop	Painter Room /		/		/		/	193 Psi	Jame	9/4/23	
65	ACP-PFE-065	Oil Station	Desel Tank		/		/		/	193 Psi	Jame	9/4/23	
66	ACP-PFE-066	Walkway Rim talay			/		/		/	193 Psi	Jame	9/4/23	
67	ACP-PFE-067	Voyagerlounge			/		/		/	193 Psi	Jame	9/4/23	
68	ACP-PFE-068	Gas Station	Laundry		/		/		/	193 Psi	Jame	9/4/23	
69	ACP-PFE-069	Mortorbike Garage1			/		/		/	193 Psi	Jame	9/4/23	
70	ACP-PFE-070	Mortorbike Garage2			/		/		/	193 Psi	Jame	9/4/23	
71	ACP-PFE-071	Rimtalay pump room			/		/		/	193 Psi	Jame	9/4/23	
72	ACP-PFE-072	Kid club			/		/		/	193 Psi	Jame	9/4/23	
73	ACP-PFE-073	Fire Training			/		/		/	193 Psi	Jame	9/4/23	
74	ACP-PFE-074	PABX room			/		/		/	193 Psi	Jame	9/4/23	
75	ACP-PFE-075	EE room B.2			/		/		/	193 Psi	Jame	9/4/23	
76	ACP-PFE-076	Pantry samurt bar 1	Samut Bar		/		/		/	193 Psi	Jame	9/4/23	
77	ACP-PFE-077	Pantry samurt bar 2	Samut Bar		/		/		/	193 Psi	Jame	9/4/23	
78	ACP-PFE-078	Idea Station Gas	Idea Room		/		/		/	193 Psi	Jame	9/4/23	
79	ACP-PFE-079	Sport Center			/		/		/	193 Psi	Jame	9/4/23	
80	ACP-PFE-080	Sport Center			/		/		/	193 Psi	Jame	9/4/23	
81	ACP-PFE-081	Server Room			/		/		/	193 Psi	Jame	9/4/23	
82	ACP-PFE-082		Front Spa		/		/		/	193 Psi	Jame	9/4/23	
83	ACP-PFE-083		Spa Reception		/		/		/	193 Psi	Jame	9/4/23	
84	ACP-PFE-084		Spa Sala 1		/		/		/	193 Psi	Jame	9/4/23	
85	ACP-PFE-085		Spa Sala 2		/		/		/	193 Psi	Jame	9/4/23	
86	ACP-PFE-086		Spa Sala 3		/		/		/	193 Psi	Jame	9/4/23	
87	ACP-PFE-087		Spa Sala 4		/		/		/	193 Psi	Jame	9/4/23	
88	ACP-PFE-088	Fitness			/		/		/	193 Psi	Jame	9/4/23	



Item no.	FLS CODE	Area		Fire Extinguisher							Checked by	Date	Remark
				Type of Chemical			Physical		Gauge				
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure			
89	ACP-PFE-089	Lift			/		/		/	195 PSI	Jame	9/18/23	
90	ACP-PFE-090	GM House			/		/		/	195 PSI	Jame	9/18/23	
91	ACP-PFE-091	Jetty 1			/		/		/	195 PSI	Jame	9/18/23	
92	ACP-PFE-092	Jetty 2			/		/		/	195 PSI	Jame	9/18/23	
93	ACP-PFE-093	Gas Station	Laundry		/		/		/	195 PSI	Jame	9/18/23	

Approved by: Amari  
 DATE: 28/8/23  
 SINGINGER: Amari  
 CHIEF ENGINEER

Acknowledge by: Kalyasit

Fire-Life Safety Teamleader  
 Heads of Department



## FLS - 10 : Portable Fire Extinguishers

Month: August Year: 2023

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark
				Section	Location	Type of Chemical			Physical				
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure			
25	ACP-PFE-0117	Ocean Wing 11	6046	/			/		/	195 Psi	Jame	15/8/25	
26	ACP-PFE-0118		6048	/			/		/	195 Psi	Jame	15/8/25	
27	ACP-PFE-0119		6050	/			/		/	195 Psi	Jame	15/8/25	
28	ACP-PFE-0120		6052	/			/		/	195 Psi	Jame	15/8/25	
29	ACP-PFE-0121	Ocean Wing 12	6053	/			/		/	195 Psi	Jame	15/8/25	
30	ACP-PFE-0122		6055	/			/		/	195 Psi	Jame	15/8/25	
31	ACP-PFE-0123		6057	/			/		/	195 Psi	Jame	15/8/25	
32	ACP-PFE-0124		6058	/			/		/	195 Psi	Jame	15/8/25	
33	ACP-PFE-0125	Ocean Wing 13	6060	/			/		/	195 Psi	Jame	15/8/25	
34	ACP-PFE-0126		6062	/			/		/	195 Psi	Jame	15/8/25	
35	ACP-PFE-0127		6063	/			/		/	195 Psi	Jame	15/8/25	
36	ACP-PFE-0128		6066	/			/		/	195 Psi	Jame	15/8/25	
37	ACP-PFE-0129	Ocean Wing 14	6067	/			/		/	195 Psi	Jame	15/8/25	
38	ACP-PFE-0130		6069	/			/		/	195 Psi	Jame	15/8/25	
39	ACP-PFE-0131		6071	/			/		/	195 Psi	Jame	15/8/25	
40	ACP-PFE-0132		6073	/			/		/	195 Psi	Jame	15/8/25	
41	ACP-PFE-0133	Ocean Wing 15	6075	/			/		/	195 Psi	Jame	15/8/25	
42	ACP-PFE-0134		6077	/			/		/	195 Psi	Jame	15/8/25	
43	ACP-PFE-0135		6079	/			/		/	195 Psi	Jame	15/8/25	
44	ACP-PFE-0136		6081	/			/		/	195 Psi	Jame	15/8/25	
45	ACP-PFE-0137	Ocean Wing 16	6083	/			/		/	195 Psi	Jame	15/8/25	
46	ACP-PFE-0138		6085	/			/		/	195 Psi	Jame	15/8/25	
47	ACP-PFE-0139		6086	/			/		/	195 Psi	Jame	15/8/25	
	ACP-PFE-0140		6087	/			/		/	195 Psi	Jame	15/8/25	
	ACP-PFE-0141	Ocean Wing 17	6089	/			/		/	195 Psi	Jame	15/8/25	



## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: August Year: 2025

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)								Checked by	Date	Remark
				Section	Location	Type of Chemical			Physical		Gauge			
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure				
50	ACP-PFE-0142	Ocean Wing 21	6090	/			/		/	195 Psi	Jame	15/8/25		
51	ACP-PFE-143		6091	/			/		/	195 Psi	Jame	15/8/25		
52	ACP-PFE-144		6093	/			/		/	195 Psi	Jame	15/8/25		
53	ACP-PFE-145		6096	/			/		/	195 Psi	Jame	15/8/25		
54	ACP-PFE-146	Ocean Wing 22	6097	/			/		/	195 Psi	Jame	15/8/25		
55	ACP-PFE-147		6099	/			/		/	195 Psi	Jame	15/8/25		
56	ACP-PFE-148		6101	/			/		/	195 Psi	Jame	15/8/25		
57	ACP-PFE-149		6103	/			/		/	195 Psi	Jame	15/8/25		
58	ACP-PFE-150	Ocean Wing 23	6105	/			/		/	195 Psi	Jame	15/8/25		
59	ACP-PFE-151		6107	/			/		/	195 Psi	Jame	15/8/25		
60	ACP-PFE-152		6109	/			/		/	195 Psi	Jame	15/8/25		
61	ACP-PFE-153		6112	/			/		/	195 Psi	Jame	15/8/25		
62	ACP-PFE-154	Ocean Wing 25	6114	/			/		/	195 Psi	Jame	15/8/25		
63	ACP-PFE-155		6116	/			/		/	195 Psi	Jame	15/8/25		
64	ACP-PFE-156		6118	/			/		/	195 Psi	Jame	15/8/25		
65	ACP-PFE-157		6120	/			/		/	195 Psi	Jame	15/8/25		
66	ACP-PFE-158	Ocean Wing 27	6121	/			/		/	195 Psi	Jame	15/8/25		
67	ACP-PFE-159		6123	/			/		/	195 Psi	Jame	15/8/25		
68	ACP-PFE-160		6124	/			/		/	195 Psi	Jame	15/8/25		
69	ACP-PFE-161		6126	/			/		/	195 Psi	Jame	15/8/25		
70	ACP-PFE-162	Ocean Wing 29	6127	/			/		/	195 Psi	Jame	15/8/25		
71	ACP-PFE-163		6128	/			/		/	195 Psi	Jame	15/8/25		
72	ACP-PFE-164		6129	/			/		/	195 Psi	Jame	15/8/25		
73	ACP-PFE-165		6130	/			/		/	195 Psi	Jame	15/8/25		



## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: August Year: 2025

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark		
				Section	Location	Type of Chemical			Physical					Gauge	
						Dry	Halotron	Wet chemical	Normal	Abnormal				Status	Pressure
74	ACP-PFE-166	Ocean Wing 31	6131	/	/		/		/	195 Psi	Jame	15/8/25			
75	ACP-PFE-167		6132	/	/		/		/	195 Psi	Jame	15/8/25			
76	ACP-PFE-168	Ocean Wing 32	6133	/	/		/		/	195 Psi	Jame	15/8/25			
77	ACP-PFE-169		6134	/	/		/		/	195 Psi	Jame	15/8/25			
78	ACP-PFE-170	Ocean Wing 33	6135	/	/		/		/	195 Psi	Jame	15/8/25			
79	ACP-PFE-171		6136	/	/		/		/	195 Psi	Jame	15/8/25			
80	ACP-PFE-172	Ocean Wing 34	6137	/	/		/		/	195 Psi	Jame	15/8/25			
81	ACP-PFE-173		6138	/	/		/		/	195 Psi	Jame	15/8/25			
82	ACP-PFE-174	Ocean Wing 35	6139	/	/		/		/	195 Psi	Jame	15/8/25			
83	ACP-PFE-175		6141	/	/		/		/	195 Psi	Jame	15/8/25			
84	ACP-PFE-176	Ocean Wing 36	6142	/	/		/		/	195 Psi	Jame	15/8/25			
85	ACP-PFE-177		6144	/	/		/		/	195 Psi	Jame	15/8/25			
86	ACP-PFE-178	Ocean Wing 37	6145	/	/		/		/	195 Psi	Jame	15/8/25			
87	ACP-PFE-179		6147	/	/		/		/	195 Psi	Jame	15/8/25			
88	ACP-PFE-180	Ocean Wing 38	6148	/	/		/		/	195 Psi	Jame	15/8/25			
89	ACP-PFE-181		6149	/	/		/		/	195 Psi	Jame	15/8/25			
90	ACP-PFE-182	Ocean Wing 39	6200	/	/		/		/	195 Psi	Jame	15/8/25			
91	ACP-PFE-183		6202	/	/		/		/	195 Psi	Jame	15/8/25			
92	ACP-PFE-184	Ocean Wing 40	6203	/	/		/		/	195 Psi	Jame	15/8/25			
93	ACP-PFE-185		6205	/	/		/		/	195 Psi	Jame	15/8/25			
94	ACP-PFE-186	Ocean Wing 41	6206	/	/		/		/	195 Psi	Jame	15/8/25			
95	ACP-PFE-187		6208	/	/		/		/	195 Psi	Jame	15/8/25			
96	ACP-PFE-188	Ocean Wing 42	6209	/	/		/		/	195 Psi	Jame	15/8/25			
97	ACP-PFE-189		6211	/	/		/		/	195 Psi	Jame	15/8/25			



## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: August Year: 2025

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark
				Section	Location	Type of Chemical			Physical				
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure			
98	ACP-PFE-190	Ocean Wing 43	6212	/			/		/	195 Psi	Jame	15/8/25	
99	ACP-PFE-191		6215	/			/		/	195 Psi	Jame	15/8/25	
100	ACP-PFE-192	Ocean Wing 44	6216	/			/		/	195 Psi	Jame	15/8/25	
101	ACP-PFE-193		6218	/			/		/	195 Psi	Jame	15/8/25	
102	ACP-PFE-194	Ocean Wing 45	6219	/			/		/	195 Psi	Jame	15/8/25	
103	ACP-PFE-195		6221	/			/		/	195 Psi	Jame	15/8/25	
104	ACP-PFE-196	Ocean Wing 46	6222	/			/		/	195 Psi	Jame	15/8/25	
105	ACP-PFE-197		6224	/			/		/	195 Psi	Jame	15/8/25	
106	ACP-PFE-198	Ocean Wing 47	6225	/			/		/	195 Psi	Jame	15/8/25	
107	ACP-PFE-199		6227	/			/		/	195 Psi	Jame	15/8/25	
108	ACP-PFE-200	Ocean Wing 48	6228	/			/		/	195 Psi	Jame	15/8/25	
109	ACP-PFE-201		6230	/			/		/	195 Psi	Jame	15/8/25	
110	ACP-PFE-202	Ocean Wing 49	6231	/			/		/	195 Psi	Jame	15/8/25	
111	ACP-PFE-203		6233	/			/		/	195 Psi	Jame	15/8/25	
112	ACP-PFE-204	Ocean Wing 50	6234	/			/		/	195 Psi	Jame	15/8/25	
113	ACP-PFE-205		6236	/			/		/	195 Psi	Jame	15/8/25	
114	ACP-PFE-206	ARP	Club Pakarang	/			/		/	195 Psi	Jame	15/8/25	
115	ACP-PFE-207	ARP	MDB 4	/			/		/	195 Psi	Jame	15/8/25	
116	ACP-PFE-208	ARP	Club Pakarang 1	/			/		/	195 Psi	Jame	15/8/25	
117	ACP-PFE-209	ARP	Club Pakarang 2	/			/		/	195 Psi	Jame	15/8/25	
118	ACP-PFE-210	ARP	C/P Kitchen	/			/		/	195 Psi	Jame	15/8/25	
119	ACP-PFE-211	ARP	C/P Kitchen	/			/		/	195 Psi	Jame	15/8/25	
120	ACP-PFE-212	ARP	EE-Pakarang	/			/		/	195 Psi	Jame	15/8/25	
121	ACP-PFE-213	ARP	H/K 2	/			/		/	195 Psi	Jame	15/8/25	
122	ACP-PFE-214	ARP	Fire pump1	/			/		/	195 Psi	Jame	15/8/25	

## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: August Year: 2023

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark
				Type of Chemical			Physical		Gauge				
				Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure			
123	ACP-PFE-215	ARP	Fire pump2		/		/		/	195 Psi	Jame	15/4/25	
124	ACP-PFE-216	ARP	Genarator2		/		/		/	195 Psi	Jame	15/4/25	
125	ACP-PFE-217	ARP	MDB3		/		/		/	195 Psi	Jame	15/4/25	
126	ACP-PFE-218	ARP	Staff toilet A7	/			/		/	195 Psi	Jame	15/4/25	
127	ACP-PFE-219	ARP	Transformer 4	/	/		/		/	195 Psi	Jame	15/8/23	
128	ACP-PFE-220	ARP	Coral Kitchen		/		/		/	195 Psi	Jame	15/4/23	
129	ACP-PFE-221	ARP	H/K1		/		/		/	195 Psi	Jame	15/4/23	
130	ACP-PFE-222	ARP	H/K3		/		/		/	195 Psi	Jame	15/4/23	
131	ACP-PFE-223	ARP	H/K4		/		/		/	195 Psi	Jame	15/4/25	
132	ACP-PFE-224	ARP	Fire Pump3		/		/		/	195 Psi	Jame	15/4/25	

Acknowledge by: Kaiyasit

Fire-Life Safety Teamleader

Approved by: .....

Heads of Department





## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: September Year: 2025

Ite m no.	FLS CODE	Area		Fire Extinguisher							Checked by	Date	Remark
		Section	Location	Type of Chemical		Physical		Gauge					
				Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure			
1	ACP-PFE-001	Floor 1/1	1101		/		/		/	195 Psi	Jame	22/9/25	
2	ACP-PFE-002	Floor 1/2	1206		/		/		/	195 Psi	Jame	22/9/25	
3	ACP-PFE-003	Floor 2/1	2101		/		/		/	195 Psi	Jame	22/9/25	
4	ACP-PFE-004	Floor 2/2	2204		/		/		/	195 Psi	Jame	22/9/25	
5	ACP-PFE-005	Floor 3/1	3101		/		/		/	195 Psi	Jame	22/9/25	
6	ACP-PFE-006	Floor 3/2	3201		/		/		/	195 Psi	Jame	22/9/25	
7	ACP-PFE-007	Floor 4/1	4101		/		/		/	195 Psi	Jame	22/9/25	
8	ACP-PFE-008	Floor 4/2	4205		/		/		/	195 Psi	Jame	22/9/25	
9	ACP-PFE-009	Floor 4/3	4305		/		/		/	195 Psi	Jame	22/9/25	
10	ACP-PFE-010	Building4	EE Room		/		/		/	195 Psi	Jame	22/9/25	
11	ACP-PFE-011	Building5	5105		/		/		/	195 Psi	Jame	22/9/25	
12	ACP-PFE-012	Building5	5205		/		/		/	195 Psi	Jame	22/9/25	
13	ACP-PFE-013	Building5	5305		/		/		/	195 Psi	Jame	22/9/25	
14	ACP-PFE-014	Building7	Coridor B7FL1		/		/		/	195 Psi	Jame	22/9/25	
15	ACP-PFE-015	Building7	Store B7FL 2		/		/		/	195 Psi	Jame	22/9/25	
16	ACP-PFE-016	Building7	Store B7FL 3		/		/		/	195 Psi	Jame	22/9/25	
17	ACP-PFE-017	Building7	7107		/		/		/	195 Psi	Jame	22/9/25	
18	ACP-PFE-018	Building7	7123		/		/		/	195 Psi	Jame	22/9/25	
19	ACP-PFE-019	Building7	7207		/		/		/	195 Psi	Jame	22/9/25	
20	ACP-PFE-020	Building7	7223		/		/		/	195 Psi	Jame	22/9/25	
21	ACP-PFE-021	Building7	7307		/		/		/	195 Psi	Jame	22/9/25	
22	ACP-PFE-022	Building7	7323		/		/		/	195 Psi	Jame	22/9/25	
23	ACP-PFE-023	Lagritta	La Gritta Kitchen			/	/		/	195 Psi	Jame	22/9/25	
24	ACP-PFE-024	Lagritta	La Gritta Kitchen		/		/		/	195 Psi	Jame	22/9/25	
25	ACP-PFE-025	Lagritta Bar	La Gritta bar		/		/		/	195 Psi	Jame	22/9/25	
26	ACP-PFE-026	Main Store	Main Store		/		/		/	195 Psi	Jame	22/9/25	




Item no.	FLS CODE	Area		Fire Extinguisher							Checked by	Date	Remark
				Type of Chemical		Physical		Gauge					
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure			
27	ACP-PFE-027	Building 1	In Garden Room	/	/		/		/	195 Psi	Jame	22/9/25	
28	ACP-PFE-028	Building 1	In Florist Room	/			/		/	195 Psi	Jame	22/9/25	
29	ACP-PFE-029	Garbage	The Room	/			/		/	195 Psi	Jame	22/9/25	
30	ACP-PFE-030	Garbage	The Room	/			/		/	195 Psi	Jame	22/9/25	
31	ACP-PFE-031	Staff Canteen	In The Kitchen	/			/		/	195 Psi	Jame	22/9/25	
32	ACP-PFE-032	Staff Canteen	In The Kitchen	/			/		/	195 Psi	Jame	22/9/25	
33	ACP-PFE-033	Staff Canteen	In The Kitchen			/	/		/	195 Psi	Jame	22/9/25	
34	ACP-PFE-034	Staff Canteen	Station Gas	/			/		/	195 Psi	Jame	22/9/25	
35	ACP-PFE-035	Male Locker	In Staff Toilets	/			/		/	195 Psi	Jame	22/9/25	
36	ACP-PFE-036	Female Locker	In Staff Toilets	/			/		/	195 Psi	Jame	22/9/25	
37	ACP-PFE-037	HR. Room	In HR. Room	/			/		/	195 Psi	Jame	22/9/25	
38	ACP-PFE-038	MDB3	Out HR. Room	/			/		/	195 Psi	Jame	22/9/25	
39	ACP-PFE-039	Lagritta Pool	Lagritta Pool	/			/		/	195 Psi	Jame	22/9/25	
40	ACP-PFE-040	Lobby	Entrance (OPR)	/			/		/	195 Psi	Jame	22/9/25	
41	ACP-PFE-041	Store bell	In The Room	/			/		/	195 Psi	Jame	22/9/25	
42	ACP-PFE-042	Executive Offices	Door Offices	/			/		/	195 Psi	Jame	22/9/25	
43	ACP-PFE-043	Lagittta Station Gas	Lobby	/			/		/	195 Psi	Jame	22/9/25	
44	ACP-PFE-044	Lagittta Station Gas	Lobby	/			/		/	195 Psi	Jame	22/9/25	
45	ACP-PFE-045	Secueity No.1	Enteance	/			/		/	195 Psi	Jame	22/9/25	
46	ACP-PFE-046	Secueity No.2	Lobby	/			/		/	195 Psi	Jame	22/9/25	
47	ACP-PFE-047	Security No.3	Old Time Kepper	/			/		/	195 Psi	Jame	22/9/25	
48	ACP-PFE-048	Accounting	In The Room	/			/		/	195 Psi	Jame	22/9/25	
49	ACP-PFE-049	Main Kitchen	Entrance	/			/		/	195 Psi	Jame	22/9/25	
50	ACP-PFE-050	Main Kitchen	Entrance	/			/		/	195 Psi	Jame	22/9/25	
51	ACP-PFE-051	Main Kitchen	Out The Room			/	/		/	195 Psi	Jame	22/9/25	
52	ACP-PFE-052	Main Kitchen	In The Room			/	/		/	195 Psi	Jame	22/9/25	
53	ACP-PFE-053	House Keeping	In The Room	/			/		/	195 Psi	Jame	22/9/25	
54	ACP-PFE-054	Generator MDB 1	Entrance			/	/		/	195 Psi	Jame	22/9/25	
55	ACP-PFE-055	Generator MDB 1	In The Room	/			/		/	195 Psi	Jame	22/9/25	
56	ACP-PFE-056	Laundry	Up The Stairs	/			/		/	195 Psi	Jame	22/9/25	
57	ACP-PFE-057	Laundry	Laundry	/			/		/	195 Psi	Jame	22/9/25	
58	ACP-PFE-058	Laundry	Laundry	/			/		/	195 Psi	Jame	22/9/25	
59	ACP-PFE-059	Laundry	Laundry	/			/		/	195 Psi	Jame	22/9/25	



Ite m no.	FLS CODE	Area		Fire Extingguisher							Checked by	Date	Remark
				Type of Chemical			Physical		Gauge				
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure			
60	ACP-PFE-060	Laundry	Laundry		/		/		/	195 Psi	Jame	22/9/25	
61	ACP-PFE-061	Boiler room	Boiler room		/		/		/	195 Psi	Jame	22/9/25	
62	ACP-PFE-062	Eng. Work Shop	Tools Room		/		/		/	195 Psi	Jame	22/9/25	
63	ACP-PFE-063	Eng. Work Shop	MDB Room		/		/		/	195 Psi	Jame	22/9/25	
64	ACP-PFE-064	Eng. Work Shop	Painter Room		/		/		/	195 Psi	Jame	22/9/25	
65	ACP-PFE-065	Oil Station	Desel Tank		/		/		/	195 Psi	Jame	22/9/25	
66	ACP-PFE-066	Walkway Rim talay			/		/		/	195 Psi	Jame	22/9/25	
67	ACP-PFE-067	Voyagerlounge			/		/		/	195 Psi	Jame	22/9/25	
68	ACP-PFE-068	Gas Station	Laundry		/		/		/	195 Psi	Jame	22/9/25	
69	ACP-PFE-069	Mortorbike Garage1			/		/		/	195 Psi	Jame	22/9/25	
70	ACP-PFE-070	Mortorbike Garage2			/		/		/	195 Psi	Jame	22/9/25	
71	ACP-PFE-071	Rimtalay pump room			/		/		/	195 Psi	Jame	22/9/25	
72	ACP-PFE-072	Kid club			/		/		/	195 Psi	Jame	22/9/25	
73	ACP-PFE-073	Fire Training			/		/		/	195 Psi	Jame	22/9/25	
74	ACP-PFE-074	PABX room			/		/		/	195 Psi	Jame	22/9/25	
75	ACP-PFE-075	EE room B.2			/		/		/	195 Psi	Jame	22/9/25	
76	ACP-PFE-076	Pantry samurt bar 1	Samut Bar		/		/		/	195 Psi	Jame	22/9/25	
77	ACP-PFE-077	Pantry samurt bar 2	Samut Bar		/		/		/	195 Psi	Jame	22/9/25	
78	ACP-PFE-078	Idea Station Gas	Idea Room		/		/		/	195 Psi	Jame	22/9/25	
79	ACP-PFE-079	Sport Center			/		/		/	195 Psi	Jame	22/9/25	
80	ACP-PFE-080	Sport Center			/		/		/	195 Psi	Jame	22/9/25	
81	ACP-PFE-081	Server Room			/		/		/	195 Psi	Jame	22/9/25	
82	ACP-PFE-082		Front Spa		/		/		/	195 Psi	Jame	22/9/25	
83	ACP-PFE-083		Spa Reception		/		/		/	195 Psi	Jame	22/9/25	
84	ACP-PFE-084		Spa Sala 1		/		/		/	195 Psi	Jame	22/9/25	
85	ACP-PFE-085		Spa Sala 2		/		/		/	195 Psi	Jame	22/9/25	
86	ACP-PFE-086		Spa Sala 3		/		/		/	195 Psi	Jame	22/9/25	
87	ACP-PFE-087		Spa Sala 4		/		/		/	195 Psi	Jame	22/9/25	
88	ACP-PFE-088	Fitness			/		/		/	195 Psi	Jame	22/9/25	

Ite m no.	FLS CODE	Area		Fire Extinguisher							Checked by	Date	Remark
				Section	Location	Type of Chemical			Physical				
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure			
89	ACP-PFE-089	Lift		/		/		/		195 Psi	22/9/23		
90	ACP-PFE-090	GM House		/		/		/		195 Psi	22/9/23		
91	ACP-PFE-091	Jetty 1		/		/		/		195 Psi	22/9/23		
92	ACP-PFE-092	Jetty 2		/		/		/		195 Psi	22/9/23		
	ACP-PFE-255	Gas Station	Laundry	/		/		/		195 Psi	22/9/23		



Acknowledge by: Kajyasit

Approved by: .....

Fire-Life Safety Teamleader

Heads of Department



## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: September Year: 2023

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark
				Section	Location	Type of Chemical			Physical				
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure			
1	ACP-PFE-093	Ocean Wing 1	6000	/			/		/	195 Psi	Jame	20/9/25	
2	ACP-PFE-094		6002	/			/		/	195 Psi	Jame	20/9/25	
3	ACP-PFE-095		6004	/			/		/	195 Psi	Jame	20/9/25	
4	ACP-PFE-096	Ocean Wing 2	6006	/			/		/	195 Psi	Jame	20/9/25	
5	ACP-PFE-097		6008	/			/		/	195 Psi	Jame	20/9/25	
6	ACP-PFE-098		6010	/			/		/	195 Psi	Jame	20/9/25	
7	ACP-PFE-099	Ocean Wing 3	6012	/			/		/	195 Psi	Jame	20/9/25	
8	ACP-PFE-100		6015	/			/		/	195 Psi	Jame	20/9/25	
9	ACP-PFE-101		6016	/			/		/	195 Psi	Jame	20/9/25	
10	ACP-PFE-102	Ocean Wing 4	6017	/			/		/	195 Psi	Jame	20/9/25	
11	ACP-PFE-103		6020	/			/		/	195 Psi	Jame	20/9/25	
12	ACP-PFE-104		6021	/			/		/	195 Psi	Jame	20/9/25	
13	ACP-PFE-105	Ocean Wing 5	6023	/			/		/	195 Psi	Jame	20/9/25	
14	ACP-PFE-106		6024	/			/		/	195 Psi	Jame	20/9/25	
15	ACP-PFE-107		6026	/			/		/	195 Psi	Jame	20/9/25	
16	ACP-PFE-108	Ocean Wing 7	6028	/			/		/	195 Psi	Jame	20/9/25	
17	ACP-PFE-109		6031	/			/		/	195 Psi	Jame	20/9/25	
18	ACP-PFE-110		6032	/			/		/	195 Psi	Jame	20/9/25	
19	ACP-PFE-111	Ocean Wing 8	6035	/			/		/	195 Psi	Jame	20/9/25	
20	ACP-PFE-112		6036	/			/		/	195 Psi	Jame	20/9/25	
21	ACP-PFE-113		6038	/			/		/	195 Psi	Jame	20/9/25	
22	ACP-PFE-114	Ocean Wing 9	6040	/			/		/	195 Psi	Jame	20/9/25	
23	ACP-PFE-0115		6042	/			/		/	195 Psi	Jame	20/9/25	
24	ACP-PFE-0116		6044	/			/		/	195 Psi	Jame	20/9/25	



# Engineering Department

## FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month:..... Year:.....

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)								Checked by	Date	Remark
				Section	Location	Type of Chemical			Physical		Gauge			
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure				
25	ACP-PFE-0117	Ocean Wing 11	6046		/		/		/	195 Psi	Jame	20/9/23		
26	ACP-PFE-0118		6048		/		/		/	195 Psi	Jame	20/9/23		
27	ACP-PFE-0119		6050		/		/		/	195 Psi	Jame	20/9/23		
28	ACP-PFE-0120		6052		/		/		/	195 Psi	Jame	20/9/23		
29	ACP-PFE-0121	Ocean Wing 12	6053		/		/		/	195 Psi	Jame	20/9/23		
30	ACP-PFE-0122		6055		/		/		/	195 Psi	Jame	20/9/23		
31	ACP-PFE-0123		6057		/		/		/	195 Psi	Jame	20/9/23		
32	ACP-PFE-0124		6058		/		/		/	195 Psi	Jame	20/9/23		
33	ACP-PFE-0125	Ocean Wing 13	6060		/		/		/	195 Psi	Jame	20/9/23		
34	ACP-PFE-0126		6062		/		/		/	195 Psi	Jame	20/9/23		
35	ACP-PFE-0127		6063		/		/		/	195 Psi	Jame	20/9/23		
36	ACP-PFE-0128		6066		/		/		/	195 Psi	Jame	20/9/23		
37	ACP-PFE-0129	Ocean Wing 14	6067		/		/		/	195 Psi	Jame	20/9/23		
38	ACP-PFE-0130		6069		/		/		/	195 Psi	Jame	20/9/23		
39	ACP-PFE-0131		6071		/		/		/	195 Psi	Jame	20/9/23		
40	ACP-PFE-0132		6073		/		/		/	195 Psi	Jame	20/9/23		
41	ACP-PFE-0133	Ocean Wing 15	6075		/		/		/	195 Psi	Jame	20/9/23		
42	ACP-PFE-0134		6077		/		/		/	195 Psi	Jame	20/9/23		
43	ACP-PFE-0135		6079		/		/		/	195 Psi	Jame	20/9/23		
44	ACP-PFE-0136		6081		/		/		/	195 Psi	Jame	20/9/23		
45	ACP-PFE-0137	Ocean Wing 16	6083		/		/		/	195 Psi	Jame	20/9/23		
46	ACP-PFE-0138		6085		/		/		/	195 Psi	Jame	20/9/23		
47	ACP-PFE-0139		6086		/		/		/	195 Psi	Jame	20/9/23		
48	ACP-PFE-0140		6087		/		/		/	195 Psi	Jame	20/9/23		
49	ACP-PFE-0141	Ocean Wing 20	6089		/		/		/	195 Psi	Jame	20/9/23		



# Engineering Department

## FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month:..... Year:.....

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark
				Section	Location	Type of Chemical			Physical				
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure			
50	ACP-PFE-0142		6090		/		/		/	195 Psi	Jame	20/9/25	
51	ACP-PFE-143	Ocean Wing 21	6091		/		/		/	195 Psi	Jame	20/9/25	
52	ACP-PFE-144		6093		/		/		/	195 Psi	Jame	20/9/25	
53	ACP-PFE-145		6096		/		/		/	195 Psi	Jame	20/9/25	
54	ACP-PFE-146		6097		/		/		/	195 Psi	Jame	20/9/25	
55	ACP-PFE-147	Ocean Wing 22	6099		/		/		/	195 Psi	Jame	20/9/25	
56	ACP-PFE-148		6101		/		/		/	195 Psi	Jame	20/9/25	
57	ACP-PFE-149		6103		/		/		/	195 Psi	Jame	20/9/25	
58	ACP-PFE-150		6105		/		/		/	195 Psi	Jame	20/9/25	
59	ACP-PFE-151	Ocean Wing 23	6107		/		/		/	195 Psi	Jame	20/9/25	
60	ACP-PFE-152		6109		/		/		/	195 Psi	Jame	20/9/25	
61	ACP-PFE-153		6112		/		/		/	195 Psi	Jame	20/9/25	
62	ACP-PFE-154		6114		/		/		/	195 Psi	Jame	20/9/25	
63	ACP-PFE-155	Ocean Wing 25	6116		/		/		/	195 Psi	Jame	20/9/25	
64	ACP-PFE-156		6118		/		/		/	195 Psi	Jame	20/9/25	
65	ACP-PFE-157		6120		/		/		/	195 Psi	Jame	20/9/25	
66	ACP-PFE-158		6121		/		/		/	195 Psi	Jame	20/9/25	
67	ACP-PFE-159	Ocean Wing 27	6123		/		/		/	195 Psi	Jame	20/9/25	
68	ACP-PFE-160		6124		/		/		/	195 Psi	Jame	20/9/25	
69	ACP-PFE-161		6126		/		/		/	195 Psi	Jame	20/9/25	
70	ACP-PFE-162		6127		/		/		/	195 Psi	Jame	20/9/25	
71	ACP-PFE-163	Ocean Wing 29	6128		/		/		/	195 Psi	Jame	20/9/25	
72	ACP-PFE-164		6129		/		/		/	195 Psi	Jame	20/9/25	
73	ACP-PFE-165		6130		/		/		/	195 Psi	Jame	20/9/25	



## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month:..... Year:.....

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark		
				Section	Location	Type of Chemical			Physical					Gauge	
						Dry	Halotron	Wet chemical	Normal	Abnormal				Status	Pressure
74	ACP-PFE-166	Ocean Wing 31	6131		/		/		/	195 Psi	Jame	20/9/25			
75	ACP-PFE-167		6132		/		/		/	195 Psi	Jame	20/9/25			
76	ACP-PFE-168	Ocean Wing 32	6133		/		/		/	195 Psi	Jame	20/9/25			
77	ACP-PFE-169		6134		/		/		/	195 Psi	Jame	20/9/25			
78	ACP-PFE-170	Ocean Wing 33	6135		/		/		/	195 Psi	Jame	20/9/25			
79	ACP-PFE-171		6136		/		/		/	195 Psi	Jame	20/9/25			
80	ACP-PFE-172	Ocean Wing 34	6137		/		/		/	195 Psi	Jame	20/9/25			
81	ACP-PFE-173		6138		/		/		/	195 Psi	Jame	20/9/25			
82	ACP-PFE-174	Ocean Wing 35	6139		/		/		/	195 Psi	Jame	20/9/25			
83	ACP-PFE-175		6141		/		/		/	195 Psi	Jame	20/9/25			
84	ACP-PFE-176	Ocean Wing 36	6142		/		/		/	195 Psi	Jame	20/9/25			
85	ACP-PFE-177		6144		/		/		/	195 Psi	Jame	20/9/25			
86	ACP-PFE-178	Ocean Wing 37	6145		/		/		/	195 Psi	Jame	20/9/25			
87	ACP-PFE-179		6147		/		/		/	195 Psi	Jame	20/9/25			
88	ACP-PFE-180	Ocean Wing 38	6148		/		/		/	195 Psi	Jame	20/9/25			
89	ACP-PFE-181		6149		/		/		/	195 Psi	Jame	20/9/25			
90	ACP-PFE-182	Ocean Wing 39	6200		/		/		/	195 Psi	Jame	20/9/25			
91	ACP-PFE-183		6202		/		/		/	195 Psi	Jame	20/9/25			
92	ACP-PFE-184	Ocean Wing 40	6203		/		/		/	195 Psi	Jame	20/9/25			
93	ACP-PFE-185		6205		/		/		/	195 Psi	Jame	20/9/25			
94	ACP-PFE-186	Ocean Wing 41	6206		/		/		/	195 Psi	Jame	20/9/25			
95	ACP-PFE-187		6208		/		/		/	195 Psi	Jame	20/9/25			
96	ACP-PFE-188	Ocean Wing 42	6209		/		/		/	195 Psi	Jame	20/9/25			
97	ACP-PFE-189		6211		/		/		/	195 Psi	Jame	20/9/25			



## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month:..... Year:.....

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark
				Section	Location	Type of Chemical			Physical				
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure			
98	ACP-PFE-190	Ocean Wing 43	6212	/			/		/	195 Psi	Jame	20/9/25	
99	ACP-PFE-191		6215	/			/		/	195 Psi	Jame	20/9/25	
100	ACP-PFE-192	Ocean Wing 44	6216	/			/		/	195 Psi	Jame	20/9/25	
101	ACP-PFE-193		6218	/			/		/	195 Psi	Jame	20/9/25	
102	ACP-PFE-194	Ocean Wing 45	6219	/			/		/	195 Psi	Jame	20/9/25	
103	ACP-PFE-195		6221	/			/		/	195 Psi	Jame	20/9/25	
104	ACP-PFE-196	Ocean Wing 46	6222	/			/		/	195 Psi	Jame	20/9/25	
105	ACP-PFE-197		6224	/			/		/	195 Psi	Jame	20/9/25	
106	ACP-PFE-198	Ocean Wing 47	6225	/			/		/	195 Psi	Jame	20/9/25	
107	ACP-PFE-199		6227	/			/		/	195 Psi	Jame	20/9/25	
108	ACP-PFE-200	Ocean Wing 48	6228	/			/		/	195 Psi	Jame	20/9/25	
109	ACP-PFE-201		6230	/			/		/	195 Psi	Jame	20/9/25	
110	ACP-PFE-202	Ocean Wing 49	6231	/			/		/	195 Psi	Jame	20/9/25	
111	ACP-PFE-203		6233	/			/		/	195 Psi	Jame	20/9/25	
112	ACP-PFE-204	Ocean Wing 50	6234	/			/		/	195 Psi	Jame	20/9/25	
113	ACP-PFE-205		6236	/			/		/	195 Psi	Jame	20/9/25	
114	ACP-PFE-206	ARP	Club Pakarang	/			/		/	195 Psi	Jame	20/9/25	
115	ACP-PFE-207	ARP	MDB 4	/			/		/	195 Psi	Jame	20/9/25	
116	ACP-PFE-208	ARP	Club Pakarang 1	/			/		/	195 Psi	Jame	20/9/25	
117	ACP-PFE-209	ARP	Club Pakarang 2	/			/		/	195 Psi	Jame	20/9/25	
118	ACP-PFE-210	ARP	C/P Kitchen	/			/		/	195 Psi	Jame	20/9/25	
119	ACP-PFE-211	ARP	C/P Kitchen	/			/		/	195 Psi	Jame	20/9/25	
120	ACP-PFE-212	ARP	EE-Pakarang	/			/		/	195 Psi	Jame	20/9/25	
121	ACP-PFE-213	ARP	H/K 2	/			/		/	195 Psi	Jame	20/9/25	
122	ACP-PFE-214	ARP	Fire pump1	/			/		/	195 Psi	Jame	20/9/25	





# Engineering Department

## FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month:..... Year:.....

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark	
				Type of Chemical			Physical		Gauge					
									Status	Pressure				
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal						
123	ACP-PFE-215	ARP	Fire pump2		/		/			/	195 Psi	Jame	20/9/25	
124	ACP-PFE-216	ARP	Genarator2		/		/			/	195 Psi	Jame	20/9/25	
125	ACP-PFE-217	ARP	MDB3		/		/			/	195 Psi	Jame	20/9/25	
126	ACP-PFE-218	ARP	Staff toilet A7		/		/			/	195 Psi	Jame	20/9/25	
127	ACP-PFE-219	ARP	Tranformer 4		/		/			/	195 Psi	Jame	20/9/25	
128	ACP-PFE-220	ARP	Coral Kitchen		/		/			/	195 Psi	Jame	20/9/25	
129	ACP-PFE-221	ARP	H/K1		/		/			/	195 Psi	Jame	20/9/25	
130	ACP-PFE-222	ARP	H/K3		/		/			/	195 Psi	Jame	20/9/25	
131	ACP-PFE-223	ARP	H/K4		/		/			/	195 Psi	Jame	20/9/25	
132	ACP-PFE-224	ARP	Fire Pump3		/	/	/			/	195 Psi	Jame	20/9/25	



Acknowledge by: *Kai Porisit*

Fire-Life Safety Teamleader

Approved by: .....

Heads of Department



## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: October Year: 2023

Ite m no.	FLS CODE	Area		Fire Extinguisher							Checked by	Date	Remark
				Type of Chemical			Physical		Gauge				
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure			
1	ACP-PFE-001	Floor 1/1	1101		/		/		/	193 Psi	Jame	15/10/23	
2	ACP-PFE-002	Floor 1/2	1206		/		/		/	193 Psi	Jame	15/10/23	
3	ACP-PFE-003	Floor 2/1	2101		/		/		/	193 Psi	Jame	15/10/23	
4	ACP-PFE-004	Floor 2/2	2204		/		/		/	193 Psi	Jame	15/10/23	
5	ACP-PFE-005	Floor 3/1	3101		/		/		/	193 Psi	Jame	15/10/23	
6	ACP-PFE-006	Floor 3/2	3201		/		/		/	193 Psi	Jame	15/10/23	
7	ACP-PFE-007	Floor 4/1	4101		/		/		/	193 Psi	Jame	15/10/23	
8	ACP-PFE-008	Floor 4/2	4205		/		/		/	193 Psi	Jame	15/10/23	
9	ACP-PFE-009	Floor 4/3	4305		/		/		/	193 Psi	Jame	15/10/23	
10	ACP-PFE-010	Building4	EE Room		/		/		/	193 Psi	Jame	15/10/23	
11	ACP-PFE-011	Building5	5105		/		/		/	193 Psi	Jame	15/10/23	
12	ACP-PFE-012	Building5	5205		/		/		/	193 Psi	Jame	15/10/23	
13	ACP-PFE-013	Building5	5305		/		/		/	193 Psi	Jame	15/10/23	
14	ACP-PFE-014	Building7	Coridor B7FL1		/		/		/	193 Psi	Jame	15/10/23	
15	ACP-PFE-015	Building7	Store B7FL 2		/		/		/	193 Psi	Jame	15/10/23	
16	ACP-PFE-016	Building7	Store B7FL 3		/		/		/	193 Psi	Jame	15/10/23	
17	ACP-PFE-017	Building7	7107		/		/		/	193 Psi	Jame	15/10/23	
18	ACP-PFE-018	Building7	7123		/		/		/	193 Psi	Jame	15/10/23	
19	ACP-PFE-019	Building7	7207		/		/		/	193 Psi	Jame	15/10/23	
20	ACP-PFE-020	Building7	7223		/		/		/	193 Psi	Jame	15/10/23	
21	ACP-PFE-021	Building7	7307		/		/		/	193 Psi	Jame	15/10/23	
22	ACP-PFE-022	Building7	7323		/		/		/	193 Psi	Jame	15/10/23	
23	ACP-PFE-023	Lagritta	La Gritta Kitchen		/		/		/	193 Psi	Jame	15/10/23	
24	ACP-PFE-024	Lagritta	La Gritta Kitchen		/		/		/	193 Psi	Jame	15/10/23	
25	ACP-PFE-025	Lagritta Bar	La Gritta bar		/		/		/	193 Psi	Jame	15/10/23	
26	ACP-PFE-026	Main Store	Main Store		/		/		/	193 Psi	Jame	15/10/23	




Item no.	FLS CODE	Area		Fire Extinguisher								Checked by	Date	Remark
				Type of			Chemical		Physical					
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Gauge Pressure				
27	ACP-PFE-027	Building 1	In Garden Room		/		/			/	195 Psi	Same	15/10/25	
28	ACP-PFE-028	Building 1	In Florist Room		/					/	195 Psi	Same	15/10/25	
29	ACP-PFE-029	Garbage	The Room		/					/	195 Psi	Same	15/10/25	
30	ACP-PFE-030	Garbage	The Room		/					/	195 Psi	Same	15/10/25	
31	ACP-PFE-031	Staff Canteen	In The Kitchen		/					/	195 Psi	Same	15/10/25	
32	ACP-PFE-032	Staff Canteen	In The Kitchen		/					/	195 Psi	Same	15/10/25	
33	ACP-PFE-033	Staff Canteen	In The Kitchen				/			/	195 Psi	Same	15/10/25	
34	ACP-PFE-034	Staff Canteen	Station Gas		/					/	195 Psi	Same	15/10/25	
35	ACP-PFE-035	Male Locker	In Staff Toilets		/					/	195 Psi	Same	15/10/25	
36	ACP-PFE-036	Female Locker	In Staff Toilets		/					/	195 Psi	Same	15/10/25	
37	ACP-PFE-037	HR. Room	In HR. Room		/					/	195 Psi	Same	15/10/25	
38	ACP-PFE-038	MDB3	Out HR. Room		/					/	195 Psi	Same	15/10/25	
39	ACP-PFE-039	Lagritta Pool	Lagritta Pool		/					/	195 Psi	Same	15/10/25	
40	ACP-PFE-040	Lobby	Entrance (OPR)		/					/	195 Psi	Same	15/10/25	
41	ACP-PFE-041	Store bell	In The Room		/					/	195 Psi	Same	15/10/25	
42	ACP-PFE-042	Executive Offices	Door Offices		/					/	195 Psi	Same	15/10/25	
43	ACP-PFE-043	Laglitla Station Gas	Lobby		/					/	195 Psi	Same	15/10/25	
44	ACP-PFE-044	Laglitla Station Gas	Lobby		/					/	195 Psi	Same	15/10/25	
45	ACP-PFE-045	Security No.1	Enteance	/						/	195 Psi	Same	15/10/25	
46	ACP-PFE-046	Security No.2	Lobby		/					/	195 Psi	Same	15/10/25	
47	ACP-PFE-047	Security No.3	Old Time Kepper		/					/	195 Psi	Same	15/10/25	
48	ACP-PFE-048	Accounting	In The Room		/					/	195 Psi	Same	15/10/25	
49	ACP-PFE-049	Main Kitchen	Entrance		/					/	195 Psi	Same	15/10/25	
50	ACP-PFE-050	Main Kitchen	Entrance		/					/	195 Psi	Same	15/10/25	
51	ACP-PFE-051	Main Kitchen	Out The Room					/		/	195 Psi	Same	15/10/25	
52	ACP-PFE-052	Main Kitchen	In The Room					/		/	195 Psi	Same	15/10/25	
53	ACP-PFE-053	House Keeping	In The Room					/		/	195 Psi	Same	15/10/25	
54	ACP-PFE-054	Generator MDB 1	Entrance					/		/	195 Psi	Same	15/10/25	
55	ACP-PFE-055	Generator MDB 1	In The Room		/					/	195 Psi	Same	15/10/25	
56	ACP-PFE-056	Laundry	Up The Stairs		/					/	195 Psi	Same	15/10/25	
57	ACP-PFE-057	Laundry	Laundry		/					/	195 Psi	Same	15/10/25	
58	ACP-PFE-058	Laundry	Laundry		/					/	195 Psi	Same	15/10/25	
59	ACP-PFE-059	Laundry	Laundry		/					/	195 Psi	Same	15/10/25	



Ite m no.	FLS CODE	Area		Fire Extinguisher						Checked by	Date	Remark	
		Section	Location	Type of Chemical			Physical		Gauge				
				Dry	Halotron	Wet chemical	Normal	Abnormal	Status				Pressure
60	ACP-PFE-060	Laundry	Laundry	/	/		/		/	195 Psi	15/10/25		
61	ACP-PFE-061	Boiler room	Boiler room	/	/		/		/	195 Psi	15/10/25		
62	ACP-PFE-062	Eng. Work Shop	Tools Room	/	/		/		/	195 Psi	15/10/25		
63	ACP-PFE-063	Eng. Work Shop	MDB Room	/	/		/		/	195 Psi	15/10/25		
64	ACP-PFE-064	Eng. Work Shop	Painter Room	/	/		/		/	195 Psi	15/10/25		
65	ACP-PFE-065	Oil Station	Desel Tank			/	/		/	195 Psi	15/10/25		
66	ACP-PFE-066	Walkway Rim talay		/	/		/		/	195 Psi	15/10/25		
67	ACP-PFE-067	Voyagerlounge		/	/		/		/	195 Psi	15/10/25		
68	ACP-PFE-068	Gas Station	Laundry	/	/		/		/	195 Psi	15/10/25		
69	ACP-PFE-069	Mortorbike Garage1		/	/		/		/	195 Psi	15/10/25		
70	ACP-PFE-070	Mortorbike Garage2		/	/		/		/	195 Psi	15/10/25		
71	ACP-PFE-071	Rimtalay pump room		/	/		/		/	195 Psi	15/10/25		
72	ACP-PFE-072	Kid club		/	/		/		/	195 Psi	15/10/25		
73	ACP-PFE-073	Fire Training		/	/		/		/	195 Psi	15/10/25		
74	ACP-PFE-074	PABX room		/	/		/		/	195 Psi	15/10/25		
75	ACP-PFE-075	EE room B.2		/	/		/		/	195 Psi	15/10/25		
76	ACP-PFE-076	Pantry samurt bar 1	Samut Bar	/	/		/		/	195 Psi	15/10/25		
77	ACP-PFE-077	Pantry samurt bar 2	Samut Bar	/	/		/		/	195 Psi	15/10/25		
78	ACP-PFE-078	Idea Station Gas	Idea Room	/	/		/		/	195 Psi	15/10/25		
79	ACP-PFE-079	Sport Center		/	/		/		/	195 Psi	15/10/25		
80	ACP-PFE-080	Sport Center		/	/		/		/	195 Psi	15/10/25		
81	ACP-PFE-081	Server Room		/	/		/		/	195 Psi	15/10/25		
82	ACP-PFE-082	SPA	Front Spa	/	/		/		/	195 Psi	15/10/25		
83	ACP-PFE-083		Spa Reception		/	/		/		/	195 Psi	15/10/25	
84	ACP-PFE-084		Spa Sala 1		/	/		/		/	195 Psi	15/10/25	
85	ACP-PFE-085		Spa Sala 2		/	/		/		/	195 Psi	15/10/25	
86	ACP-PFE-086		Spa Sala 3		/	/		/		/	195 Psi	15/10/25	
87	ACP-PFE-087		Spa Sala 4		/	/		/		/	195 Psi	15/10/25	
88	ACP-PFE-088	Fitness		/	/		/		/	195 Psi	15/10/25		

Item no.	FLS CODE	Area		Fire Extinguisher							Checked by	Date	Remark
				Section	Location	Type of Chemical			Physical				
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure			
89	ACP-PFE-089	Lift			/		/		/	195 Psi	Jame	15/10/25	
90	ACP-PFE-090	GM House			/		/		/	195 Psi	Jame	15/10/25	
91	ACP-PFE-091	Jetty 1			/		/		/	195 Psi	Jame	15/10/25	
92	ACP-PFE-092	Jetty 2			/		/		/	195 Psi	Jame	15/10/25	
93	ACP-PFE-093	Gas Station	Laundry		/		/		/	195 Psi	Jame	15/10/25	
							/						



Acknowledge by: Kaiyosit

Approved by: .....

Fire-Life Safety Teamleader

Heads of Department





Engineering Department

FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: October Year: 2025

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark
				Type of Chemical			Physical		Gauge				
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure			
1	ACP-PFE-093	Ocean Wing 1	6000		/		/		/	195 Psi	Jane	17/10/25	
2	ACP-PFE-094		6002		/		/		/	195 Psi	Jane	17/10/25	
3	ACP-PFE-095		6004		/		/		/	195 Psi	Jane	17/10/25	
4	ACP-PFE-096	Ocean Wing 2	6006		/		/		/	195 Psi	Jane	17/10/25	
5	ACP-PFE-097		6008		/		/		/	195 Psi	Jane	17/10/25	
6	ACP-PFE-098		6010		/		/		/	195 Psi	Jane	17/10/25	
7	ACP-PFE-099	Ocean Wing 3	6012		/		/		/	195 Psi	Jane	17/10/25	
8	ACP-PFE-100		6015		/		/		/	195 Psi	Jane	17/10/25	
9	ACP-PFE-101		6016		/		/		/	195 Psi	Jane	17/10/25	
10	ACP-PFE-102	Ocean Wing 4	6017		/		/		/	195 Psi	Jane	17/10/25	
11	ACP-PFE-103		6020		/		/		/	195 Psi	Jane	17/10/25	
12	ACP-PFE-104		6021		/		/		/	195 Psi	Jane	17/10/25	
13	ACP-PFE-105	Ocean Wing 5	6023		/		/		/	195 Psi	Jane	17/10/25	
14	ACP-PFE-106		6024		/		/		/	195 Psi	Jane	17/10/25	
15	ACP-PFE-107		6026		/		/		/	195 Psi	Jane	17/10/25	
16	ACP-PFE-108	Ocean Wing 7	6028		/		/		/	195 Psi	Jane	17/10/25	
17	ACP-PFE-109		6031		/		/		/	195 Psi	Jane	17/10/25	
18	ACP-PFE-110		6032		/		/		/	195 Psi	Jane	17/10/25	
19	ACP-PFE-111	Ocean Wing 8	6035		/		/		/	195 Psi	Jane	17/10/25	
20	ACP-PFE-112		6036		/		/		/	195 Psi	Jane	17/10/25	
21	ACP-PFE-113		6038		/		/		/	195 Psi	Jane	17/10/25	
22	ACP-PFE-114	Ocean Wing 9	6040		/		/		/	195 Psi	Jane	17/10/25	
23	ACP-PFE-0115		6042		/		/		/	195 Psi	Jane	17/10/25	
24	ACP-PFE-0116		6044		/		/		/	195 Psi	Jane	17/10/25	





## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: October Year: 2023

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark
				Section	Location	Type of Chemical			Physical				
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure			
25	ACP-PFE-0117		6046		/		/		/	195 Psi	Jane	17/10/23	
26	ACP-PFE-0118	Ocean Wing 11	6048		/		/		/	195 Psi	Jane	17/10/23	
27	ACP-PFE-0119		6050		/		/		/	195 Psi	Jane	17/10/23	
28	ACP-PFE-0120		6052		/		/		/	195 Psi	Jane	17/10/23	
29	ACP-PFE-0121		6053 *			/		/		/	195 Psi	Jane	17/10/23
30	ACP-PFE-0122	Ocean Wing 12	6055		/		/		/	195 Psi	Jane	17/10/23	
31	ACP-PFE-0123		6057		/		/		/	195 Psi	Jane	17/10/23	
32	ACP-PFE-0124		6058		/		/		/	195 Psi	Jane	17/10/23	
33	ACP-PFE-0125		6060		/		/		/	195 Psi	Jane	17/10/23	
34	ACP-PFE-0126	Ocean Wing 13	6062		/		/		/	195 Psi	Jane	17/10/23	
35	ACP-PFE-0127		6063		/		/		/	195 Psi	Jane	17/10/23	
36	ACP-PFE-0128		6066		/		/		/	195 Psi	Jane	17/10/23	
37	ACP-PFE-0129		6067		/		/		/	195 Psi	Jane	17/10/23	
38	ACP-PFE-0130	Ocean Wing 15	6069		/		/		/	195 Psi	Jane	17/10/23	
39	ACP-PFE-0131		6071		/		/		/	195 Psi	Jane	17/10/23	
40	ACP-PFE-0132		6073		/		/		/	195 Psi	Jane	17/10/23	
41	ACP-PFE-0133		6075		/		/		/	195 Psi	Jane	17/10/23	
42	ACP-PFE-0134	Ocean Wing 17	6077		/		/		/	195 Psi	Jane	17/10/23	
43	ACP-PFE-0135		6079		/		/		/	195 Psi	Jane	17/10/23	
44	ACP-PFE-0136		6081		/		/		/	195 Psi	Jane	17/10/23	
45	ACP-PFE-0137		6083		/		/		/	195 Psi	Jane	17/10/23	
46	ACP-PFE-0138	Ocean Wing 19	6085		/		/		/	195 Psi	Jane	17/10/23	
47	ACP-PFE-0139		6086		/		/		/	195 Psi	Jane	17/10/23	
48	ACP-PFE-0140		6087		/		/		/	195 Psi	Jane	17/10/23	
49	ACP-PFE-0141		Ocean Wing 20	6089		/		/		/	195 Psi	Jane	17/10/23





Engineering Department  
FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: October Year: 2025

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)								Checked by	Date	Remark	
				Section	Location	Type of Chemical			Physical		Gauge				
						Dry	Halotron	Wet chemical	Normal	Abnormal	Status				Pressure
50	ACP-PFE-0142	Ocean Wing 21	6090		/		/		/	195 Psi	Same	17/10/25			
51	ACP-PFE-143		6091		/		/		/	195 Psi	Same	17/10/25			
52	ACP-PFE-144		6093		/		/		/	195 Psi	Same	17/10/25			
53	ACP-PFE-145		6096		/		/		/	195 Psi	Same	17/10/25			
54	ACP-PFE-146	Ocean Wing 22	6097		/		/		/	195 Psi	Same	17/10/25			
55	ACP-PFE-147		6099		/		/		/	195 Psi	Same	17/10/25			
56	ACP-PFE-148		6101		/		/		/	195 Psi	Same	17/10/25			
57	ACP-PFE-149		6103		/		/		/	195 Psi	Same	17/10/25			
58	ACP-PFE-150	Ocean Wing 23	6105		/		/		/	195 Psi	Same	17/10/25			
59	ACP-PFE-151		6107		/		/		/	195 Psi	Same	17/10/25			
60	ACP-PFE-152		6109		/		/		/	195 Psi	Same	17/10/25			
61	ACP-PFE-153		6112		/		/		/	195 Psi	Same	17/10/25			
62	ACP-PFE-154	Ocean Wing 25	6114		/		/		/	195 Psi	Same	17/10/25			
63	ACP-PFE-155		6116		/		/		/	195 Psi	Same	17/10/25			
64	ACP-PFE-156		6118		/		/		/	195 Psi	Same	17/10/25			
65	ACP-PFE-157		6120		/		/		/	195 Psi	Same	17/10/25			
66	ACP-PFE-158	Ocean Wing 27	6121		/		/		/	195 Psi	Same	17/10/25			
67	ACP-PFE-159		6123		/		/		/	195 Psi	Same	17/10/25			
68	ACP-PFE-160		6124		/		/		/	195 Psi	Same	17/10/25			
69	ACP-PFE-161		6126		/		/		/	195 Psi	Same	17/10/25			
70	ACP-PFE-162	Ocean Wing 29	6127		/		/		/	195 Psi	Same	17/10/25			
71	ACP-PFE-163		6128		/		/		/	195 Psi	Same	17/10/25			
72	ACP-PFE-164		6129		/		/		/	195 Psi	Same	17/10/25			
73	ACP-PFE-165		6130		/		/		/	195 Psi	Same	17/10/25			





Engineering Department

FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: Oct 2025 Year: 2025

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)								Checked by	Date	Remark
				Type of Chemical			Physical		Gauge					
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure				
74	ACP-PFE-166	Ocean Wing 31	6131		/		/		/	195 Psi	Same	17/10/25		
75	ACP-PFE-167		6132		/		/		/	195 Psi	Same	17/10/25		
76	ACP-PFE-168	Ocean Wing 32	6133		/		/		/	195 Psi	Same	17/10/25		
77	ACP-PFE-169		6134		/		/		/	195 Psi	Same	17/10/25		
78	ACP-PFE-170	Ocean Wing 33	6135		/		/		/	195 Psi	Same	17/10/25		
79	ACP-PFE-171		6136		/		/		/	195 Psi	Same	17/10/25		
80	ACP-PFE-172	Ocean Wing 34	6137		/		/		/	195 Psi	Same	17/10/25		
81	ACP-PFE-173		6138		/		/		/	195 Psi	Same	17/10/25		
82	ACP-PFE-174	Ocean Wing 35	6139		/		/		/	195 Psi	Same	17/10/25		
83	ACP-PFE-175		6141		/		/		/	195 Psi	Same	17/10/25		
84	ACP-PFE-176	Ocean Wing 36	6142		/		/		/	195 Psi	Same	17/10/25		
85	ACP-PFE-177		6144		/		/		/	195 Psi	Same	17/10/25		
86	ACP-PFE-178	Ocean Wing 37	6145		/		/		/	195 Psi	Same	17/10/25		
87	ACP-PFE-179		6147		/		/		/	195 Psi	Same	17/10/25		
88	ACP-PFE-180	Ocean Wing 38	6148		/		/		/	195 Psi	Same	17/10/25		
89	ACP-PFE-181		6149		/		/		/	195 Psi	Same	17/10/25		
90	ACP-PFE-182	Ocean Wing 39	6200		/		/		/	195 Psi	Same	17/10/25		
91	ACP-PFE-183		6202		/		/		/	195 Psi	Same	17/10/25		
92	ACP-PFE-184	Ocean Wing 40	6203		/		/		/	195 Psi	Same	17/10/25		
93	ACP-PFE-185		6205		/		/		/	195 Psi	Same	17/10/25		
94	ACP-PFE-186	Ocean Wing 41	6206		/		/		/	195 Psi	Same	17/10/25		
95	ACP-PFE-187		6208		/		/		/	195 Psi	Same	17/10/25		
96	ACP-PFE-188	Ocean Wing 42	6209		/		/		/	195 Psi	Same	17/10/25		
97	ACP-PFE-189		6211		/		/		/	195 Psi	Same	17/10/25		





Engineering Department  
FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: October Year: 2025

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark
				Type of Chemical			Physical		Gauge				
				Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure			
98	ACP-PFE-190	Ocean Wing 43	6212	/		/			/	195 Psi	Jane	17/10/25	
99	ACP-PFE-191		6215	/		/			/	195 Psi	Jane	17/10/25	
100	ACP-PFE-192	Ocean Wing 44	6216	/		/			/	195 Psi	Jane	17/10/25	
101	ACP-PFE-193		6218	/		/			/	195 Psi	Jane	17/10/25	
102	ACP-PFE-194	Ocean Wing 45	6219	/		/			/	195 Psi	Jane	17/10/25	
103	ACP-PFE-195		6221	/		/			/	195 Psi	Jane	17/10/25	
104	ACP-PFE-196	Ocean Wing 46	6222	/		/			/	195 Psi	Jane	17/10/25	
105	ACP-PFE-197		6224	/		/			/	195 Psi	Jane	17/10/25	
106	ACP-PFE-198	Ocean Wing 47	6225	/		/			/	195 Psi	Jane	17/10/25	
107	ACP-PFE-199		6227	/		/			/	195 Psi	Jane	17/10/25	
108	ACP-PFE-200	Ocean Wing 48	6228	/		/			/	195 Psi	Jane	17/10/25	
109	ACP-PFE-201		6230	/		/			/	195 Psi	Jane	17/10/25	
110	ACP-PFE-202	Ocean Wing 49	6231	/		/			/	195 Psi	Jane	17/10/25	
111	ACP-PFE-203		6233	/		/			/	195 Psi	Jane	17/10/25	
112	ACP-PFE-204	Ocean Wing 50	6234	/		/			/	195 Psi	Jane	17/10/25	
113	ACP-PFE-205		6236	/		/			/	195 Psi	Jane	17/10/25	
114	ACP-PFE-206	ARP	Club Pakarang	/		/			/	195 Psi	Jane	17/10/25	
115	ACP-PFE-207	ARP	MDB 4	/		/			/	195 Psi	Jane	17/10/25	
116	ACP-PFE-208	ARP	Club Pakarang 1	/		/			/	195 Psi	Jane	17/10/25	
117	ACP-PFE-209	ARP	Club Pakarang 2	/		/			/	195 Psi	Jane	17/10/25	
118	ACP-PFE-210	ARP	C/P Kitchen	/		/			/	195 Psi	Jane	17/10/25	
119	ACP-PFE-211	ARP	C/P Kitchen	/		/			/	195 Psi	Jane	17/10/25	
120	ACP-PFE-212	ARP	EE-Pakarang	/		/			/	195 Psi	Jane	17/10/25	
121	ACP-PFE-213	ARP	H/K 2						/	195 Psi	Jane	17/10/25	
122	ACP-PFE-214	ARP	Fire pump1	/		/			/	195 Psi	Jane	17/10/25	





## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: October Year: 2025

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark
				Type of Chemical			Physical		Gauge				
				Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure			
123	ACP-PFE-215	ARP	Fire pump2		/		/			195 Psi	Jame	17/10/25	
124	ACP-PFE-216	ARP	Genarator2		/		/			195 Psi	Jame	17/10/25	
125	ACP-PFE-217	ARP	MDB3		/		/			195 Psi	Jame	17/10/25	
126	ACP-PFE-218	ARP	Staff toilet A7		/		/			195 Psi	Jame	17/10/25	
127	ACP-PFE-219	ARP	Tranformer 4		/		/			195 Psi	Jame	17/10/25	
128	ACP-PFE-220	ARP	Coral Kitchen		/		/			195 Psi	Jame	17/10/25	
129	ACP-PFE-221	ARP	H/K1		/		/			195 Psi	Jame	17/10/25	
130	ACP-PFE-222	ARP	H/K3		/		/			195 Psi	Jame	17/10/25	
131	ACP-PFE-223	ARP	H/K4		/		/			195 Psi	Jame	17/10/25	
132	ACP-PFE-224	ARP	Fire Pump3		/		/			195 Psi	Jame	17/10/25	

Acknowledge by: Kayazit

Fire-Life Safety Teamleader

Approved by: Jame

Heads of Department

DATE: 17/10/25

SIGNATURE

CHIEF ENGINEER





## FLS - 10 : Portable Fire Extinguishers

10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: November Year: 2023



Item no.	FLS CODE	Area		Fire Extinguisher							Checked by	Date	Remark
				Type of Chemical			Physical		Gauge				
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure			
27	ACP-PFE-027	Building 1	In Garden Room	/			/		/		Karigasit	20-11-25	
28	ACP-PFE-028	Building 1	In Florist Room	/			/		/		"	"	
29	ACP-PFE-029	Garbage	The Room	/			/		/		"	"	
30	ACP-PFE-030	Garbage	The Room	/			/		/		"	"	
31	ACP-PFE-031	Staff Canteen	In The Kitchen	/			/		/		"	"	
32	ACP-PFE-032	Staff Canteen	In The Kitchen	/			/		/		"	"	
33	ACP-PFE-033	Staff Canteen	In The Kitchen	/			/		/		"	"	
34	ACP-PFE-034	Staff Canteen	Station Gas	/			/		/		"	"	
35	ACP-PFE-035	Male Locker	In Staff Toilets	/			/		/		Karigasit	20-11-25	
36	ACP-PFE-036	Female Locker	In Staff Toilets	/			/		/		"	"	
37	ACP-PFE-037	HR. Room	In HR. Room	/			/		/		"	"	
38	ACP-PFE-038	MDB3	Out HR. Room	/			/		/		"	"	
39	ACP-PFE-039	Lagritta Pool	Lagritta Pool	/			/		/		"	"	
40	ACP-PFE-040	Lobby	Entrance (OPR)	/			/		/		"	"	
41	ACP-PFE-041	Store bell	In The Room	/			/		/		"	"	
42	ACP-PFE-042	Executive Offices	Door Offices	/			/		/		"	"	
43	ACP-PFE-043	Lagitta Station Gas	Lobby	/			/		/		"	"	
44	ACP-PFE-044	Lagitta Station Gas	Lobby	/			/		/		"	"	
45	ACP-PFE-045	Secueity No.1	Enteance	/			/		/		"	"	
46	ACP-PFE-046	Secueity No.2	Lobby	/			/		/		Karigasit	20-11-25	
47	ACP-PFE-047	Secueity No.3	Old Time Kepper	/			/		/		"	"	
48	ACP-PFE-048	Accounting	In The Room	/			/		/		"	"	
49	ACP-PFE-049	Main Kitchen	Entrance	/			/		/		"	"	
50	ACP-PFE-050	Main Kitchen	Entrance	/			/		/		"	"	
51	ACP-PFE-051	Main Kitchen	Out The Room	/			/		/		"	"	
52	ACP-PFE-052	Main Kitchen	In The Room	/			/		/		"	"	
53	ACP-PFE-053	House Keeping	In The Room	/			/		/		"	"	
54	ACP-PFE-054	Generator MDB 1	Entrance	/			/		/		"	"	
55	ACP-PFE-055	Generator MDB 1	In The Room	/			/		/		"	"	
56	ACP-PFE-056	Laundry	Up The Stairs	/			/		/		"	"	
57	ACP-PFE-057	Laundry	Laundry	/			/		/		"	"	
58	ACP-PFE-058	Laundry	Laundry	/			/		/		"	"	
59	ACP-PFE-059	Laundry	Laundry	/			/		/		Karigasit	20-11-25	



Item no.	FLS CODE	Area		Fire Extinguisher							Checked by	Date	Remark	
				Type of Chemical			Physical		Gauge					
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure				
60	ACP-PFE-060	Laundry	Laundry	✓	✓		✓			✓		Kaityasit 20-11-23		
61	ACP-PFE-061	Boiler room	Boiler room	✓			✓			✓		h	h	
62	ACP-PFE-062	Eng. Work Shop	Tools Room	✓			✓			✓		h	h	
63	ACP-PFE-063	Eng. Work Shop	MDB Room	✓			✓			✓		h	h	
64	ACP-PFE-064	Eng. Work Shop	Painter Room	✓			✓			✓		h	h	
65	ACP-PFE-065	Oil Station	Desel Tank	✓			✓			✓		h	h	
66	ACP-PFE-066	Walkway Rim talay		✓			✓			✓		h	h	
67	ACP-PFE-067	Voyagerlounge		✓			✓			✓		h	h	
68	ACP-PFE-068	Gas Station	Laundry	✓			✓			✓		Kaityasit 20-11-23		
69	ACP-PFE-069	Mortorbike Garage1		✓			✓			✓		h	h	
70	ACP-PFE-070	Mortorbike Garage2		✓			✓			✓		h	h	
71	ACP-PFE-071	Rimtalay pump room		✓			✓			✓		h	h	
72	ACP-PFE-072	Kid club		✓			✓			✓		h	h	
73	ACP-PFE-073	Fire Training		✓			✓			✓		h	h	
74	ACP-PFE-074	PABX room		✓			✓			✓		h	h	
75	ACP-PFE-075	EE room B.2		✓			✓			✓		h	h	
76	ACP-PFE-076	Pantry samurt bar 1	Samut Bar	✓			✓			✓		h	h	
77	ACP-PFE-077	Pantry samurt bar 2	Samut Bar	✓			✓			✓		Kaityasit 20-11-23		
78	ACP-PFE-078	Idea Station Gas	Idea Room	✓			✓			✓		h	h	
79	ACP-PFE-079	Sport Center		✓			✓			✓		h	h	
80	ACP-PFE-080	Sport Center		✓			✓			✓		h	h	
81	ACP-PFE-081	Server Room		✓			✓			✓		h	h	
82	ACP-PFE-082		Front Spa	✓			✓			✓		h	h	
83	ACP-PFE-083		Spa Reception	✓			✓			✓		h	h	
84	ACP-PFE-084		Spa Sala 1	✓			✓			✓		h	h	
85	ACP-PFE-085		Spa Sala 2	✓			✓			✓		h	h	
86	ACP-PFE-086		Spa Sala 3	✓			✓			✓		h	h	
87	ACP-PFE-087		Spa Sala 4	✓			✓			✓		h	h	
88	ACP-PFE-088	Fitness		✓			✓			✓		Kaityasit 20-11-23		



Ite m no.	FLS CODE	Area		Fire Extinguisher							Checked by	Date	Remark
				Section	Location	Type of Chemical			Physical				
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure			
89	ACP-PFE-089	Lift		/			/			/		Kalyasit 20-11-25	
90	ACP-PFE-090	GM House		/			/			/		Kalyasit 20-11-25	
91	ACP-PFE-091	Jetty 1		/			/			/		Kalyasit 20-11-25	
92	ACP-PFE-092	Jetty 2		/			/			/		Kalyasit 20-11-25	
	ACP-PFE-255	Gas Station	Laundry	/			/			/		Kalyasit 20-11-25	

Acknowledge by: Kalyasit .....

Fire-Life Safety Teamleader

Approved by: Amari .....

Heads of Department



## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: November Year: 2025

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark	
				Type of Chemical			Physical		Gauge					
		Section	Location	Dry	Halotron	Wet chemical	Normal	Abnormal	Status	Pressure				
1	ACP-PFE-093	Ocean Wing 1	6000		/		/		/		Karayasit	22-11-25		
2	ACP-PFE-094		6002		/		/		/		"	"		
3	ACP-PFE-095		6004		/		/		/					
4	ACP-PFE-096		6006		/		/		/					
5	ACP-PFE-097	Ocean Wing 2	6008		/		/		/		"	"		
6	ACP-PFE-098		6010		/		/		/					
7	ACP-PFE-099		6012		/		/		/					
8	ACP-PFE-100		6015		/		/		/		Karayasit	22-11-25		
9	ACP-PFE-101	Ocean Wing 3	6016		/		/		/		"	"		
10	ACP-PFE-102		6017		/		/		/		"	"		
11	ACP-PFE-103		6020		/		/		/		"	"		
12	ACP-PFE-104		6021		/		/		/					
13	ACP-PFE-105	Ocean Wing 5	6023		/		/		/		"	"		
14	ACP-PFE-106		6024		/		/		/		"	"		
15	ACP-PFE-107		6026		/		/		/		"	"		
16	ACP-PFE-108		6028		/		/		/					
17	ACP-PFE-109	Ocean Wing 7	6031		/		/		/		Karayasit	22-11-25		
18	ACP-PFE-110		6032		/		/		/		"	"		
19	ACP-PFE-111		6035		/		/		/		"	"		
20	ACP-PFE-112		6036		/		/		/					
21	ACP-PFE-113	Ocean Wing 9	6038		/		/		/		"	"		
22	ACP-PFE-114		6040		/		/		/		"	"		
23	ACP-PFE-0115		6042					/		/		"	"	
24	ACP-PFE-0116		Ocean Wing 10	6044		/		/		/		Karayasit	22-11-25	



## Engineering Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: November Year: 2023

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)								Checked by	Date	Remark	
				Section	Location	Type of Chemical			Physical		Gauge				
		Dry	Halotron			Wet chemical	Normal	Abnormal	Status	Pressure					
25	ACP-PFE-0117	Ocean Wing 11	6046		/		/			/		Kalyasit	22-11-25		
26	ACP-PFE-0118		6048		/		/				/		"	"	
27	ACP-PFE-0119		6050		/			/			/		"	"	
28	ACP-PFE-0120		6052		/			/			/		"	"	
29	ACP-PFE-0121	Ocean Wing 12	6053		/		/			/		"	"		
30	ACP-PFE-0122		6055		/		/				/		"	"	
31	ACP-PFE-0123		6057		/			/			/		"	"	
32	ACP-PFE-0124		6058		/			/			/		Kalyasit	22-11-25	
33	ACP-PFE-0125	Ocean Wing 13	6060		/		/			/		"	"		
34	ACP-PFE-0126		6062		/			/			/		"	"	
35	ACP-PFE-0127		6063		/			/			/		"	"	
36	ACP-PFE-0128		6066		/			/			/		"	"	
37	ACP-PFE-0129	Ocean Wing 15	6067		/		/			/		"	"		
38	ACP-PFE-0130		6069		/			/			/		"	"	
39	ACP-PFE-0131		6071		/			/			/		"	"	
40	ACP-PFE-0132		6073		/			/			/		Kalyasit	22-11-25	
41	ACP-PFE-0133	Ocean Wing 17	6075		/		/			/		"	"		
42	ACP-PFE-0134		6077		/			/			/		"	"	
43	ACP-PFE-0135		6079		/			/			/		"	"	
44	ACP-PFE-0136		6081		/			/			/		"	"	
45	ACP-PFE-0137	Ocean Wing 19	6083		/		/			/		"	"		
46	ACP-PFE-0138		6085		/			/			/		"	"	
47	ACP-PFE-0139		6086		/			/			/		"	"	
48	ACP-PFE-0140		6087		/			/			/		"	"	
49	ACP-PFE-0141	Ocean Wing 20	6089		/		/			/		Kalyasit	22-11-25		



## Engineerin Department

### FLS - 10 : Portable Fire Extinguishers

FLS 10-02 Record of monthly inspection of all Portable Fire Extinguishers.

Month: November Year: 2025

Item No.	FLS CODE	Area		Extinguisher (Dry chemical)							Checked by	Date	Remark		
				Section	Location	Type of Chemical			Physical					Gauge	
						Dry	Halotron	Wet chemical	Normal	Abnormal				Status	Pressure
50	ACP-PFE-0142	Ocean Wing 21	6090		✓		✓		✓		Kalyasit	22-11-25			
51	ACP-PFE-143		6091		✓			✓		✓		u	u		
52	ACP-PFE-144		6093		✓			✓		✓		u	u		
53	ACP-PFE-145		6096		✓			✓		✓		u	u		
54	ACP-PFE-146	Ocean Wing 22	6097		✓		✓		✓		u	u			
55	ACP-PFE-147		6099		✓			✓		✓		u	u		
56	ACP-PFE-148		6101		✓			✓		✓		Kalyasit	22-11-25		
57	ACP-PFE-149		6103		✓			✓		✓		u	u		
58	ACP-PFE-150	Ocean Wing 23	6105		✓		✓		✓		u	u			
59	ACP-PFE-151		6107		✓			✓		✓		u	u		
60	ACP-PFE-152		6109		✓			✓		✓		u	u		
61	ACP-PFE-153		6112		✓			✓		✓		u	u		
62	ACP-PFE-154	Ocean Wing 25	6114		✓		✓		✓		u	u			
63	ACP-PFE-155		6116		✓			✓		✓		u	u		
64	ACP-PFE-156		6118		✓			✓		✓		Kalyasit	22-11-25		
65	ACP-PFE-157		6120		✓			✓		✓		u	u		
66	ACP-PFE-158	Ocean Wing 27	6121		✓		✓		✓		u	u			
67	ACP-PFE-159		6123		✓			✓		✓		u	u		
68	ACP-PFE-160		6124		✓			✓		✓		u	u		
69	ACP-PFE-161		6126		✓			✓		✓		u	u		
70	ACP-PFE-162	Ocean Wing 29	6127		✓		✓		✓		u	u			
71	ACP-PFE-163		6128		✓			✓		✓		u	u		
72	ACP-PFE-164		6129		✓			✓		✓		u	u		
73	ACP-PFE-165		6130		✓			✓		✓		Kalyasit	22-11-25		