

ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : JULY 30, 2025
SAMPLING TIME : 16:15 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : MR SUKSAN BOONLEANG
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM

RECEIVED DATE : JULY 31, 2025
ANALYTICAL DATE : JULY 31 - AUGUST 6, 2025
ISSUE DATE : AUGUST 8, 2025
REPORT NO. : 2025-U071491
WORK NO. : 2024-012452
ANALYSIS NO. : T25AQ606-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ปอดตรวจคุณภาพน้ำ T25AQ606-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	6.1 (32.2°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	14.6	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	18.0	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	475	≤ 1,300	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	< 5.0	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION						
WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JULY 30, 2025
SAMPLING TIME : 16:10 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SUKSAN BOONLEANG
ANALYZED BY : MISS BUSSAKORN MAJAI

RECEIVED DATE : JULY 31, 2025
ANALYTICAL DATE : JULY 31 - AUGUST 4, 2025
ISSUE DATE : AUGUST 8, 2025
REPORT NO. : 2025-U071492
WORK NO. : 2024-012452
ANALYSIS NO. : T25AQ606-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25AQ606-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JULY 30, 2025
SAMPLING TIME : 16:05 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SUKSAN BOONLEANG
ANALYZED BY : MISS BUSSAKORN MAJAI
RECEIVED DATE : JULY 31, 2025
ANALYTICAL DATE : JULY 31 - AUGUST 4, 2025
ISSUE DATE : AUGUST 8, 2025
REPORT NO. : 2025-U071493
WORK NO. : 2024-012452
ANALYSIS NO. : T25AQ606-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25AQ606-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : AUGUST 27, 2025
SAMPLING TIME : 10:55 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS BUSSAKORN MAJAI
RECEIVED DATE : AUGUST 27, 2025
ANALYTICAL DATE : AUGUST 27-31, 2025
ISSUE DATE : SEPTEMBER 5, 2025
REPORT NO. : 2025-U079986
WORK NO. : 2024-012452
ANALYSIS NO. : T25AS723-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25AS723-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : AUGUST 27, 2025
SAMPLING TIME : 11:00 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS BUSSAKORN MAJAI
RECEIVED DATE : AUGUST 27, 2025
ANALYTICAL DATE : AUGUST 27-31, 2025
ISSUE DATE : SEPTEMBER 5, 2025
REPORT NO. : 2025-U079987
WORK NO. : 2024-012452
ANALYSIS NO. : T25AS723-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25AS723-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : AUGUST 27, 2025
SAMPLING TIME : 11:05 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : AUGUST 27, 2025
ANALYTICAL DATE : AUGUST 27 - SEPTEMBER 3, 2025
ISSUE DATE : SEPTEMBER 4, 2025
REPORT NO. : 2025-U079985
WORK NO. : 2024-012452
ANALYSIS NO. : T25AS723-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ผลการตรวจภาพน้ำ T25AS723-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	6.8 (30.9°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	112	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	13.5	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	407	≤ 1,300	-	25
SETTLEABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	7.0	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN			


^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT **RECEIVED DATE** : SEPTEMBER 19, 2025
SAMPLING DATE : SEPTEMBER 19, 2025 **ANALYTICAL DATE** : SEPTEMBER 19-26, 2025
SAMPLING TIME : 11:55 HOUR **ISSUE DATE** : SEPTEMBER 29, 2025
SAMPLING METHOD : GRAB **REPORT NO.** : 2025-U088102
SAMPLING BY : MR SUKSAN BOONLEANG **WORK NO.** : 2024-012452
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM **ANALYSIS NO.** : T25AV083-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			บอตรวจคุณภาพน้ำ T25AV083-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	5.6 (33.3°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	18.5	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	34.3	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	369	≤ 1,300	-	25
SETTLEABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	6.6	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : SEPTEMBER 19, 2025
SAMPLING TIME : 11:45 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SUKSAN BOONLEANG
ANALYZED BY : MISS CHATTRAPORN RATCHANET


RECEIVED DATE : SEPTEMBER 19, 2025
ANALYTICAL DATE : SEPTEMBER 19-24, 2025
ISSUE DATE : SEPTEMBER 30, 2025
REPORT NO. : 2025-U088103
WORK NO. : 2024-012452
ANALYSIS NO. : T25AV083-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25AV083-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : SEPTEMBER 19, 2025
SAMPLING TIME : 11:40 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SUKSAN BOONLEANG
ANALYZED BY : MISS CHATRAPORN RATCHANET


RECEIVED DATE : SEPTEMBER 19, 2025
ANALYTICAL DATE : SEPTEMBER 19-24, 2025
ISSUE DATE : SEPTEMBER 30, 2025
REPORT NO. : 2025-U088104
WORK NO. : 2024-012452
ANALYSIS NO. : T25AV083-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25AV083-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : OCTOBER 29, 2025
SAMPLING TIME : 13:20 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : OCTOBER 30, 2025
ANALYTICAL DATE : OCTOBER 30 - NOVEMBER 5, 2025
ISSUE DATE : NOVEMBER 7, 2025
REPORT NO. : 2025-U101506
WORK NO. : 2024-012452
ANALYSIS NO. : T25AY398-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ปอดตรวจคุณภาพน้ำ T25AY398-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H* B AND 1060 B	7.1 (30.7°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	46.5	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	17.9	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	227	≤ 1,300	-	25
SETTLEABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^p	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	25.1	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT


CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : OCTOBER 29, 2025
SAMPLING TIME : 13:15 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS CHATRAPORN RATCHANET
RECEIVED DATE : OCTOBER 30, 2025
ANALYTICAL DATE : OCTOBER 30 - NOVEMBER 1, 2025
ISSUE DATE : NOVEMBER 10, 2025
REPORT NO. : 2025-U101507
WORK NO. : 2024-012452
ANALYSIS NO. : T25AY398-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25AY398-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT


CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : OCTOBER 29, 2025
SAMPLING TIME : 13:10 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS CHATRAPORN RATCHANET
RECEIVED DATE : OCTOBER 30, 2025
ANALYTICAL DATE : OCTOBER 30 - NOVEMBER 1, 2025
ISSUE DATE : NOVEMBER 10, 2025
REPORT NO. : 2025-U101509
WORK NO. : 2024-012452
ANALYSIS NO. : T25AY398-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25AY398-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : NOVEMBER 27, 2025
SAMPLING TIME : 13:45 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM

RECEIVED DATE : NOVEMBER 27, 2025
ANALYTICAL DATE : NOVEMBER 27-DECEMBER 2, 2025
ISSUE DATE : DECEMBER 4, 2025
REPORT NO. : 2025-U110682
WORK NO. : 2024-012452
ANALYSIS NO. : T25BA882-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ผลการตรวจภาพน้ำ T25BA882-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	6.3 (30.8°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	19.1	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	33.8	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	351	≤ 1,300	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	6.7	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/TURBID			
SEDIMENT			BROWN			


^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL **RECEIVED DATE** : NOVEMBER 27, 2025
SAMPLING DATE : NOVEMBER 27, 2025 **ANALYTICAL DATE** : NOVEMBER 27-DECEMBER 1, 2025
SAMPLING TIME : 13:25 HOUR **ISSUE DATE** : DECEMBER 4, 2025
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE **REPORT NO.** : 2025-U110684
SAMPLING BY ° : MR SITTHIPOL PROMPOCHENBOON **WORK NO.** : 2024-012452
ANALYZED BY : MISS CHATRAPORN RATCHANET **ANALYSIS NO.** : T25BA882-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25BA882-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : NOVEMBER 27, 2025
SAMPLING TIME : 13:30 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS CHATTRAPORN RATCHANET
RECEIVED DATE : NOVEMBER 27, 2025
ANALYTICAL DATE : NOVEMBER 27-DECEMBER 1, 2025
ISSUE DATE : DECEMBER 4, 2025
REPORT NO. : 2025-U110686
WORK NO. : 2024-012452
ANALYSIS NO. : T25BA882-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25BA882-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT **RECEIVED DATE** : DECEMBER 12, 2025
SAMPLING DATE : DECEMBER 12, 2025 **ANALYTICAL DATE** : DECEMBER 12-20, 2025
SAMPLING TIME : 15:20 HOUR **ISSUE DATE** : DECEMBER 22, 2025
SAMPLING METHOD : GRAB **REPORT NO.** : 2025-U115756
SAMPLING BY : MR SITTHIPOL PROMPOCHENBOON **WORK NO.** : 2024-012452
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM **ANALYSIS NO.** : T25BC190-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			บอตรวจคุณภาพน้ำ T25BC190-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H* B AND 1060 B	6.8 (30.1°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	9.2	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	23.4	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	353	≤ 1,300	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500 -S ² - F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	< 5.0	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/CLEAR			
SEDIMENT			BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : DECEMBER 12, 2025
SAMPLING TIME : 15:15 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS CHATTRAPORN RATCHANET

RECEIVED DATE : DECEMBER 12, 2025
ANALYTICAL DATE : DECEMBER 12-17, 2025
ISSUE DATE : DECEMBER 22, 2025
REPORT NO. : 2025-U115758
WORK NO. : 2024-012452
ANALYSIS NO. : T25BC190-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T25BC190-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 9764 8460 e-mail : Tawatchai.s@yps.co.th
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : DECEMBER 12, 2025
SAMPLING TIME : 15:10 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS CHATTRAPORN RATCHANET
RECEIVED DATE : DECEMBER 12, 2025
ANALYTICAL DATE : DECEMBER 12-17, 2025
ISSUE DATE : DECEMBER 22, 2025
REPORT NO. : 2025-U115759
WORK NO. : 2024-012452
ANALYSIS NO. : T25BC190-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T25BC190-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

