

LOG SHEET OF SWIMMING POOL / POND									
BUILDING : Windshell Naradhiwas									
Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015 Month: 31/01/2015 Year 2025									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
22	Morning 09:00	1.5	7.5						
	Afternoon 14:00	1.5	7.5						
23	Morning 09:00	1.5	7.5						
	Afternoon 14:00	1.5	7.5						
24	Morning 09:00	1.5	7.5						
	Afternoon 14:00	1.5	7.5						
25	Morning 09:00	1.4	7.4						
	Afternoon 14:00	1.4	7.4						
26	Morning 09:00	1.4	7.3						
	Afternoon 14:00	1.4	7.3						
27	Morning 09:00	1.4	7.3						
	Afternoon 14:00	1.4	7.3						
28	Morning 09:00	1.4	7.3						
	Afternoon 14:00	1.4	7.3						
Comment: _____									
BSE: _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING : Windshell Naradhiwas									
Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015 Month: 31/01/2015 Year 2025									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
29	Morning 09:00	1.5	7.5	10					
	Afternoon 14:00	1.5	7.5	10					
30	Morning 09:00	1.5	7.5	10					
	Afternoon 14:00	1.5	7.5	10					
31	Morning 09:00	1.5	7.5	10					
	Afternoon 14:00	1.5	7.5	10					
	Morning 09:00								
	Afternoon 14:00								
	Morning 09:00								
	Afternoon 14:00								
	Morning 09:00								
	Afternoon 14:00								
	Morning 09:00								
	Afternoon 14:00								
Comment: _____									
BSE: _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING : Windshell Naradhiwas									
Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015 Month: 31/01/2015 Year 2025									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning 09:00	1.5	7.5	10					
	Afternoon 14:00	1.5	7.5	10					
9	Morning 09:00	1.5	7.4	10					
	Afternoon 14:00	1.5	7.4	10					
10	Morning 09:00	1.5	7.5	10					
	Afternoon 14:00	1.5	7.5	10					
11	Morning 09:00	1.5	7.5	10					
	Afternoon 14:00	1.5	7.5	10					
12	Morning 09:00	1.5	7.5	10					
	Afternoon 14:00	1.5	7.5	10					
13	Morning 09:00	1.5	7.6	10					
	Afternoon 14:00	1.5	7.6	10					
14	Morning 09:00	1.5	7.5	10					
	Afternoon 14:00	1.5	7.5	10					
Comment: _____									
BSE: _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING : Windshell Naradhiwas									
Ref No: JLL-OP-SN-004/01 Rev. Date: 31/01/2015 Month: 31/01/2015 Year 2025									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
15	Morning 09:00	1.4	7.5	10					
	Afternoon 14:00	1.4	7.5	10					
16	Morning 09:00	1.4	7.5	10					
	Afternoon 14:00	1.4	7.5	10					
17	Morning 09:00	1.4	7.5	10					
	Afternoon 14:00	1.4	7.5	10					
18	Morning 09:00	1.5	7.5	10					
	Afternoon 14:00	1.5	7.5	10					
19	Morning 09:00	1.5	7.4	10					
	Afternoon 14:00	1.5	7.4	10					
20	Morning 09:00	1.5	7.5	10					
	Afternoon 14:00	1.5	7.5	10					
21	Morning 09:00	1.5	7.5	10					
	Afternoon 14:00	1.5	7.5	10					
Comment: _____									
BSE: _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING : Windshell Naradhiwas									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : Year 2026									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
15	Morning	1.3	7.2						
	Afternoon	1.1	7.0						
16	Morning	1.1	7.0						
	Afternoon	1.3	7.2						
17	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
18	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
19	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
20	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
21	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
Comment :								BSE : / /	

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING : Windshell Naradhiwas									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : Year 2026									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
1	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
2	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
3	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
4	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
5	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
6	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
7	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
Comment :								BSE : / /	

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING : Windshell Naradhiwas									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : Year 2026									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
22	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
23	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
24	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
25	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
26	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
27	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
28	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
Comment :								BSE : / /	

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING : Windshell Naradhiwas									
Ref No: JLL-OP-SN-004/01									
Rev. Date : 31/01/2015									
Month : Year 2026									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
9	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
10	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
11	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
12	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
13	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
14	Morning	1.3	7.2						
	Afternoon	1.3	7.2						
Comment :								BSE : / /	

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING : Windshell Naradiwas									
Ref No: JLL-OP-SN-00401									
Rev. Date : 31/01/2015									
Month : 01/2015 Year 2025									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr.Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning 09:00	1.5	7.4	10					
	Afternoon 16:00	3.5	7.4	10					
9	Morning 09:00	2.5	7.4	10					
	Afternoon 16:00	1.5	7.5	10					
10	Morning 09:00	1.5	7.4	10					
	Afternoon 16:00	1.5	7.4	10					
11	Morning 09:00	1.5	7.5	10					
	Afternoon 16:00	1.4	7.4	10					
12	Morning 09:00	1.4	7.5	10					
	Afternoon 16:00	1.5	7.5	10					
13	Morning 09:00	1.5	7.4	10					
	Afternoon 16:00	1.5	7.5	10					
14	Morning 09:00	1.5	7.5	10					
	Afternoon 16:00	1.5	7.5	10					
Comment : _____									
BSE : _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING : Windshell Naradiwas									
Ref No: JLL-OP-SN-00401									
Rev. Date : 31/01/2015									
Month : 01/2015 Year 2025									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr.Technician)	Remark		
		Chlorine (ppm)	pH						
29	Morning 09:00	1.3	7.2	10					
	Afternoon 16:00	1.3	7.2	10					
30	Morning 09:00	1.3	7.2	10					
	Afternoon 16:00	1.3	7.2	10					
	Morning 09:00								
	Afternoon 16:00								
	Morning 09:00								
	Afternoon 16:00								
	Morning 09:00								
	Afternoon 16:00								
	Morning 09:00								
	Afternoon 16:00								
Comment : _____									
BSE : _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING : Windshell Naradiwas									
Ref No: JLL-OP-SN-00401									
Rev. Date : 31/01/2015									
Month : 01/2015 Year 2025									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr.Technician)	Remark		
		Chlorine (ppm)	pH						
15	Morning 09:00	1.5	7.4	10					
	Afternoon 16:00	1.5	7.5	10					
16	Morning 09:00	1.5	7.5	10					
	Afternoon 16:00	1.5	7.5	10					
17	Morning 09:00	1.5	7.5	10					
	Afternoon 16:00	1.5	7.5	10					
18	Morning 09:00	1.4	7.4	10					
	Afternoon 16:00	1.4	7.4	10					
19	Morning 09:00	1.4	7.5	10					
	Afternoon 16:00	1.4	7.5	10					
20	Morning 09:00	1.5	7.4	10					
	Afternoon 16:00	1.5	7.5	10					
21	Morning 09:00	1.5	7.5	10					
	Afternoon 16:00	1.5	7.5	10					
Comment : _____									
BSE : _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND									
BUILDING : Windshell Naradiwas									
Ref No: JLL-OP-SN-00401									
Rev. Date : 31/01/2015									
Month : 01/2015 Year 2025									
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr.Technician)	Remark		
		Chlorine (ppm)	pH						
1	Morning 09:00	1.5	7.4	10					
	Afternoon 16:00	1.5	7.4	10					
2	Morning 09:00	1.5	7.4	10					
	Afternoon 16:00	1.5	7.4	10					
3	Morning 09:00	1.5	7.5	10					
	Afternoon 16:00	1.5	7.5	10					
4	Morning 09:00	1.5	7.5	10					
	Afternoon 16:00	1.5	7.5	10					
5	Morning 09:00	1.5	7.4	10					
	Afternoon 16:00	1.5	7.4	10					
6	Morning 09:00	1.5	7.6	10					
	Afternoon 16:00	1.5	7.6	10					
7	Morning 09:00	1.5	7.5	10					
	Afternoon 16:00	1.5	7.5	10					
Comment : _____									
BSE : _____									

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

BUILDING : Windshell Naradhiwas

Ref No : JLL-OP-SN-04/01

Rev. Date : 31/01/2015

Month : 07 08 09 Year 2020

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
22	Morning	09:00	1.5	7.5			
	Afternoon	16:00	1.5	7.5			
23	Morning	09:00	1.5	7.5			
	Afternoon	16:00	1.5	7.5			
24	Morning	09:00	1.5	7.4			
	Afternoon	16:00	1.5	7.4			
25	Morning	09:00	1.5	7.6			
	Afternoon	16:00	1.5	7.6			
26	Morning	09:00	1.5	7.6			
	Afternoon	16:00	1.5	7.6			
27	Morning	09:00	1.4	7.6			
	Afternoon	16:00	1.4	7.5			
28	Morning	09:00	1.4	7.4			
	Afternoon	16:00	1.4	7.5			

Comment :

BSE : / /

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

BUILDING : Windshell Naradhiwas

Ref No : JLL-OP-SN-04/01

Rev. Date : 31/01/2015

Month : 07 08 09 Year 2020

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
29	Morning	09:00	1.5	7.5			
	Afternoon	16:00	1.5	7.5			
30	Morning	09:00	1.5	7.5			
	Afternoon	16:00	1.5	7.5			
31	Morning	09:00	1.5	7.5			
	Afternoon	16:00	1.5	7.5			
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						

Comment :

BSE : / /

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm

