



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Lot ID: 2579441

Date Received : Sep 03, 2025

Date Reported : Sep 19, 2025

Report Number : 3408962-1

Page 1 of 1

Sample Number	2579441-9
Sampled Date	Sep 02, 2025 12:23 PM
Sample Description	น้ำอ่างล้างตา - โรงบำบัดน้ำเสีย
Location	จุดล้างตาล้างตัว - โรงบำบัดน้ำเสีย
Date Analysis Commenced	Sep 03, 2025
Condition of Sample	Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Microbiological Testing							
<i>Escherichia coli</i>	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 B, F	Songkhla
<i>Legionella spp.</i>	CFU/L	-	-	<1	No Standard	ISO 11731 (2017)	Bangkok
<i>Pseudomonas aeruginosa</i> *	in 100 mL	-	-	Not Detected	No Standard	In-house method in connection with: - Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9213 E	Bangkok
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 B	Songkhla

Guideline : เกณฑ์คุณภาพน้ำประปาดื่มได้ ประกาศ กรมอนามัย พ.ศ. 2563

Note : Microbiological Testing Result <1 mean Bacteria not found in agar plate.

Sampling By : Thaksin Aintrom , Furakan Kasetka

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- [A] Analysis conducted by ALS Laboratory Group (Thailand) Co.,Ltd. Bangkok Branch, DMSc Accreditation No. 1031/47.
- Sampling is not included in scope of accreditation ISO/IEC 17025

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

Approved by

Chompoonuch F.

Chompoonuch Funtha
Supervisor

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



ISO/IEC 17025

Accreditation No. 1031/47

Analysis / Test Report

Client : Bangkok Phuket Hospital Co., Ltd.

2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Lot ID: 2579441

Date Received : Sep 03, 2025

Date Reported : Sep 19, 2025

Report Number : 3408976-1

Page 1 of 1

Sample Number	2579441-23
Sampled Date	Sep 02, 2025 12:15 PM
Sample Description	น้ำบ่อเก็บน้ำใต้ดิน
Location	บ่อเก็บน้ำใต้ดิน - ห้อง Fire Pump
Date Analysis Commenced	Sep 03, 2025
Condition of Sample	Contained in two plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Microbiological Testing							
<i>Legionella spp.</i>	CFU/L	-	-	<1	No Standard	ISO 11731 (2017)	Bangkok

Guideline : Notification of the National Environmental Board, No. 20, B.E.2543

Note : Microbiological Testing Result <1 mean Bacteria not found in agar plate.

Sampling By : Thaksin Aintrom , Furakan Kasetka

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- Sampling is not included in scope of accreditation ISO/IEC 17025

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

Approved by

Suwannee Chuamkeaw
Section HeadADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER

11575-31/ EMAIL

S:\Reports_All_GL.rpt (3:32PM)