



Analysis / Test Report

TESTING

No.0009

Lot ID: 2589232

Date Received : Oct 08, 2025

Date Reported : Oct 28, 2025

Report Number : 3435949-1

Client : Bangkok Phuket Hospital Co., Ltd.

2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Page 1 of 5

Sample Number	2589232-25
Sampled Date	Oct 07, 2025 11:00 AM
Sample Description	น้ำคลองหลังจุดปล่อยน้ำออก 100 m
Location	น้ำคลองหลังจุดปล่อยน้ำออก 100 m
Date Analysis Commenced	Oct 08, 2025
Condition of Sample	Contained in two BOD bottles, two glass vials, two amber glass bottles and nine plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Arsenic	mg/L	0.0003	0.0005	0.006	≤0.01	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Cadmium	mg/L	0.0003	0.0005	Not Detected	≤0.005	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Copper	mg/L	0.0003	0.0005	0.0007	≤0.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Hexavalent Chromium	mg/L	0.003	0.01	Not Detected	≤0.05	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3500-Cr B	Bangkok
Lead	mg/L	0.0003	0.0005	<0.0005	≤0.05	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Manganese	mg/L	0.0003	0.0005	0.24	≤1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Mercury	mg/L	0.0001	0.0005	Not Detected	≤0.002	In-house method : STM 05-007 based on United States Environmental Protection Agency, 2002, EPA Method 1631, Revision E	Bangkok
Nickel	mg/L	0.0003	0.0005	Not Detected	≤0.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

Approved by

Chanatt L.

Chanattagarn Imchom
Section Head

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER

11575-31/ EMAIL

S:\Reports_All_GL.rpt (2:30PM)



Analysis / Test Report

TESTING

No.0009

Lot ID: 2589232

Date Received : Oct 08, 2025

Date Reported : Oct 28, 2025

Report Number : 3435949-1

Client : Bangkok Phuket Hospital Co., Ltd.

2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Page 2 of 5

Sample Number	2589232-25						
Sampled Date	Oct 07, 2025 11:00 AM						
Sample Description	น้ำคลองหลังจุดปล่อยน้ำออก 100 m						
Location	น้ำคลองหลังจุดปล่อยน้ำออก 100 m						
Date Analysis Commenced	Oct 08, 2025						
Condition of Sample	Contained in two BOD bottles, two glass vials, two amber glass bottles and nine plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)						

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Zinc	mg/L	0.003	0.005	0.007	≤1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B, 3030 F	Bangkok
Microbiological Testing							
Fecal Coliform	MPN/100mL	-	-	3300.0	≤1000	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 B, E	Bangkok
Total Coliform	MPN/100mL	-	-	13000.0	≤5000	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 B	Bangkok
Pesticides - Organochlorine Group							
Aldrin	ug/L	0.01	0.02	Not Detected	≤0.10	In-house method : STM 04-101 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 6630 D, part 6410 B	Bangkok
alpha-BHC	ug/L	0.01	0.02	Not Detected	≤0.02	In-house method : STM 04-101 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 6630 D, part 6410 B	Bangkok
DDT	ug/L	0.06	0.12	Not Detected	≤1	In-house method : STM 04-101 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 6630 D, part 6410 B	Bangkok
Dieldrin	ug/L	0.01	0.02	Not Detected	≤0.10	In-house method : STM 04-101 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 6630 D, part 6410 B	Bangkok

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

Approved by

Chanatt L.

Chanattagarn Imchom
Section Head

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER

11575-31/ EMAIL

S:\Reports\All_GL.rpt (2:30PM)



Analysis / Test Report

TESTING

No.0009

Lot ID: 2589232

Date Received : Oct 08, 2025

Date Reported : Oct 28, 2025

Report Number : 3435949-1

Client : Bangkok Phuket Hospital Co., Ltd.

2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Page 3 of 5

Sample Number	2589232-25
Sampled Date	Oct 07, 2025 11:00 AM
Sample Description	น้ำคลองหลังจุดปล่อยน้ำออก 100 m
Location	น้ำคลองหลังจุดปล่อยน้ำออก 100 m
Date Analysis Commenced	Oct 08, 2025
Condition of Sample	Contained in two BOD bottles, two glass vials, two amber glass bottles and nine plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Pesticides - Organochlorine Group							
Endrin	ug/L	0.01	0.02	Not Detected	Not Detected	In-house method : STM 04-101 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 6630 D, part 6410 B	Bangkok
Heptachlor and Heptachlor epoxide *	ug/L	0.01	0.02	Not Detected	≤0.2	In-house method : STM 04-101 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 6630 D, part 6410 B	Bangkok
Water Testing							
Ammonia Nitrogen *	mg/L	-	0.06	1.77	≤0.5	Based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4500-NH3 (B, F)	Bangkok
BOD (5 days at 20 degree C) *	mg/L	-	2.0	<2.0	≤1.5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 5210 B, 4500 - O (C)	Bangkok
Color *	Color unit	-	5	<5	n	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2120 B	Bangkok
Cyanide as CN	mg/L	0.002	0.005	Not Detected	≤0.005	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4500 - CN (C, E)	Bangkok
Dissolved Oxygen *	mg/L	-	0.1	5.7	≥6	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4500-O (C)	Bangkok

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

Approved by

Chanatt L.

Chanattagarn Imchom
Section Head

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER

11575-31/ EMAIL

S:\Reports_All_GL.rpt (2:30PM)



Analysis / Test Report

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

TESTING

No.0009

Lot ID: 2589232

Date Received : Oct 08, 2025

Date Reported : Oct 28, 2025

Report Number : 3435949-1

Page 4 of 5

Sample Number	2589232-25
Sampled Date	Oct 07, 2025 11:00 AM
Sample Description	น้ำคลองหลังจุดปล่อยน้ำออก 100 m
Location	น้ำคลองหลังจุดปล่อยน้ำออก 100 m
Date Analysis Commenced	Oct 08, 2025
Condition of Sample	Contained in two BOD bottles, two glass vials, two amber glass bottles and nine plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Water Testing							
Gross alpha activity *	Bq/L	0.018	0.063	Not Detected	≤0.10	In-house method based on United States Environmental Protection Agency, EPA Method 900.0 Section I and EPA-600/4/80-032 (1980)	Bangkok
Gross beta activity *	Bq/L	0.012	0.063	0.235 ± 0.024	≤1	In-house method based on United States Environmental Protection Agency, EPA Method 900.0 Section I and EPA-600/4/80-032 (1980)	Bangkok
Nitrate as N	mg/L	0.06	0.2	1.0	≤5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4110 B	Bangkok
Odour *		-	-	Odourless	n	In-house method : STM 04-025 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2150 B	Bangkok
pH at 25 degree C		-	-	7.4	5.0-9.0	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4500 - H (B)	Bangkok
Phenol	mg/L	0.0005	0.001	Not Detected	≤0.005	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 5530 D	Bangkok
Temperature *	Degree C	-	-	32.0	n'	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2550 B	Bangkok
Total Hardness as CaCO ₃ *	mg/L	-	1	59	No Standard	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2340 C	Bangkok

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

Approved by

Chanatt L.

Chanattagarn Imchom
Section Head

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER

11575-31/ EMAIL

S:\Reports_All_GL.rpt (2:30PM)



Analysis / Test Report

Client : Bangkok Phuket Hospital Co., Ltd.

2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

TESTING

No.0009

Lot ID: 2589232

Date Received : Oct 08, 2025

Date Reported : Oct 28, 2025

Report Number : 3435949-1

Page 5 of 5

Guideline : Notification of the National Environmental Board, No. 8, B.E.2537 issued under the Enhancement and Conservation of National Environmental Quality Act. B.E.2535, published in the Royal Government Gazette, Vol. 111, Part 16, Dated February 24, B.E. 2537 (Class 2)

n : Not Change from natural condition

n': Change from Natural condition not more than 3 degree C

Note : Gross alpha activity and Gross beta activity analysis has been subcontracted to outsource lab.

Sampling By : Yuttapong Rattana

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- Sampling is not included in scope of accreditation ISO/IEC 17025

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

Approved by

Chanatt L.

Chanattagarn Imchom
Section Head

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER

11575-31/ EMAIL

S:\Reports_All_GL.rpt (2:30PM)