



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Lot ID: 266327

Date Received : Feb 04, 2026

Date Reported : Feb 19, 2026

Report Number : 3511838-1

Page 1 of 1

Sample Number	266327-13
Sampled Date	Feb 03, 2026 12:10 PM
Sample Description	น้ำอ่างล้างตา - จุดล้างตัวฉุกเฉิน
Location	จุดล้างตาล้างตัว - จุดล้างตัวฉุกเฉิน
Date Analysis Commenced	Feb 04, 2026
Condition of Sample	Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Microbiological Testing							
<i>Escherichia coli</i>	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 B, F	Songkhla
^[A] <i>Legionella spp.</i>	CFU/L	-	-	Not Detected**	No Standard	ISO 11731 (2017)	Bangkok
<i>Pseudomonas aeruginosa</i> *	in 100 mL	-	-	Not Detected	No Standard	In-house method in connection with: - Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9213 E	Bangkok
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 B	Songkhla

Guideline : เกณฑ์คุณภาพน้ำประปาดื่มได้ ประกาศ กรมอนามัย พ.ศ. 2563

Note : ** Not Detected mean Bacteria not found in agar plate.

Sampling By : Yuttapong Rattana

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- [A] Analysis conducted by ALS Laboratory Group (Thailand) Co., Ltd. Bangkok Branch, DMSc Accreditation No. 1031/47.
- Sampling is not included in scope of accreditation ISO/IEC 17025

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

Approved by

Chompoonuch F.

Chompoonuch Funtha
Supervisor

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER

11575-31/ EMAIL

S:\Reports_All_GL.rpt (6:26PM)



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Lot ID: 266327

Date Received : Feb 04, 2026

Date Reported : Feb 20, 2026

Report Number : 3511851-1

Page 1 of 2

Sample Number	266327-26
Sampled Date	Feb 03, 2026 10:25 AM
Sample Description	น้ำดื่มขวดเขียวในระบบ Cooling tower
Location	น้ำดื่มขวดเขียวในระบบ Cooling tower
Date Analysis Commenced	Feb 04, 2026
Condition of Sample	Contained in five plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Iron	mg/L	0.003	0.005	Not Detected	≤1.0	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Songkhla
Microbiological Testing							
<i>Legionella spp.</i> *	CFU/L	-	-	Not Detected**	Not Detected (1)	ISO 11731 (2017)	Bangkok
Water Testing							
Calcium Hardness as CaCO ₃ *	mg/L	-	1	<1	No Standard	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3500-Ca (B)	Songkhla
^[A] Chloride as Cl	mg/L	0.06	0.2	25.2	≤300	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4110 B	Bangkok
Conductivity *	micromhos/cm	-	0.5	221	≤3000	Based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2510 B	Songkhla
pH at 25 degree C		-	-	7.7	7-9	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4500 - H (B)	Songkhla
Phosphate as P *	mg/L	0.15	0.5	Not Detected	≤20	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4110 B	Bangkok
Silica as SiO ₂ *	mg/L	0.007	0.02	17.4	≤120	Based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4500-SiO ₂ (D)	Bangkok
Total Alkalinity as CaCO ₃ *	mg/L	-	1	27	≤1000	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2320 B	Songkhla

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

Approved by

Ananta B.

Ananta Boonphet
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER

11575-31/ EMAIL

S:\Reports\All_GL.rpt (10:40AM)



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Lot ID: 266327

Date Received : Feb 04, 2026

Date Reported : Feb 20, 2026

Report Number : 3511852-1

Page 1 of 2

Sample Number	266327-27
Sampled Date	Feb 03, 2026 10:16 AM
Sample Description	น้ำในถาด Cooling tower
Location	Cooling tower 1
Date Analysis Commenced	Feb 04, 2026
Condition of Sample	Contained in five plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Iron	mg/L	0.003	0.005	0.05	≤1.0	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Songkhla
Microbiological Testing							
<i>Legionella spp.</i> *	CFU/L	-	-	Not Detected**	Not Detected (1)	ISO 11731 (2017)	Bangkok
Water Testing							
Calcium Hardness as CaCO ₃ *	mg/L	-	1	16	No Standard	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3500-Ca (B)	Songkhla
^[A] Chloride as Cl	mg/L	0.06	0.2	210	≤300	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4110 B	Bangkok
Conductivity *	micromhos/cm	-	0.5	1510	≤3000	Based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2510 B	Songkhla
pH at 25 degree C		-	-	8.7	7-9	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4500 - H (B)	Songkhla
Phosphate as P *	mg/L	0.15	0.5	Not Detected	≤20	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4110 B	Bangkok
Silica as SiO ₂ *	mg/L	0.007	0.02	108	≤120	Based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4500-SiO ₂ (D)	Bangkok
Total Alkalinity as CaCO ₃ *	mg/L	-	1	154	≤1000	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2320 B	Songkhla

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

Approved by

Ananta B.

Ananta Boonphet
Scientist (2)

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER

11575-31/ EMAIL

S:\Reports\All_GL.rpt (10:40AM)