



Analysis / Test Report

TESTING
No.0166

Client : Bangkok Phuket Hospital Co., Ltd.
2/1, Hongyok Utis Road, Taladyai, Muang, Phuket Thailand 83000

P/O :

Project Name : Water Testing : BPK

Project Location :

Lot ID: 2624286

Date Received : Apr 03, 2026

Date Reported : Apr 23, 2026

Report Number : 3555234-1

Page 1 of 1

Sample Number	2624286-14
Sampled Date	Apr 02, 2026 11:19 AM
Sample Description	น้ำอ่างล้างตา - โรงผลิตน้ำ
Location	จุดล้างด่างล้างตัว - โรงผลิตน้ำ
Date Analysis Commenced	Apr 03, 2026
Condition of Sample	Contained in four plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Microbiological Testing							
<i>Escherichia coli</i>	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 B, F	Songkhla
<i>Legionella spp.</i> *	CFU/L	-	-	Not Detected**	No Standard	ISO 11731 (2017)	Bangkok
<i>Pseudomonas aeruginosa</i> *	in 100 mL	-	-	Not Detected	No Standard	In-house method in connection with: - Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9213 E	Bangkok
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 B	Songkhla

Guideline : เกณฑ์คุณภาพน้ำประปาดื่มได้ ประกาศ กรมอนามัย พ.ศ. 2563

Note : ** Not Detected mean Bacteria not found in agar plate.

Sampling By : Thaksin Aintrom

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- Sampling is not included in scope of accreditation ISO/IEC 17025

Approved by

Chompoonuch F.

Chompoonuch Funtha
Supervisor

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

ADDRESS 114/1 Moo 8 Karnchanawanich Road T. Ban Phru A. Hat Yai Songkhla 90250 Thailand | PHONE +66 0 7489 5060 | FAX +66 0 7489 5068
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER