

ภาคผนวกที่ 6

แบบบันทึกระบบป้องกันอัคคีภัย

MONTHLY FIRE CABINET & FIRE EXTINGUISHER CHECKLIST												
No.	Location	Fire Hose Cabinet								Extinguisher Type	Defect	Remarks
		Cabinet	Fire Hose Reel	Valve 1 1/2"	Valve 2 2"	Extinguisher	Chalk	Axe	Instruction			
1	Fire Hose Cabinet 705/707	✓	✓	✗	✓	✓	✗	✗	✗	Dry Chemical	Fire hose don't have glass cover 	
2	Fire Hose Cabinet near 743	✓	✓	✗	✓	✓	✗	✗	✗	Dry Chemical	Fire hose don't have glass cover 	
3	Fire Hose Cabinet 605/607	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Nothing 	
4	Fire Hose Cabinet near 643	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Don't have Fire Hose signage 	Install Fire Hose Signage

5	Fire Hose Cabinet 505/507	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Nothing 	
6	Fire Hose Cabinet near 543	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Don't have Fire Hose signage 	Install Fire Hose Signage
7	Fire Hose Cabinet 405/407	✓	✓	✗	✓	✓	✗	✗	✗	Dry Chemical	Nothing 	
8	Fire Hose Cabinet near 443	✓	✓	✗	✓	✓	✗	✗	✗	Dry Chemical	Don't have Fire Hose signage 	Install Fire Hose Signage
9	Fire Hose Cabinet 305/307	✓	✓	✗	✓	✓	✗	✗	✗	Dry Chemical	Fire Hydrant Cap 2-1/2 missing.  	Install Fire Hydrant cap
10	Fire Hose Cabinet near 343	✓	✓	✗	✓	✓	✗	✗	✗	Dry Chemical	Nothing 	

[illegible]

Fire Extinguisher						
No	Location	Type	Status	Defect	Action Taken	Remarks
1	Pool Bar	Fireade 2000	✓			
2	MDB Room 1	Fireade 2000	✓			
3	MDB Room 2	Fireade 2000	✓			
4	In Front Chef Office	Fireade 2000	✓			
5	Main Kitchen	FOAM	✓			
6	Beside 3 Uncles Kitchen	Fireade 2000	✓			
7	Beside Bar	Fireade 2000	✓			
8	Merge Office	Fireade 2000	✓			
9	In Front Of Server Room 1	Fireade 2000	✓			
10	In Front Of Server Room 2	Fireade 2000	✓			
11	Gas Store 1	Fireade 2000	✓			
12	Gas Store 2	Fireade 2000	✓			
13	ENG Store	Fireade 2000	✓			
14	Parking Space	Fireade 2000	✓			
15	HK Store	Fireade 2000	✓			
16	F&B Store	Fireade 2000	✓			
17	In Front Of IT office 1	Fireade 2000	✓			
18	In Front Of IT office 2	Fireade 2000	✓			
19	Fire Pump Room 1	Fireade 2000	✓			
20	Fire Pump Room 2	Fireade 2000	✓			
21	Canteen	Fireade 2000	✓			
22	SC Office	Fireade 2000	✓			
23	In Front Male Locker	Fireade 2000	✓			
24	The roof top 1	Fireade 2000	✗	During Worker still use the location not put over there	Security will set up when location ready	
25	The roof top 2	Fireade 2000	✗	During Worker still use the location not put over there	Security will set up when location ready	
Fire Equipment				Checking By : Security Supervisor Mr. Nuttapong Sapisiri 23/07/2025 Verify By : Security Manager Mr. Apiwat Pohkaew 23/07/2025		
Fire Fighting Suit (2)	2	Nozzle (1)	1			
Hood (2)	2	Connecting Valve 3 Ways (2)	-			
Helmet (2)	2	Axe (1)	1			
Boot (2)	2	Oxygen Tank ()	-			
Glove (2)	2	Spinal Board (1)	1			
Hose Reel 2.5" ()	-	Crutch (1)	2			
Reflection Vest (24)	-	Megaphone (1)	1			
Wheel Chair (1)	1					

MONTHLY FIRE CABINET & FIRE EXTINGUISHER CHECKLIST												
Fire Hose Cabinet												
No.	Location	Cabinet	Fire Hose Reel	Valve 1 1/2"	Valve 2 2"	Extinguisher	Chalk	Axe	Instruction	Extinguisher Type	Defect	Remarks
1	Fire Hose Cabinet 705/707	✓	✓	✗	✓	✓	✗	✗	✗	Dry Chemical	Fire hose don't have glass cover 	
2	Fire Hose Cabinet near 743	✓	✓	✗	✓	✓	✗	✗	✗	Dry Chemical	Fire hose don't have glass cover 	
3	Fire Hose Cabinet 605/607	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Nothing 	
4	Fire Hose Cabinet near 643	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Don't have Fire Hose signage 	Install Fire Hose Signage

5	Fire Hose Cabinet 505/507	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Nothing 	
6	Fire Hose Cabinet near 543	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Don't have Fire Hose signage 	Install Fire Hose Signage
7	Fire Hose Cabinet 405/407	✓	✓	✗	✓	✓	✗	✗	✗	Dry Chemical	Nothing 	
8	Fire Hose Cabinet near 443	✓	✓	✗	✓	✓	✗	✗	✗	Dry Chemical	Don't have Fire Hose signage 	Install Fire Hose Signage
9	Fire Hose Cabinet 305/307	✓	✓	✗	✓	✓	✗	✗	✗	Dry Chemical	Fire Hydrant Cap 2-1/2 missing.  	Install Fire Hydrant cap
10	Fire Hose Cabinet near 343	✓	✓	✗	✓	✓	✗	✗	✗	Dry Chemical	Nothing 	

[illegible]

Fire Extinguisher						
No	Location	Type	Status	Defect	Action Taken	Remarks
1	Pool Bar	Fireade 2000	✓			
2	MDB Room 1	Fireade 2000	✓			
3	MDB Room 2	Fireade 2000	✓			
4	In Front Chef Office	Fireade 2000	✓			
5	Main Kitchen	FOAM	✓			
6	Beside 3 Uncles Kitchen	Fireade 2000	✓			
7	Beside Bar	Fireade 2000	✓			
8	Merge Office	Fireade 2000	✓			
9	In Front Of Server Room 1	Fireade 2000	✓			
10	In Front Of Server Room 2	Fireade 2000	✓			
11	Gas Store 1	Fireade 2000	✓			
12	Gas Store 2	Fireade 2000	✓			
13	ENG Store	Fireade 2000	✓			
14	Parking Space	Fireade 2000	✓			
15	HK Store	Fireade 2000	✓			
16	F&B Store	Fireade 2000	✓			
17	In Front Of IT office 1	Fireade 2000	✓			
18	In Front Of IT office 2	Fireade 2000	✓			
19	Fire Pump Room 1	Fireade 2000	✓			
20	Fire Pump Room 2	Fireade 2000	✓			
21	Canteen	Fireade 2000	✓			
22	SC Office	Fireade 2000	✓			
23	In Front Male Locker	Fireade 2000	✓			
24	The roof top 1	Fireade 2000	✗	During Worker still use the location not put over there	Security will set up when location ready	
25	The roof top 2	Fireade 2000	✗	During Worker still use the location not put over there	Security will set up when location ready	
Fire Equipment				Checking By : Security Manager Mr. Apiwat Pohkaew 29/08/2025 Verify By : Security Manager Mr. Apiwat Pohkaew 29/08/2025		
Fire Fighting Suit (2)	2	Nozzle (1)	1			
Hood (2)	-	Connecting Valve 3 Ways (2)	-			
Helmet (2)	2	Axe (1)	1			
Boot (2)	2	Oxygen Tank ()	-			
Glove (2)	2	Spinal Board (1)	1			
Hose Reel 2.5" ()	-	Crutch (1)	2			
Reflection Vest (24)	-	Megaphone (1)	1			
Wheel Chair (1)	1					

MONTHLY FIRE CABINET & FIRE EXTINGUISHER CHECKLIST												
Fire Hose Cabinet												
No.	Location	Cabinet	Fire Hose Reel	Valve 1 1/2"	Valve 2 2"	Extinguisher	Chalk	Axe	Instruction	Extinguisher Type	Defect	Remarks
1	Fire Hose Cabinet 705/707	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Fire hose don't have glass cover 	
2	Fire Hose Cabinet near 743	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Fire hose don't have glass cover 	
3	Fire Hose Cabinet 605/607	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Nothing 	
4	Fire Hose Cabinet near 643	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Don't have Fire Hose signage 	Install Fire Hose Signage

5	Fire Hose Cabinet 505/507	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Nothing 	
6	Fire Hose Cabinet near 543	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Don't have Fire Hose signage 	Install Fire Hose Signage
7	Fire Hose Cabinet 405/407	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Nothing 	
8	Fire Hose Cabinet near 443	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Don't have Fire Hose signage 	Install Fire Hose Signage
9	Fire Hose Cabinet 305/307	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Fire Hydrant Cap 2-1/2 missing.  	Install Fire Hydrant cap
10	Fire Hose Cabinet near 343	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	Nothing 	

[illegible]

Fire Extinguisher						
No	Location	Type	Status	Defect	Action Taken	Remarks
1	Pool Bar	Fireade 2000	✓			
2	MDB Room 1	Fireade 2000	✓			
3	MDB Room 2	Fireade 2000	✓			
4	In Front Chef Office	Fireade 2000	✓			
5	Main Kitchen 1	FOAM	✓			
5	Main Kitchen 2	Fireade 2000	✓			
5	Main Kitchen 3	Fireade 2000	✓			
8	Merge Office	Fireade 2000	✓			
9	In Front Of Server Room 1	Fireade 2000	✓			
10	In Front Of Server Room 2	Fireade 2000	✓			
11	Gas Store 1	Fireade 2000	✓			
12	Gas Store 2	Fireade 2000	✓			
13	ENG Store	Fireade 2000	✓			
14	Parking Space	Fireade 2000	✓			
15	HK Store	Fireade 2000	✓			
16	F&B Store	Fireade 2000	✓			
17	In Front Of IT office 1	Fireade 2000	✓			
18	In Front Of IT office 2	Fireade 2000	✓			
19	Fire Pump Room 1	Fireade 2000	✓			
20	Fire Pump Room 2	Fireade 2000	✓			
21	Canteen	Fireade 2000	✓			
22	SC Office	Fireade 2000	✓			
23	In Front Male Locker	Fireade 2000	✓			
24	The roof top 1	Fireade 2000	✗	During Worker still use the location not put over there	Security will set up when location ready	
25	The roof top 2	Fireade 2000	✗	During Worker still use the location not put over there	Security will set up when location ready	
Fire Equipment				Checking By : Security Manager Mr. Apiwat Pohkaew 22/09/2025 Verify By : Security Manager Mr. Apiwat Pohkaew 30/09/2025		
Fire Fighting Suit (2)	2	Nozzle (1)	1			
Hood (2)	2	Connecting Valve 3 Ways (2)	-			
Helmet (2)	2	Axe (1)	1			
Boot (2)	2	Oxygen Tank ()	-			
Glove (2)	2	Spinal Board (1)	1			
Hose Reel 2.5" ()	-	Crutch (1)	2			
Reflection Vest (24)	-	Megaphone (1)	1			
Wheel Chair (1)	1					

MONTHLY FIRE CABINET & FIRE EXTINGUISHER CHECKLIST

Fire Hose Cabinet												
No.	Location	Cabinet	Fire Hose Reel	Valve 1 1/2'	Valve 2 2"	Extinguisher	Chalk	Axe	Instruction	Extinguisher Type	Defect	Remarks
1	Fire Hose Cabinet 705/707	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage
2	Fire Hose Cabinet near 743	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage
3	Fire Hose Cabinet 605/607	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
4	Fire Hose Cabinet near 643	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage

5	Fire Hose Cabinet 505/507	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
6	Fire Hose Cabinet near 543	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage
7	Fire Hose Cabinet 405/407	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
8	Fire Hose Cabinet near 443	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage
9	Fire Hose Cabinet 305/307	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
10	Fire Hose Cabinet near 343	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		

[illegible]

Fire Extinguisher						
No	Location	Type	Status	Defect	Action Taken	Remarks
1	Beside Bar	Fireade 2000	✓			
2	MDB Room 1	Fireade 2000	✓			
3	MDB Room 2	Fireade 2000	✓			
4	In Front Chef Office	Fireade 2000	✓			
5	Main Kitchen 1	FOAM	✓			
5	Main Kitchen 2	Fireade 2000	✓			
5	Main Kitchen 3	Fireade 2000	✓			
8	Merge Office	Fireade 2000	✓			
9	In Front Of Server Room 1	Fireade 2000	✓			
10	In Front Of Server Room 2	Fireade 2000	✓			
11	Gas Store 1	Fireade 2000	✓			
12	Gas Store 2	Fireade 2000	✓			
13	ENG Store	Fireade 2000	✓			
14	Parking Space	Fireade 2000	✓			
15	HK Store	Fireade 2000	✓			
16	F&B Store	Fireade 2000	✓			
17	In Front Of IT office 1	Fireade 2000	✓			
18	In Front Of IT office 2	Fireade 2000	✓			
19	Fire Pump Room 1	Fireade 2000	✓			
20	Fire Pump Room 2	Fireade 2000	✓			
21	Canteen	Fireade 2000	✓			
22	SC Office	Fireade 2000	✓			
23	In Front Male Locker	Fireade 2000	✓			
24	Pool Bar	Fireade 2000	✓			
25	The roof top 1	Fireade 2000	✗	During Worker still use the location not put over there	Security will set up when location ready	
26	The roof top 2	Fireade 2000	✗	During Worker still use the location not put over there	Security will set up when location ready	
Fire Equipment				Checking By : Security Supervisor Mr. Supachai Kanchanaaksorn Verify By : Security Manager Mr. Apiwat Pohkaew		
Fire Fighting Suit (2)	2	Nozzle (1)	1			
Hood (2)	-	Connecting Valve 3 Ways (2)	-			
Helmet (2)	2	Axe (1)	1			
Boot (2)	2	Oxygen Tank ()	-			
Glove (2)	2	Spinal Board (1)	1			
Hose Reel 2.5" ()	-	Crutch (1)	2			
Reflection Vest (24)	-	Megaphone (1)	1			
Wheel Chair (1)	1					
				Date : 26/10/2025 Date : 26/10/2025 		

MONTHLY FIRE CABINET & FIRE EXTINGUISHER CHECKLIST

Fire Hose Cabinet												
No.	Location	Cabinet	Fire Hose Reel	Valve 1 1/2'	Valve 2 2"	Extinguisher	Chalk	Axe	Instruction	Extinguisher Type	Defect	Remarks
1	Fire Hose Cabinet 705/707	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage
2	Fire Hose Cabinet near 743	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage
3	Fire Hose Cabinet 605/607	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
4	Fire Hose Cabinet near 643	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage

5	Fire Hose Cabinet 505/507	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
6	Fire Hose Cabinet near 543	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage
7	Fire Hose Cabinet 405/407	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
8	Fire Hose Cabinet near 443	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage
9	Fire Hose Cabinet 305/307	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
10	Fire Hose Cabinet near 343	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		

11	Fire Hose Cabinet 205/207	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
12	Fire Hose Cabinet near 243	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	 	Install Fire Hose Signage, Install Fire Hydrant cap
13	Entrance to Lobby	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
14	Behind Restaurant	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	 	Install Fire Hydrant cap
15	Beside ENG Office	✓	✓	✗	✓	✗	✗	✗	✗		Fire hose don't have glass cover, Don't have Fire Extiguisher  	Fire Extinguisher will put after cabinet completed
16	In Front Of Staircase	✓	✓	✗	✓	✗	✗	✗	✗		Hotel stuffs put in front of the Fire hose, Don't have Fire Extiguisher  	Waiting to move to keep at AVG, Fire Extinguisher will put after cabinet completed

Fire Extinguisher						
No	Location	Type	Status	Defect	Action Taken	Remarks
1	Beside Bar	Fireade 2000	✓			
2	MDB Room 1	Fireade 2000	✓			
3	MDB Room 2	Fireade 2000	✓			
4	In Front Chef Office	Fireade 2000	✓			
5	Main Kitchen 1	FOAM	✓			
5	Main Kitchen 2	Fireade 2000	✓			
5	Main Kitchen 3	Fireade 2000	✓			
8	Merge Office	Fireade 2000	✓			
9	In Front Of Server Room 1	Fireade 2000	✓			
10	In Front Of Server Room 2	Fireade 2000	✓			
11	Gas Store 1	Fireade 2000	✓			
12	Gas Store 2	Fireade 2000	✓			
13	ENG Store	Fireade 2000	✓			
14	Parking Space	Fireade 2000	✓			
15	HK Store	Fireade 2000	✓			
16	F&B Store	Fireade 2000	✓			
17	In Front Of IT office 1	Fireade 2000	✓			
18	In Front Of IT office 2	Fireade 2000	✓			
19	Fire Pump Room 1	Fireade 2000	✓			
20	Fire Pump Room 2	Fireade 2000	✓			
21	Canteen	Fireade 2000	✓			
22	SC Office	Fireade 2000	✓			
23	In Front Male Locker	Fireade 2000	✓			
24	Pool Bar	Fireade 2000	✓			
25	The roof top 1	Fireade 2000	✗	During Worker still use the location not put over there	Security will set up when location ready	
26	The roof top 2	Fireade 2000	✗	During Worker still use the location not put over there	Security will set up when location ready	
Fire Equipment						
Fire Fighting Suit (2)	2	Nozzle (1)	1	Checking By : Security Supervisor Mr. Supachai Kanchana-aksorn		
Hood (2)	-	Connecting Valve 3 Ways (2)	-			
Helmet (2)	2	Axe (1)	1	Verify By : Security Manager Mr. Apiwat Pohkaew		
Boot (2)	2	Oxygen Tank ()	-			
Glove (2)	2	Spinal Board (1)	1	Date : 27/11/2025 		
Hose Reel 2.5" ()	-	Crutch (1)	2			
Reflection Vest (24)	-	Megaphone (1)	1			
Wheel Chair (1)	1			Date : 27/11/2025 		

MONTHLY FIRE CABINET & FIRE EXTINGUISHER CHECKLIST DECEMBER 2025

Fire Hose Cabinet												
No.	Location	Cabinet	Fire Hose Reel	Valve 1 1/2'	Valve 2 2"	Extinguisher	Chalk	Axe	Instruction	Extinguisher Type	Defect	Remarks
1	Fire Hose Cabinet 705/707	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage
2	Fire Hose Cabinet near 743	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage
3	Fire Hose Cabinet 605/607	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
4	Fire Hose Cabinet near 643	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage

5	Fire Hose Cabinet 505/507	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
6	Fire Hose Cabinet near 543	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage
7	Fire Hose Cabinet 405/407	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
8	Fire Hose Cabinet near 443	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		Install Fire Hose Signage
9	Fire Hose Cabinet 305/307	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
10	Fire Hose Cabinet near 343	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		

11	Fire Hose Cabinet 205/207	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
12	Fire Hose Cabinet near 243	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	 	Install Fire Hose Signage, Install Fire Hydrant cap
13	Entrance to Lobby	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000		
14	Behind Restaurant	✓	✓	✗	✓	✓	✗	✗	✗	FireAde 2000	 	Install Fire Hydrant cap
15	Beside ENG Office	✓	✓	✗	✓	✗	✗	✗	✗		 	
16	In Front Of Staircase	✓	✓	✗	✓	✗	✗	✗	✗		 	

Fire Extinguisher						
No	Location	Type	Status	Defect	Action Taken	Remarks
1	Beside Bar	Fireade 2000	✓			
2	MDB Room 1	Fireade 2000	✓			
3	MDB Room 2	Fireade 2000	✓			
4	In Front Chef Office	Fireade 2000	✓			
5	Main Kitchen 1	FOAM	✓			
5	Main Kitchen 2	Fireade 2000	✓			
5	Main Kitchen 3	Fireade 2000	✓			
8	Merge Office	Fireade 2000	✓			
9	In Front Of Server Room 1	Fireade 2000	✓			
10	In Front Of Server Room 2	Fireade 2000	✓			
11	Gas Store 1	Fireade 2000	✓			
12	Gas Store 2	Fireade 2000	✓			
13	ENG Store	Fireade 2000	✓			
14	Parking Space	Fireade 2000	✓			
15	HK Store	Fireade 2000	✓			
16	F&B Store	Fireade 2000	✓			
17	In Front Of IT office 1	Fireade 2000	✓			
18	In Front Of IT office 2	Fireade 2000	✓			
19	Fire Pump Room 1	Fireade 2000	✓			
20	Fire Pump Room 2	Fireade 2000	✓			
21	Canteen	Fireade 2000	✓			
22	SC Office	Fireade 2000	✓			
23	In Front Male Locker	Fireade 2000	✓			
24	Pool Bar	Fireade 2000	✓			
25	The roof top 1	Dry Chemical	✗	Used for Annual Fire Basictraining	Waiting Refill	
26	The roof top 2	Dry Chemical	✗	Used for Annual Fire Basictraining	Waiting Refill	
Fire Equipment						
Fire Fighting Suit (2)	2	Nozzle (1)	1			
Hood (2)	-	Connecting Valve 3 Ways (2)	-			
Helmet (2)	2	Axe (1)	1			
Boot (2)	2	Oxygen Tank ()	-			
Glove (2)	2	Spinal Board (1)	1			
Hose Reel 2.5" ()	-	Crutch (1)	2			
Reflection Vest (24)	-	Megaphone (1)	1			
Wheel Chair (1)	1					
				Checking By : Security Supervisor		Date : 26/12/2025
				Mr. Supachai Kanchana-aksorn		
				Verify By : Security Manager		Date : 26/12/2025
				Mr. Apiwat Pohkaew		