

ผลวิเคราะห์คุณภาพน้ำทิ้ง โครงการ CAPE RACHA HOTEL

UAE United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com



ANALYSIS REPORT

CUSTOMER NAME : KALEIDOSCOPE PROPERTIES CO., LTD. (CAPE RACHA HOTEL)
ADDRESS : 35,35/1 JIRM JOMPOL ROAD SI RACHA SI RACHA CHON BURI 20110
CONTACT INFORMATION : TEL : 0 2233 8989-98 e-mail : kj-qc@kasemkij.com
SAMPLING SOURCE : WASTEWATER TREATMENT PLANT OF CAPE RACHA HOTEL 1
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : APRIL 8, 2026
SAMPLING TIME : -
SAMPLING METHOD : -
SAMPLING BY : CUSTOMER
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : APRIL 9, 2026
ANALYTICAL DATE : APRIL 9-21, 2026
ISSUE DATE : APRIL 22, 2026
REPORT NO. : 2026-U031642
WORK NO. : 2026-002745
ANALYSIS NO. : T26AH786-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	LIMIT OF QUANTITATION (LOQ)
			EFFLUENT T26AH786-0001		
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	2.3	≤ 30	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	6.5	≤ 40	5.0
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN		

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

Wilailak Srisuk.

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR



- PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
- THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

1/1



- End of Analysis Report -