

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด นัมเบอร์วันแลนด์ อพาร์ทเมนต์
Project Name : โครงการอาคารพักอาศัย นัมเบอร์วันแลนด์ อพาร์ทเมนต์
Address Project : ถนนรามคำแหง 2 เขตประเวศ กรุงเทพมหานคร 10250
Sampling Point : จุดน้ำเสียเข้าระบบบำบัดน้ำเสียส่วนกลาง
GPS. Coordinate : 47 P 681745 E 1511528 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69067
Sample No. : W69067/1
Sample Type : Wastewater
Sampling Date : 16 April 2026
Sampling Time : 01.34 p.m.
Received Date : 17 April 2026
Analytical Date : 17 - 28 April 2026
Report Date : 29 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result
pH at 25.2 °C	-	Electrometric Method (4500-H ⁺ B)	7.7
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	< 5.0
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	< 2.0
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	170
Total Kjeldahl Nitrogen ^{*, 2/}	mg/L	APHA:4500-Norg (B) ^{3/}	< 0.28
Sample Appearance		Clear/Little Sediment/Odorless	

- Remark**
- ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
- ^{2/} Analyzed by Environment & Laboratory Co., Ltd. registration number Wo-029.
- ^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.
- * This item is out the scope ISO/IEC 17025:2017 Accreditation.

Analyst

Laboratory Manager

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด นัมเบอร์วันแลนด์ อพาร์ทเมนต์
Project Name : โครงการอาคารพักอาศัย นัมเบอร์วันแลนด์ อพาร์ทเมนต์
Address Project : ถนนรามคำแหง 2 เขตประเวศ กรุงเทพมหานคร 10250
Sampling Point : จุดบ่อพักน้ำทั้งที่ผ่านการบำบัดแล้ว
GPS. Coordinate : 47 P 681753 E 1511537 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69067
Sample No. : W69067/2
Sample Type : Wastewater
Sampling Date : 16 April 2026
Sampling Time : 01.11 p.m.
Received Date : 17 April 2026
Analytical Date : 17 - 28 April 2026
Report Date : 29 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.9 °C	-	Electrometric Method (4500-H ⁺ B)	7.6	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	< 5.0	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	< 2.0	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	130	-
Total Kjeldahl Nitrogen *, ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	< 0.28	≤ 35
Sample Appearance		Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co., Ltd. registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

Analyst

Laboratory Manager