



TNP ENVIRONMENT CO.,LTD.

เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273

E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่



NSC-TISI-TIS 17025

Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด รัชดา เพรสทีจ
Project Name : โครงการอาคารชุดพักอาศัย รัชดา เพรสทีจ
Address Project : ซอยพิบูลย์อุปถัมภ์ ถนนลาดพร้าว แขวงสามเสนนอก
เขตห้วยขวาง กรุงเทพมหานคร
Sampling Point : บ่อตรวจคุณภาพน้ำทิ้ง
GPS. Coordinate : 47 P 681721 E 1525652 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69066
Sample No. : W69066/1
Sample Type : Wastewater
Sampling Date : 29 April 2026
Sampling Time : 11.13 a.m.
Received Date : 30 April 2026
Analytical Date : 30 April – 08 May 2026
Report Date : 11 May 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.4 °C	-	Electrometric Method (4500-H ⁺ B)	7.2	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	6.9	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	80.2	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000	-
Sample Appearance		Yellow/Turbid/Little Sediment/Smelly		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

Analyst

Laboratory Manager