ภาคผนวก ค

มาตรฐานที่เกี่ยวข้อง

ภาคผนวก ค-1

มาตรฐานคุณภาพอากาศจากแหล่งกำเนิด

ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม

เรื่อง กำหนดมาตรฐานควบคุมการปล่อยทิ้งอากาศเสียจากโรงไฟฟ้า

พ.ศ. ๒๕๖๖

โดยที่เป็นการสมควรปรับปรุงมาตรฐานควบคุมการปล่อยทิ้งอากาศเสียจากโรงไฟฟ้า ให้มีความสอดคล้องกับสถานการณ์ด้านพลังงาน สิ่งแวดล้อม และเทคโนโลยีในปัจจุบัน

อาศัยอำนาจตามความในมาตรา ๕๕ แห่งพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. ๒๕๓๕ รัฐมนตรีว่าการกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม โดยคำแนะนำของคณะกรรมการควบคุมมลพิษ และโดยความเห็นชอบของคณะกรรมการสิ่งแวดล้อมแห่งชาติ จึงออกประกาศไว้ดังต่อไปนี้

ข้อ ๑ ให้ยกเลิก

(๑) ประกาศกระทรวงวิทยาศาสตร์ เทคโนโลยีและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการปล่อยทิ้งอากาศเสียจากโรงไฟฟ้า ลงวันที่ ๒๕ ธันวาคม พ.ศ. ๒๕๓๘

(๒) ประกาศกระทรวงวิทยาศาสตร์ เทคโนโลยีและสิ่งแวดล้อม ฉบับที่ ๒ (พ.ศ. ๒๕๔๒) เรื่อง การกำหนดมาตรฐานควบคุมการปล่อยทิ้งอากาศเสียจากโรงไฟฟ้าเก่า ลงวันที่ ๒ ธันวาคม พ.ศ. ๒๕๔๒

(๓) ประกาศกระทรวงวิทยาศาสตร์ เทคโนโลยีและสิ่งแวดล้อม ฉบับที่ ๓ (พ.ศ. ๒๕๔๔) เรื่อง กำหนดมาตรฐานควบคุมการปล่อยทิ้งอากาศเสียจากโรงไฟฟ้าแม่เมาะ ลงวันที่ ๒๙ มกราคม พ.ศ. ๒๕๔๔

(๔) ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการปล่อยทิ้งอากาศเสียจากโรงไฟฟ้าใหม่ ลงวันที่ ๒๐ ธันวาคม พ.ศ. ๒๕๕๒

ข้อ ๒ ในประกาศนี้

“โรงไฟฟ้า” หมายความว่า โรงงานผลิตพลังงานไฟฟ้าจากพลังงานความร้อน ลำดับที่ ๘๘ (๒) ตามกฎหมายว่าด้วยโรงงาน หรือสถานประกอบกิจการไฟฟ้า ที่มีการผลิตไฟฟ้าจากพลังงานความร้อนตามกฎหมายว่าด้วยการประกอบกิจการพลังงาน

“โรงไฟฟ้าเก่า” หมายความว่า โรงไฟฟ้า ดังต่อไปนี้

(๑) โรงไฟฟ้าที่ได้รับอนุญาตให้ประกอบกิจการ หรือขยายโรงงาน หรือเดินเครื่องจักร ก่อนวันที่ ๓๑ มกราคม ๒๕๓๙ ดังนี้

(๑.๑) โรงไฟฟ้าบางปะกง (พลังงานความร้อน) หน่วยการผลิตที่ ๓ และหน่วยการผลิตที่ ๔

(๑.๒) โรงไฟฟ้าน้ำพอง ชุดที่ ๑ และชุดที่ ๒

(๑.๓) โรงไฟฟ้าแม่เมาะ หน่วยการผลิตที่ ๔ และหน่วยการผลิตที่ ๘ - ๑๓

(๒) โรงไฟฟ้าที่ได้รับอนุญาตให้ประกอบกิจการ ผลิต หรือเปลี่ยนแปลงกำลังผลิตไฟฟ้า ตั้งแต่วันที่ ๓๑ มกราคม ๒๕๓๙ ถึงวันที่ ๑๖ มกราคม ๒๕๕๓

(๓) โรงไฟฟ้าที่ได้รับอนุญาตให้ประกอบกิจการ ผลิต หรือเปลี่ยนแปลงกำลังผลิตไฟฟ้า ตั้งแต่วันที่ ๑๗ มกราคม ๒๕๕๓ ถึงก่อนวันที่ประกาศนี้มีผลใช้บังคับ

“โรงไฟฟ้าใหม่” หมายความว่า โรงไฟฟ้าที่ได้รับอนุญาตให้ประกอบกิจการ ขยาย เปลี่ยนแปลง หรือสร้างทดแทนหน่วยผลิตเดิม ตั้งแต่วันที่ประกาศนี้มีผลใช้บังคับเป็นต้นไป

“โรงไฟฟ้าที่ใช้ขยะเป็นเชื้อเพลิง” หมายความว่า โรงไฟฟ้าที่ใช้มูลฝอยตามกฎหมายว่าด้วยการสาธารณสุข หรือสิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้วที่ไม่เป็นของเสียอันตรายตามกฎหมายว่าด้วยโรงงานมาเป็นเชื้อเพลิงในการผลิตไฟฟ้า ทั้งนี้ ให้หมายความรวมถึงเชื้อเพลิงที่ได้จากกระบวนการแปรรูปมูลฝอยหรือสิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้วดังกล่าวด้วย

“เชื้อเพลิงชีวมวล” หมายความว่า เชื้อเพลิงที่ได้มาจากอินทรีย์สารหรือสิ่งมีชีวิต รวมทั้งผลผลิตจากการเกษตร การปศุสัตว์ การทำป่าไม้ และการแปรรูปผลผลิตดังกล่าว เช่น ไม้ฟืน เศษไม้ แกลบ ฟาง ชานอ้อย ต้นและใบอ้อย ใยปาล์ม กะลาปาล์ม ทะลายปาล์ม กะลามะพร้าว ใยมะพร้าว เศษพืช มูลสัตว์ และกากตะกอน เป็นต้น

“ก๊าซชีวภาพ” หมายความว่า ก๊าซที่เกิดจากกระบวนการย่อยสลายของสารอินทรีย์ในวัตถุดิบในสภาวะไม่ใช้อากาศโดยการทำงานของจุลินทรีย์ โดยมีองค์ประกอบหลัก คือก๊าซมีเทน (CH_4) และก๊าซคาร์บอนไดออกไซด์ (CO_2) ทั้งนี้ วัตถุดิบหลักสามารถมาจากของเสีย น้ำเสีย หรือพืชพลังงานก็ได้

ข้อ ๓ กำหนดมาตรฐานควบคุมการปล่อยทิ้งอากาศเสียจากโรงไฟฟ้าเก่าไว้ ดังต่อไปนี้

โรงไฟฟ้า	ค่ามาตรฐาน		
	ฝุ่นละออง (มิลลิกรัมต่อลูกบาศก์เมตร)	ก๊าซซัลเฟอร์ไดออกไซด์ (ส่วนในล้านส่วน)	ก๊าซออกไซด์ของไนโตรเจนซึ่งคำนวณผลในรูปก๊าซไนโตรเจนไดออกไซด์ (ส่วนในล้านส่วน)
(๑) โรงไฟฟ้าที่ได้รับอนุญาตให้ประกอบกิจการหรือขยายโรงงาน หรือเดินเครื่องจักร ก่อนวันที่ ๓๑ มกราคม ๒๕๓๙			
(๑.๑) โรงไฟฟ้าบางปะกง (พลังงานความร้อน) หน่วยการผลิตที่ ๓ และ หน่วยการผลิตที่ ๔ ที่ใช้ก๊าซธรรมชาติและน้ำมันเป็นเชื้อเพลิง	ไม่เกิน ๑๒๐	ไม่เกิน ๓๒๐	ไม่เกิน ๒๐๐
(๑.๒) โรงไฟฟ้าน้ำพอง ชุดที่ ๑ และชุดที่ ๒ ที่ใช้ก๊าซธรรมชาติเป็นเชื้อเพลิง	ไม่เกิน ๖๐	ไม่เกิน ๖๐	ไม่เกิน ๒๕๐

โรงไฟฟ้า	ค่ามาตรฐาน		
	ฝุ่นละออง (มิลลิกรัมต่อลูกบาศก์เมตร)	ก๊าซซัลเฟอร์ไดออกไซด์ (ส่วนในล้านส่วน)	ก๊าซออกไซด์ของไนโตรเจนซึ่งคำนวณผลในรูปก๊าซไนโตรเจนไดออกไซด์ (ส่วนในล้านส่วน)
(๑.๓) โรงไฟฟ้าแม่เมาะ หน่วยการผลิตที่ ๔ และ หน่วยการผลิตที่ ๘ - ๑๓ ที่ใช้ลิกไนต์เป็นเชื้อเพลิง	ไม่เกิน ๑๘๐	ไม่เกิน ๓๒๐	ไม่เกิน ๕๐๐
(๒) โรงไฟฟ้าที่ได้รับอนุญาตให้ประกอบกิจการ ผลิต หรือเปลี่ยนแปลงกำลังผลิตไฟฟ้า ตั้งแต่วันที่ ๓๑ มกราคม ๒๕๓๙ ถึงวันที่ ๑๖ มกราคม ๒๕๕๓			
(๒.๑) โรงไฟฟ้าที่ใช้ถ่านหินเป็นเชื้อเพลิง			
(ก) ที่มีกำลังการผลิตไฟฟ้าไม่เกิน ๓๐๐ เมกะวัตต์	ไม่เกิน ๑๒๐	ไม่เกิน ๖๔๐	ไม่เกิน ๓๕๐
(ข) ที่มีกำลังการผลิตไฟฟ้าเกิน ๓๐๐ แต่ไม่เกิน ๕๐๐ เมกะวัตต์	ไม่เกิน ๑๒๐	ไม่เกิน ๔๕๐	ไม่เกิน ๓๕๐
(ค) ที่มีกำลังการผลิตไฟฟ้าเกิน ๕๐๐ เมกะวัตต์ขึ้นไป	ไม่เกิน ๑๒๐	ไม่เกิน ๓๒๐	ไม่เกิน ๓๕๐
(๒.๒) โรงไฟฟ้าที่ใช้น้ำมันเป็นเชื้อเพลิง			
(ก) ที่มีกำลังการผลิตไฟฟ้าไม่เกิน ๓๐๐ เมกะวัตต์	ไม่เกิน ๑๒๐	ไม่เกิน ๖๔๐	ไม่เกิน ๑๘๐
(ข) ที่มีกำลังการผลิตไฟฟ้าเกิน ๓๐๐ แต่ไม่เกิน ๕๐๐ เมกะวัตต์	ไม่เกิน ๑๒๐	ไม่เกิน ๔๕๐	ไม่เกิน ๑๘๐
(ค) ที่มีกำลังการผลิตไฟฟ้าเกิน ๕๐๐ เมกะวัตต์ขึ้นไป	ไม่เกิน ๑๒๐	ไม่เกิน ๓๒๐	ไม่เกิน ๑๘๐
(๒.๓) โรงไฟฟ้าทุกขนาดที่ใช้ ก๊าซธรรมชาติเป็นเชื้อเพลิง	ไม่เกิน ๖๐	ไม่เกิน ๒๐	ไม่เกิน ๑๒๐
(๒.๔) โรงไฟฟ้าทุกขนาดที่ใช้เชื้อเพลิงชีวมวลเป็นเชื้อเพลิง	ไม่เกิน ๑๒๐	ไม่เกิน ๖๐	ไม่เกิน ๒๐๐
(๓) โรงไฟฟ้าที่ได้รับอนุญาตให้ประกอบกิจการผลิต หรือเปลี่ยนแปลงกำลังผลิตไฟฟ้า ตั้งแต่วันที่ ๑๗ มกราคม ๒๕๕๓ ถึงก่อนวันที่ประกาศนี้มีผลใช้บังคับ			
(๓.๑) โรงไฟฟ้าที่ใช้ถ่านหินเป็นเชื้อเพลิง			
(ก) ที่มีกำลังการผลิตไฟฟ้าไม่เกิน ๕๐ เมกะวัตต์	ไม่เกิน ๘๐	ไม่เกิน ๓๖๐	ไม่เกิน ๒๐๐
(ข) ที่มีกำลังการผลิตไฟฟ้าเกิน ๕๐ เมกะวัตต์ขึ้นไป	ไม่เกิน ๘๐	ไม่เกิน ๑๘๐	ไม่เกิน ๒๐๐

โรงไฟฟ้า	ค่ามาตรฐาน		
	ฝุ่นละออง (มิลลิกรัมต่อลูกบาศก์เมตร)	ก๊าซซัลเฟอร์ไดออกไซด์ (ส่วนในล้านส่วน)	ก๊าซออกไซด์ของไนโตรเจนซึ่งคำนวณผลในรูปก๊าซไนโตรเจนไดออกไซด์ (ส่วนในล้านส่วน)
(๓.๒) โรงไฟฟ้าทุกขนาดที่ใช้น้ำมันเป็นเชื้อเพลิง	ไม่เกิน ๑๒๐	ไม่เกิน ๒๖๐	ไม่เกิน ๑๘๐
(๓.๓) โรงไฟฟ้าทุกขนาดที่ใช้ก๊าซธรรมชาติเป็นเชื้อเพลิง	ไม่เกิน ๖๐	ไม่เกิน ๒๐	ไม่เกิน ๑๒๐
(๓.๔) โรงไฟฟ้าทุกขนาดที่ใช้เชื้อเพลิงชีวมวลเป็นเชื้อเพลิง	ไม่เกิน ๑๒๐	ไม่เกิน ๖๐	ไม่เกิน ๒๐๐
(๓.๕) โรงไฟฟ้าทุกขนาดที่ใช้ก๊าซชีวภาพเป็นเชื้อเพลิง	ไม่เกิน ๑๒๐	ไม่เกิน ๖๐	ไม่เกิน ๒๐๐

ข้อ ๔ กำหนดมาตรฐานควบคุมการปล่อยทิ้งอากาศเสียจากโรงไฟฟ้าใหม่ ไว้ดังต่อไปนี้

โรงไฟฟ้า	ค่ามาตรฐาน			
	ฝุ่นละออง (มิลลิกรัมต่อลูกบาศก์เมตร)	ก๊าซซัลเฟอร์ไดออกไซด์ (ส่วนในล้านส่วน)	ก๊าซออกไซด์ของไนโตรเจนซึ่งคำนวณผลในรูปก๊าซไนโตรเจนไดออกไซด์ (ส่วนในล้านส่วน)	สารปรอท (มิลลิกรัมต่อลูกบาศก์เมตร)
(๑) โรงไฟฟ้าใหม่ที่ใช้ถ่านหินเป็นเชื้อเพลิง				
(๑.๑) ที่มีกำลังการผลิตไฟฟ้าไม่เกิน ๑๐๐ เมกะวัตต์	ไม่เกิน ๕๐	ไม่เกิน ๑๕๐	ไม่เกิน ๒๐๐	ไม่เกิน ๐.๐๓
(๑.๒) ที่มีกำลังการผลิตไฟฟ้าเกิน ๑๐๐ เมกะวัตต์	ไม่เกิน ๓๐	ไม่เกิน ๑๕๐	ไม่เกิน ๒๐๐	ไม่เกิน ๐.๐๓
(๒) โรงไฟฟ้าใหม่ทุกขนาดที่ใช้น้ำมันเป็นเชื้อเพลิง	ไม่เกิน ๓๐	ไม่เกิน ๕๐	ไม่เกิน ๑๓๐	-
(๓) โรงไฟฟ้าใหม่ทุกขนาดที่ใช้ก๊าซธรรมชาติเป็นเชื้อเพลิง	ไม่เกิน ๒๐	ไม่เกิน ๑๕	ไม่เกิน ๘๐	-
(๔) โรงไฟฟ้าใหม่ทุกขนาดที่ใช้เชื้อเพลิงชีวมวลเป็นเชื้อเพลิง	ไม่เกิน ๙๐	ไม่เกิน ๓๐	ไม่เกิน ๒๐๐	-
(๕) โรงไฟฟ้าใหม่ทุกขนาดที่ใช้ก๊าซชีวภาพเป็นเชื้อเพลิง	ไม่เกิน ๓๐	ไม่เกิน ๓๐	ไม่เกิน ๒๐๐	-

ข้อ ๕ กำหนดมาตรฐานควบคุมการปล่อยทิ้งอากาศเสียจากโรงไฟฟ้าที่ใช้ขยะเป็นเชื้อเพลิงไว้ ดังต่อไปนี้

สารมลพิษทางอากาศ	ค่ามาตรฐาน	
	โรงไฟฟ้าเก่า	โรงไฟฟ้าใหม่
ฝุ่นละออง (มิลลิกรัมต่อลูกบาศก์เมตร)	ไม่เกิน ๗๐	ไม่เกิน ๕๐
ก๊าซซัลเฟอร์ไดออกไซด์ (ส่วนในล้านส่วน)	ไม่เกิน ๓๐	ไม่เกิน ๒๕
ก๊าซออกไซด์ของไนโตรเจน ซึ่งคำนวณผลในรูปก๊าซไนโตรเจนไดออกไซด์ (ส่วนในล้านส่วน)	ไม่เกิน ๑๘๐	ไม่เกิน ๑๕๐
ก๊าซไฮโดรเจนคลอไรด์ (ส่วนในล้านส่วน)	ไม่เกิน ๒๕	ไม่เกิน ๒๕
สารปรอท (มิลลิกรัมต่อลูกบาศก์เมตร)	ไม่เกิน ๐.๐๕	ไม่เกิน ๐.๐๓
สารแคดเมียม (มิลลิกรัมต่อลูกบาศก์เมตร)	ไม่เกิน ๐.๐๕	ไม่เกิน ๐.๐๕
สารตะกั่ว (มิลลิกรัมต่อลูกบาศก์เมตร)	ไม่เกิน ๐.๕	ไม่เกิน ๐.๑
สารประกอบไดออกซิน (นาโนกรัมต่อลูกบาศก์เมตร คำนวณในรูปของหน่วยความเข้มข้นเทียบเคียงความเป็นพิษต่อมนุษย์ (PCDD/Fs as Toxic Equivalent ; I-TEQ)	ไม่เกิน ๐.๑	ไม่เกิน ๐.๑
ค่าความทึบแสง (ร้อยละ)	ไม่เกิน ๑๐	ไม่เกิน ๑๐

ข้อ ๖ ให้มาตรฐานควบคุมการปล่อยทิ้งอากาศเสียจากโรงไฟฟ้าเก่าตามข้อ ๓ (๑) มีผลสิ้นสุดลง ตั้งแต่วันที่ ๑ มกราคม ๒๕๗๕ เป็นต้นไป และให้ใช้มาตรฐานควบคุมการปล่อยทิ้งอากาศเสียจากโรงไฟฟ้าใหม่แทน

ข้อ ๗ กรณีโรงไฟฟ้าใช้เชื้อเพลิงร่วมกันตั้งแต่ ๒ ประเภทขึ้นไป ให้คำนวณค่ามาตรฐานควบคุมการปล่อยทิ้งอากาศเสียจากผลรวมของค่ามาตรฐานควบคุมอากาศเสียที่ปล่อยทิ้งของเชื้อเพลิงแต่ละประเภทคูณกับสัดส่วนของความร้อน (Heat Input) ของเชื้อเพลิงประเภทนั้น ๆ

ค่ามาตรฐานควบคุมการปล่อยทิ้งอากาศเสีย = AU + BV + CW + DX + EY + FZ

เมื่อ A = ค่ามาตรฐานอากาศเสียที่ปล่อยทิ้งเมื่อใช้ถ่านหินเป็นเชื้อเพลิงอย่างเดียว

B = ค่ามาตรฐานอากาศเสียที่ปล่อยทิ้งเมื่อใช้น้ำมันเป็นเชื้อเพลิงอย่างเดียว

C = ค่ามาตรฐานอากาศเสียที่ปล่อยทิ้งเมื่อใช้ก๊าซธรรมชาติเป็นเชื้อเพลิงอย่างเดียว

D = ค่ามาตรฐานอากาศเสียที่ปล่อยทิ้งเมื่อใช้เชื้อเพลิงชีวมวลเป็นเชื้อเพลิงอย่างเดียว

E = ค่ามาตรฐานอากาศเสียที่ปล่อยทิ้งเมื่อใช้ก๊าซชีวภาพเป็นเชื้อเพลิงอย่างเดียว

F = ค่ามาตรฐานอากาศเสียที่ปล่อยทิ้งเมื่อใช้ขยะเป็นเชื้อเพลิงอย่างเดียว

U = สัดส่วนของความร้อน (Heat Input) ที่ได้จากเชื้อเพลิงประเภทถ่านหิน

V = สัดส่วนของความร้อน (Heat Input) ที่ได้จากเชื้อเพลิงประเภทน้ำมัน

W = สัดส่วนของความร้อน (Heat Input) ที่ได้จากเชื้อเพลิงประเภทก๊าซธรรมชาติ

X = สัดส่วนของความร้อน (Heat Input) ที่ได้จากเชื้อเพลิงประเภทเชื้อเพลิงชีวมวล

Y = สัดส่วนของความร้อน (Heat Input) ที่ได้จากเชื้อเพลิงประเภทก๊าซชีวภาพ

Z = สัดส่วนของความร้อน (Heat Input) ที่ได้จากเชื้อเพลิงประเภทขยะ

ข้อ ๘ การตรวจวัดมลพิษทางอากาศจากปล่องโรงไฟฟ้า ให้ใช้วิธี ดังต่อไปนี้

(๑) ฝุ่นละออง ให้ใช้วิธี Determination of Particulate Matter Emissions from Stationary Sources หรือวิธี Determination of Low Level Particulate Matter Emissions from Stationary Sources หรือ Determination of Metals Emissions from Stationary Sources ที่องค์การพิทักษ์สิ่งแวดล้อมแห่งประเทศสหรัฐอเมริกา (United States Environmental Protection Agency) กำหนดไว้ หรือวิธีอื่นที่คณะกรรมการควบคุมมลพิษเห็นชอบ

(๒) ก๊าซซัลเฟอร์ไดออกไซด์ ให้ใช้วิธี Determination of Sulfur Dioxide Emissions from Stationary Sources หรือวิธี Determination of Sulfuric Acid and Sulfur Dioxide Emissions from Stationary Sources ที่องค์การพิทักษ์สิ่งแวดล้อมแห่งประเทศสหรัฐอเมริกา (United States Environmental Protection Agency) กำหนดไว้ หรือวิธีอื่นที่คณะกรรมการควบคุมมลพิษเห็นชอบ

(๓) ก๊าซออกไซด์ของไนโตรเจน ซึ่งคำนวณผลในรูปก๊าซไนโตรเจนไดออกไซด์ ให้ใช้วิธี Determination of Nitrogen Oxide Emissions from Stationary Sources หรือวิธี Determination of Nitrogen Oxide Emissions from Stationary Sources - Ion Chromatographic Method หรือ Ultraviolet Spectrophotometric Method หรือ Alkaline Permanganate/Colorimetric Method หรือ Alkaline - Permanganate/Ion Chromatographic Method หรือ Instrumental Analyzer Procedure ที่องค์การพิทักษ์สิ่งแวดล้อมแห่งประเทศสหรัฐอเมริกา (United States Environmental Protection Agency) กำหนดไว้ หรือวิธีอื่นที่คณะกรรมการควบคุมมลพิษเห็นชอบ

(๔) ก๊าซไฮโดรเจนคลอไรด์ ให้ใช้วิธี Determination of Hydrogen Halide and Halogen Emissions from Stationary Sources ที่องค์การพิทักษ์สิ่งแวดล้อมแห่งประเทศสหรัฐอเมริกา (United States Environmental Protection Agency) กำหนดไว้ หรือวิธีอื่นที่คณะกรรมการควบคุมมลพิษเห็นชอบ

(๕) สารปรอท สารแคดเมียม และสารตะกั่ว ให้ใช้วิธี Determination of Metals Emissions from Stationary Sources ที่องค์การพิทักษ์สิ่งแวดล้อมแห่งประเทศสหรัฐอเมริกา (United States Environmental Protection Agency) กำหนดไว้ หรือวิธีอื่นที่คณะกรรมการควบคุมมลพิษเห็นชอบ

(๖) สารประกอบไดออกซิน ให้ใช้วิธี Determination of Polychlorinated Dibenzo-*p*-Dioxins and Polychlorinated Dibenzofurans from Stationary Sources ที่องค์การพิทักษ์สิ่งแวดล้อมแห่งประเทศสหรัฐอเมริกา (United States Environmental Protection Agency) กำหนดไว้ หรือวิธีอื่นที่คณะกรรมการควบคุมมลพิษเห็นชอบ

(๗) ค่าความทึบแสง ให้ใช้วิธีตรวจวัดด้วยแผนภูมิเขม่าควันของริงเกิลมานน์ตามประกาศคณะกรรมการควบคุมมลพิษ เรื่อง แบบบันทึกผลการตรวจวัดค่าความทึบแสง และแบบสรุปผลการตรวจวัดค่าความทึบแสงของเขม่าควัน จากปล่องปล่อยทิ้งอากาศเสียของเตาเผามูลฝอย รวมทั้งลักษณะ และหน่วยวัดค่าความทึบแสงของแผนภูมิเขม่าควันของริงเกิลมานน์ หรือวิธีอื่นที่คณะกรรมการควบคุมมลพิษเห็นชอบ

ข้อ ๙ การคำนวณผลการตรวจวัดมลพิษทางอากาศ ให้คำนวณผลที่ความดัน ๑ บรรยากาศ หรือ ๗๖๐ มิลลิเมตรปรอท อุณหภูมิ ๒๕ องศาเซลเซียส ที่สภาวะแห้ง (Dry Basis) โดยมีปริมาตรออกซิเจนส่วนเกิน (Excess Oxygen) ในการเผาไหม้ร้อยละ ๗

ข้อ ๑๐ ประกาศนี้ให้ใช้บังคับเมื่อพ้นกำหนดเก้าสิบวันนับแต่วันประกาศในราชกิจจานุเบกษาเป็นต้นไป

ประกาศ ณ วันที่ ๒๗ กรกฎาคม พ.ศ. ๒๕๖๖
วราวุธ ศิลปอาชา
รัฐมนตรีว่าการกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม

ประกาศกระทรวงอุตสาหกรรม

เรื่อง กำหนดค่าปริมาณของสารเจือปนในอากาศที่ระบายออกจากโรงไฟฟ้า
พ.ศ. ๒๕๖๗

โดยที่เป็นการสมควรปรับปรุงค่าปริมาณของสารเจือปนในอากาศที่ระบายออกจากโรงงานผลิตพลังงานไฟฟ้าจากพลังงานความร้อนให้มีความสอดคล้องกับสถานการณ์ด้านพลังงาน สิ่งแวดล้อม และเทคโนโลยีในปัจจุบัน

อาศัยอำนาจตามความในข้อ ๑๖ แห่งกฎกระทรวง ฉบับที่ ๒ (พ.ศ. ๒๕๓๕) ออกตามความในพระราชบัญญัติโรงงาน พ.ศ. ๒๕๓๕ รัฐมนตรีว่าการกระทรวงอุตสาหกรรม ออกประกาศไว้ดังต่อไปนี้

ข้อ ๑ ประกาศนี้เรียกว่า “ประกาศกระทรวงอุตสาหกรรม เรื่อง กำหนดค่าปริมาณของสารเจือปนในอากาศที่ระบายออกจากโรงไฟฟ้า พ.ศ. ๒๕๖๗”

ข้อ ๒ ให้ยกเลิกประกาศกระทรวงอุตสาหกรรม เรื่อง กำหนดค่าปริมาณของสารเจือปนในอากาศที่ระบายออกจากโรงงานผลิต ส่ง หรือจำหน่ายพลังงานไฟฟ้า พ.ศ. ๒๕๔๗ และให้ใช้ประกาศนี้แทน

ข้อ ๓ เว้นแต่ข้อความนั้นจะกำหนดเป็นอย่างอื่น ในประกาศนี้

“โรงไฟฟ้า” หมายความว่า โรงงานผลิตพลังงานไฟฟ้าจากพลังงานความร้อนในประเภทหรือชนิดของโรงงานที่ออกตามกฎกระทรวงกำหนดประเภท ชนิด และขนาดของโรงงาน พ.ศ. ๒๕๖๓ และที่แก้ไขเพิ่มเติม หรือโรงงานที่ได้รับใบอนุญาตประกอบกิจการผลิตไฟฟ้า เฉพาะหน่วยที่มีการผลิตไฟฟ้าจากพลังงานความร้อนตามกฎหมายว่าด้วยการประกอบกิจการพลังงาน

“โรงไฟฟ้าเก่า” หมายความว่า โรงไฟฟ้า ดังต่อไปนี้

(๑) โรงไฟฟ้าที่ได้รับใบอนุญาตประกอบกิจการโรงงานหรือที่ได้รับอนุญาตให้ขยายโรงงานก่อนวันที่ ๓๑ มกราคม พ.ศ. ๒๕๓๙ ดังนี้

(๑.๑) โรงไฟฟ้าบางปะกง (พลังงานความร้อน) หน่วยการผลิตที่ ๓ และหน่วยการผลิตที่ ๔

(๑.๒) โรงไฟฟ้าน้ำพอง ชุดที่ ๑ และชุดที่ ๒

(๑.๓) โรงไฟฟ้าแม่เมาะ หน่วยการผลิตที่ ๔ และหน่วยการผลิตที่ ๘ ถึงหน่วยการผลิตที่ ๑๓

(๒) โรงไฟฟ้าที่ได้รับใบอนุญาตประกอบกิจการโรงงาน หรือโรงไฟฟ้าที่ได้รับอนุญาตให้ขยายโรงงานหรือโรงไฟฟ้าที่ได้แจ้งเปลี่ยนแปลงเครื่องจักรเพื่อทดแทนหน่วยผลิตพลังงานไฟฟ้าจากพลังงานความร้อนเดิมหรือโรงไฟฟ้าที่ได้รับใบอนุญาตประกอบกิจการผลิตไฟฟ้าตามกฎหมายว่าด้วยการประกอบกิจการพลังงาน ตั้งแต่วันที่ ๓๑ มกราคม พ.ศ. ๒๕๓๙ ถึงวันที่ ๑๖ มกราคม พ.ศ. ๒๕๕๓

(๓) โรงไฟฟ้าที่ได้รับใบอนุญาตประกอบกิจการโรงงาน หรือโรงไฟฟ้าที่ได้รับอนุญาตให้ขยายโรงงานหรือโรงไฟฟ้าที่ได้แจ้งเปลี่ยนแปลงเครื่องจักรเพื่อทดแทนหน่วยผลิตพลังงานไฟฟ้าจากพลังงานความร้อนเดิมหรือโรงไฟฟ้าที่ได้รับใบอนุญาตประกอบกิจการผลิตไฟฟ้าตามกฎหมายว่าด้วยการประกอบกิจการพลังงาน ตั้งแต่วันที่ ๑๗ มกราคม พ.ศ. ๒๕๕๓ ถึงวันที่ ๒๕ พฤศจิกายน พ.ศ. ๒๕๖๖

“โรงไฟฟ้าใหม่” หมายความว่า โรงไฟฟ้าที่ได้รับใบอนุญาตประกอบกิจการโรงงาน หรือโรงไฟฟ้าที่ได้รับอนุญาตให้ขยายโรงงาน หรือโรงไฟฟ้าที่ได้แจ้งเปลี่ยนแปลงเครื่องจักรเพื่อทดแทนหน่วยผลิตพลังงานไฟฟ้าจากพลังงานความร้อนเดิม หรือโรงไฟฟ้าที่ได้รับใบอนุญาตประกอบกิจการผลิตไฟฟ้าตามกฎหมายว่าด้วยการประกอบกิจการพลังงาน ตั้งแต่วันที่ ๒๖ พฤศจิกายน พ.ศ. ๒๕๖๖ เป็นต้นไป

“โรงไฟฟ้าที่ใช้ขยะเป็นเชื้อเพลิง” หมายความว่า โรงไฟฟ้าที่ใช้มูลฝอยตามกฎหมายว่าด้วยการสาธารณสุข หรือใช้สิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้วที่ไม่เป็นของเสียอันตรายตามกฎหมายว่าด้วยโรงงานมาเป็นเชื้อเพลิงในการผลิตไฟฟ้า ทั้งนี้ ให้หมายความรวมถึงโรงไฟฟ้าที่ใช้เชื้อเพลิงที่ได้จากกระบวนการแปรรูปมูลฝอย หรือสิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้วดังกล่าวด้วย

“เชื้อเพลิงชีวมวล” หมายความว่า เชื้อเพลิงที่ได้มาจากอินทรีย์สารหรือสิ่งมีชีวิต รวมทั้งผลผลิตจากการเกษตร การปศุสัตว์ การทำป่าไม้ และการแปรรูปผลผลิตดังกล่าว เช่น ไม้ฟืน เศษไม้ แกลบ ฟาง ชานอ้อย ต้นและใบอ้อย ใยปาล์ม กะลาปาล์ม ทะลายปาล์ม กะลามะพร้าว ใยมะพร้าว เศษพืช มูลสัตว์ และกากตะกอน เป็นต้น

“ก๊าซชีวภาพ” หมายความว่า ก๊าซที่เกิดจากกระบวนการย่อยสลายของสารอินทรีย์ในวัตถุดิบในสภาวะไม่ใช้อากาศโดยการทำงานของจุลินทรีย์ โดยมีองค์ประกอบหลัก คือก๊าซมีเทน (CH_4) และก๊าซคาร์บอนไดออกไซด์ (CO_2)

ข้อ ๔ อากาศที่ระบายออกจากโรงไฟฟ้าเก่า ต้องมีค่าปริมาณสารเจือปนในอากาศแต่ละชนิดไม่เกินตามมาตรฐานที่กำหนดไว้ ดังต่อไปนี้

โรงไฟฟ้า	ค่าปริมาณสารเจือปนในอากาศ		
	ฝุ่นละออง (มิลลิกรัมต่อลูกบาศก์เมตร)	ก๊าซซัลเฟอร์ไดออกไซด์ (ส่วนในล้านส่วน)	ก๊าซออกไซด์ของไนโตรเจนซึ่งคำนวณผลในรูปก๊าซไนโตรเจนไดออกไซด์ (ส่วนในล้านส่วน)
(๑) โรงไฟฟ้าที่ได้รับใบอนุญาตประกอบกิจการโรงงาน หรือโรงไฟฟ้าที่ได้รับอนุญาตให้ขยายโรงงาน ก่อนวันที่ ๓๑ มกราคม พ.ศ. ๒๕๓๙			
(๑.๑) โรงไฟฟ้าบางปะกง (พลังงานความร้อน) หน่วยการผลิตที่ ๓ และหน่วยการผลิตที่ ๔ ที่ใช้ก๊าซธรรมชาติและน้ำมันเป็นเชื้อเพลิง	ไม่เกิน ๑๒๐	ไม่เกิน ๓๒๐	ไม่เกิน ๒๐๐
(๑.๒) โรงไฟฟ้าน้ำพอง ชุดที่ ๑ และชุดที่ ๒ ที่ใช้ก๊าซธรรมชาติเป็นเชื้อเพลิง	ไม่เกิน ๖๐	ไม่เกิน ๖๐	ไม่เกิน ๒๕๐
(๑.๓) โรงไฟฟ้าแม่เมาะ หน่วยการผลิตที่ ๔ และหน่วยการผลิตที่ ๘ ถึงหน่วยการผลิตที่ ๑๓ ที่ใช้ลิกไนต์เป็นเชื้อเพลิง	ไม่เกิน ๑๘๐	ไม่เกิน ๓๒๐	ไม่เกิน ๕๐๐

โรงไฟฟ้า	ค่าปริมาณสารเจือปนในอากาศ		
	ฝุ่นละออง (มิลลิกรัมต่อลูกบาศก์เมตร)	ก๊าซซัลเฟอร์ไดออกไซด์ (ส่วนในล้านส่วน)	ก๊าซออกไซด์ของไนโตรเจนซึ่งคำนวณผลในรูปก๊าซไนโตรเจนไดออกไซด์ (ส่วนในล้านส่วน)
(๒) โรงไฟฟ้าที่ได้รับใบอนุญาตประกอบกิจการโรงงาน หรือโรงไฟฟ้าที่ได้รับอนุญาตให้ขยายโรงงาน หรือโรงไฟฟ้าที่ได้แจ้งเปลี่ยนแปลงเครื่องจักรเพื่อทดแทนหน่วยผลิตพลังงานไฟฟ้าจากพลังงานความร้อนเดิม หรือโรงไฟฟ้าที่ได้รับใบอนุญาตประกอบกิจการผลิตไฟฟ้าตามกฎหมายว่าด้วยการประกอบกิจการพลังงาน ตั้งแต่วันที่ ๓๑ มกราคม พ.ศ. ๒๕๓๙ ถึงวันที่ ๑๖ มกราคม พ.ศ. ๒๕๕๓			
(๒.๑) โรงไฟฟ้าที่ใช้ถ่านหินเป็นเชื้อเพลิง			
(ก) ที่มีกำลังการผลิตไฟฟ้าไม่เกิน ๓๐๐ เมกะวัตต์	ไม่เกิน ๑๒๐	ไม่เกิน ๖๔๐	ไม่เกิน ๓๕๐
(ข) ที่มีกำลังการผลิตไฟฟ้าเกิน ๓๐๐ แต่ไม่เกิน ๕๐๐ เมกะวัตต์	ไม่เกิน ๑๒๐	ไม่เกิน ๔๕๐	ไม่เกิน ๓๕๐
(ค) ที่มีกำลังการผลิตไฟฟ้าเกิน ๕๐๐ เมกะวัตต์ขึ้นไป	ไม่เกิน ๑๒๐	ไม่เกิน ๓๒๐	ไม่เกิน ๓๕๐
(๒.๒) โรงไฟฟ้าที่ใช้น้ำมันเป็นเชื้อเพลิง			
(ก) ที่มีกำลังการผลิตไฟฟ้าไม่เกิน ๓๐๐ เมกะวัตต์	ไม่เกิน ๑๒๐	ไม่เกิน ๖๔๐	ไม่เกิน ๑๘๐
(ข) ที่มีกำลังการผลิตไฟฟ้าเกิน ๓๐๐ แต่ไม่เกิน ๕๐๐ เมกะวัตต์	ไม่เกิน ๑๒๐	ไม่เกิน ๔๕๐	ไม่เกิน ๑๘๐
(ค) ที่มีกำลังการผลิตไฟฟ้าเกิน ๕๐๐ เมกะวัตต์ขึ้นไป	ไม่เกิน ๑๒๐	ไม่เกิน ๓๒๐	ไม่เกิน ๑๘๐
(๒.๓) โรงไฟฟ้าทุกขนาดที่ใช้ก๊าซธรรมชาติเป็นเชื้อเพลิง	ไม่เกิน ๖๐	ไม่เกิน ๒๐	ไม่เกิน ๑๒๐
(๒.๔) โรงไฟฟ้าทุกขนาดที่ใช้เชื้อเพลิงชีวมวลเป็นเชื้อเพลิง	ไม่เกิน ๑๒๐	ไม่เกิน ๖๐	ไม่เกิน ๒๐๐
(๓) โรงไฟฟ้าที่ได้รับใบอนุญาตประกอบกิจการโรงงาน หรือโรงไฟฟ้าที่ได้รับอนุญาตให้ขยายโรงงาน หรือโรงไฟฟ้าที่ได้แจ้งเปลี่ยนแปลงเครื่องจักรเพื่อทดแทนหน่วยผลิตพลังงานไฟฟ้าจากพลังงานความร้อนเดิม หรือโรงไฟฟ้าที่ได้รับใบอนุญาตประกอบกิจการผลิตไฟฟ้าตามกฎหมายว่าด้วย			

โรงไฟฟ้า	ค่าปริมาณสารเจือปนในอากาศ		
	ฝุ่นละออง (มิลลิกรัมต่อลูกบาศก์เมตร)	ก๊าซซัลเฟอร์ไดออกไซด์ (ส่วนในล้านส่วน)	ก๊าซออกไซด์ของไนโตรเจนซึ่งคำนวณผลในรูปก๊าซไนโตรเจนไดออกไซด์ (ส่วนในล้านส่วน)
การประกอบกิจการพลังงาน ตั้งแต่วันที่ ๑๗ มกราคม พ.ศ. ๒๕๕๓ ถึงวันที่ ๒๕ พฤศจิกายน พ.ศ. ๒๕๖๖			
(๓.๑) โรงไฟฟ้าที่ใช้ถ่านหินเป็นเชื้อเพลิง			
(ก) ที่มีกำลังการผลิตไฟฟ้าไม่เกิน ๕๐ เมกะวัตต์	ไม่เกิน ๘๐	ไม่เกิน ๓๖๐	ไม่เกิน ๒๐๐
(ข) ที่มีกำลังการผลิตไฟฟ้าเกิน ๕๐ เมกะวัตต์ขึ้นไป	ไม่เกิน ๘๐	ไม่เกิน ๑๘๐	ไม่เกิน ๒๐๐
(๓.๒) โรงไฟฟ้าทุกขนาดที่ใช้น้ำมันเป็นเชื้อเพลิง	ไม่เกิน ๑๒๐	ไม่เกิน ๒๖๐	ไม่เกิน ๑๘๐
(๓.๓) โรงไฟฟ้าทุกขนาดที่ใช้ก๊าซธรรมชาติเป็นเชื้อเพลิง	ไม่เกิน ๖๐	ไม่เกิน ๒๐	ไม่เกิน ๑๒๐
(๓.๔) โรงไฟฟ้าทุกขนาดที่ใช้เชื้อเพลิงชีวมวลเป็นเชื้อเพลิง	ไม่เกิน ๑๒๐	ไม่เกิน ๖๐	ไม่เกิน ๒๐๐
(๓.๕) โรงไฟฟ้าทุกขนาดที่ใช้ก๊าซชีวภาพเป็นเชื้อเพลิง	ไม่เกิน ๑๒๐	ไม่เกิน ๖๐	ไม่เกิน ๒๐๐

ข้อ ๕ อากาศที่ระบายออกจากโรงไฟฟ้าใหม่ ต้องมีค่าปริมาณสารเจือปนไม่เกินกว่าที่กำหนดไว้ดังต่อไปนี้

โรงไฟฟ้า	ค่าปริมาณสารเจือปนในอากาศ			
	ฝุ่นละออง (มิลลิกรัมต่อลูกบาศก์เมตร)	ก๊าซซัลเฟอร์ไดออกไซด์ (ส่วนในล้านส่วน)	ก๊าซออกไซด์ของไนโตรเจนซึ่งคำนวณผลในรูปก๊าซไนโตรเจนไดออกไซด์ (ส่วนในล้านส่วน)	สารปรอท (มิลลิกรัมต่อลูกบาศก์เมตร)
(๑) โรงไฟฟ้าใหม่ที่ใช้ถ่านหินเป็นเชื้อเพลิง				
(๑.๑) ที่มีกำลังการผลิตไฟฟ้าไม่เกิน ๑๐๐ เมกะวัตต์	ไม่เกิน ๕๐	ไม่เกิน ๑๕๐	ไม่เกิน ๒๐๐	ไม่เกิน ๐.๐๓
(๑.๒) ที่มีกำลังการผลิตไฟฟ้าเกิน ๑๐๐ เมกะวัตต์	ไม่เกิน ๓๐	ไม่เกิน ๑๕๐	ไม่เกิน ๒๐๐	ไม่เกิน ๐.๐๓
(๒) โรงไฟฟ้าใหม่ทุกขนาดที่ใช้น้ำมันเป็นเชื้อเพลิง	ไม่เกิน ๓๐	ไม่เกิน ๕๐	ไม่เกิน ๑๓๐	-

โรงไฟฟ้า	ค่าปริมาณสารเจือปนในอากาศ			
	ฝุ่นละออง (มิลลิกรัมต่อลูกบาศก์เมตร)	ก๊าซซัลเฟอร์ไดออกไซด์ (ส่วนในล้านส่วน)	ก๊าซออกไซด์ของไนโตรเจนซึ่งคำนวณผลในรูปก๊าซไนโตรเจนไดออกไซด์ (ส่วนในล้านส่วน)	สารปรอท (มิลลิกรัมต่อลูกบาศก์เมตร)
(๓) โรงไฟฟ้าใหม่ทุกขนาดที่ใช้ก๊าซธรรมชาติเป็นเชื้อเพลิง	ไม่เกิน ๒๐	ไม่เกิน ๑๕	ไม่เกิน ๘๐	-
(๔) โรงไฟฟ้าใหม่ทุกขนาดที่ใช้เชื้อเพลิงชีวมวลเป็นเชื้อเพลิง	ไม่เกิน ๙๐	ไม่เกิน ๓๐	ไม่เกิน ๒๐๐	-
(๕) โรงไฟฟ้าใหม่ทุกขนาดที่ใช้ก๊าซชีวภาพเป็นเชื้อเพลิง	ไม่เกิน ๓๐	ไม่เกิน ๓๐	ไม่เกิน ๒๐๐	-

ข้อ ๖ อากาศที่ระบายออกจากโรงไฟฟ้าที่ใช้ขยะเป็นเชื้อเพลิง ไม่ว่าจะเป็นโรงไฟฟ้าเก่าหรือโรงไฟฟ้าใหม่ ต้องมีค่าปริมาณสารเจือปนไม่เกินกว่าที่กำหนดไว้ ดังต่อไปนี้

ชนิดสารเจือปน (หน่วยวัด)	ค่าปริมาณสารเจือปนในอากาศ	
	โรงไฟฟ้าเก่า	โรงไฟฟ้าใหม่
๑. ฝุ่นละออง (มิลลิกรัมต่อลูกบาศก์เมตร)	ไม่เกิน ๗๐	ไม่เกิน ๕๐
๒. ก๊าซซัลเฟอร์ไดออกไซด์ (ส่วนในล้านส่วน)	ไม่เกิน ๓๐	ไม่เกิน ๒๕
๓. ก๊าซออกไซด์ของไนโตรเจน ซึ่งคำนวณผลในรูปก๊าซไนโตรเจนไดออกไซด์ (ส่วนในล้านส่วน)	ไม่เกิน ๑๘๐	ไม่เกิน ๑๕๐
๔. ก๊าซไฮโดรเจนคลอไรด์ (ส่วนในล้านส่วน)	ไม่เกิน ๒๕	ไม่เกิน ๒๕
๕. สารปรอท (มิลลิกรัมต่อลูกบาศก์เมตร)	ไม่เกิน ๐.๐๕	ไม่เกิน ๐.๐๓
๖. สารแคดเมียม (มิลลิกรัมต่อลูกบาศก์เมตร)	ไม่เกิน ๐.๐๕	ไม่เกิน ๐.๐๕
๗. สารตะกั่ว (มิลลิกรัมต่อลูกบาศก์เมตร)	ไม่เกิน ๐.๕	ไม่เกิน ๐.๑
๘. สารประกอบไดออกซิน (นาโนกรัมต่อลูกบาศก์เมตร คำนวณในรูปของหน่วยความเข้มข้นเทียบเคียง ความเป็นพิษต่อมนุษย์ (PCDD/Fs as Toxic Equivalent ; I-TEQ)	ไม่เกิน ๐.๑	ไม่เกิน ๐.๑
๙. ค่าความทึบแสง (ร้อยละ)	ไม่เกิน ๑๐	ไม่เกิน ๑๐

ข้อ ๗ ให้ค่าปริมาณสารเจือปนในอากาศที่ระบายออกจากโรงไฟฟ้าเก่า ตามข้อ ๔ (๑) ของประกาศฉบับนี้ มีผลใช้บังคับได้ไม่เกิน วันที่ ๑ มกราคม พ.ศ. ๒๕๗๕ จากนั้นให้ใช้ค่าปริมาณสารเจือปนในอากาศที่ระบายออกจากโรงไฟฟ้าใหม่ตามที่กำหนดในประกาศฉบับนี้บังคับแทน

ข้อ ๘ กรณีโรงไฟฟ้าใช้เชื้อเพลิงร่วมกันตั้งแต่ ๒ ประเภทขึ้นไป ให้คำนวณค่าปริมาณสารเจือปนในอากาศจากผลรวมของค่าปริมาณของสารเจือปนในอากาศของเชื้อเพลิงแต่ละประเภทคูณกับสัดส่วนของความร้อน (Heat Input) ของเชื้อเพลิงประเภทนั้น ๆ

ค่าปริมาณของสารเจือปนในอากาศ = AU + BV + CW + DX + EY + FZ

เมื่อ A = ค่าปริมาณของสารเจือปนในอากาศเมื่อใช้ถ่านหินเป็นเชื้อเพลิงอย่างเดียว

B = ค่าปริมาณของสารเจือปนในอากาศเมื่อใช้น้ำมันเป็นเชื้อเพลิงอย่างเดียว

C = ค่าปริมาณของสารเจือปนในอากาศเมื่อใช้ก๊าซธรรมชาติเป็นเชื้อเพลิงอย่างเดียว

D = ค่าปริมาณของสารเจือปนในอากาศเมื่อใช้เชื้อเพลิงชีวมวลเป็นเชื้อเพลิง อย่างเดียว

E = ค่าปริมาณของสารเจือปนในอากาศเมื่อใช้ก๊าซชีวภาพเป็นเชื้อเพลิงอย่างเดียว

F = ค่าปริมาณของสารเจือปนในอากาศเมื่อใช้ขยะเป็นเชื้อเพลิงอย่างเดียว

U = สัดส่วนของความร้อน (Heat Input) ที่ได้จากเชื้อเพลิงประเภทถ่านหิน

V = สัดส่วนของความร้อน (Heat Input) ที่ได้จากเชื้อเพลิงประเภทน้ำมัน

W = สัดส่วนของความร้อน (Heat Input) ที่ได้จากเชื้อเพลิงประเภทก๊าซธรรมชาติ

X = สัดส่วนของความร้อน (Heat Input) ที่ได้จากเชื้อเพลิงประเภทเชื้อเพลิงชีวมวล

Y = สัดส่วนของความร้อน (Heat Input) ที่ได้จากเชื้อเพลิงประเภทก๊าซชีวภาพ

Z = สัดส่วนของความร้อน (Heat Input) ที่ได้จากเชื้อเพลิงประเภทขยะ

ข้อ ๙ การวัดค่าปริมาณของสารเจือปนในอากาศแต่ละชนิดที่ระบายออกจากโรงไฟฟ้า ให้วัดอากาศที่ระบายออกจากปล่องในขณะประกอบกิจการโรงงาน

ข้อ ๑๐ การตรวจวัดค่าปริมาณสารเจือปนในอากาศแต่ละชนิดที่ระบายออกจากปล่อ โรงไฟฟ้า ให้ใช้วิธี ดังต่อไปนี้

(๑) ฝุ่นละออง ให้ใช้วิธี Determination of Particulate Matter Emissions from Stationary Sources หรือวิธี Determination of Low Level Particulate Matter Emissions from Stationary Sources หรือ Determination of Metals Emissions from Stationary Sources ที่องค์การพิทักษ์สิ่งแวดล้อมแห่งประเทศสหรัฐอเมริกา (United States Environmental Protection Agency) กำหนดไว้ หรือวิธีอื่นที่กรมโรงงานอุตสาหกรรมเห็นชอบ

(๒) ก๊าซซัลเฟอร์ไดออกไซด์ ให้ใช้วิธี Determination of Sulfur Dioxide Emissions from Stationary Sources หรือวิธี Instrumental Analyzer Procedure หรือวิธี Determination of Sulfuric Acid Mist and Sulfur Dioxide Emissions from Stationary Sources ที่องค์การพิทักษ์สิ่งแวดล้อมแห่งประเทศสหรัฐอเมริกา (United States Environmental Protection Agency) กำหนดไว้ หรือวิธีอื่นที่กรมโรงงานอุตสาหกรรมเห็นชอบ

(๓) ก๊าซออกไซด์ของไนโตรเจน ซึ่งคำนวณผลในรูปก๊าซไนโตรเจนไดออกไซด์ ให้ใช้วิธี Determination of Nitrogen Oxide Emissions from Stationary Sources หรือวิธี Determination of Nitrogen Oxide Emissions from Stationary Sources - Ion Chromatographic Method หรือ Ultraviolet Spectrophotometric Method หรือ Alkaline Permanganate/Colorimetric Method หรือ Alkaline - Permanganate/Ion Chromatographic Method หรือ Instrumental

Analyzer Procedure ที่องค์การพิทักษ์สิ่งแวดล้อมแห่งประเทศสหรัฐอเมริกา (United States Environmental Protection Agency) กำหนดไว้ หรือวิธีอื่นที่กรมโรงงานอุตสาหกรรมเห็นชอบ

(๔) ก๊าซไฮโดรเจนคลอไรด์ ให้ใช้วิธี Determination of Hydrogen Halide and Halogen Emissions from Stationary Sources ที่องค์การพิทักษ์สิ่งแวดล้อมแห่งประเทศสหรัฐอเมริกา (United States Environmental Protection Agency) กำหนดไว้ หรือวิธีอื่นที่กรมโรงงานอุตสาหกรรมเห็นชอบ

(๕) สารปรอท สารแคดเมียม และสารตะกั่ว ให้ใช้วิธี Determination of Metals Emissions from Stationary Sources ที่องค์การพิทักษ์สิ่งแวดล้อมแห่งประเทศสหรัฐอเมริกา (United States Environmental Protection Agency) กำหนดไว้หรือวิธีอื่นที่กรมโรงงานอุตสาหกรรมเห็นชอบ

(๖) สารประกอบไดออกซิน ให้ใช้วิธี Determination of Polychlorinated Dibenzo-p-Dioxins and Polychlorinated Dibenzofurans from Stationary Sources ที่องค์การพิทักษ์สิ่งแวดล้อมแห่งประเทศสหรัฐอเมริกา (United States Environmental Protection Agency) กำหนดไว้หรือวิธีอื่นที่กรมโรงงานอุตสาหกรรมเห็นชอบ

(๗) ค่าความทึบแสง ให้ใช้วิธีตรวจวัดด้วยแผนภูมิเขม่าควันของริงเกิลมานน์ตามประกาศกระทรวงอุตสาหกรรม เรื่อง กำหนดค่าปริมาณเขม่าควันที่เจือปนในอากาศที่ระบายออกจากปล่องของหม้อน้ำโรงสีข้าวที่ใช้แกลบเป็นเชื้อเพลิง พ.ศ. ๒๕๔๙ หรือวิธีอื่นที่กรมโรงงานอุตสาหกรรมเห็นชอบ

ข้อ ๑๑ การคำนวณผลการตรวจวัดค่าปริมาณของสารเจือปนในอากาศ ให้คำนวณผลที่ความดัน ๑ บรรยากาศ หรือ ๗๖๐ มิลลิเมตรปรอท อุณหภูมิ ๒๕ องศาเซลเซียส ที่สภาวะแห้ง (Dry Basis) โดยมีปริมาตรออกซิเจนส่วนเกิน (Excess Oxygen) ในการเผาไหม้ร้อยละ ๗

ข้อ ๑๒ ประกาศนี้ใช้บังคับตั้งแต่วันถัดจากวันประกาศในราชกิจจานุเบกษาเป็นต้นไป

ประกาศ ณ วันที่ ๒๔ ธันวาคม พ.ศ. ๒๕๖๗
เอกนัฏ พร้อมพันธุ์
รัฐมนตรีว่าการกระทรวงอุตสาหกรรม

ภาคผนวก ค-2

มาตรฐานคุณภาพอากาศในบรรยากาศทั่วไป

ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ

เรื่อง กำหนดมาตรฐานคุณภาพอากาศในบรรยากาศโดยทั่วไป

พ.ศ. ๒๕๖๙

โดยที่เป็นการสมควรปรับปรุงการกำหนดมาตรฐานคุณภาพอากาศในบรรยากาศโดยทั่วไป ให้เหมาะสมตามความก้าวหน้าในทางวิทยาศาสตร์ เทคโนโลยี และความเปลี่ยนแปลงทางเศรษฐกิจและสังคมของประเทศ เพื่อเป็นเกณฑ์ทั่วไปสำหรับการส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมตามพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. ๒๕๓๕

อาศัยอำนาจตามความในมาตรา ๓๒ (๔) และมาตรา ๓๔ แห่งพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. ๒๕๓๕ และตามคำสั่งสำนักนายกรัฐมนตรี ที่ ๓๐๒/๒๕๖๘ ลงวันที่ ๒๔ กันยายน พ.ศ. ๒๕๖๘ เรื่อง มอบหมายและมอบอำนาจให้รองนายกรัฐมนตรีและรัฐมนตรีประจำสำนักนายกรัฐมนตรี ปฏิบัติหน้าที่ประธานกรรมการ และมอบหมายให้รองนายกรัฐมนตรีและรัฐมนตรีประจำสำนักนายกรัฐมนตรีปฏิบัติหน้าที่ประธานกรรมการ รองประธานกรรมการและกรรมการในคณะกรรมการต่าง ๆ ตามกฎหมาย และระเบียบสำนักนายกรัฐมนตรี ประกอบกับมติคณะกรรมการสิ่งแวดล้อมแห่งชาติ ในการประชุมครั้งที่ ๕/๒๕๖๘ เมื่อวันที่ ๑๕ ตุลาคม พ.ศ. ๒๕๖๘ จึงออกประกาศไว้ ดังต่อไปนี้

ข้อ ๑ ให้ยกเลิก

๑.๑ ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ ฉบับที่ ๑๐ (พ.ศ. ๒๕๓๘) ออกตามความในพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. ๒๕๓๕ เรื่อง กำหนดมาตรฐานคุณภาพอากาศในบรรยากาศโดยทั่วไป ลงวันที่ ๑๗ เมษายน พ.ศ. ๒๕๓๘

๑.๒ ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ ฉบับที่ ๑๒ (พ.ศ. ๒๕๓๘) ออกตามความในพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. ๒๕๓๕ เรื่อง กำหนดมาตรฐานค่าก๊าซซัลเฟอร์ไดออกไซด์ในบรรยากาศโดยทั่วไป ในเวลา ๑ ชั่วโมง ลงวันที่ ๒๖ มิถุนายน พ.ศ. ๒๕๓๘

๑.๓ ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ ฉบับที่ ๒๑ (พ.ศ. ๒๕๔๔) ออกตามความในพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. ๒๕๓๕ เรื่อง กำหนดมาตรฐานค่าก๊าซซัลเฟอร์ไดออกไซด์ในบรรยากาศโดยทั่วไป ในเวลา ๑ ชั่วโมง ลงวันที่ ๙ เมษายน พ.ศ. ๒๕๔๔

๑.๔ ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ ฉบับที่ ๒๔ (พ.ศ. ๒๕๔๗) เรื่อง กำหนดมาตรฐานคุณภาพอากาศในบรรยากาศโดยทั่วไป ลงวันที่ ๙ สิงหาคม พ.ศ. ๒๕๔๗

๑.๕ ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ ฉบับที่ ๒๘ (พ.ศ. ๒๕๕๐) เรื่อง กำหนดมาตรฐานคุณภาพอากาศในบรรยากาศโดยทั่วไป ลงวันที่ ๑๐ เมษายน พ.ศ. ๒๕๕๐

๑.๖ ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ ฉบับที่ ๓๓ (พ.ศ. ๒๕๕๒) เรื่อง กำหนดมาตรฐานค่าก๊าซไนโตรเจนไดออกไซด์ในบรรยากาศโดยทั่วไป ลงวันที่ ๑๗ มิถุนายน พ.ศ. ๒๕๕๒

๑.๗ ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ เรื่อง กำหนดมาตรฐานฝุ่นละอองขนาดไม่เกิน ๒.๕ ไมครอน ในบรรยากาศโดยทั่วไป ลงวันที่ ๒๓ มิถุนายน พ.ศ. ๒๕๖๕

ข้อ ๒ กำหนดค่ามาตรฐานคุณภาพอากาศในบรรยากาศโดยทั่วไปไว้ ดังนี้

๒.๑ ก๊าซซัลเฟอร์ไดออกไซด์

(๑) ค่าเฉลี่ยของก๊าซซัลเฟอร์ไดออกไซด์ ในเวลา ๑ ชั่วโมง จะต้องไม่เกิน ๑๐๐ ส่วนในพันล้านส่วน

(๒) ค่าเฉลี่ยของก๊าซซัลเฟอร์ไดออกไซด์ ในเวลา ๒๔ ชั่วโมง จะต้องไม่เกิน ๕๐ ส่วนในพันล้านส่วน

๒.๒ ก๊าซไนโตรเจนไดออกไซด์

(๑) ค่าเฉลี่ยของก๊าซไนโตรเจนไดออกไซด์ ในเวลา ๑ ชั่วโมง จะต้องไม่เกิน ๑๒๐ ส่วนในพันล้านส่วน

(๒) ค่าเฉลี่ยของก๊าซไนโตรเจนไดออกไซด์ในเวลา ๑ ปี จะต้องไม่เกิน ๓๐ ส่วนในพันล้านส่วน

๒.๓ ก๊าซคาร์บอนมอนอกไซด์

(๑) ค่าเฉลี่ยของก๊าซคาร์บอนมอนอกไซด์ ในเวลา ๑ ชั่วโมง จะต้องไม่เกิน ๓๐ ส่วนในล้านส่วน

(๒) ค่าเฉลี่ยของก๊าซคาร์บอนมอนอกไซด์ ในเวลา ๘ ชั่วโมง จะต้องไม่เกิน ๙ ส่วนในล้านส่วน

๒.๔ ก๊าซโอโซน

(๑) ค่าเฉลี่ยของก๊าซโอโซน ในเวลา ๑ ชั่วโมง จะต้องไม่เกิน ๑๐๐ ส่วนในพันล้านส่วน

(๒) ค่าเฉลี่ยของก๊าซโอโซน ในเวลา ๘ ชั่วโมง จะต้องไม่เกิน ๗๐ ส่วนในพันล้านส่วน

๒.๕ ฝุ่นรวมหรือฝุ่นละอองขนาดไม่เกิน ๑๐๐ ไมครอน

(๑) ค่าเฉลี่ยของฝุ่นรวมหรือฝุ่นละอองขนาดไม่เกิน ๑๐๐ ไมครอน ในเวลา ๒๔ ชั่วโมง จะต้องไม่เกิน ๒๐๐ ไมโครกรัมต่อลูกบาศก์เมตร

(๒) ค่าเฉลี่ยของฝุ่นรวมหรือฝุ่นละอองขนาดไม่เกิน ๑๐๐ ไมครอน ในเวลา ๑ ปี จะต้องไม่เกิน ๘๐ ไมโครกรัมต่อลูกบาศก์เมตร

๒.๖ ฝุ่นละอองขนาดไม่เกิน ๑๐ ไมครอน

(๑) ค่าเฉลี่ยของฝุ่นละอองขนาดไม่เกิน ๑๐ ไมครอน ในเวลา ๒๔ ชั่วโมง จะต้องไม่เกิน ๑๐๐ ไมโครกรัมต่อลูกบาศก์เมตร

(๒) ค่าเฉลี่ยของฝุ่นละอองขนาดไม่เกิน ๑๐ ไมครอน ในเวลา ๑ ปี จะต้องไม่เกิน ๕๐ ไมโครกรัมต่อลูกบาศก์เมตร

๒.๗ ฝุ่นละอองขนาดไม่เกิน ๒.๕ ไมครอน

(๑) ค่าเฉลี่ยของฝุ่นละอองขนาดไม่เกิน ๒.๕ ไมครอน ในเวลา ๒๔ ชั่วโมง จะต้องไม่เกิน ๓๗.๕ ไมโครกรัมต่อลูกบาศก์เมตร

(๒) ค่าเฉลี่ยของฝุ่นละอองขนาดไม่เกิน ๒.๕ ไมครอน ในเวลา ๑ ปี จะต้องไม่เกิน ๑๕ ไมโครกรัมต่อลูกบาศก์เมตร

๒.๘ สารตะกั่ว ค่าเฉลี่ยของสารตะกั่ว ในเวลา ๑ เดือน จะต้องไม่เกิน ๑ ไมโครกรัมต่อลูกบาศก์เมตร

ข้อ ๓ วิธีการตรวจวัดค่าเฉลี่ยของสารมลพิษทางอากาศ ดังนี้

๓.๑ ค่าเฉลี่ยของก๊าซซัลเฟอร์ไดออกไซด์ในเวลา ๑ ชั่วโมง หรือค่าเฉลี่ยในเวลา ๒๔ ชั่วโมง ให้ใช้วิธีพาราโรซานิลีน (Pararosaniline) หรือวิธีอุลตร้าไวโอเลต ฟลูออเรสเซน (Ultraviolet Fluorescence)

๓.๒ ค่าเฉลี่ยของก๊าซไนโตรเจนไดออกไซด์ในเวลา ๑ ชั่วโมง หรือค่าเฉลี่ยในเวลา ๑ ปี ให้ใช้วิธีเคมีลูมิเนสเซน (Chemiluminescence) หรือวิธีคาวิตี แอทเทนนูเอเต็ด เฟสชิฟ สเปกโทรสโกปี (Cavity Attenuated Phase Shift Spectroscopy : CAPS)

๓.๓ ค่าเฉลี่ยของก๊าซคาร์บอนมอนอกไซด์ในเวลา ๑ ชั่วโมง หรือค่าเฉลี่ยในเวลา ๘ ชั่วโมง ให้ใช้วิธีนันดีสเปอร์ซีฟ อินฟราเรด ดีเทคชัน (Non-dispersive Infrared Detection) หรือวิธีนันดีสเปอร์ซีฟ อินฟราเรด ดีเทคชัน ก๊าซฟิลเตอร์คอริเรชัน (Non-dispersive Infrared Detection Gas Filter Correlation)

๓.๔ ค่าเฉลี่ยของก๊าซโอโซนในเวลา ๑ ชั่วโมง หรือค่าเฉลี่ยของก๊าซโอโซนในเวลา ๘ ชั่วโมง ให้ใช้วิธีเคมีลูมิเนสเซน (Chemiluminescence) หรือวิธีอุลตร้าไวโอเลต แอ็บซอปชัน โฟโตเมตตริก (Ultraviolet Absorption Photometry)

๓.๕ ค่าเฉลี่ยของฝุ่นรวมหรือฝุ่นละอองขนาดไม่เกิน ๑๐๐ ไมครอน ในเวลา ๒๔ ชั่วโมง หรือค่าเฉลี่ย ในเวลา ๑ ปี ให้ใช้วิธีตรวจวัดอ้างอิง คือวิธีกราวิเมตริก (Gravimetric)

๓.๖ ค่าเฉลี่ยของฝุ่นละอองขนาดไม่เกิน ๑๐ ไมครอน ในเวลา ๒๔ ชั่วโมง หรือค่าเฉลี่ยในเวลา ๑ ปี ให้ใช้วิธีตรวจวัดอ้างอิง คือวิธีกราวิเมตริก (Gravimetric) หรือวิธีตรวจวัดเทียบเท่า ได้แก่ วิธีเบต้าเรดิเอชัน แอทเทนนูเอชัน (Beta Radiation Attenuation) วิธีเทปเปอร์ อิลิเมนต์ ออสซิเลติง ไมโครบาลานซ์ (Tapered Element Oscillating Microbalance : TEOM)

วิธีการกระเจิงของแสง (Light Scattering) และวิธีเก็บตัวอย่างด้วยเครื่องเก็บตัวอย่างอากาศแบบไดโคโตมัส (Dichotomous Air Sampler)

๓.๗ ค่าเฉลี่ยของฝุ่นละอองขนาดไม่เกิน ๒.๕ ไมครอน ในเวลา ๒๔ ชั่วโมง หรือค่าเฉลี่ยในเวลา ๑ ปี ให้ใช้วิธีตรวจวัดอ้างอิง คือวิธีกราวิเมตริก (Gravimetric) หรือวิธีตรวจวัดเทียบเท่า ได้แก่ วิธีเบต้า เรดิเอชัน แอทเทนนูเอชัน (Beta Radiation Attenuation) วิธีเทปเปอร์ อิลิเมนต์ ออสซิเลติง ไมโครบาลานซ์ (Tapered Element Oscillating Microbalance : TEOM) วิธีการกระเจิงของแสง (Light Scattering) และวิธีเก็บตัวอย่างด้วยเครื่องเก็บตัวอย่างอากาศแบบไดโคโตมัส (Dichotomous Air Sampler)

๓.๘ ค่าเฉลี่ยของสารตะกั่ว ในเวลา ๑ เดือน ให้ใช้วิธีอะตอมมิก แอบซอพชัน สเปคโตรมิเตอร์ (Atomic Absorption Spectrometer)

ข้อ ๔ วิธีการตรวจวัดค่าเฉลี่ยของสารมลพิษทางอากาศตามข้อ ๓ ให้ใช้วิธีตรวจวัดอ้างอิง หรือวิธีตรวจวัดเทียบเท่า ตามที่องค์การพิทักษ์สิ่งแวดล้อมแห่งสหรัฐอเมริกา (United States Environmental Protection Agency : US EPA) หรือมาตรฐานของสหภาพยุโรป (European Union : EU) กำหนด หรือวิธีอื่นตามที่อธิบดีกรมควบคุมมลพิษประกาศในราชกิจจานุเบกษา

ข้อ ๕ การตรวจวัดค่าเฉลี่ยของสารมลพิษทางอากาศให้ดำเนินการ ดังนี้

๕.๑ การตรวจวัดค่าเฉลี่ยของสารมลพิษทางอากาศในข้อ ๓.๑ ถึงข้อ ๓.๔ ให้ทำในบรรยากาศโดยทั่วไป และต้องสูงจากพื้นดินอย่างน้อย ๓ เมตร แต่ไม่เกิน ๖ เมตร ตามวัตถุประสงค์ของการตรวจวัด การคำนวณค่าความเข้มข้นของสารมลพิษทางอากาศให้เทียบที่อุณหภูมิ ๒๕ องศาเซลเซียส และความดัน ๑ บรรยากาศ

๕.๒ การตรวจวัดค่าเฉลี่ยของสารมลพิษทางอากาศในข้อ ๓.๕ ข้อ ๓.๖ และข้อ ๓.๘ ให้ทำในบรรยากาศโดยทั่วไป และต้องสูงจากพื้นดินอย่างน้อย ๑.๕๐ เมตร แต่ไม่เกิน ๖ เมตร ตามวัตถุประสงค์ของการตรวจวัด การคำนวณค่าความเข้มข้นของสารมลพิษทางอากาศให้เทียบที่อุณหภูมิ ๒๕ องศาเซลเซียส และความดัน ๑ บรรยากาศ

๕.๓ การตรวจวัดค่าเฉลี่ยของสารมลพิษทางอากาศในข้อ ๓.๗ ให้ทำในบรรยากาศโดยทั่วไป และต้องสูงจากพื้นดินอย่างน้อย ๑.๕๐ เมตร แต่ไม่เกิน ๑๕ เมตร ตามวัตถุประสงค์ของการตรวจวัด การคำนวณค่าความเข้มข้นของสารมลพิษทางอากาศให้เทียบที่อุณหภูมิและความดันบรรยากาศสภาวะจริง

ข้อ ๖ การคำนวณค่าความเข้มข้นของสารมลพิษทางอากาศตามข้อ ๕ ต้องมีความครบถ้วนสมบูรณ์ของข้อมูล ไม่น้อยกว่าร้อยละ ๗๕

ข้อ ๗ การกำหนดดัชนีคุณภาพอากาศของประเทศไทยสำหรับสารมลพิษทางอากาศตามประกาศนี้ ให้เป็นไปตามหลักเกณฑ์ วิธีการ และเงื่อนไข ที่อธิบดีกรมควบคุมมลพิษประกาศในราชกิจจานุเบกษา

ข้อ ๘ ประกาศนี้ให้ใช้บังคับนับแต่วันถัดจากวันประกาศในราชกิจจานุเบกษา

ประกาศ ณ วันที่ ๖ มกราคม พ.ศ. ๒๕๖๙
สุชาติ ชมกลิ่น
รองนายกรัฐมนตรี
ประธานกรรมการสิ่งแวดล้อมแห่งชาติ

ภาคผนวก ค-3

มาตรฐานระดับเสียงทั่วไป



ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ
ฉบับที่ ๑๕ (พ.ศ. ๒๕๔๐)
เรื่อง กำหนดมาตรฐานระดับเสียงโดยทั่วไป

อาศัยอำนาจตามความในมาตรา ๓๒ (๕) แห่งพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. ๒๕๓๕ คณะกรรมการสิ่งแวดล้อมแห่งชาติกำหนดมาตรฐานระดับเสียงโดยทั่วไปไว้ดังต่อไปนี้

ข้อ ๑ ในประกาศนี้

"ระดับเสียงโดยทั่วไป" หมายความว่า ระดับเสียงที่เกิดขึ้นในสิ่งแวดล้อม

"ค่าระดับเสียงสูงสุด" หมายความว่า ค่าระดับเสียงสูงสุดที่เกิดขึ้นในขณะใดขณะหนึ่งระหว่างการตรวจวัดระดับเสียง โดยมีหน่วยเป็นเดซิเบลเอ หรือ dB (A)

"ค่าระดับเสียงเฉลี่ย ๒๔ ชั่วโมง" หมายความว่า ค่าระดับเสียงคงที่ที่มีพลังงานเทียบเท่าระดับเสียงที่เกิดขึ้นจริง ซึ่งมีระดับเสียงเปลี่ยนแปลงตามเวลาในช่วง ๒๔ ชั่วโมง (๒๔ hours A-weighted Equivalent Continuous Sound Level) ซึ่งเรียกโดยย่อว่า Leq ๒๔ hr โดยมีหน่วยเป็นเดซิเบลเอ หรือ dB (A)

"มาตรระดับเสียง" หมายความว่า เครื่องวัดระดับเสียงตามมาตรฐาน IEC ๖๕๑ หรือ IEC ๘๐๔ ของคณะกรรมาธิการระหว่างประเทศว่าด้วยเทคนิคไฟฟ้า (International Electrotechnical Commission, IEC)

ข้อ ๒ ให้กำหนดมาตรฐานระดับเสียงโดยทั่วไป ไว้ดังต่อไปนี้

(๑) ค่าระดับเสียงสูงสุด ไม่เกิน ๑๑๕ เดซิเบลเอ

(๒) ค่าระดับเสียงเฉลี่ย ๒๔ ชั่วโมง ไม่เกิน ๗๐ เดซิเบลเอ

ข้อ ๓ การตรวจวัดระดับเสียงโดยทั่วไป ให้ดำเนินการดังต่อไปนี้

(๑) การตรวจวัดค่าระดับเสียงสูงสุด ให้ใช้มาตรระดับเสียงตรวจวัดระดับเสียงในบริเวณที่มีคนอยู่หรืออาศัยอยู่

(๒) การตรวจวัดค่าระดับเสียงเฉลี่ย ๒๔ ชั่วโมง ให้ใช้มาตรระดับเสียงตรวจวัดระดับเสียงอย่างต่อเนื่องตลอดเวลา ๒๔ ชั่วโมงใดๆ

(๓) การตั้งไมโครโฟนของมาตรระดับเสียงที่บริเวณภายนอกอาคารให้ตั้งสูงจากพื้นไม่น้อยกว่า ๑.๒๐ เมตร โดยในรัศมี ๓.๕๐ เมตร ตามแนวราบรอบไมโครโฟนต้องไม่มีกำแพงหรือสิ่งอื่นใดที่มีคุณสมบัติในการสะท้อนเสียงกีดขวางอยู่

(๔) การตั้งไมโครโฟนของมาตรระดับเสียงที่บริเวณภายในอาคารให้ตั้งสูงจากพื้นไม่น้อยกว่า ๑.๒๐ เมตร โดยในรัศมี ๑.๐๐ เมตร ตามแนวราบรอบไมโครโฟนต้องไม่มีกำแพงสิ่งอื่นใดที่มีคุณสมบัติในการสะท้อนเสียงกีดขวางอยู่และต้องห่างจากช่องหน้าต่างหรือช่องทางที่เปิดออกนอกอาคารอย่างน้อย ๑.๕๐ เมตร

ข้อ ๔ การคำนวณค่าระดับเสียงจะต้องเป็นไปตามวิธีการที่องค์การระหว่างประเทศว่าด้วยมาตรฐาน (International Organization for Standardization, ISO) กำหนด ซึ่งกรมควบคุมมลพิษจะประกาศในราชกิจจานุเบกษา

ประกาศ ณ วันที่ ๑๒ มีนาคม พ.ศ. ๒๕๔๐

พลเอก ชวลิต ยงใจยุทธ

นายกรัฐมนตรี

ประธานคณะกรรมการสิ่งแวดล้อมแห่งชาติ

(ประกาศในราชกิจจานุเบกษา เล่ม ๑๑๔ ตอนที่ ๒๗ ง วันที่ ๓ เมษายน ๒๕๔๐)

ภาคผนวก ค-4

มาตรฐานคุณภาพน้ำ



ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ
ฉบับที่ ๘ (พ.ศ. ๒๕๓๗)
ออกตามความในพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. ๒๕๓๕
เรื่อง กำหนดมาตรฐานคุณภาพน้ำในแหล่งน้ำผิวดิน

อาศัยอำนาจตามความในมาตรา ๓๒ (๑) แห่งพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. ๒๕๓๕ คณะกรรมการสิ่งแวดล้อมแห่งชาติประกาศกำหนดมาตรฐานคุณภาพน้ำในแหล่งน้ำผิวดิน ไว้ดังต่อไปนี้

หมวด ๑
บททั่วไป

ข้อ ๑ ในประกาศนี้

"แหล่งน้ำผิวดิน" หมายถึง แม่น้ำ ลำคลอง หนอง บึง ทะเลสาบ อ่างเก็บน้ำ และแหล่งน้ำสาธารณะอื่นๆ ที่อยู่ภายในผืนแผ่นดิน ซึ่งหมายความรวมถึงแหล่งน้ำสาธารณะที่อยู่ภายในผืนแผ่นดินบนเกาะด้วย แต่ไม่รวมถึงน้ำบาดาล และในกรณีที่แหล่งน้ำนั้นอยู่ติดกับทะเลให้หมายความถึงแหล่งน้ำที่อยู่ภายในปากแม่น้ำหรือปากทะเลสาบ

ปากแม่น้ำและปากทะเลสาบให้ถือแนวเขตตามที่กรมเจ้าท่ากำหนด

หมวด ๒
ประเภทและมาตรฐานคุณภาพน้ำในแหล่งน้ำผิวดิน

ข้อ ๒ ให้แบ่งแหล่งน้ำผิวดินออกเป็น ๕ ประเภทคือ แหล่งน้ำประเภทที่ ๑ แหล่งน้ำประเภทที่ ๒ แหล่งน้ำประเภทที่ ๓ แหล่งน้ำประเภทที่ ๔ และแหล่งน้ำประเภทที่ ๕

(๑) แหล่งน้ำประเภทที่ ๑ ได้แก่ แหล่งน้ำที่คุณภาพน้ำมีสภาพตามธรรมชาติโดยปราศจากน้ำทิ้งจากกิจกรรมทุกประเภทและสามารถเป็นประโยชน์เพื่อ

(ก) การอุปโภคและบริโภคโดยต้องผ่านการฆ่าเชื้อโรคตามปกติก่อน

(ข) การขยายพันธุ์ตามธรรมชาติของสิ่งมีชีวิตระดับพื้นฐาน

(ค) การอนุรักษ์ระบบนิเวศน์ของแหล่งน้ำ

(๒) แหล่งน้ำประเภทที่ ๒ ได้แก่ แหล่งน้ำที่ได้รับน้ำทิ้งจากกิจกรรมบางประเภทและสามารถเป็นประโยชน์เพื่อ

(ก) การอุปโภคและบริโภคโดยต้องผ่านการฆ่าเชื้อโรคตามปกติและผ่านกระบวนการปรับปรุงคุณภาพน้ำทั่วไปก่อน

(ข) การอนุรักษ์สัตว์น้ำ

(ค) การประมง

(ง) การว่ายน้ำและกีฬาทางน้ำ

(๓) แหล่งน้ำประเภทที่ ๓ ได้แก่ แหล่งน้ำที่ได้รับน้ำทิ้งจากกิจกรรมบางประเภทและสามารถเป็นประโยชน์เพื่อ

(ก) การอุปโภคและบริโภคโดยต้องผ่านการฆ่าเชื้อโรคตามปกติและผ่านกระบวนการปรับปรุงคุณภาพน้ำทั่วไปก่อน

(ข) การเกษตร

(๔) แหล่งน้ำประเภทที่ ๔ ได้แก่ แหล่งน้ำที่ได้รับน้ำทิ้งจากกิจกรรมบางประเภทและสามารถเป็นประโยชน์เพื่อ

(ก) การอุปโภคและบริโภคโดยต้องผ่านการฆ่าเชื้อโรคตามปกติและผ่านกระบวนการปรับปรุงคุณภาพน้ำเป็นพิเศษก่อน

(ข) การอุตสาหกรรม

(๕) แหล่งน้ำประเภทที่ ๕ ได้แก่ แหล่งน้ำที่ได้รับน้ำทิ้งจากกิจกรรมบางประเภท และสามารถเป็นประโยชน์เพื่อการคมนาคม

ข้อ ๓ คุณภาพน้ำในแหล่งน้ำประเภทที่ ๑ ต้องมีสภาพตามธรรมชาติ และสามารถใช้ประโยชน์ได้ตามข้อ ๒ (๑)

ข้อ ๔ คุณภาพน้ำในแหล่งน้ำประเภทที่ ๒ ต้องมีมาตรฐานดังต่อไปนี้

(๑) ไม่มีวัตถุหรือสิ่งของที่เกิดจากการกระทำของมนุษย์ซึ่งจะทำให้ สี กลิ่น และรสของน้ำเปลี่ยนไปตามธรรมชาติ

(๒) อุณหภูมิ (Temperature) ไม่สูงกว่าอุณหภูมิตามธรรมชาติเกิน ๓ องศาเซลเซียส

(๓) ความเป็นกรดและด่าง (pH) มีค่าระหว่าง ๕.๐-๙.๐

(๔) ออกซิเจนละลาย (DO) มีค่าไม่น้อยกว่า ๖.๐ มิลลิกรัมต่อลิตร

(๕) บีโอดี (BOD) มีค่าไม่เกินกว่า ๑.๕ มิลลิกรัมต่อลิตร

(๖) แบคทีเรียกลุ่มโคลิฟอร์มทั้งหมด (Total Coliform Bacteria) มีค่าไม่เกินกว่า ๕,๐๐๐ เอ็ม.พี.เอ็น. ต่อ ๑๐๐ มิลลิลิตร

(๗) แบคทีเรียกลุ่มฟีคอลโคลิฟอร์ม (Fecal Coliform Bacteria) มีค่าไม่เกินกว่า ๑,๐๐๐ เอ็ม.พี.เอ็น. ต่อ ๑๐๐ มิลลิลิตร

(๘) ไนเตรต (NO_3) ในหน่วยไนโตรเจน มีค่าไม่เกินกว่า ๕.๐ มิลลิกรัมต่อลิตร

(๙) แอมโมเนีย (NH_3) ในหน่วยไนโตรเจน มีค่าไม่เกินกว่า ๐.๕ มิลลิกรัมต่อลิตร

(๑๐) ฟีนอล (Phenols) มีค่าไม่เกินกว่า ๐.๐๐๕ มิลลิกรัมต่อลิตร

(๑๑) ทองแดง (Cu) มีค่าไม่เกินกว่า ๐.๑ มิลลิกรัมต่อลิตร

(๑๒) นิคเกิล (Ni) มีค่าไม่เกินกว่า ๐.๑ มิลลิกรัมต่อลิตร

(๑๓) แมงกานีส (Mn) มีค่าไม่เกินกว่า ๑.๐ มิลลิกรัมต่อลิตร

(๑๔) สังกะสี (Zn) มีค่าไม่เกินกว่า ๑.๐ มิลลิกรัมต่อลิตร

(๑๕) แคดเมียม (Cd) ในน้ำที่มีความกระด้างในรูปของ $CaCO_3$ ไม่เกินกว่า ๑๐๐ มิลลิกรัมต่อลิตร มีค่าไม่เกินกว่า ๐.๐๐๕ มิลลิกรัมต่อลิตร และในน้ำที่มีความกระด้างในรูปของ $CaCO_3$ เกินกว่า ๑๐๐ มิลลิกรัมต่อลิตร มีค่าไม่เกินกว่า ๐.๐๕ มิลลิกรัมต่อลิตร

(๑๖) โครเมียมชนิดเฮ็กซาวาเล้นท์ (Cr Hexavalent) มีค่าไม่เกินกว่า ๐.๐๕ มิลลิกรัมต่อลิตร

(๑๗) ตะกั่ว (Pb) มีค่าไม่เกิน ๐.๐๕ มิลลิกรัมต่อลิตร

(๑๘) ปรอททั้งหมด (Total Hg) มีค่าไม่เกินกว่า ๐.๐๐๒ มิลลิกรัมต่อลิตร

(๑๙) สารหนู (As) มีค่าไม่เกินกว่า ๐.๐๑ มิลลิกรัมต่อลิตร

(๒๐) ไซยาไนด์ (Cyanide) มีค่าไม่เกินกว่า ๐.๐๐๕ มิลลิกรัมต่อลิตร

(๒๑) กัมมันตภาพรังสี (Radioactivity) มีค่ารังสีแอลฟา (Alpha) ไม่เกินกว่า ๐.๑ เบคเคอเรลต่อลิตร และรังสีเบตา (Beta) ไม่เกินกว่า ๑.๐ เบคเคอเรลต่อลิตร

(๒๒) สารฆ่าศัตรูพืชและสัตว์ชนิดที่มีคลอรีนทั้งหมด (Total Organochlorine Pesticides) มีค่าไม่เกินกว่า ๐.๐๕ มิลลิกรัมต่อลิตร

(๒๓) ดีดีที (DDT) มีค่าไม่เกินกว่า ๑.๐ ไมโครกรัมต่อลิตร

(๒๔) บีเอชซีชนิดแอลฟา (Alpha-BHC) มีค่าไม่เกินกว่า ๐.๐๒ ไมโครกรัมต่อลิตร

(๒๕) ดิลดริน (Dieldrin) มีค่าไม่เกินกว่า ๐.๑ ไมโครกรัมต่อลิตร

(๒๖) อัลดริน (Aldrin) มีค่าไม่เกินกว่า ๐.๑ ไมโครกรัมต่อลิตร

(๒๗) เฮปตาคลอร์ (Heptachlor) และเฮปตาคลอร์อีปอกไซด์ (Heptachlorepoxide) มีค่าไม่เกินกว่า ๐.๒ ไมโครกรัมต่อลิตร

(๒๘) เอนดริน (Endrin) ไม่สามารถตรวจพบได้ตามวิธีการตรวจสอบที่กำหนด

ข้อ ๕ คุณภาพน้ำในแหล่งน้ำประเภทที่ ๓ ต้องมีมาตรฐานตาม ข้อ ๔ เว้นแต่

(๑) ออกซิเจนละลาย มีค่าไม่น้อยกว่า ๔.๐ มิลลิกรัมต่อลิตร

(๒) บีโอดี มีค่าไม่เกินกว่า ๒.๐ มิลลิกรัมต่อลิตร

(๓) แบคทีเรียกลุ่มโคลิฟอร์มทั้งหมด มีค่าไม่เกินกว่า ๒๐,๐๐๐ เอ็ม.พี.เอ็น. ต่อ ๑๐๐ มิลลิลิตร

(๔) แบคทีเรียกลุ่มฟีคอลโคลิฟอร์ม มีค่าไม่เกินกว่า ๔,๐๐๐ เอ็ม.พี.เอ็น. ต่อ ๑๐๐ มิลลิลิตร

ข้อ ๖ คุณภาพน้ำในแหล่งน้ำประเภทที่ ๔ ต้องมีมาตรฐานตามข้อ ๔ (๑) ถึง (๕) และ (๘) ถึง (๒๘) เว้นแต่

(๑) ออกซิเจนละลาย มีค่าไม่น้อยกว่า ๒.๐ มิลลิกรัมต่อลิตร

(๒) บีโอดี มีค่าไม่เกินกว่า ๔.๐ มิลลิกรัมต่อลิตร

ข้อ ๗ คุณภาพน้ำในแหล่งน้ำประเภทที่ ๕ ต้องมีมาตรฐานต่ำกว่าคุณภาพน้ำ ในแหล่งน้ำประเภทที่ ๔

ข้อ ๘ การกำหนดให้แหล่งน้ำผิวดินแหล่งใดแหล่งหนึ่งเป็นประเภทใดตามข้อ ๒ ให้เป็นไปตามที่กรมควบคุมมลพิษประกาศในราชกิจจานุเบกษา

หมวด ๓

วิธีการเก็บตัวอย่างและตรวจสอบคุณภาพน้ำในแหล่งน้ำผิวดิน

ข้อ ๙ การเก็บตัวอย่างน้ำเพื่อตรวจสอบคุณภาพตามข้อ ๓ ถึง ข้อ ๗ ให้ใช้วิธีการดังต่อไปนี้

(๑) แหล่งน้ำไหล ซึ่งได้แก่ แม่น้ำ ลำคลอง เป็นต้น ให้เก็บที่จุดกึ่งกลางความกว้างของแหล่งน้ำที่ระดับกึ่งกลางความลึก ณ จุดตรวจสอบ เว้นแต่แบคทีเรียกลุ่มโคลิฟอร์มทั้งหมดและแบคทีเรียกลุ่มฟีคอลโคลิฟอร์ม ให้เก็บที่ระดับความลึก ๓๐ เซนติเมตร ณ จุดตรวจสอบ

(๒) แหล่งน้ำนิ่ง ซึ่งได้แก่ ทะเลสาบ หนอง บึง อ่างเก็บน้ำ เป็นต้น ให้เก็บที่ระดับความลึก ๑ เมตร ณ จุดตรวจสอบสำหรับแหล่งน้ำที่มีความลึกเกินกว่า ๒ เมตร และให้เก็บที่จุดกึ่งกลางความลึก ณ จุดตรวจสอบสำหรับแหล่งน้ำที่มีความลึกไม่เกิน ๒ เมตร เว้นแต่แบคทีเรียกลุ่มโคลิฟอร์มทั้งหมดและแบคทีเรียกลุ่มฟีคอลโคลิฟอร์ม ให้เก็บที่ระดับความลึก ๓๐ เซนติเมตร ณ จุดตรวจสอบ

จุดตรวจสอบตาม (๑) และ (๒) ของแหล่งน้ำที่กำหนดตามข้อ ๘ ให้เป็นไปตามที่กรมควบคุมมลพิษกำหนด

ข้อ ๑๐ การตรวจสอบคุณภาพน้ำตามข้อ ๓ ถึงข้อ ๗ ให้ใช้วิธีการดังต่อไปนี้

(๑) การตรวจสอบอุณหภูมิ ให้ใช้เครื่องวัดอุณหภูมิ (Thermometer) วัดขณะทำการเก็บตัวอย่างน้ำ

(๒) การตรวจสอบค่าความเป็นกรดและด่าง ให้ใช้เครื่องวัดความเป็นกรดและด่างของน้ำ (pH meter) ตามวิธีการหาค่าแบบอีเล็คโตรเมตริก (Electrometric)

(๓) การตรวจสอบค่าออกซิเจนละลาย ให้ใช้วิธีอะไซด์โมดิฟิเคชั่น (Azide Modification)

(๔) การตรวจสอบค่าบีโอดี ให้ใช้วิธีอะไซด์โมดิฟิเคชั่น (Azide Modification) ที่อุณหภูมิ ๒๐ องศาเซลเซียส เป็นเวลา ๕ วันติดต่อกัน

(๕) การตรวจสอบค่าแบคทีเรียกลุ่มโคลิฟอร์มทั้งหมดและค่าแบคทีเรียกลุ่มฟีคอลโคลิฟอร์ม ให้ใช้วิธีมัลติเพิ้ล ทิ้วบ์ เฟอร์เมนเตชั่น เทคนิค (Multiple Tube Fermentation Technique)

(๖) การตรวจสอบค่าไนเตรตในหน่วยไนโตรเจน ให้ใช้วิธีแคดเมียมรีดัคชั่น (Cadmium Reduction)

(๗) การตรวจสอบค่าแอมโมเนียในหน่วยไนโตรเจน ให้ใช้วิธีดิสทิลเลชั่น เนสสเลอร์ไรเซชั่น (Distillation Nesslerization)

(๘) การตรวจสอบค่าฟีนอล ให้ใช้วิธีดิสทิลเลชั่น ๔ - อะมิโนแอนติไพรีน (Distillation, 4-Amino antipyrene)

(๙) การตรวจสอบค่าทองแดง นิคเกิล แมงกานีส สังกะสี แคดเมียม โครเมียมชนิดเฮ็กซาวาเล้นท์ และตะกั่ว ให้ใช้วิธีอะตอมมิค แอบซอพชั่น ไดเร็ค แอสไพเรชั่น (Atomic Absorption - Direct Aspiration)

(๑๐) การตรวจสอบค่าปรอททั้งหมด ให้ใช้วิธีอะตอมมิค แอบซอพชั่น โคลด์เวเปอร์ เทคนิค (Atomic Absorption-Cold Vapour Technique)

(๑๑) การตรวจสอบค่าสารหนู ให้ใช้วิธีอะตอมมิค แอบซอพชั่น แก๊สซัส ไฮไดรด์ (Atomic Absorption - Gaseous Hydride)

(๑๒) การตรวจสอบค่าไซยาไนด์ ให้ใช้วิธีไพริดีน บาร์บิทูริค แอซิด (Pyridine - Barbituric Acid)

(๑๓) การตรวจสอบค่ากัมมันตภาพรังสี ให้ใช้วิธีโลว์ แบ็คกราวด์ พร็อพพอร์ชั่นนอล เคาน์เตอร์ (Low Background Proportional Counter)

(๑๔) การตรวจค่าสารฆ่าศัตรูพืชและสัตว์ชนิดที่มีคลอรีนทั้งหมด ดีดีที บีเอชซีชนิดแอลฟา ดิลดริน อัลดริน เฮปตาคลอร์อีปอกไซด์ และเอนดริน ให้ใช้วิธีก๊าซ - โครมาโตกราฟี่ (Gas - Chromatography)

ข้อ ๑๑ การตรวจสอบค่าออกซิเจนละลายให้ใช้ค่าเปอร์เซ็นไทล์ที่ ๒๐ (20th Percentile Value) ส่วนการตรวจสอบค่าบีโอดี แบคทีเรียกลุ่มโคลิฟอร์มทั้งหมด และแบคทีเรียกลุ่มฟีคอลโคลิฟอร์ม ให้ใช้ค่าเปอร์เซ็นไทล์ที่ ๘๐ โดยจำนวนและระยะเวลาสำหรับการเก็บตัวอย่างน้ำดังกล่าว ให้เป็นไปตามที่กรมควบคุมมลพิษกำหนด

ข้อ ๑๒ การเก็บตัวอย่างน้ำตามข้อ ๙ และการตรวจสอบคุณภาพน้ำตามข้อ ๑๐ จะต้องเป็นไปตามวิธีการมาตรฐานสำหรับการวิเคราะห์น้ำและน้ำเสีย (Standard Methods for Examination of Water and Wastewater) ซึ่ง American Public Health Association และ American Water Works Association กับ Water Pollution Control Federation ของสหรัฐอเมริกา ร่วมกันกำหนดไว้ด้วย

ประกาศ ณ วันที่ ๒๐ มกราคม พ.ศ. ๒๕๓๗

ชวน หลีกภัย

นายกรัฐมนตรี

ประธานคณะกรรมการสิ่งแวดล้อมแห่งชาติ

(ประกาศในราชกิจจานุเบกษา เล่ม ๑๑๑ ตอนที่ ๑๖ ง วันที่ ๒๔ กุมภาพันธ์ ๒๕๓๗)



ประกาศกระทรวงอุตสาหกรรม
เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากโรงงาน
พ.ศ.๒๕๖๐

.....

โดยที่เป็นการสมควรปรับปรุงการกำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากการประกอบกิจการโรงงาน เพื่อให้มีค่ามาตรฐานและวิธีการตรวจสอบน้ำทิ้งจากโรงงานให้เหมาะสมและเป็นไปตามมาตรฐานสากล รวมถึงเป็นการควบคุมการระบายน้ำทิ้งจากโรงงาน อาศัยอำนาจตามความในข้อ ๑๔ แห่งกฎกระทรวงฉบับที่ ๒ (พ.ศ.๒๕๓๕) ออกตามความในพระราชบัญญัติโรงงาน พ.ศ. ๒๕๓๕ ที่ระบุว่า "ห้ามระบายน้ำทิ้งออกจากโรงงาน เว้นแต่ได้ทำการอย่างใดอย่างหนึ่งหรือหลายอย่างจนน้ำทิ้งนั้นมีลักษณะเป็นไปตามที่รัฐมนตรีกำหนดโดยประกาศในราชกิจจานุเบกษา แต่ทั้งนี้ต้องไม่ใช้วิธีทำให้เจือจาง (dilution)" รัฐมนตรีว่าการกระทรวงอุตสาหกรรมจึงออกประกาศ ดังต่อไปนี้

ข้อ ๑ ประกาศนี้เรียกว่า " ประกาศกระทรวงอุตสาหกรรม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากโรงงาน พ.ศ.๒๕๖๐ "

ข้อ ๒ ประกาศนี้ใช้บังคับตั้งแต่วันที่ ๗ มิถุนายน พ.ศ.๒๕๖๐ เป็นต้นไป

ข้อ ๓ ให้ยกเลิกประกาศกระทรวงอุตสาหกรรม ฉบับที่ ๒ (พ.ศ. ๒๕๓๙) ออกตามความในพระราชบัญญัติโรงงาน พ.ศ.๒๕๓๕ เรื่อง กำหนดคุณลักษณะของน้ำทิ้งที่ระบายออกจากโรงงาน ลงวันที่ ๑๔ มิถุนายน พ.ศ.๒๕๓๙

ข้อ ๔ ในประกาศนี้

"โรงงาน" หมายความว่า โรงงานจำพวกที่ ๑ จำพวกที่ ๒ จำพวกที่ ๓ ตามกฎหมายว่าด้วยโรงงาน

"น้ำทิ้ง" หมายความว่า น้ำที่เกิดจากการประกอบกิจการโรงงาน น้ำจากการใช้น้ำของคนงานหรือน้ำจากกิจกรรมอื่นในโรงงาน ที่จะระบายออกจากโรงงาน หรือเขตประกอบการอุตสาหกรรม

ข้อ ๕ มาตรฐานน้ำทิ้ง ต้องมีคุณภาพดังต่อไปนี้

๕.๑ ความเป็นกรดและด่าง (pH) ตั้งแต่ ๕.๕ ถึง ๙.๐

๕.๒ อุณหภูมิ (Temperature) ไม่เกิน ๔๐ องศาเซลเซียส

๕.๓ สี (Color) ไม่เกิน ๓๐๐ เอดีเอ็มไอ

๕.๔ ของแข็งละลายน้ำทั้งหมด (Total Dissolved Solids หรือ TDS) มีค่าดังนี้

(๑) กรณีระบายลงแหล่งน้ำ ต้องไม่เกิน ๓,๐๐๐ มิลลิกรัมต่อลิตร

(๒) กรณีระบายลงแหล่งน้ำที่มีค่าของแข็งละลายน้ำทั้งหมดเกินกว่า ๓,๐๐๐ มิลลิกรัมต่อลิตร ค่าของแข็งละลายน้ำทั้งหมดในน้ำทิ้งที่จะระบายได้ต้องมีค่าเกินกว่าค่าของแข็งละลายน้ำทั้งหมดที่มีอยู่ในแหล่งน้ำนั้นไม่เกิน ๕,๐๐๐ มิลลิกรัมต่อลิตร

๕.๕ ของแข็งแขวนลอยทั้งหมด (Total Suspended Solids) ไม่เกิน ๕๐ มิลลิกรัมต่อลิตร

๕.๖ บีโอดี (Biochemical Oxygen Demand) ไม่เกิน ๒๐ มิลลิกรัมต่อลิตร

๕.๗ ซีโอดี (Chemical Oxygen Demand) ไม่เกิน ๑๒๐ มิลลิกรัมต่อลิตร

๕.๘ ซัลไฟด์ (Sulfide) ไม่เกิน ๑ มิลลิกรัมต่อลิตร

/๕.๙ ไซยาไนด์...

๕.๙ ไซยาไนด์ (Cyanides CN) ไม่เกิน ๐.๒ มิลลิกรัมต่อลิตร

๕.๑๐ น้ำมันและไขมัน (Oil and Grease) ไม่เกิน ๕ มิลลิกรัมต่อลิตร

๕.๑๑ ฟอร์มาลดีไฮด์ (Formaldehyde) ไม่เกิน ๑ มิลลิกรัมต่อลิตร

๕.๑๒ สารประกอบฟีนอล (Phenols) ไม่เกิน ๑ มิลลิกรัมต่อลิตร

๕.๑๓ คลอรีนอิสระ (Free Chlorine) ไม่เกิน ๑ มิลลิกรัมต่อลิตร

๕.๑๔ สารฆ่าศัตรูพืชและสัตว์ (Pesticide) ต้องตรวจไม่พบ

๕.๑๕ ทีเคเอ็น (Total Kjeldahl Nitrogen) ไม่เกิน ๑๐๐ มิลลิกรัมต่อลิตร

๕.๑๖ โลหะหนัก มีค่าดังนี้

(๑) สังกะสี (Zn) ไม่เกิน ๕.๐ มิลลิกรัมต่อลิตร

(๒) โครเมียมเฮกซะวาเลนท์ (Hexavalent Chromium) ไม่เกิน ๐.๒๕ มิลลิกรัมต่อลิตร

(๓) โครเมียมไตรวาเลนท์ (Trivalent Chromium) ไม่เกิน ๐.๗๕ มิลลิกรัมต่อลิตร

(๔) สารหนู (As) ไม่เกิน ๐.๒๕ มิลลิกรัมต่อลิตร

(๕) ทองแดง (Cu) ไม่เกิน ๒.๐ มิลลิกรัมต่อลิตร

(๖) ปรอท (Hg) ไม่เกิน ๐.๐๐๕ มิลลิกรัมต่อลิตร

(๗) แคดเมียม (Cd) ไม่เกิน ๐.๐๓ มิลลิกรัมต่อลิตร

(๘) แบเรียม (Ba) ไม่เกิน ๑.๐ มิลลิกรัมต่อลิตร

(๙) ซีลีเนียม (Se) ไม่เกิน ๐.๐๒ มิลลิกรัมต่อลิตร

(๑๐) ตะกั่ว (Pb) ไม่เกิน ๐.๒ มิลลิกรัมต่อลิตร

(๑๑) นิกเกิล (Ni) ไม่เกิน ๑.๐ มิลลิกรัมต่อลิตร

(๑๒) แมงกานีส (Mn) ไม่เกิน ๕.๐ มิลลิกรัมต่อลิตร

ข้อ ๖ การตรวจสอบค่ามาตรฐานน้ำทิ้งจากโรงงาน ตามข้อ ๕ ให้ใช้วิธีดังต่อไปนี้

๖.๑ ความเป็นกรดและด่าง ให้ใช้เครื่องวัดความเป็นกรดและด่างของน้ำ (pH Meter) ที่มีความละเอียดไม่ต่ำกว่า ๐.๑ หน่วย

๖.๒ อุณหภูมิ ให้ใช้เครื่องวัดอุณหภูมิวัดขณะทำการเก็บตัวอย่าง

๖.๓ สี ให้ใช้วิธีเอดีเอ็มไอ (ADMI Method)

๖.๔ ของแข็งละลายน้ำทั้งหมด ให้ใช้วิธีระเหยตัวอย่างที่กรองผ่านกระดาษกรองใยแก้ว (Glass Fiber Filter Disk) และอบแห้งที่อุณหภูมิ ๑๘๐ องศาเซลเซียส เป็นเวลาอย่างน้อย ๑ ชั่วโมง

๖.๕ ของแข็งแขวนลอยทั้งหมด ให้ใช้วิธีกรองผ่านกระดาษกรองใยแก้ว (Glass Fiber Filter) และอบแห้งที่อุณหภูมิ ๑๐๓ – ๑๐๕ องศาเซลเซียส เป็นเวลาอย่างน้อย ๑ ชั่วโมง

๖.๖ บีโอดี ให้ใช้วิธีบ่มตัวอย่างที่อุณหภูมิ ๒๐ องศาเซลเซียส เป็นเวลา ๕ วันติดต่อกัน และหาค่าออกซิเจนละลายด้วยวิธีเอไซด์โมดิฟิเคชั่น (Azide Modification) หรือวิธีเมมเบรนอิเลคโทรด (Membrane Electrode)

๖.๗ ซีโอดี ให้ใช้วิธีย่อยสลายโดยใช้โพแทสเซียมไดโครเมต (Potassium Dichromate)

๖.๘ ซัลไฟด์ ให้ใช้วิธีไอโอโดเมตริก (Iodometric Method) หรือวิธีเมทิลีนบลู (Methylene Blue Method)

/๖.๙ ไซยาไนด์...

๖.๙ ไซยาไนด์ ให้ใช้การกลั่น (Distillation) และตรวจวัดด้วยวิธีเทียบสี (Colorimetric Method) หรือวิธี Flow Injection Analysis

๖.๑๐ น้ำมันและไขมัน ให้ใช้วิธีสกัดด้วยเทคนิค Liquid – Liquid Extraction หรือ Soxhlet Extraction ด้วยตัวทำละลายแล้วแยกหาน้ำหนักของน้ำมันและไขมัน

๖.๑๑ ฟอร์มาลดีไฮด์ ให้ใช้วิธีเทียบสี (Colorimetric Method)

๖.๑๒ สารประกอบฟีนอล ให้ใช้การกลั่น (Distillation) และตรวจวัดด้วยวิธีเทียบสี (Colorimetric Method)

๖.๑๓ คลอรีนอิสระ ให้ใช้วิธีไตเตรท (Titrimetric Method) หรือวิธีเทียบสี (Colorimetric Method)

๖.๑๔ สารฆ่าศัตรูพืชและสัตว์ ให้ใช้วิธีก๊าซโครมาโตกราฟิค (Gas-Chromatographic Method) หรือวิธีไฮเพอร์ฟอร์แมนซ ลิควิด โครมาโตกราฟิค (High-Performance Liquid Chromatographic Method)

๖.๑๕ ทีเคเอ็น ให้ใช้วิธีเจลดาห์ล (Kjeldahl)

๖.๑๖ โลหะหนัก

(๑) สังกะสี ทองแดง แคดเมียม แบเรียม ตะกั่ว นิกเกิลและแมงกานีส ให้ใช้วิธีย่อยสลายตัวอย่างด้วยกรด (Acid digestion) และวัดหาปริมาณโลหะด้วยวิธีอะตอมมิคแอบซอฟชั่น สเปคโตรเมตตรี (Atomic Absorption Spectrometry : AAS) หรือวิธีอินดักทีฟลีคัพเพิลพลาสม่า (Inductively Coupled Plasma)

(๒) โครเมียม

ก) โครเมียมทั้งหมด ให้ใช้วิธีย่อยสลายตัวอย่างด้วยกรด (Acid digestion) และวัดหาปริมาณโลหะด้วยวิธีอะตอมมิคแอบซอฟชั่นสเปคโตรเมตตรี (Atomic Absorption Spectrometry : AAS) หรือวิธีอินดักทีฟลีคัพเพิลพลาสม่า (Inductively Coupled Plasma)

ข) โครเมียมเฮกซะวาเลนท์ ให้ใช้วิธีเทียบสี (Colorimetric Method) หรือวิธีสกัดและตรวจวัดด้วยวิธีอะตอมมิคแอบซอฟชั่นสเปคโตรเมตตรี (Atomic Absorption Spectrometry: AAS) หรือวิธีสกัดและตรวจวัดด้วยวิธีอินดักทีฟลีคัพเพิลพลาสม่า (Inductively Coupled Plasma)

ค) โครเมียมไตรวาเลนท์ ให้ใช้วิธีคำนวณจากค่าส่วนต่างของโครเมียมทั้งหมดกับโครเมียมเฮกซะวาเลนท์

(๓) สารหนูและซีลีเนียม ให้ใช้วิธีอะตอมมิคแอบซอฟชั่นสเปคโตร์โฟโตเมตตรี (Atomic Absorption Spectrophotometry) ชนิดไฮไดรด์เจนเนอเรชั่น (Hydride Generation) หรือวิธีอินดักทีฟลี คัพเพิลพลาสม่า (Inductively Coupled Plasma)

(๔) ปรอท ให้ใช้วิธีโคลด์เวเปอร์อะตอมมิคแอบซอฟชั่นสเปคโตรเมตตรี (Cold Vapor Atomic Absorption Spectrometry) หรือวิธีโคลด์เวเปอร์อะตอมมิคฟลูออเรสเซนซ์สเปคโตรเมตตรี (Cold Vapor Atomic Fluorescence Spectrometry) หรือวิธีอินดักทีฟลีคัพเพิลพลาสม่า (Inductively Coupled Plasma)

ข้อ ๗ การตรวจสอบค่ามาตรฐานน้ำทิ้งจากโรงงาน ตามข้อ ๖ ให้เป็นไปตามคู่มือวิเคราะห์น้ำและน้ำเสียของสมาคมวิศวกรรมสิ่งแวดล้อมแห่งประเทศไทย หรือ Standard Methods for the Examination of Water and Wastewater ซึ่ง American Public Health Association, American Water Work

/ Association ...

Association และ Water Environment Federation ของประเทศสหรัฐอเมริกากำหนด หรือตามที่กรมโรงงานอุตสาหกรรมกำหนด

ข้อ ๘ การเก็บตัวอย่างน้ำทิ้งเพื่อการตรวจสอบค่ามาตรฐาน ตามข้อ ๕ ให้เป็นดังต่อไปนี้

๘.๑ จุดเก็บตัวอย่าง ให้เก็บในจุดระบายทิ้งออกจากโรงงาน ไม่ว่าจะมีจุดเดียวหรือหลายจุดก็ตาม หรือจุดอื่นที่สามารถใช้เป็นตัวแทนของน้ำทิ้งที่ระบายออกจากโรงงาน กรณีมีการระบายทิ้งหลายจุดให้เก็บทุกจุด

๘.๒ วิธีการเก็บตัวอย่างน้ำทิ้ง ณ จุดเก็บตัวอย่างตาม ๘.๑ ให้เก็บแบบจ้วง (Grab Sample)

ข้อ ๙ การกำหนดค่ามาตรฐานน้ำทิ้งให้แตกต่างไปจากข้อ ๕ สำหรับโรงงานในประเภทหรือชนิดใดเป็นการเฉพาะให้เป็นไปตามประกาศกรมโรงงานอุตสาหกรรม

ข้อ ๑๐ ให้ประกาศกรมโรงงานอุตสาหกรรม (พ.ศ.๒๕๓๙) เรื่อง กำหนดคุณลักษณะน้ำทิ้งที่ระบายออกนอกโรงงานให้มีค่าแตกต่างจากที่กำหนดไว้ในประกาศกระทรวงอุตสาหกรรม ฉบับที่ ๒ (พ.ศ. ๒๕๓๙) เรื่อง กำหนดคุณลักษณะของน้ำทิ้งที่ระบายออกจากโรงงาน ลงวันที่ ๑๘ กุมภาพันธ์ พ.ศ. ๒๕๔๐ ยังคงบังคับใช้ได้ต่อไปจนกว่าจะได้มีการยกเลิก

ประกาศ ณ วันที่ ๓๐ พฤษภาคม พ.ศ. ๒๕๖๐

(นายอุตตม สาวนายน)
รัฐมนตรีว่าการกระทรวงอุตสาหกรรม

ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม

เรื่อง กำหนดหลักเกณฑ์และมาตรการในทางวิชาการสำหรับการป้องกันด้านสาธารณสุขและการป้องกันในเรื่องสิ่งแวดล้อมเป็นพิษ

พ.ศ. ๒๕๕๑

ด้วยปัจจุบัน กรมทรัพยากรน้ำบาดาล ได้ส่งเสริมและพัฒนาความรู้ความสามารถของช่างเจาะน้ำบาดาลทั้งของรัฐและเอกชน ให้มีประสิทธิภาพเพียงพอด้านวิชาการน้ำบาดาล จึงสมควรปรับปรุงหลักเกณฑ์การเลิกใช้น้ำบาดาลให้เหมาะสมและสอดคล้องกับสถานการณ์ในปัจจุบัน อาศัยอำนาจตามความในมาตรา ๖ (๑) แห่งพระราชบัญญัติน้ำบาดาล พ.ศ. ๒๕๒๐ รัฐมนตรีว่าการกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม โดยคำแนะนำของคณะกรรมการน้ำบาดาล ออกประกาศกำหนดหลักเกณฑ์และมาตรการในทางวิชาการสำหรับการป้องกันด้านสาธารณสุขและการป้องกันในเรื่องสิ่งแวดล้อมเป็นพิษไว้ ดังต่อไปนี้

ข้อ ๑ ให้ยกเลิกประกาศกระทรวงอุตสาหกรรม ฉบับที่ ๑๒ (พ.ศ. ๒๕๔๒) ออกตามความในพระราชบัญญัติน้ำบาดาล พ.ศ. ๒๕๒๐

ข้อ ๒ การป้องกันน้ำภายนอกไหลลงบ่อน้ำบาดาล

(๑) บ่อน้ำบาดาลทุกบ่อ ต้องผนึกข้างบ่อตั้งแต่ดอนบนสุดนับจากผิวดินลึกลงไปไม่น้อยกว่า ๖ เมตร ด้วยซีเมนต์ล้วนหรือซีเมนต์ผสมทราย เพื่อป้องกันมิให้น้ำภายนอกไหลซึมลงข้างท่อกรุ

(๒) ในกรณีที่บ่อน้ำบาดาลอยู่ในที่ลุ่มหรืออยู่ต่ำกว่าบริเวณข้างเคียงจะต้องปรับบริเวณที่ตั้งบ่อให้สูงกว่าบริเวณข้างเคียงเพื่อป้องกันมิให้น้ำจากภายนอกไหลเข้ามาในบริเวณที่ตั้งบ่อ

(๓) ในกรณีที่บ่อน้ำบาดาลติดตั้งเครื่องสูบน้ำไฟฟ้า ต้องทำลานคอนกรีตเป็นขานบ่อรอบปากบ่อน้ำบาดาลหนาไม่น้อยกว่า ๑๕ เซนติเมตร คลุมพื้นที่ไม่น้อยกว่า ๑ ตารางเมตร ส่วนในกรณีที่บ่อน้ำบาดาลติดตั้งเครื่องสูบน้ำมือโยก ต้องทำลานคอนกรีตเป็นขานบ่อรอบปากบ่อน้ำบาดาลหนาไม่น้อยกว่า ๑๕ เซนติเมตร คลุมพื้นที่ไม่น้อยกว่า ๔ ตารางเมตร และรอบขานบ่อจะต้องมีทางระบายน้ำออกจากบริเวณบ่อ

(๔) ในกรณีที่จะระงับการใช้บ่อน้ำบาดาลชั่วคราวโดยการถอดถอนเครื่องสูบน้ำออกไป จะต้องปิดปากบ่อให้แน่นหนา เพื่อป้องกันมิให้สิ่งหนึ่งสิ่งใดตกลงไปในบ่อ

ข้อ ๓ คุณภาพของน้ำบาดาลที่จะใช้บริโภคได้

(๑) น้ำบาดาลที่จะใช้บริโภคต้องเป็นน้ำที่ได้ผ่านการวิเคราะห์คุณลักษณะจากกรมทรัพยากรน้ำบาดาลหรือส่วนราชการอื่น หรือองค์การของรัฐที่มีหน้าที่เกี่ยวกับการวิเคราะห์คุณลักษณะของน้ำ หรือสถาบันอื่นที่ได้รับการรับรองคุณภาพมาตรฐาน มอก. 1300 - 2537 (ISO / IEC Guide 25) หรือสถาบันที่กรมทรัพยากรน้ำบาดาลให้ความเห็นชอบตามหลักเกณฑ์ วิธีการ และเงื่อนไขที่กรมทรัพยากรน้ำบาดาลกำหนด

(๒) น้ำบาดาลที่จะใช้บริโภค ต้องเป็นน้ำบาดาลที่มีคุณลักษณะทางกายภาพ และคุณลักษณะทางเคมีไม่เกินเกณฑ์อนุโลมสูงสุดตามที่กำหนดไว้ในมาตรฐานน้ำบาดาลที่จะใช้บริโภคได้ ท้ายประกาศนี้

(๓) ในท้องที่ที่กรมทรัพยากรน้ำบาดาลกำหนด ต้องทำการวิเคราะห์หาคุณลักษณะที่เป็นพิษโดยให้มีปริมาณไม่เกินเกณฑ์อนุโลมสูงสุดตามที่กำหนดไว้ในมาตรฐานน้ำบาดาล ที่จะใช้บริโภคได้ ท้ายประกาศนี้

(๔) ในกรณีที่มีความจำเป็นกรมทรัพยากรน้ำบาดาล อาจสั่งให้วิเคราะห์คุณลักษณะทางบัคเตรี/แบคทีเรียก็ได้ โดยต้องมีคุณลักษณะทางบัคเตรี/แบคทีเรีย ไม่เกินเกณฑ์กำหนดที่เหมาะสมตามที่กำหนดไว้ท้ายประกาศนี้

ข้อ ๔ การฆ่าจุลินทรีย์ในบ่อน้ำบาดาล

(๑) หลังการเจาะน้ำบาดาล หรือหลังการติดตั้งเครื่องสูบน้ำบาดาล หรือหลังการซ่อมส่วนประกอบของเครื่องสูบน้ำบาดาลที่อยู่ในบ่อน้ำบาดาล ต้องทำการฆ่าจุลินทรีย์ในบ่อน้ำบาดาลที่จะใช้น้ำเพื่อการอุปโภคบริโภค

(๒) การฆ่าเชื้อจุลินทรีย์ในบ่อน้ำบาดาลให้กระทำโดยการกวนน้ำในบ่อน้ำบาดาล โดยใช้ปูนคลอรีน หรือก๊าซคลอรีน เป็นตัวยาฆ่าเชื้อจุลินทรีย์ โดยให้มีความเข้มข้นของคลอรีนไม่น้อยกว่า ๕๐ มิลลิกรัมต่อลิตร

(๓) ภายหลังการกวนน้ำในบ่อน้ำบาดาลตาม (๒) ต้องปล่อยทิ้งไว้ไม่น้อยกว่า ๑๒ ชั่วโมง แล้วสูบน้ำในบ่อน้ำบาดาลออกทิ้งจนหมดกลิ่นคลอรีน

ข้อ ๕ เครื่องสูบน้ำบาดาล

(๑) ต้องล้างอุปกรณ์หรือชิ้นส่วนของเครื่องสูบน้ำให้สะอาดก่อนใส่ลงไปในบ่อน้ำบาดาล

(๒) ในการติดตั้งเครื่องสูบน้ำทุกชนิด จะต้องอุดช่องที่ปากบ่อน้ำบาดาลระหว่างเครื่องสูบน้ำกับตัวบ่อน้ำบาดาลให้แน่น เพื่อป้องกันมิให้น้ำ หรือมลสารอื่นใดจากภายนอกเข้าไปในบ่อน้ำบาดาลได้

ข้อ ๖ การเลิกใช้น้ำบาดาล

(๑) บ่อน้ำบาดาลที่เลิกใช้แล้ว ต้องอุดกลบด้วยซีเมนต์หรือดินเหนียวบริสุทธิ์ หรือวัสดุอื่นตามที่กรมทรัพยากรน้ำบาดาลกำหนด โดยคำแนะนำของคณะกรรมการน้ำบาดาล

การอุดกลบบ่อน้ำบาดาลด้วยวัสดุตามวรรคหนึ่ง ต้องอุดกลบตั้งแต่ก้นบ่อจนถึงปากบ่อตามหลักเกณฑ์ วิธีการ และเงื่อนไขที่กรมทรัพยากรน้ำบาดาลกำหนด โดยมีช่างเจาะน้ำบาดาลเป็นผู้ควบคุม รับผิดชอบในการอุดกลบบ่อน้ำบาดาล ทั้งนี้ ต้องดำเนินการภายใต้การกำกับ ดูแลของพนักงานน้ำบาดาลประจำท้องที่ หรือพนักงานเจ้าหน้าที่ผู้ซึ่งพนักงานน้ำบาดาลประจำท้องที่มอบหมาย

(๒) ช่างเจาะน้ำบาดาลตาม (๑) ต้องเป็นผู้ที่อธิบดีกรมทรัพยากรน้ำบาดาล ออกหนังสือรับรองให้ ตามหลักเกณฑ์ วิธีการ และเงื่อนไขที่อธิบดีกรมทรัพยากรน้ำบาดาลกำหนด

(๓) ต้องจัดทำรายงานการอุดกลบบ่อน้ำบาดาล ตามแบบที่กรมทรัพยากรน้ำบาดาลกำหนด แล้วส่งรายงานดังกล่าวให้พนักงานน้ำบาดาลประจำท้องที่ภายใน ๗ วัน นับแต่วันอุดกลบบ่อน้ำบาดาลแล้วเสร็จ

ประกาศ ณ วันที่ ๒๔ มีนาคม พ.ศ. ๒๕๕๑
อนงค์วรรณ เทพสุทิน
รัฐมนตรีว่าการกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม

มาตรฐานน้ำบาดาลที่จะใช้บริโภคได้

คุณลักษณะทางกายภาพ

รายการ	เกณฑ์กำหนดที่เหมาะสม	เกณฑ์อนุโลมสูงสุด
สี (Color)	5 (หน่วยแพลทินัม-โคบอลต์)	15 (หน่วยแพลทินัม- โคบอลต์)
ความขุ่น (Turbidity)	5 (หน่วยความขุ่น)	20 (หน่วยความขุ่น)
ความเป็นกรด-ด่าง (pH)	7.0-8.5	6.5-9.2

คุณลักษณะทางเคมี

รายการ	เกณฑ์กำหนดที่เหมาะสม (มิลลิกรัมต่อลิตร)	เกณฑ์อนุโลมสูงสุด (มิลลิกรัมต่อลิตร)
เหล็ก (Fe)	ไม่เกิน 0.5	1.0
แมงกานีส (Mn)	ไม่เกิน 0.3	0.5
ทองแดง (Cu)	ไม่เกิน 1.0	1.5
สังกะสี (Zn)	ไม่เกิน 5.0	15
ซัลเฟต (SO_4)	ไม่เกิน 200	250
คลอไรด์ (Cl)	ไม่เกิน 250	600
ฟลูออไรด์ (F)	ไม่เกิน 0.7	1.0
ไนเตรท (NO_3)	ไม่เกิน 45	45
ความกระด้างทั้งหมด (Total hardness as $CaCO_3$)	ไม่เกิน 300	500
ความกระด้างถาวร (Non-carbonate hardness as $CaCO_3$)	ไม่เกิน 200	250
ปริมาณมวลสารทั้งหมดที่ละลายได้ (Total dissolved solids)	ไม่เกิน 600	1,200

คุณลักษณะที่เป็นพิษ

รายการ	เกณฑ์กำหนดที่เหมาะสม (มิลลิกรัมต่อลิตร)	เกณฑ์อนุโลมสูงสุด (มิลลิกรัมต่อลิตร)
สารหนู (As)	ต้องไม่มี	0.05
ไซยาไนด์ (CN)	ต้องไม่มี	0.1
ตะกั่ว(Pb)	ต้องไม่มี	0.05
ปรอท(Hg)	ต้องไม่มี	0.001
แคดเมียม(Cd)	ต้องไม่มี	0.01
ซีลีเนียม(Se)	ต้องไม่มี	0.01

คุณลักษณะทางบัคเตรี/แบคทีเรีย

รายการ	เกณฑ์กำหนดที่เหมาะสม
Standard plate count	ไม่เกิน 500 โคโลนีต่อลูกบาศก์เซนติเมตร
Most probable number of Coliform organism (MPN)	น้อยกว่า 2.2 ต่อร้อยลูกบาศก์เซนติเมตร
E. coli	ต้องไม่มี

หมายเหตุ :- เหตุผลในการประกาศใช้ประกาศฉบับนี้ คือ เนื่องจากหลักเกณฑ์ และมาตรการในทางวิชาการสำหรับการป้องกันด้านสาธารณสุขและการป้องกันในเรื่องสิ่งแวดล้อมเป็นพิษ ตามประกาศกระทรวงอุตสาหกรรม ฉบับที่ ๑๒ (พ.ศ. ๒๕๔๒) ออกตามความในพระราชบัญญัติน้ำบาดาล พ.ศ. ๒๕๒๐ สมควรปรับปรุงหลักเกณฑ์การเลิกใช้น้ำบาดาลให้มีความเหมาะสม และสอดคล้องกับสถานการณ์ในปัจจุบัน โดยกำหนด ผู้ควบคุมการอุดกลบบ่อน้ำบาดาลตามขนาดของบ่อน้ำบาดาล ตลอดจนปรับปรุงข้อความให้มีความถูกต้องตามมาตรา ๗ ทวิ และมาตรา ๗ ตรี แห่งพระราชบัญญัติน้ำบาดาล พ.ศ. ๒๕๒๐ จึงจำเป็นต้องออกประกาศกระทรวงนี้



ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ
ฉบับที่ ๒๐ (พ.ศ. ๒๕๔๓)
ออกตามความในพระราชบัญญัติส่งเสริมและรักษาคุณภาพ สิ่งแวดล้อมแห่งชาติ พ.ศ. ๒๕๓๕
เรื่อง กำหนดมาตรฐานคุณภาพน้ำใต้ดิน

อาศัยอำนาจตามความในมาตรา ๓๒ (๖) แห่งพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. ๒๕๓๕ คณะกรรมการสิ่งแวดล้อมแห่งชาติออกประกาศกำหนดมาตรฐานคุณภาพน้ำใต้ดิน ไว้ดังต่อไปนี้

ข้อ ๑ ในประกาศนี้

"น้ำใต้ดิน" หมายความว่า น้ำที่อยู่ใต้ดิน และให้หมายความรวมถึงน้ำบาดาลตามกฎหมายว่าด้วยน้ำบาดาล

"มาตรฐานคุณภาพน้ำใต้ดิน" หมายความว่า ระดับความเข้มข้นสูงสุดของสารอันตรายที่ยอมให้มีได้ในน้ำใต้ดิน โดยไม่ก่อให้เกิดอันตรายและผลกระทบต่อสุขภาพอนามัยของประชาชน เมื่อนำน้ำใต้ดินมาใช้บริโภค

ข้อ ๒ คุณภาพน้ำใต้ดินต้องมีมาตรฐานดังต่อไปนี้

๒.๑ สารอินทรีย์ระเหยง่าย (Volatile Organic Compounds)

(๑) เบนซีน (Benzene) ต้องไม่เกิน ๕ ไมโครกรัมต่อลิตร

(๒) คาร์บอนเตตระคลอไรด์ (Carbon Tetrachloride) ต้องไม่เกิน ๕ ไมโครกรัมต่อลิตร

(๓) 1, 2 - ไดคลอโรอีเทน (1, 2 - Dichloroethane) ต้องไม่เกิน ๕ ไมโครกรัมต่อลิตร

(๔) 1, 1 - ไดคลอโรเอทธิลีน (1, 1 - Dichloroethylene) ต้องไม่เกิน ๗ ไมโครกรัมต่อลิตร

(๕) ซิส - 1, 2 - ไดคลอโรเอทธิลีน (cis - 1, 2 - Dichloroethylene) ต้องไม่เกิน ๗๐ ไมโครกรัมต่อลิตร

(๖) ทรานส์ - 1, 2 - ไดคลอโรเอทธิลีน (trans - 1, 2 - Dichloroethylene) ต้องไม่เกิน ๑๐๐ ไมโครกรัมต่อลิตร

(๗) ไดคลอโรมีเทน (Dichloromethane) ต้องไม่เกิน ๕ ไมโครกรัมต่อลิตร

(๘) เอทธิลเบนซีน (Ethylbenzene) ต้องไม่เกิน ๗๐๐ ไมโครกรัมต่อลิตร

(๙) สไตรีน (Styrene) ต้องไม่เกิน ๑๐๐ ไมโครกรัมต่อลิตร

(๑๐) เตตระคลอโรเอทธิลีน (Tetrachloroethylene) ต้องไม่เกิน ๕ ไมโครกรัมต่อลิตร

(๑๑) โทลูอีน (Toluene) ต้องไม่เกิน ๑,๐๐๐ ไมโครกรัมต่อลิตร

(๑๒) ไตรคลอโรเอทธิลีน (Trichloroethylene) ต้องไม่เกิน ๕ ไมโครกรัมต่อลิตร

(๑๓) 1, 1, 1- ไตรคลอโรอีเทน (1, 1, 1 - Trichloroethane) ต้องไม่เกิน ๒๐๐ ไมโครกรัมต่อลิตร

(๑๔) 1, 1, 2 - ไตรคลอโรอีเทน (1, 1, 2 - Trichloroethane) ต้องไม่เกิน ๕ ไมโครกรัมต่อลิตร

(๑๕) ไซลีนทั้งหมด (Total Xylenes) ต้องไม่เกิน ๑๐,๐๐๐ ไมโครกรัมต่อลิตร

๒.๒ โลหะหนัก (Heavy Metals)

(๑) แคดเมียม (Cadmium) ต้องไม่เกิน ๐.๐๐๓ มิลลิกรัมต่อลิตร

(๒) โครเมียมชนิดเฮ็กซาวาเล้นท์ (Hexavalent Chromium) ต้องไม่เกิน ๐.๐๕ มิลลิกรัมต่อลิตร

(๓) ทองแดง (Copper) ต้องไม่เกิน ๑.๐ มิลลิกรัมต่อลิตร

(๔) ตะกั่ว (Lead) ต้องไม่เกิน ๐.๐๑ มิลลิกรัมต่อลิตร

(๕) แมงกานีส (Manganese) ต้องไม่เกิน ๐.๕ มิลลิกรัมต่อลิตร

(๖) นิกเกิล (Nickel) ต้องไม่เกิน ๐.๐๒ มิลลิกรัมต่อลิตร

(๗) สังกะสี (Zinc) ต้องไม่เกิน ๕.๐ มิลลิกรัมต่อลิตร

(๘) สารหนู (Arsenic) ต้องไม่เกิน ๐.๐๑ มิลลิกรัมต่อลิตร

(๙) ซีลีเนียม (Selenium) ต้องไม่เกิน ๐.๐๑ มิลลิกรัมต่อลิตร

(๑๐) ปรอท (Mercury) ต้องไม่เกิน ๐.๐๐๑ มิลลิกรัมต่อลิตร

๒.๓ สารป้องกันกำจัดศัตรูพืชและสัตว์ (Pesticides)

(๑) คลอเดน (Chlordane) ต้องไม่เกิน ๐.๒ ไมโครกรัมต่อลิตร

(๒) ดิลดริน (Dieldrin) ต้องไม่เกิน ๐.๐๓ ไมโครกรัมต่อลิตร

(๓) เฮปตาคลอร์ (Heptachlor) ต้องไม่เกิน ๐.๔ ไมโครกรัมต่อลิตร

(๔) เฮปตาคลอร์ อีพ็อกไซด์ (Heptachlor Epoxide) ต้องไม่เกิน ๐.๒ ไมโครกรัมต่อลิตร

(๕) ดีดีที (DDT) ต้องไม่เกิน ๒ ไมโครกรัมต่อลิตร

(๖) 2, 4 - ดี (2, 4 -D) ต้องไม่เกิน ๓๐ ไมโครกรัมต่อลิตร

(๗) อะทราซีน (Atrazine) ต้องไม่เกิน ๓ ไมโครกรัมต่อลิตร

(๘) ลินเดน (Lindane) ต้องไม่เกิน ๐.๒ ไมโครกรัมต่อลิตร

(๙) เพนตะคลอโรฟีนอล (Pentachlorophenol) ต้องไม่เกิน ๑ ไมโครกรัมต่อลิตร

๒.๔ สารพิษอื่นๆ

(๑) เบนโซ (เอ) ไพรีน (Benzo (a) pyrene) ต้องไม่เกิน ๐.๒ ไมโครกรัมต่อลิตร

(๒) ไซยาไนด์ (Cyanide) ต้องไม่เกิน ๒๐๐ ไมโครกรัมต่อลิตร

(๓) พีซีบี (PCBs) ต้องไม่เกิน ๐.๕ ไมโครกรัมต่อลิตร

(๔) ไวนิลคลอไรด์ (Vinyl Chloride) ต้องไม่เกิน ๒ ไมโครกรัมต่อลิตร

ข้อ ๓ การตรวจสอบคุณภาพน้ำใต้ดินตามข้อ ๒ ให้ใช้วิธีการมาตรฐานสำหรับการวิเคราะห์น้ำและน้ำเสีย (Standard Methods for the Examination of Water and Wastewater) ซึ่ง American Public Health Association, American Water Works Association และ Water Environment Federation ของสหรัฐอเมริการ่วมกันกำหนดหรือตามคู่มือวิเคราะห์น้ำและน้ำเสียของสมาคมวิศวกรสิ่งแวดล้อมแห่งประเทศไทย ดังต่อไปนี้

(๑) การตรวจสอบคุณภาพน้ำใต้ดินตามข้อ ๒.๑ (๑) - (๑๕) ให้ใช้วิธี Purge and Trap Gas Chromatography หรือวิธี Purge and Trap Gas Chromatography/Mass Spectrometry หรือวิธีอื่นที่กรมควบคุมมลพิษเห็นชอบ

(๒) การตรวจสอบคุณภาพน้ำใต้ดินตามข้อ ๒.๒ (๑) - (๗) ให้ใช้วิธี Direct Aspiration/Atomic Absorption Spectrometry หรือวิธี Inductively Coupled Plasma/Plasma Emission Spectroscopy หรือวิธีอื่นที่กรมควบคุมมลพิษเห็นชอบ

(๓) การตรวจสอบคุณภาพน้ำใต้ดินตามข้อ ๒.๒ (๘) - (๙) ให้ใช้วิธี Hydride Generation/Atomic Absorption Spectrometry หรือวิธี Inductively Coupled Plasma/Plasma Emission Spectroscopy หรือวิธีอื่นที่กรมควบคุมมลพิษเห็นชอบ

(๔) การตรวจสอบคุณภาพน้ำใต้ดินตามข้อ ๒.๒ (๑๐) ให้ใช้วิธี Cold-Vapor Atomic Absorption Spectrometry/Plasma Emission Spectroscopy หรือวิธีอื่นที่กรมควบคุมมลพิษเห็ฯชอบ

(๕) การตรวจสอบคุณภาพน้ำใต้ดินตามข้อ ๒.๓ (๑) - (๕) ให้ใช้วิธี Liquid - Liquid Extraction Gas Chromtography/Mass Spectrometry หรือวิธี Liquid - Liquid Extraction Gas Chromatography (Method I) หรือวิธีอื่นที่กรมควบคุมมลพิษเห็นชอบ

(๖) การตรวจสอบคุณภาพน้ำใต้ดินตามข้อ ๒.๓ (๖) - (๗) ให้ใช้วิธี Liquid - Liquid Extraction Gas Chromatography หรือวิธีอื่นที่กรมควบคุมมลพิษเห็นชอบ

(๗) การตรวจสอบคุณภาพน้ำใต้ดินตามข้อ ๒.๓ (๘) ให้ใช้วิธี Liquid - Liquid Extraction Gas Chromatography (Method I) หรือวิธีอื่นที่กรมควบคุมมลพิษเห็นชอบ

(๘) การตรวจสอบคุณภาพน้ำใต้ดินตามข้อ ๒.๓ (๙) ให้ใช้วิธี Liquid - Liquid Extraction Gas Chromatography/Mass Spectrometry หรือวิธี Liquid - Liquid Extraction Gas Chromatography หรือวิธีอื่นที่กรมควบคุมมลพิษเห็นชอบ

(๙) การตรวจสอบคุณภาพน้ำใต้ดินตามข้อ ๒.๔ (๑) ให้ใช้วิธี Liquid - Liquid Extraction Chromatography หรือ Liquid - Liquid Extraction Gas Chromatography/Mass Spectrometry หรือวิธีอื่นที่กรมควบคุมมลพิษเห็นชอบ

(๑๐) การตรวจสอบคุณภาพน้ำใต้ดินตามข้อ ๒.๔ (๒) ให้ใช้วิธี Pyridine Barbituric Acid หรือวิธี Colorimetry หรือ Ion Chromatography หรือวิธีอื่นที่กรมควบคุมมลพิษเห็นชอบ

(๑๑) การตรวจสอบคุณภาพน้ำใต้ดินตามข้อ ๒.๔ (๓) ให้ใช้วิธี Liquid - Liquid Extraction Gas Chromatography (Method II) หรือวิธีอื่นที่กรมควบคุมมลพิษเห็นชอบ

(๑๒) การตรวจสอบคุณภาพน้ำใต้ดินตามข้อ ๒.๔ (๔) ให้ใช้วิธี Purge and Trap Gas Chromatography หรือวิธี Purge and Trap Gas Chromatography/Mass Spectrometry หรือวิธีอื่นที่กรมควบคุมมลพิษเห็นชอบ

ข้อ ๔ วิธีการเก็บและรักษาตัวอย่างน้ำใต้ดินให้เป็นไปตามที่กรมควบคุมมลพิษประกาศในราชกิจจานุเบกษา

ประกาศ ณ วันที่ ๓๑ สิงหาคม พ.ศ. ๒๕๔๓
ไตรรงค์ สุวรรณคีรี
รองนายกรัฐมนตรี ปฏิบัติหน้าที่
ประธานคณะกรรมการสิ่งแวดล้อมแห่งชาติ

(ประกาศในราชกิจจานุเบกษา เล่ม ๑๑๗ ตอนพิเศษ ๘๕ง ลงวันที่ ๑๕ กันยายน ๒๕๔๓)

ภาคผนวก ค-5

มาตรฐานด้านอาชีวอนามัยและความปลอดภัย

ประกาศกรมสวัสดิการและคุ้มครองแรงงาน

เรื่อง มาตรฐานระดับเสียงที่ยอมให้ลูกจ้างได้รับเฉลี่ยตลอดระยะเวลาการทำงานในแต่ละวัน

โดยที่กฎกระทรวงกำหนดมาตรฐานในการบริหาร จัดการ และดำเนินการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานเกี่ยวกับความร้อน แสงสว่าง และเสียง พ.ศ. ๒๕๕๙ กำหนดให้นายจ้างต้องควบคุมระดับเสียงที่ลูกจ้างได้รับเฉลี่ยตลอดระยะเวลาการทำงานในแต่ละวันมิให้เกินมาตรฐานตามที่อธิบดีประกาศกำหนด

อาศัยอำนาจตามความในข้อ ๘ แห่งกฎกระทรวงกำหนดมาตรฐานในการบริหาร จัดการและดำเนินการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานเกี่ยวกับความร้อน แสงสว่าง และเสียง พ.ศ. ๒๕๕๙ อธิบดีกรมสวัสดิการและคุ้มครองแรงงานจึงออกประกาศไว้ดังต่อไปนี้

ข้อ ๑ ประกาศนี้เรียกว่า “ประกาศกรมสวัสดิการและคุ้มครองแรงงาน เรื่อง มาตรฐานระดับเสียงที่ยอมให้ลูกจ้างได้รับเฉลี่ยตลอดระยะเวลาการทำงานในแต่ละวัน”

ข้อ ๒ ประกาศนี้ให้ใช้บังคับเมื่อพ้นกำหนดเก้าสิบวันนับแต่วันประกาศในราชกิจจานุเบกษา

ข้อ ๓ นายจ้างต้องควบคุมระดับเสียงที่ลูกจ้างได้รับเฉลี่ยตลอดระยะเวลาการทำงานในแต่ละวัน (Time Weighted Average-TWA) มิให้เกินมาตรฐานตามตารางแนบท้ายประกาศ โดยหน่วยวัดระดับเสียงดังที่ใช้ในประกาศนี้ใช้หน่วยเป็น เดซิเบลเอ

ประกาศ ณ วันที่ ๑๓ ธันวาคม พ.ศ. ๒๕๖๐
อนันต์ชัย อุทัยพัฒนาชีพ
ผู้ตรวจราชการกระทรวง รักษาราชการแทน
อธิบดีกรมสวัสดิการและคุ้มครองแรงงาน

(ตารางแนบท้ายประกาศ)

ตารางมาตรฐานระดับเสียงที่ยอมให้ลูกจ้างได้รับเฉลี่ยตลอดระยะเวลาการทำงานในแต่ละวัน

ระดับเสียงเฉลี่ยตลอดเวลาการทำงาน (TWA) ไม่เกิน (เดซิเบลเอ)	ระยะเวลาการทำงานที่ได้รับเสียงต่อวัน*	
	ชั่วโมง	นาที
๘๒	๑๖	-
๘๓	๑๒	๔๒
๘๔	๑๐	๕
๘๕	๘	-
๘๖	๖	๒๑
๘๗	๕	๒
๘๘	๔	-
๘๙	๓	๑๑
๙๐	๒	๓๑
๙๑	๒	-
๙๒	๑	๓๕
๙๓	๑	๑๖
๙๔	๑	-
๙๕	-	๔๘
๙๖	-	๓๘
๙๗	-	๓๐
๙๘	-	๒๔
๙๙	-	๑๙
๑๐๐	-	๑๕
๑๐๑	-	๑๒
๑๐๒	-	๙
๑๐๓	-	๗.๕
๑๐๔	-	๖
๑๐๕	-	๕
๑๐๖	-	๔
๑๐๗	-	๓
๑๐๘	-	๒.๕
๑๐๙	-	๒
๑๑๐	-	๑.๕
๑๑๑	-	๑

หมายเหตุ * ระยะเวลาการทำงานที่ได้รับเสียงและระดับเสียงเฉลี่ยตลอดเวลาการทำงาน (TWA) ให้ใช้ค่ามาตรฐานที่กำหนดในตารางข้างต้นเป็นลำดับแรก หากไม่มีค่ามาตรฐานที่กำหนดตรงตามตารางให้คำนวณจากสูตรดังนี้

$$T = \frac{๘}{๒^{(L-๘๕)/๓}}$$

เมื่อ T หมายถึง เวลาการทำงานที่ยอมให้ได้รับเสียง (ชั่วโมง)
L หมายถึง ระดับเสียง (เดซิเบลเอ)

ในกรณีค่าระดับเสียงเฉลี่ยตลอดเวลาการทำงาน (TWA) ที่ได้จากการคำนวณมีเศษทศนิยมให้ตัดเศษทศนิยมออก

ประกาศกรมสวัสดิการและคุ้มครองแรงงาน

เรื่อง มาตรฐานความเข้มของแสงสว่าง

โดยที่กฎกระทรวงกำหนดมาตรฐานในการบริหาร จัดการ และดำเนินการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานเกี่ยวกับความร้อน แสงสว่าง และเสียง พ.ศ. ๒๕๕๙ กำหนดให้นายจ้างจัดให้สถานประกอบกิจการมีความเข้มของแสงสว่างไม่ต่ำกว่ามาตรฐานตามที่อธิบดีประกาศกำหนด

อาศัยอำนาจตามความในข้อ ๔ แห่งกฎกระทรวงกำหนดมาตรฐานในการบริหาร จัดการและดำเนินการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานเกี่ยวกับความร้อน แสงสว่าง และเสียง พ.ศ. ๒๕๕๙ อธิบดีกรมสวัสดิการและคุ้มครองแรงงานจึงออกประกาศไว้ดังต่อไปนี้

ข้อ ๑ ประกาศนี้เรียกว่า “ประกาศกรมสวัสดิการและคุ้มครองแรงงาน เรื่อง มาตรฐานความเข้มของแสงสว่าง”

ข้อ ๒ ประกาศนี้ให้ใช้บังคับตั้งแต่วันถัดจากวันประกาศในราชกิจจานุเบกษา

ข้อ ๓ ในประกาศนี้

“ความเข้มของแสงสว่าง” หมายความว่า ปริมาณแสงที่ตกกระทบต่อหนึ่งหน่วยตารางเมตร ซึ่งในประกาศนี้ใช้หน่วยความเข้มของแสงสว่างเป็นลักซ์ (lux)

ข้อ ๔ นายจ้างต้องจัดให้สถานประกอบกิจการมีความเข้มของแสงสว่างไม่ต่ำกว่ามาตรฐานที่กำหนดไว้ตามตารางแนบท้ายประกาศนี้

ประกาศ ณ วันที่ ๒๗ พฤศจิกายน พ.ศ. ๒๕๖๐
อนันต์ชัย อุทัยพัฒนาชีพ
ผู้ตรวจราชการกระทรวง รักษาราชการแทน
อธิบดีกรมสวัสดิการและคุ้มครองแรงงาน

ตารางที่ ๑ มาตรฐานความเข้มของแสงสว่าง ณ บริเวณพื้นที่ทั่วไปและบริเวณการผลิตภายในสถานประกอบกิจการ

บริเวณพื้นที่และ/หรือลักษณะงาน	ลักษณะพื้นที่เฉพาะ	ตัวอย่างบริเวณพื้นที่และ/หรือลักษณะงาน	ค่าเฉลี่ยความเข้มของแสงสว่าง (ลักซ์)	จุดที่ความเข้มของแสงสว่างต่ำสุด (ลักซ์)
บริเวณพื้นที่ทำงานร้อยในกระบวนการผลิตหรือการปฏิบัติงาน		ห้องเก็บวัตถุดิบ บริเวณห้องบรรจุหรือห้องทำให้แห้งของโรงฟอกย้อม	๑๐๐	๕๐
		- จุดโถงทางเข้าสินค้า - คลังสินค้า - โกดังเก็บของไว้เพื่อการเคลื่อนย้าย - อาคารหม้อน้ำ - ห้องควบคุม - ห้องสุขาชาย/หญิง	๒๐๐	๑๐๐
		- บริเวณผลิตภัณฑ์ การเตรียมวัตถุดิบ - บริเวณพื้นที่ปรุงวัตถุดิบ - บริเวณกระบวนการผลิตที่ต้องการความแม่นยำ/บริเวณที่ต้องการแก้ไขงานที่ผิดพลาดอย่างรวดเร็ว - บริเวณการต่อท่อ งานเชื่อม และงานขึ้นรูปโลหะด้วยเครื่องจักร - งานเคมี	๓๐๐	๑๕๐

ตารางที่ ๒ มาตรฐานความเข้มของแสงสว่าง ณ บริเวณที่ผู้ปฏิบัติงานทำงานโดยใช้สายตาเป็นระยะเวลาหนึ่งหรือตลอดเวลาที่ปฏิบัติงานอยู่ในที่นั้นๆ ตามประเภทของงานที่ปฏิบัติ

การใช้สายตา	ลักษณะงาน	ตัวอย่างลักษณะงาน	ค่าความเข้มของแสงสว่าง (ลักซ์)
งานหยาบ	งานที่ชิ้นงานมีขนาดใหญ่มากและมองเห็นได้อย่างชัดเจน มีความแตกต่างของสีของแบบ	- งานหยิบจับที่ใช้เครื่องจักร ชิ้นงานที่มีขนาดใหญ่กว่า ๑๕๐ ไมโครเมตร (๐.๑๕ มิลลิเมตร) - การตรวจงานหยาบด้วยสายตา การประกอบ การนับ การขนย้ายชิ้นส่วนขนาดใหญ่ - การจัดเก็บ - การจัดแสง การผสมสีน้ำมัน หรือการสานเส้นใย - การขัดผิวหยาบ ขัดแห้ง ขัดเปียก - การฉีดพ่นปูนเก่า ปูนแก้ว และทีฉาบหยาบ - งานสี และเชื่อมเหล็ก	๒๐๐ – ๓๐๐
งานละเอียดเล็กน้อย	งานที่งานมีรายละเอียดปานกลาง ความแตกต่างของสีพื้นได้ และมีความแตกต่างของสีชัดเจน	- งานรับจ้างเลื่อยตัด - การทำงานไม้ที่มีงานมีขนาดปานกลาง - งานบรรจุในลงหีบห่อกระดาษ - งานเจาะรู ทากาว หรือเย็บด้วยมือ งานบันทึกและคัดลอกข้อมูล - งานเครื่องเขียนอาหาร ประกอบอาหาร และสร้างงาน - งานผสมและย้อมแต่งของผ้าปัง - การขจัดสิ่งสิ่ง	๓๐๐ – ๕๐๐
	งานที่ชิ้นงานมีรายละเอียดปานกลางหรือเล็ก และมองเห็นสีแตกต่างของสีได้ปานกลาง	- งานประจำในสำนักงาน ห่อ งานเขียน งานพิมพ์ งานบันทึกข้อมูล การอ่านและประมวลผลข้อมูล การจัดเก็บเอกสาร - การปฏิบัติงานที่ต้องงานมีขนาดที่ต่างๆ ๑๕๕ ไมโครเมตร (๐.๑๖๕ มิลลิเมตร) - งานออกแบบและเขียนแบบ โดยใช้โปรแกรมคอมพิวเตอร์ - งานประกอบชิ้นส่วนเล็กๆ - งานตรวจสอบแผ่นเหล็ก - การทำงานไม่ต่อเนื่องและมีความต้องการใช้สายตาในการมองเห็นวัตถุที่มีขนาดเล็กมาก	๕๐๐ - ๕๐๐
		- การขจัดสิ่งสิ่งอื่น หลอดเสียง	

บริเวณพื้นที่และ/หรือลักษณะงาน	ลักษณะพื้นที่เฉพาะ	ตัวอย่างบริเวณพื้นที่และ/หรือลักษณะงาน	ค่าเฉลี่ยความเข้มของแสงสว่าง (ลักซ์)	จุดที่ความเข้มของแสงสว่างต่ำสุด (ลักซ์)
บริเวณพื้นที่ทั่วไปที่มีการสัญจรของบุคคลและ/หรือยานพาหนะในภาวะปกติ และบริเวณที่มีการสัญจรในภาวะฉุกเฉิน	ทางสัญจรในภาวะฉุกเฉิน	ทางออกฉุกเฉิน เส้นทางหนีไฟ ป้ายไฟทางออกฉุกเฉิน (กรณีเกิดเหตุฉุกเฉินไฟดับ โดยวัดความสว่างของทางออกที่ระดับพื้น)	๑๐	-
	ภายนอกอาคาร	ลานจอดรถ ทางเดิน บันได	๕๐	๒๕
		ประตูทางเข้าใหญ่ของสถานประกอบกิจการ	๕๐	-
	ภายในอาคาร	ทางเดิน บันได ทางเข้าห้องโถง	๑๐๐	๕๐
		ลิฟท์	๑๐๐	-
บริเวณพื้นที่ใช้ประโยชน์ทั่วไป		ห้องพักพื้นสำหรับการปฐมพยาบาล ห้องพักผ่อน	๕๐	๒๕
		ป้อยยาม	๑๐๐	-
		- ห้องสุขา ห้องอาบน้ำ ห้องเปลี่ยนเสื้อผ้า - ห้องล็อบบี้หรือบริเวณต้อนรับ - ห้องรับรอง	๑๐๐	๕๐
บริเวณพื้นที่ใช้ประโยชน์ในสำนักงาน		- ห้องสำนักงาน ห้องฝึกอบรม ห้องประชุม ห้องสืบค้นหนังสือ/เอกสาร ห้องถ่ายเอกสาร ห้องคอมพิวเตอร์ ห้องประชุม บริเวณเคาน์เตอร์รับฝากสิ่งของ หรือห้องต้อนรับ ที่มีห้องออกแบบ เขียนแบบ	๑๐๐	๑๕๐

ตารางที่ ๓ มาตรฐานความเข้มของแสงสว่าง (ลักซ์) บริเวณโดยรอบที่ให้ลูกจ้างคนใดคนหนึ่งทำงาน โดยสายตามองเฉพาะจุดในการปฏิบัติงาน

พื้นที่ ๑	พื้นที่ ๒	พื้นที่ ๓
๑,๐๐๐ – ๒,๐๐๐	๓๐๐	๒๐๐
มากกว่า ๒,๐๐๐ – ๕,๐๐๐	๖๐๐	๓๐๐
มากกว่า ๕,๐๐๐ – ๑๐,๐๐๐	๑,๐๐๐	๔๐๐
มากกว่า ๑๐,๐๐๐	๒,๐๐๐	๖๐๐

หมายเหตุ : พื้นที่ ๑ หมายถึง จุดที่ให้ลูกจ้างทำงานโดยใช้สายตามองเฉพาะจุดในการปฏิบัติงาน
พื้นที่ ๒ หมายถึง บริเวณถัดจากที่ที่ให้ลูกจ้างคนใดคนหนึ่งทำงานในรัศมีที่ลูกจ้างเอื้อมมือถึง
พื้นที่ ๓ หมายถึง บริเวณโดยรอบที่ติดพื้นที่ ๒ ที่มีการปฏิบัติงานของลูกจ้างคนใดคนหนึ่ง

การใช้สายตา	ลักษณะงาน	ตัวอย่างลักษณะงาน	ค่าความเข้มของแสงสว่าง (ลักซ์)
		- การคัดเกรดแป้ง - การเตรียมอาหาร เช่น การทำความสะอาด การต้มฯ - การสืบด้าย การแต่ง การบรรจุในงานทอผ้า	
งานละเอียดปานกลาง	งานที่ชิ้นงานมีขนาดปานกลางหรือเล็ก สามารถมองเห็นได้แต่ไม่ชัดเจน และมีความแตกต่างของสีบ้าง และต้องใช้สายตาในการทำงานค่อนข้างมาก	- งานระบายสี พ่นสี ตกแต่งสี หรือขัดตกแต่งละเอียด - งานพิสูจน์อักษร - งานตรวจสอบขั้นสุดท้ายในโรงผลิตรถยนต์	๕๐๐ - ๖๐๐
		- งานออกแบบและเขียนแบบ โดยไม่ใช้โปรแกรมคอมพิวเตอร์ - งานตรวจสอบอาหาร เช่น การตรวจอาหารกระป๋อง - การคัดเกรดน้ำตาล	๖๐๐ – ๗๐๐
งานละเอียดสูง	งานที่ชิ้นงานมีขนาดเล็ก สามารถมองเห็นได้แต่ไม่ชัดเจน และมีความแตกต่างของสีน้อย ต้องใช้สายตาในการทำงานมาก	- การปฏิบัติงานที่ชิ้นงานมีขนาดตั้งแต่ ๒๕ ไมโครเมตร (๐.๐๒๕ มิลลิเมตร) - งานปรับเทียบมาตรฐานความถูกต้องและความแม่นยำของอุปกรณ์ - การระบายสี พ่นสี และตกแต่งชิ้นงานที่ต้องการความละเอียดมากหรือต้องการความแม่นยำสูง - งานย้อมสี	๗๐๐ - ๘๐๐
	งานที่ชิ้นงานมีขนาดเล็ก สามารถมองเห็นได้แต่ไม่ชัดเจน และมีความแตกต่างของสีน้อย ต้องใช้สายตาในการทำงานมากและใช้เวลาในการทำงาน	- การตรวจสอบ การตัดเย็บเสื้อผ้าด้วยมือ - การตรวจสอบและตกแต่งสิ่งทอ สิ่งถัก หรือเสื้อผ้าที่มีสีอ่อนขั้นสุดท้ายด้วยมือ - การคัดแยกและเทียบสีหนังที่มีสีเข้ม - การเทียบสีในงานย้อมผ้า - การทอผ้าสีเข้ม ทอละเอียด - การร้อยตะกร้อ	๘๐๐ - ๑,๒๐๐

การใช้สายตา	ลักษณะงาน	ตัวอย่างลักษณะงาน	ค่าความเข้มของแสงสว่าง (ลักซ์)
งานละเอียดสูงมาก	งานที่ชิ้นงานมีขนาดเล็กมาก ไม่สามารถมองเห็นได้อย่างชัดเจน และมีความแตกต่างของสีน้อยมากหรือมีสีไม่แตกต่างกัน ต้องใช้สายตาเพ่งในการทำงานมาก และใช้เวลาในการทำงานระยะเวลานาน	- งานละเอียดที่ทำที่โต๊ะหรือเครื่องจักร ชิ้นงานที่มีขนาดเล็กกว่า ๒๕ ไมโครเมตร (๐.๐๒๕ มิลลิเมตร) - งานตรวจสอบชิ้นส่วนที่มีขนาดเล็ก - งานซ่อมแซม สิ่งทอ สิ่งถักที่มีสีอ่อน - งานตรวจสอบและตกแต่งชิ้นส่วนของสิ่งทอ สิ่งถักที่มีสีเข้มด้วยมือ - การตรวจสอบและตกแต่งผลิตภัณฑ์สีเข้มและสีอ่อนด้วยมือ	๑,๒๐๐ - ๑,๖๐๐
งานละเอียดสูงมากเป็นพิเศษ	งานที่ชิ้นงานมีขนาดเล็กมากเป็นพิเศษ ไม่สามารถมองเห็นได้อย่างชัดเจน และมีความแตกต่างของสีน้อยมากหรือมีสีไม่แตกต่างกัน ต้องใช้สายตาเพ่งในการทำงานมากหรือใช้ทักษะและความชำนาญสูง และใช้เวลาในการทำงานระยะเวลานาน	- การปฏิบัติงานตรวจสอบชิ้นงานที่มีขนาดเล็กมากเป็นพิเศษ - การเจียระไนเพชร พลอย การทำนาฬิกาข้อมือสำหรับกระบวนการผลิตที่มีขนาดเล็กมากเป็นพิเศษ - งานทางการแพทย์ เช่น งานทันตกรรม ห้องผ่าตัด	๒,๔๐๐ หรือมากกว่า



กฎกระทรวง

กำหนดมาตรฐานในการบริหาร จัดการ และดำเนินการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานเกี่ยวกับความร้อน แสงสว่าง และเสียง พ.ศ. ๒๕๕๙

อาศัยอำนาจตามความในมาตรา ๕ วรรคหนึ่ง และมาตรา ๘ วรรคหนึ่ง แห่งพระราชบัญญัติความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงาน พ.ศ. ๒๕๕๔ รัฐมนตรีว่าการกระทรวงแรงงานออกกฎกระทรวงไว้ ดังต่อไปนี้

ข้อ ๑ ในกฎกระทรวงนี้

“อุณหภูมิเวตบัลป์โกลบ” (Wet Bulb Globe Temperature - WBGT) หมายความว่า

(๑) อุณหภูมิที่วัดเป็นองศาเซลเซียสซึ่งวัดนอกอาคารที่ไม่มีแสงแดดหรือในอาคารมีระดับความร้อนเท่ากับ ๐.๗ เท่าของอุณหภูมิที่อ่านค่าจากเทอร์โมมิเตอร์กระเปาะเปียกตามธรรมชาติ (natural wet bulb thermometer) บวก ๐.๓ เท่าของอุณหภูมิที่อ่านค่าจากโกลบเทอร์โมมิเตอร์ (globe thermometer) หรือ

(๒) อุณหภูมิที่วัดเป็นองศาเซลเซียสซึ่งวัดนอกอาคารที่มีแสงแดด มีระดับความร้อนเท่ากับ ๐.๗ เท่าของอุณหภูมิที่อ่านค่าจากเทอร์โมมิเตอร์กระเปาะเปียกตามธรรมชาติ บวก ๐.๒ เท่าของอุณหภูมิที่อ่านค่าจากโกลบเทอร์โมมิเตอร์ และบวก ๐.๑ เท่าของอุณหภูมิที่อ่านค่าจากเทอร์โมมิเตอร์กระเปาะแห้ง (dry bulb thermometer)

“ระดับความร้อน” หมายความว่า อุณหภูมิเวตบัลป์โกลบในบริเวณที่ลูกจ้างทำงานตรวจวัดโดยค่าเฉลี่ยในช่วงเวลาสองชั่วโมงที่มีอุณหภูมิเวตบัลป์โกลบสูงสุดของการทำงานปกติ

“สภาวะการทำงาน” หมายความว่า สภาวะแวดล้อมซึ่งปรากฏอยู่ในบริเวณที่ทำงานของลูกจ้าง ซึ่งรวมถึงสภาพต่าง ๆ ในบริเวณที่ทำงาน เครื่องจักร อาคาร สถานที่ การระบายอากาศ ความร้อน แสงสว่าง เสียง ตลอดจนสภาพและลักษณะการทำงานของลูกจ้างด้วย

“งานเบา” หมายความว่า ลักษณะงานที่ใช้แรงน้อยหรือใช้กำลังงานที่ทำให้เกิดการเผาผลาญอาหารในร่างกายไม่เกิน ๒๐๐ กิโลแคลอรีต่อชั่วโมง เช่น งานเขียนหนังสือ งานพิมพ์ดีด งานบันทึกข้อมูล งานเย็บจักร งานนั่งตรวจสอบผลิตภัณฑ์ งานประกอบชิ้นงานขนาดเล็ก งานบังคับเครื่องจักรด้วยเท้า การยืนคุมงาน

“งานปานกลาง” หมายความว่า ลักษณะงานที่ใช้แรงปานกลางหรือใช้กำลังงานที่ทำให้เกิดการเผาผลาญอาหารในร่างกายเกิน ๒๐๐ กิโลแคลอรีต่อชั่วโมง ถึง ๓๕๐ กิโลแคลอรีต่อชั่วโมง เช่น งานยก ลาก ดัน หรือเคลื่อนย้ายสิ่งของด้วยแรงปานกลาง งานตอกตะปู งานตะไบ งานขับรถบรรทุก งานขับรถแทรกเตอร์

“งานหนัก” หมายความว่า ลักษณะงานที่ใช้แรงมากหรือใช้กำลังงานที่ทำให้เกิดการเผาผลาญอาหารในร่างกายเกิน ๓๕๐ กิโลแคลอรีต่อชั่วโมง เช่น งานที่ใช้พลั่วตักหรือเครื่องมือลักษณะคล้ายกัน งานขุด งานเลื่อยไม้ งานเจาะไม้เนื้อแข็ง งานทุบโดยใช้ค้อนขนาดใหญ่ งานยก หรือเคลื่อนย้ายของหนักขึ้นที่สูงหรือที่ลาดชัน

หมวด ๑
ความร้อน

ข้อ ๒ ให้นายจ้างควบคุมและรักษาระดับความร้อนภายในสถานประกอบกิจการที่มีลูกจ้างทำงานอยู่มิให้เกินมาตรฐาน ดังต่อไปนี้

(๑) งานที่ลูกจ้างทำในลักษณะงานเบาต้องมีมาตรฐานระดับความร้อนไม่เกินค่าเฉลี่ยอุณหภูมิเวตบัลป์โกลบ ๓๔ องศาเซลเซียส

(๒) งานที่ลูกจ้างทำในลักษณะงานปานกลางต้องมีมาตรฐานระดับความร้อนไม่เกินค่าเฉลี่ยอุณหภูมิเวตบัลป์โกลบ ๓๒ องศาเซลเซียส

(๓) งานที่ลูกจ้างทำในลักษณะงานหนักต้องมีมาตรฐานระดับความร้อนไม่เกินค่าเฉลี่ยอุณหภูมิเวตบัลป์โกลบ ๓๐ องศาเซลเซียส

ข้อ ๓ ในกรณีที่ภายในสถานประกอบกิจการมีแหล่งความร้อนที่อาจเป็นอันตรายให้นายจ้างติดป้ายหรือประกาศเตือนอันตรายในบริเวณดังกล่าว โดยให้ลูกจ้างสามารถมองเห็นได้ชัดเจน

ในกรณีที่บริเวณการทำงานตามวรรคหนึ่งมีระดับความร้อนเกินมาตรฐานที่กำหนดในข้อ ๒ ให้นายจ้างดำเนินการปรับปรุงหรือแก้ไขสภาวะการทำงานทางด้านวิศวกรรม เพื่อควบคุมระดับความร้อนให้เป็นไปตามมาตรฐาน และจัดให้มีการปิดประกาศและเอกสารหรือหลักฐานในการดำเนินการปรับปรุงหรือแก้ไขดังกล่าวไว้ เพื่อให้พนักงานตรวจความปลอดภัยสามารถตรวจสอบได้

ในกรณีที่ไม่สามารถดำเนินการให้เป็นไปตามวรรคสองได้ ให้นายจ้างจัดให้มีมาตรการควบคุมหรือลดภาระงาน และต้องจัดให้ลูกจ้างสวมใส่อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคลตามที่กำหนดไว้ในหมวด ๔ ตลอดเวลาที่ทำงาน

หมวด ๒
แสงสว่าง

ข้อ ๔ นายจ้างต้องจัดให้สถานประกอบกิจการมีความเข้มของแสงสว่างไม่ต่ำกว่ามาตรฐานที่อธิบดีประกาศกำหนด

ข้อ ๕ นายจ้างต้องใช้หรือจัดให้มีฉาก แผ่นฟิล์มกรองแสง หรือมาตรการอื่นที่เหมาะสมและเพียงพอเพื่อป้องกันมิให้แสงตรงหรือแสงสะท้อนจากแหล่งกำเนิดแสงหรือดวงอาทิตย์ที่มีแสงจ้าส่องเข้านัยน์ตาลูกจ้างโดยตรงในขณะทำงาน ในกรณีที่ไม่อาจป้องกันได้ ต้องจัดให้ลูกจ้างสวมใส่อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคลตามที่กำหนดไว้ในหมวด ๔ ตลอดเวลาที่ทำงาน

ข้อ ๖ ในกรณีที่ลูกจ้างต้องทำงานในสถานที่มืด ทึบ และคับแคบ เช่น ในถ้ำ อุโมงค์ หรือในที่ที่มีลักษณะเช่นว่านั้น นายจ้างต้องจัดให้มีอุปกรณ์ส่องแสงสว่างที่เหมาะสมแก่สภาพและลักษณะงาน โดยอาจเป็นชนิดที่ติดอยู่ในพื้นที่ทำงานหรือติดที่ตัวบุคคลได้ หากไม่สามารถจัดหาหรือดำเนินการได้ ต้องจัดให้ลูกจ้างสวมใส่อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคลตามที่กำหนดไว้ในหมวด ๔ ตลอดเวลาที่ทำงาน

หมวด ๓
เสียง

ข้อ ๗ นายจ้างต้องควบคุมระดับเสียงมิให้ลูกจ้างได้รับสัมผัสเสียงในบริเวณสถานประกอบกิจการที่มีระดับเสียงสูงสุด (peak sound pressure level) ของเสียงกระทบหรือเสียงกระแทก (impact or impulse noise) เกิน ๑๔๐ เดซิเบล หรือได้รับสัมผัสเสียงที่มีระดับเสียงดังต่อเนื่องแบบคงที่ (continuous steady noise) เกินกว่า ๑๑๕ เดซิเบลเอ

ข้อ ๘ นายจ้างต้องควบคุมระดับเสียงที่ลูกจ้างได้รับเฉลี่ยตลอดเวลาการทำงานในแต่ละวัน (Time Weighted Average-TWA) มิให้เกินมาตรฐานตามที่อธิบดีประกาศกำหนด

ข้อ ๙ ภายในสถานประกอบกิจการที่สภาวะการทำงานมีระดับเสียงเกินมาตรฐานที่กำหนดในข้อ ๗ หรือมีระดับเสียงที่ลูกจ้างได้รับเกินมาตรฐานที่กำหนดในข้อ ๘ นายจ้างต้องให้ลูกจ้างหยุดทำงานจนกว่าจะได้ปรับปรุงหรือแก้ไขให้ระดับเสียงเป็นไปตามมาตรฐานที่กำหนด และให้นายจ้างดำเนินการปรับปรุงหรือแก้ไขทางด้านวิศวกรรม โดยการควบคุมที่ต้นกำเนิดของเสียงหรือทางผ่านของเสียง หรือบริหารจัดการเพื่อควบคุมระดับเสียงที่ลูกจ้างจะได้รับให้ไม่เกินมาตรฐานที่กำหนด และจัดให้มีการปิดประกาศและเอกสารหรือหลักฐานในการดำเนินการปรับปรุงหรือแก้ไขดังกล่าวไว้ เพื่อให้พนักงานตรวจความปลอดภัยสามารถตรวจสอบได้

ในกรณีที่ไม่สามารถดำเนินการตามวรรคหนึ่งได้ นายจ้างต้องจัดให้ลูกจ้างสวมใส่อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคลตามที่กำหนดไว้ในหมวด ๔ ตลอดเวลาที่ทำงาน เพื่อลดระดับเสียงที่สัมผัสในหูเมื่อสวมใส่อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคลแล้ว โดยให้อยู่ในระดับที่ไม่เกินมาตรฐานตามที่กำหนดไว้ในข้อ ๗ และข้อ ๘

การคำนวณระดับเสียงที่สัมผัสในหูเมื่อสวมใส่อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคลตามวรรคสองให้เป็นไปตามที่อธิบดีประกาศกำหนด

ข้อ ๑๐ ในบริเวณที่มีระดับเสียงเกินมาตรฐานที่กำหนดในข้อ ๗ หรือข้อ ๘ นายจ้างต้องจัดให้มีเครื่องหมายเตือนให้ใช้อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคลติดไว้ให้ลูกจ้างเห็นได้โดยชัดเจน

ข้อ ๑๑ ในกรณีที่สภาวะการทำงานในสถานประกอบกิจการมีระดับเสียงที่ลูกจ้างได้รับเฉลี่ยตลอดระยะเวลาการทำงานแปดชั่วโมงตั้งแต่ ๘๕ เดซิเบลเอขึ้นไป ให้นายจ้างจัดให้มีมาตรการอนุรักษ์การได้ยินในสถานประกอบกิจการตามหลักเกณฑ์และวิธีการที่อธิบดีประกาศกำหนด

หมวด ๔
อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคล

ข้อ ๑๒ นายจ้างต้องจัดให้มีและดูแลให้ลูกจ้างใช้อุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคลตามความเหมาะสมกับลักษณะงานตลอดเวลาที่ทำงาน ดังต่อไปนี้

(๑) งานที่มีระดับความร้อนเกินมาตรฐานที่กำหนด ให้สวมใส่ชุดแต่งกาย รองเท้า และถุงมือสำหรับป้องกันความร้อน

(๒) งานที่มีแสงตรงหรือแสงสะท้อนจากแหล่งกำเนิดแสงหรือดวงอาทิตย์ที่มีแสงจ้าส่องเข้านัยน์ตาโดยตรง ให้สวมใส่แว่นตาลดแสงหรือกระบังหน้าลดแสง

(๓) งานที่ทำในสถานที่มืด ทึบ และคับแคบ ให้สวมใส่หมวกนิรภัยที่มีอุปกรณ์ส่องแสงสว่าง

(๔) งานที่มีระดับเสียงเกินมาตรฐานที่กำหนด ให้สวมใส่ปลั๊กลดเสียงหรือที่ครอบหูลดเสียง

ข้อ ๑๓ ให้นายจ้างบำรุงรักษาอุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคลให้อยู่ในสภาพที่ใช้งานได้อย่างปลอดภัย รวมทั้งจัดให้ลูกจ้างได้รับการฝึกอบรมเกี่ยวกับวิธีการใช้และบำรุงรักษาอุปกรณ์คุ้มครองความปลอดภัยส่วนบุคคล และเก็บหลักฐานการฝึกอบรมไว้ ณ สถานประกอบกิจการเพื่อให้พนักงานตรวจความปลอดภัยสามารถตรวจสอบได้

หมวด ๕
การตรวจวัดและวิเคราะห์สภาวะการทำงาน และการรายงานผล

ข้อ ๑๔ นายจ้างต้องจัดให้มีการตรวจวัดและวิเคราะห์สภาวะการทำงานเกี่ยวกับระดับความร้อน แสงสว่าง หรือเสียงภายในสถานประกอบกิจการ

หลักเกณฑ์ วิธีการตรวจวัด และการวิเคราะห์สภาวะการทำงานเกี่ยวกับระดับความร้อน แสงสว่าง หรือเสียง รวมทั้งระยะเวลาและประเภทกิจการที่ต้องดำเนินการให้เป็นไปตามที่อธิบดีประกาศกำหนด

ในกรณีที่นายจ้างไม่สามารถตรวจวัดและวิเคราะห์สภาวะการทำงานตามวรรคหนึ่งได้ ต้องให้ผู้ที่ขึ้นทะเบียนตามมาตรา ๙ หรือนิติบุคคลที่ได้รับใบอนุญาตตามมาตรา ๑๑ แห่งพระราชบัญญัติความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงาน พ.ศ. ๒๕๕๔ เพื่อเป็นผู้ให้บริการในการตรวจวัดและวิเคราะห์สภาวะการทำงานเกี่ยวกับระดับความร้อน แสงสว่าง หรือเสียงภายในสถานประกอบกิจการ แล้วแต่กรณี เป็นผู้ดำเนินการแทน

ให้นายจ้างเก็บผลการตรวจวัดและวิเคราะห์สภาวะการทำงานดังกล่าวไว้ ณ สถานประกอบกิจการ เพื่อให้พนักงานตรวจความปลอดภัยสามารถตรวจสอบได้

ข้อ ๑๕ ให้นายจ้างจัดทำรายงานผลการตรวจวัดและวิเคราะห์สภาวะการทำงานตามแบบที่อธิบดีประกาศกำหนด พร้อมทั้งส่งรายงานผลดังกล่าวต่ออธิบดีหรือผู้ซึ่งอธิบดีมอบหมายภายในสามสิบวันนับแต่วันที่เสร็จสิ้นการตรวจวัด และเก็บรายงานผลการตรวจวัดและวิเคราะห์สภาวะการทำงานดังกล่าวไว้ ณ สถานประกอบกิจการ เพื่อให้พนักงานตรวจความปลอดภัยสามารถตรวจสอบได้

หมวด ๖
การตรวจสุขภาพและการรายงานผล

ข้อ ๑๖ ให้นายจ้างจัดให้มีการตรวจสุขภาพลูกจ้างที่ทำงานในสภาวะการทำงานที่อาจได้รับอันตรายจากความร้อน แสงสว่าง หรือเสียง และรายงานผล รวมทั้งดำเนินการที่เกี่ยวข้องกับการตรวจสุขภาพของลูกจ้างตามพระราชบัญญัติความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงาน พ.ศ. ๒๕๕๔

บทเฉพาะกาล

ข้อ ๑๗ ให้ผู้ซึ่งขึ้นทะเบียนเป็นผู้รับรองรายงานการตรวจวัดและวิเคราะห์สภาวะการทำงานกับกรมสวัสดิการและคุ้มครองแรงงานตามกฎกระทรวงกำหนดมาตรฐานในการบริหารและการจัดการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานเกี่ยวกับความร้อน แสงสว่าง และเสียง พ.ศ. ๒๕๔๙ มีสิทธิดำเนินการตรวจวัดและวิเคราะห์สภาวะการทำงานเกี่ยวกับระดับความร้อน แสงสว่าง หรือเสียงภายในสถานประกอบกิจการตามข้อ ๑๔ ต่อไปจนกว่าการขึ้นทะเบียนจะสิ้นอายุ

ในกรณีที่ไม่มีผู้ซึ่งขึ้นทะเบียนตามวรรคหนึ่ง และยังไม่มีการออกกฎกระทรวงกำหนดรายละเอียดของบุคคลที่จะขอขึ้นทะเบียนหรือนิติบุคคลที่จะขอรับใบอนุญาตตามมาตรา ๙ หรือมาตรา ๑๑ แห่งพระราชบัญญัติความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงาน พ.ศ. ๒๕๕๔ เพื่อเป็นผู้ให้บริการในการตรวจวัดและวิเคราะห์สภาวะการทำงานเกี่ยวกับระดับความร้อน แสงสว่าง

หรือเสียงภายในสถานประกอบกิจการ แล้วแต่กรณี ให้ผู้ซึ่งสำเร็จการศึกษาไม่ต่ำกว่าระดับปริญญาตรี สาขาอาชีวอนามัย หรือเทียบเท่า ที่เคยขึ้นทะเบียนตามกฎกระทรวงกำหนดมาตรฐานในการบริหารและการจัดการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานเกี่ยวกับความร้อน แสงสว่าง และเสียง พ.ศ. ๒๕๔๙ หรือให้ผู้ซึ่งสำเร็จการศึกษาไม่ต่ำกว่าระดับปริญญาตรี สาขาอาชีวอนามัย หรือเทียบเท่า และมีประสบการณ์เป็นผู้รับรองรายงานการตรวจวัดและวิเคราะห์สภาวะการทำงานไม่น้อยกว่าสามปี สามารถดำเนินการตรวจวัดแทนผู้ทำการตรวจวัดตามกฎกระทรวงนี้ไปพลางก่อนได้

ข้อ ๑๘ กรณีที่นายจ้างทำการตรวจวัดและวิเคราะห์สภาวะการทำงานเกี่ยวกับระดับความร้อน แสงสว่าง หรือเสียงภายในสถานประกอบกิจการตามกฎกระทรวงกำหนดมาตรฐานในการบริหารและการจัดการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานเกี่ยวกับความร้อน แสงสว่าง และเสียง พ.ศ. ๒๕๔๙ ก่อนที่กฎกระทรวงนี้จะมีผลใช้บังคับ และมีระยะเวลายังไม่ครบหนึ่งปีนับแต่วันที่ทำการตรวจวัด ให้ถือว่านายจ้างได้ดำเนินการตรวจวัดตามกฎกระทรวงนี้แล้ว จนกว่าจะครบระยะเวลาหนึ่งปี

ให้ไว้ ณ วันที่ ๗ ตุลาคม พ.ศ. ๒๕๕๙
พลเอก ศิริชัย ดิษฐกุล
รัฐมนตรีว่าการกระทรวงแรงงาน

หมายเหตุ :- เหตุผลในการประกาศใช้กฎกระทรวงฉบับนี้ คือ โดยที่มาตรา ๘ วรรคหนึ่ง แห่งพระราชบัญญัติความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงาน พ.ศ. ๒๕๕๔ บัญญัติให้รัฐมนตรีว่าการกระทรวงแรงงานมีอำนาจออกกฎกระทรวงกำหนดให้นายจ้างบริหาร จัดการ และดำเนินการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงาน ซึ่งในการทำงานเกี่ยวกับความร้อน แสงสว่าง และเสียง สมควรจะต้องมีระบบการบริหาร จัดการ และดำเนินการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานที่ได้มาตรฐาน อันจะทำให้ลูกจ้างมีความปลอดภัยในการทำงานเกี่ยวกับความร้อน แสงสว่าง และเสียงยิ่งขึ้น จึงจำเป็นต้องออกกฎกระทรวงนี้

ประกาศกรมสวัสดิการและคุ้มครองแรงงาน

เรื่อง ขีดจำกัดความเข้มข้นของสารเคมีอันตราย

อาศัยอำนาจตามความในข้อ ๒๘ แห่งกฎกระทรวงกำหนดมาตรฐานในการบริหาร จัดการและดำเนินการด้านความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานเกี่ยวกับสารเคมีอันตราย พ.ศ. ๒๕๕๖ อธิบดีกรมสวัสดิการและคุ้มครองแรงงาน จึงออกประกาศไว้ ดังต่อไปนี้

ข้อ ๑ ประกาศนี้เรียกว่า “ประกาศกรมสวัสดิการและคุ้มครองแรงงาน เรื่อง ขีดจำกัดความเข้มข้นของสารเคมีอันตราย”

ข้อ ๒ ประกาศนี้ให้ใช้บังคับตั้งแต่วันถัดจากวันประกาศในราชกิจจานุเบกษาเป็นต้นไป

ข้อ ๓ ขีดจำกัดความเข้มข้นของสารเคมีอันตรายในบรรยากาศของสถานที่ทำงานและสถานที่เก็บรักษาสารเคมีอันตราย ให้เป็นไปตามท้ายประกาศนี้

ประกาศ ณ วันที่ ๒๘ มิถุนายน พ.ศ. ๒๕๖๐
สุเมธ มโหสถ
อธิบดีกรมสวัสดิการและคุ้มครองแรงงาน

ขีดจำกัดความเข้มข้นของสารเคมีอันตราย

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
1	อะเซตัลดีไฮด์	acetaldehyde	75-07-0	200 ppm	-	-	-
2	กรดอะซิติค (กรดน้ำส้ม)	acetic acid	64-19-7	10 ppm	-	-	-
3	อะซิติค แอนไฮไดรด์	acetic anhydride	108-24-7	5 ppm	-	-	-
4	อะซีโตน	acetone	67-64-1	1000 ppm	-	-	-
5	อะซีโตน ไซยาโนไฮดริน ในรูปของไซยาไนด์	acetone cyanohydrin, as CN	75-86-5	-	-	-	5 mg/m^3
6	อะซีโตไนไตรล์	acetonitrile	75-05-8	40 ppm	-	-	-
7	อะโครลีน	acrolein	107-02-8	0.1 ppm	-	-	-
8	อะครีลาไมด์	acrylamide	79-06-1	0.3 mg/m^3	-	-	-
9	กรดอะครีลิค	acrylic acid	79-10-7	2 ppm	-	-	-
10	อะครีโลไนไตรล์	acrylonitrile	107-13-1	2 ppm	10 ppm	15 min	-
11	กรดอะดิพิค	adipic acid	124-04-9	5 mg/m^3	-	-	-
12	อัลดริน	aldrin	309-00-2	0.25 mg/m^3	-	-	-
13	อัลลิล แอลกอฮอล์	allyl alcohol	107-18-6	2 ppm	-	-	-
14	อัลลิล คลอไรด์	allyl chloride	107-05-1	1 ppm	-	-	-
15	อัลลิล ไกลซิดิล อีเธอร์	allyl glycidyl ether	106-92-3	-	-	-	10 ppm
16	อัลลิล โพรพิล ไดซัลไฟด์	allyl propyl disulfide	2179-59-1	2 ppm	-	-	-
17	โลหะอะลูมิเนียม ในรูปของอะลูมิเนียม	aluminium metal, as Al	7429-90-5				
	- อนุภาคทุกขนาดที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- inhalable dust		15 mg/m^3	-	-	-
	- อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- respirable dust		5 mg/m^3	-	-	-
18	แอลฟา-อะลูมินา	alpha-alumina	1344-28-1				
	- อนุภาคทุกขนาดที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- inhalable dust		15 mg/m^3	-	-	-
	- อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- respirable dust		5 mg/m^3	-	-	-
19	2-อะมิโนไพริดีน	2-aminopyridine	504-29-0	0.5 ppm	-	-	-
20	อะมิโทรล	amitrole	61-82-5	0.2 mg/m^3	-	-	-
21	แอมโมเนีย	ammonia	7664-41-7	50 ppm	-	-	-

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
22	ฟูมของแอมโมเนียมคลอไรด์	ammonium chloride, fume	12125-02-9	10 mg/m^3	20 mg/m^3	15 min	-
23	แอมโมเนียม ซัลฟาเมท	ammonium sulfamate	7773-06-0				
	- อนุภาคทุกขนาดที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- inhalable dust		15 mg/m^3	-	-	-
	- อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- respirable dust		5 mg/m^3	-	-	-
24	นอร์มอล-เอมิล อะซีเตท	n-amyl acetate	628-63-7	100 ppm	-	-	-
25	เซค-เอมิล อะซีเตท	sec-amyl acetate	626-38-0	125 ppm	-	-	-
26	อะนิลีน และโฮโมล็อกซ์	aniline and homologs	62-53-3	5 ppm	-	-	-
27	อะนิซิดีน (ออโท-, พารา- ไอโซเมอร์)	anisidine (*o*-, *p*- isomers)	29191-52-4	0.5 mg/m^3	-	-	-
28	แอนติโมนีและสารประกอบในรูปของแอนติโมนี	antimony and compounds, as Sb	7440-36-0	0.5 mg/m^3	-	-	-
29	อะเซนิค (สารหนู) สารประกอบอนินทรีย์ ในรูปของอะเซนิค (สารหนู)	arsenic, inorganic compounds, as As	7440-38-2	0.01 mg/m^3	-	-	-
30	อะเซนิค (สารหนู) สารประกอบอินทรีย์ ในรูปของอะเซนิค (สารหนู)	arsenic, organic compounds, as As	7440-38-2	0.5 mg/m^3	-	-	-
31	อาร์ซีน	arsine	7784-42-1	0.05 ppm	-	-	-
32	แอสเบสทอส ชนิดไครโซไทล์	asbestos (chrysotile form)	77536-68-6	0.1 f/cm^3	-	-	-
33	แอสฟัลท์ (บิทูเมน) ในรูปของละอองสารละลายเบนซีน	asphalt (bitumen), as benzene soluble aerosol	8052-42-4	0.5 mg/m^3	-	-	-
34	อะทราซีน	atrazine	1912-24-9	5 mg/m^3	-	-	-
35	อะซินฟอส เมทธิล	azinphos-methyl	86-50-0	0.2 mg/m^3	-	-	-
36	แบเรียม สารประกอบที่ละลายได้ในรูปของแบเรียม	barium, soluble compounds, as Ba	7440-39-3	0.5 mg/m^3	-	-	-
37	แบเรียม ซัลเฟต	barium sulfate	7727-43-7				
	- อนุภาคทุกขนาดที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- inhalable dust		15 mg/m^3	-	-	-
	- อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- respirable dust		5 mg/m^3	-	-	-
38	เบนโนมิล	benomyl	17804-35-2				
	- อนุภาคทุกขนาดที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- inhalable dust		15 mg/m^3	-	-	-
	- อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- respirable dust		5 mg/m^3	-	-	-

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
39	เบนซีน	benzene	71-43-2	1 ppm	5 ppm	15 min	-
40	เบนโซอิล เพอร์ออกไซด์	benzoyl peroxide	94-36-0	5 mg/m^3	-	-	-
41	เบนซิล คลอไรด์	benzyl chloride	100-44-7	1 ppm	-	-	-
42	เบอริลเลียมและสารประกอบของเบอริลเลียม ในรูปของเบอริลเลียม	beryllium and beryllium compounds, as Be	7440-41-7	0.002 mg/m^3	0.025 mg/m^3	30 min	0.005 mg/m^3
43	ไบฟีนิล (ไดฟีนิล)	biphenyl (diphenyl)	92-52-4	0.2 ppm	-	-	-
44	บิสมัท เทลลูไรด์ อันโดป	bismuth telluride, undoped	1304-82-1				
	- อนุภาคทุกขนาดที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- inhalable dust		15 mg/m^3	-	-	-
	- อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- respirable dust		5 mg/m^3	-	-	-
45	บอเรทส์ เตตรา เกลือโซเดียม	borates, tetra, sodium salts					
	- แอนไฮดรัส	- anhydrous	1330-43-4	1 mg/m^3	-	-	-
	- เดคะไฮเดรท	- decahydrate	1303-96-4	5 mg/m^3	-	-	-
	- เพนตะไฮเดรท	- pentahydrate	12179-04-3	1 mg/m^3	-	-	-
46	โบรอน ไตรโบรไมด์	boron tribromide	10294-33-4	-	-	-	1 ppm
47	โบรอน ไตรฟลูออไรด์	boron trifluoride	7637-07-2	-	-	-	1 ppm
48	โบรมาซิล	bromacil	314-40-9	10 mg/m^3	-	-	-
49	โบรมีน เพนตะฟลูออไรด์	bromine pentafluoride	7789-30-2	0.1 ppm	-	-	-
50	โบรโมฟอร์ม	bromoform	75-25-2	0.5 ppm	-	-	-
51	1,3-บิวตะไดอีน	1,3-butadiene	106-99-0	1 ppm	5 ppm	15 min	-
52	บิวทีน ไอโซเมอร์ทุกรูป	butenes, all isomers		250 ppm	-	-	-
53	นอร์มอล-บิวทานอล	n-butanol	71-36-3	100 ppm	-	-	-
54	เซค-บิวทานอล	sec-butanol	78-92-2	150 ppm	-	-	-
55	เทอร์ท-บิวทานอล	tert-butanol	75-65-0	100 ppm	-	-	-
56	2-บิวทอกซีเอทธานอล	2-butoxyethanol	111-76-2	50 ppm	-	-	-
57	เทอร์ท-บิวทิล อะซีเตท	tert-butyl acetate	540-88-5	200 ppm	-	-	-
58	นอร์มอล-บิวทิล อะครีเลท	n-butyl acrylate	141-32-2	2 ppm	-	-	-
59	บิวทิลอะมีน	butylamine	109-73-9	-	-	-	5 ppm
60	นอร์มอล-บิวทิล ไกลซิดิล อีเธอร์ (บีจีอี)	n-butyl glycidyl ether (BGE)	2426-08-6	50 ppm	-	-	-

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
61	นอร์มอล-บิวทิล แลคเตท	n-butyl lactate	138-22-7	5 ppm	-	-	-
62	บิวทิล เมอร์แคพแทน	butyl mercaptan	109-79-5	10 ppm	-	-	-
63	ออโท-เซค-บิวทิลฟีนอล	*o*-sec-butylphenol	89-72-5	5 ppm	-	-	-
64	พารา-เทอร์ท-บิวทิลโทลูอีน	*p*-tert-butyltoluene	98-51-1	10 ppm	-	-	-
65	แคดเมียม ในรูปของแคดเมียม	cadmium, as Cd	7440-43-9	0.005 mg/m^3	-	-	-
66	แคลเซียม คาร์บอเนท	calcium carbonate	1317-65-3				
	- อนุภาคทุกขนาดที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- inhalable dust		15 mg/m^3	-	-	-
	- อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- respirable dust		5 mg/m^3	-	-	-
67	แคลเซียม โครเมท ในรูปของโครเมียม	calcium chromate, as Cr	13765-19-0	0.001 mg/m^3	-	-	-
68	แคลเซียม ไซยานาไมด์	calcium cyanamide	156-62-7	0.5 mg/m^3	-	-	-
69	แคลเซียม ไฮดรอกไซด์	calcium hydroxide	1305-62-0				
	- อนุภาคทุกขนาดที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- inhalable dust		15 mg/m^3	-	-	-
	-อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- respirable dust		5 mg/m^3	-	-	-
70	แคลเซียม ออกไซด์	calcium oxide	1305-78-8	5 mg/m^3	-	-	-
71	คาร์บาริล (เซวิน)	carbaryl (sevin)	63-25-2	5 mg/m^3	-	-	-
72	คาร์โบฟิวแรน	carbofuran	1563-66-2	0.1 mg/m^3	-	-	-
73	คาร์บอน ไดซัลไฟด์	carbon disulfide	75-15-0	20 ppm	100 ppm	30 min	30 ppm
74	คาร์บอน มอนอกไซด์	carbon monoxide	630-08-0	50 ppm	-	-	-
75	คาร์บอนเตตระคลอไรด์	carbon tetrachloride	56-23-5	10 ppm	200 ppm	5 min in any 3 hr	25 ppm
76	ซีเซียม ไฮดรอกไซด์	cesium hydroxide	21351-79-1	2 mg/m^3	-	-	-
77	คลอร์เดน	chlordane	57-74-9	0.5 mg/m^3	-	-	-
78	คลอริเนเทด แคมพีน	chlorinated camphene	8001-35-2	0.5 mg/m^3	-	-	-
79	คลอรีน	chlorine	7782-50-5	-	-	-	1 ppm
80	คลอโรอะซีติล คลอไรด์	chloroacetyl chloride	79-04-9	0.05 ppm	-	-	-
81	คลอโรเบนซีน	chlorobenzene	108-90-7	75 ppm	-	-	-
82	คลอโรไดฟลูออโรมีเธน	chlorodifluoromethane	75-45-6	1000 ppm	-	-	-

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
83	คลอโรฟอร์ม (ไตรคลอโรมีเธน)	chloroform (trichloromethane)	67-66-3	-	-	-	50 ppm
84	1-คลอโร-1-ไนโตรโพรเพน	1-chloro-1-nitropropane	600-25-9	20 ppm	-	-	-
85	คลอโรเพนตะฟลูออโรอีเธน	chloropentafluoroethane	76-15-3	1000 ppm	-	-	-
86	คลอโรพิคริน	chloropicrin	76-06-2	0.1 ppm	-	-	-
87	บีตา-คลอโรพรีน	*β*-chloroprene	126-99-8	25 ppm	-	-	-
88	กรด 2-คลอโรโพรพิโอนิค	2-chloropropionic acid	598-78-7	0.1 ppm	-	-	-
89	ออโท-คลอโรสไตรีน	*o*-chlorostyrene	2039-87-4	50 ppm	75 ppm	15 min	-
90	ออโท-คลอโรโทลูอีน	*o*-chlorotoluene	95-49-8	50 ppm	-	-	-
91	คลอร์ไพริฟอส	chlorpyrifos	2921-88-2	0.1 mg/m^3	-	-	-
92	โคล ดัส (ฝุ่นถ่านหิน)	coal dust					
	- แอนทราไซต์ อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- anthracite ,respirable dust)		0.4 mg/m^3	-	-	-
	- บิทูมินัส หรือ ลิกไนต์ อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- bituminous or lignite , respirable dust		0.9 mg/m^3	-	-	-
93	โคล ทาร์ พิช วอลาไทล์ ในรูปของละอองสารละลายเบนซีน	coal tar pitch volatiles, as benzene soluble aerosol	65996-93-2	0.2 mg/m^3	-	-	-
94	โคบอลท์ คาร์โบนิล ในรูปของโคบอลท์	cobalt carbonyl, as Co	10210-68-1	0.1 mg/m^3	-	-	-
95	โคบอลท์ ไฮโดรคาร์โบนิล ในรูปของโคบอลท์	cobalt hydrocarbonyl, as Co	16842-03-8	0.1 mg/m^3	-	-	-
96	โลหะโคบอลท์ ฝุ่น และฟูม ในรูปของโคบอลท์	cobalt metal, dust, and fume, as Co	7440-48-4	0.1 mg/m^3	-	-	-
97	ฝุ่นฝ้ายดิบ (ยังไม่ปรับสภาพ)	cotton dust, raw, untreated		1 mg/m^3	-	-	-
98	คิวมีน (ไอโซโพรพิล เบนซีน)	cumene (isopropyl benzene)	98-82-8	50 ppm	-	-	-
99	ไซยานาไมด์	cyanamide	420-04-2	2 mg/m^3	-	-	-
100	ไซโคลเฮกเซน	cyclohexane	110-82-7	300 ppm	-	-	-
101	ไซโคลเฮกซานอล	cyclohexanol	108-93-0	50 ppm	-	-	-
102	ไซโคลเฮกซาโนน	cyclohexanone	108-94-1	50 ppm	-	-	-
103	ไซโคลเฮกซิลอะมีน	cyclohexylamine	108-91-8	10 ppm	-	-	-
104	ไซโคลเพนเทน	cyclopentane	287-92-3	600 ppm	-	-	-

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
105	ไซเฮกซะติน (ไตรไซโคลเฮกซิลทิน ไฮดรอกไซด์)	cyhexatin (tricyclohexyltin hydroxide)	13121-70-5	5 mg/m^3	-	-	-
106	ดีดีที (ไดคลอโรไดฟีนิลไตรคลอโรอีเทน)	DDT (dichlorodiphenyltrichloro ethane)	50-29-3	1 mg/m^3	-	-	-
107	ดิมิทอน (ซีสท็อก)	demeton (systox)	8065-48-3	0.1 mg/m^3	-	-	-
108	ไดอะซินอน	diazinon	333-41-5	0.01 mg/m^3	-	-	-
109	ออโท-ไดคลอโรเบนซีน	*o*-dichlorobenzene	95-50-1	-	-	-	50 ppm
110	พารา-ไดคลอโรเบนซีน	*p*-dichlorobenzene	106-46-7	75 ppm	-	-	-
111	1,1-ไดคลอโรอีเธน	1,1-dichloroethane	75-34-3	100 ppm	-	-	-
112	1,2-ไดคลอโรเอทธิลลีน	1,2-dichloroethylene	540-59-0	200 ppm	-	-	-
113	2,4-ดี (กรด 2,4-ไดคลอโรฟีนอกซีอะซิติค)	2,4-D (2,4 dichlorophenoxyacetic acid)	94-75-7	10 mg/m^3	-	-	-
114	1,1-ไดคลอโร-1-ไนโตรอีเธน	1,1-dichloro-1-nitroethane	594-72-9	-	-	-	10 ppm
115	ไดคลอร์วอส (ดีดีวีพี)	dichlorvos (DDVP)	62-73-7	1 mg/m^3	-	-	-
116	ไดโครโตฟอส	dicrotophos	141-66-2	0.05 mg/m^3	-	-	-
117	ดีลดริน	dieldrin	60-57-1	0.25 mg/m^3	-	-	-
118	ไดเอทธาโนลามีน	diethanolamine	111-42-2	1 mg/m^3	-	-	-
119	2-ไดเอทธิลอะมิโนเอทธานอล	2-diethylaminoethanol	100-37-8	10 ppm	-	-	-
120	ไดเอทธิลีน ไตรอะมีน	diethylene triamine	111-40-0	1 ppm	-	-	-
121	ไดเอทธิล คีโตน	diethyl ketone	96-22-0	200 ppm	-	-	-
122	ไดไอโซบิวทิล คีโตน	diisobutyl ketone	108-83-8	50 ppm	-	-	-
123	ไดไอโซโพรพิลอะมีน	diisopropylamine	108-18-9	5 ppm	-	-	-
124	ไดเมทธิลอะนิลีน (เอ็น,เอ็น-ไดเมทธิลอะนิลีน)	dimethylaniline (N,N-dimethylaniline)	121-69-7	5 ppm	-	-	-
125	ไดเมทธิล ฟอร์มาไมด์	dimethylformamide	68-12-2	10 ppm	-	-	-
126	1,1-ไดเมทธิลไฮดราซีน	1,1-dimethylhydrazine	57-14-7	0.5 ppm	-	-	-
127	ไดเมทธิล ซัลเฟท	dimethyl sulfate	77-78-1	1 ppm	-	-	-
128	ไดไนโตรเบนซีน ไอโซเมอร์ทุกรูป	dinitrobenzene, all isomers					
	ออโท	ortho-	528-29-0	1 mg/m^3	-	-	-
	เมตา	meta-	99-65-0	1 mg/m^3	-	-	-
	พารา	para-	100-25-4	1 mg/m^3	-	-	-

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
129	ไดไนโตร-ออโท-ครีซอล	dinitro-o-cresol	534-52-1	0.2 mg/m^3	-	-	-
130	ไดไนโตรโทลูอีน	dinitrotoluene	25321-14-6	1.5 mg/m^3	-	-	-
131	ไดออกเซน (ไดเอทธิลลีน ไดออกไซด์)	dioxane (diethylene dioxide)	123-91-1	100 ppm	-	-	-
132	ไดออกซะไธออน	dioxathion	78-34-2	0.1 mg/m^3	-	-	-
133	ไดฟีนิลอะมีน	diphenylamine	122-39-4	10 mg/m^3	-	-	-
134	ไดโพรพิล คีโตน	dipropyl ketone	123-19-3	50 ppm	-	-	-
135	ไดควอท	diquat	85-00-7 2764-72-9 6385-62-2				
	- อนุภาคทุกขนาดที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- inhalable dust		0.5 mg/m^3	-	-	-
	- อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- respirable dust		0.1 mg/m^3	-	-	-
136	ไดยูรอน	diuron	330-54-1	10 mg/m^3	-	-	-
137	เอ็นโดซัลแฟน	endosulfan	115-29-7	0.1 mg/m^3	-	-	-
138	เอ็นดริน	endrin	72-20-8	0.1 mg/m^3	-	-	-
139	อีพิคลอโรไฮดริน (1-คลอโร-2,3-อีพอกซีโพรเพน)	epichlorohydrin (1-chloro-2, 3-epoxypropane)	106-89-8	5 ppm	-	-	-
140	อีพีเอ็น (เอทธิล พารา-ไนโตรฟีนิล)	EPN (ethyl *p*-nitrophenyl)	2104-64-5	0.5 mg/m^3	-	-	-
141	เอทธานอล (เอทธิล แอลกอฮอล์)	ethanol (ethyl alcohol)	64-17-5	1000 ppm	-	-	-
142	เอทธาโนลามีน	ethanolamine	141-43-5	3 ppm	-	-	-
143	เอทไธออน	ethion	563-12-2	0.05 mg/m^3	-	-	-
144	2-เอทธอกซีเอทธานอล (เซลโลโซล์ฟ)	2-ethoxyethanol (cellosolve)	110-80-5	200 ppm	-	-	-
145	2-เอทธอกซีเอทธิล อะซีเตท (เซลโลโซล์ฟ อะซีเตท)	2-ethoxyethyl acetate (cellosolve acetate)	111-15-9	100 ppm	-	-	-
146	เอทธิล อะซีเตท	ethyl acetate	141-78-6	400 ppm	-	-	-
147	เอทธิล อะครีเลท	ethyl acrylate	140-88-5	25 ppm	-	-	-
148	เอทธิลอะมีน	ethylamine	75-04-7	10 ppm	-	-	-
149	เอทธิล เบนซีน	ethyl benzene	100-41--4	100 ppm	-	-	-
150	เอทธิล โบรไมด์	ethyl bromide	74-96-4	200 ppm	-	-	-
151	เอทธิล คลอไรด์	ethyl chloride	75-00-3	1000 ppm	-	-	-

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
152	เอทธิลีน คลอโรไฮดริน	ethylene chlorohydrin	107-07-3	5 ppm	-	-	-
153	เอทธิลีนไดอะมีน	ethylenediamine	107-15-3	10 ppm	-	-	-
154	เอทธิลีน ไดโบรไมด์	ethylene dibromide	106-93-4	20 ppm	50 ppm	5 min	30 ppm
155	เอทธิลีน ไดคลอไรด์ (1,2-ไดคลอโรอีเทน)	ethylene dichloride (1,2-dichloroethane)	107-06-2	50 ppm	200 ppm	5 min in any 3 hr	100 ppm
156	เอทธิลีน ไกลคอล	ethylene glycol	107-21-1	-	-	-	100 mg/m^3
157	เอทธิลีน ไกลคอล ไดไนเตรท	ethylene glycol dinitrate	628-96-6	-	-	-	0.2 ppm
158	เอทธิลีน ออกไซด์	ethylene oxide	75-21-8	1 ppm	5 ppm	15 min	-
159	เอทธิล อีเธอร์	ethyl ether	60-29-7	400 ppm	-	-	-
160	เอทธิล ฟอร์เมท	ethyl formate	109-94-4	100 ppm	-	-	-
161	เอทธิล เมอร์แคพแทน	ethyl mercaptan	75-08-1	-	-	-	10 ppm
162	เอทธิล ซิลิเคท	ethyl silicate	78-10-4	100 ppm	-	-	-
163	เฟนซัลโฟไธออน	fensulfothion	115-90-2	0.01 mg/m^3	-	-	-
164	เฟนไธออน	fenthion	55-38-9	0.05 mg/m^3	-	-	-
165	ฟลูออรีน	fluorine	7782-41-4	0.1 ppm	-	-	-
166	ฟลูออไรด์ ในรูปของฟลูออรีน	fluorides, as F		2.5 mg/m^3	-	-	-
167	โฟโนฟอส	fonofos	944-22-9	0.1 mg/m^3	-	-	-
168	ฟอร์มัลดีไฮด์	formaldehyde	50-00-0	0.75 ppm	2 ppm	15 min	-
169	กรดฟอร์มิค	formic acid	64-18-6	5 ppm	-	-	-
170	เฟอร์ฟิวรัล	furfural	98-01-1	5 ppm	-	-	-
171	เฟอร์ฟิวริล แอลกอฮอล์	furfuryl alcohol	98-00-0	50 ppm	-	-	-
172	ไกลซีดอล	glycidol	556-52-5	50 ppm	-	-	-
173	เฮพตะคลอร์	heptachlor	76-44-8	0.5 mg/m^3	-	-	-
174	เฮพเทน (นอร์มอล-เฮพเทน)	heptane (n-heptane)	142-82-5	500 ppm	-	-	-
175	เฮกซะเมทธิลีน-ได-ไอโซไซยาเนท	hexamethylene diisocyanate	822-06-0	0.005 ppm	-	-	-
176	นอร์มอล-เฮกเซน	n-hexane	110-54-3	500 ppm	-	-	-
177	ไฮดราซีน	hydrazine	302-01-2	1 ppm	-	-	-
178	ไฮโดรเจน โบรไมด์	hydrogen bromide	10035-10-6	3 ppm	-	-	-
179	ไฮโดรเจน คลอไรด์	hydrogen chloride	7647-01-0	-	-	-	5 ppm

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
180	ไฮโดรเจน ไซยาไนด์	hydrogen cyanide	74-90-8	10 ppm	-	-	-
181	ไฮโดรเจน ฟลูออไรด์ ในรูปของฟลูออรีน	hydrogen fluoride, as F	7664-39-3	3 ppm	-	-	-
182	ไฮโดรเจน เพอร์ออกไซด์	hydrogen peroxide	7722-84-1	1 ppm	-	-	-
183	ไฮโดรเจน ซัลไฟด์	hydrogen sulfide	7783-06-4	-	50 ppm	10 min	20 ppm
184	ไฮโดรควิโนน	hydroquinone	123-31-9	2 mg/m^3	-	-	-
185	2-ไฮดรอกซีโพรพิล อะครีเลท	2-hydroxypropyl acrylate	999-61-1	0.5 ppm	-	-	-
186	ไอโอดีน	iodine	7553-56-2	-	-	-	0.1 ppm
187	ไอโซบิวทิล อะซีเตต	isobutyl acetate	110-19-0	150 ppm	-	-	-
188	ไอโซฟอโรน	isophorone	78-59-1	25 ppm	-	-	-
189	ไอโซฟอโรน ไดไอโซไซยาเนท	isophorone diisocyanate	4098-71-9	0.005 ppm	-	-	-
190	2-ไอโซโพรพอกซีเอทธานอล	2-isopropoxyethanol	109-59-1	25 ppm	-	-	-
191	ไอโซโพรพิล อะซีเตท	isopropyl acetate	108-21-4	250 ppm	-	-	-
192	ไอโซโพรพิล แอลกอฮอล์ (ไอพีเอ)	isopropyl alcohol (IPA)	67-63-0	400 ppm	-	-	-
193	ไอโซโพรพิลอะมีน	isopropylamine	75-31-0	5 ppm	-	-	-
194	ตะกั่วอนินทรีย์ ในรูปของตะกั่ว	lead inorganic, as Pb	7439-92-1	0.05 mg/m^3	-	-	-
195	เลด โครเมท	lead chromate	7758-97-6				
	- ในรูปของตะกั่ว	- as Pb		0.05 mg/m^3	-	-	-
	- ในรูปของโครเมี่ยม	- as Cr		0.012 mg/m^3	-	-	-
196	แอล.พี.จี. (ก๊าซปิโตรเลียมเหลว)	L.P.G. liquified petroleum gas)	68476-85-7	1000 ppm	-	-	-
197	เมอร์คิวรี่ (ปรอท)	mercury	7439-97-6	-	-	-	0.1 mg/m^3
198	ออกาโน (อัลคิล) เมอคิวรี	organo (alkyl) mercury	7439-97-6	0.01 mg/m^3	-	-	0.04 mg/m^3
199	เมทธิล นอร์มอล-บิวทิลคีโตน	methyl n-butyl ketone	591-78-6	100 ppm	-	-	-
200	เมทธิล คลอไรด์	methyl chloride	74-87-3	100 ppm	300 ppm	5 min in any 3 hr	200 ppm
201	เมทธิลไซโคลเฮกเซน	methylcyclohexane	108-87-2	500 ppm	-	-	-
202	เมทธิลไซโคลเฮกซะนอล	methylcyclohexanol	25639-42-3	100 ppm	-	-	-
203	ออโท- เมทธิลไซโคลเฮกซะโนน	*o*-methylcyclohexanone	583-60-8	100 ppm	-	-	-
204	เมทธิลลีน คลอไรด์	methylene chloride	75-09-2	25 ppm	125 ppm	15 min	-

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
205	4,4-เมทธิลีนไดอะนิลีน	4,4-methylene dianiline	101-77-9	0.1 ppm	-	-	-
206	เมทธิล เอทธิล คีโตน (เอ็มอีเค)	methyl ethyl ketone (MEK)	78-93-3	200 ppm	-	-	-
207	เมทธิล เอทธิล คีโตน เพอร์ออกไซด์	methyl ethyl ketone peroxide	1338-23-4	-	-	-	0.2 ppm
208	เมทธิล ฟอร์เมท	methyl formate	107-31-3	100 ppm	-	-	-
209	เมทธิล ไอโอไดด์	methyl iodide	74-88-4	5 ppm	-	-	-
210	เมทธิล ไอโซเอมิล คีโตน	methyl isoamyl ketone	110-12-3	100 ppm	-	-	-
211	เมทธิล ไอโซบิวทิล คาร์บินอล	methyl isobutyl carbinol	108-11-2	25 ppm	-	-	-
212	เมทธิล ไอโซบิวทิลคีโตน	methyl isobutyl ketone	108-10-1	100 ppm	-	-	-
213	เมทธิล ไอโซโพลพิล คีโตน	methyl isopropyl ketone	563-80-4	20 ppm	-	-	-
214	เมทธิล เมอร์แคพแทน	methyl mercaptan	74-93-1	-	-	-	10 ppm
215	เมทธิล เมธาคริเลท	methyl methacrylate	80-62-6	100 ppm	-	-	-
216	เมทธิล พาราไธออน	methyl parathion	298-00-0	0.02 mg/m^3	-	-	-
217	แอลฟา-เมทธิล สไตรีน	alpha-methyl styrene	98-83-9	-	-	-	100 ppm
218	เมวินฟอส (ฟอสดริน)	mevinphos (phosdrin)	7786-34-7	0.01 mg/m^3	-	-	-
219	ไมกา อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	mica, respirable dust	12001-26-2	3 mg/m^3	-	-	-
220	โมโนโครโตฟอส	monocrotophos	6923-22-4	0.05 mg/m^3	-	-	-
221	มอร์โฟลีน	morpholine	110-91-8	20 ppm	-	-	-
222	นิเกิล	nickel	7440-02-0				
	- โลหะ และสารประกอบที่ไม่ละลาย ในรูปของนิเกิล	- metal and insoluble compounds, as Ni		1 mg/m^3	-	-	-
	- สารประกอบที่ละลายได้ ในรูปของนิเกิล	- soluble compounds, as Ni		1 mg/m^3	-	-	-
223	นิโคติน	nicotine	54-11-5	0.5 mg/m^3	-	-	-
224	กรดไนตริค	nitric acid	7697-37-2	2 ppm	-	-	-
225	ไนตรัสออกไซด์	nitrous oxide	10024-97-2	50 ppm	-	-	-
226	ไนตริก ออกไซด์	nitric oxide	10102-43-9	25 ppm	-	-	-
227	ไนโตรเบนซีน	nitrobenzene	98-95-3	1 ppm	-	-	-
228	ไนโตรอีเธน	nitroethane	79-24-3	100 ppm	-	-	-
229	ไนโตรเจน ไดออกไซด์	nitrogen dioxide	10102-44-0	-	-	-	5 ppm

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
230	ไนโตรกลีเซอรีน	nitroglycerin	55-63-0	-	-	-	0.2 ppm
231	ไนโตรมีเธน	nitromethane	75-52-5	100 ppm	-	-	-
232	1-ไนโตรโพรเพน	1-nitropropane	108-03-2	25 ppm	-	-	-
233	2-ไนโตรโพรเพน	2-nitropropane	79-46-9	25 ppm	-	-	-
234	ไนโตรโทลูอีน ทุกไอโซเมอร์	nitrotoluene, all isomers	88-72-2, 99-08-1, 99-99-0	5 ppm	-	-	-
235	ออคเทน	octane	111-65-9	500 ppm	-	-	-
236	ออสเมียม เตตรอกไซด์ ในรูปของออสเมียม	osmium tetroxide, as Os	20816-12-0	0.002 mg/m^3	-	-	-
237	กรดออกซาลิค	oxalic acid	144-62-7	1 mg/m^3	-	-	-
238	ออกซิเจน ไดฟลูออไรด์	oxygen difluoride	7783-41-7	0.05 ppm	-	-	-
239	พาราควอท อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	paraquat, respirable dust	4685-14-7	0.5 mg/m^3	-	-	-
240	พาราไธออน	parathion	56-38-2	0.1 mg/m^3	-	-	-
241	เพนตะบอเรน	pentaborane	19624-22-7	0.005 ppm	-	-	-
242	เพนตะคลอโรแนพธาลีน	pentachloronaphthalene	1321-64-8	0.5 mg/m^3	-	-	-
243	เพนตะคลอโรฟีนอล	pentachlorophenol	87-86-5	0.5 mg/m^3	-	-	-
244	เพนเทน	pentane	109-66-0	1000 ppm	-	-	-
245	เพอร์คลอโรเอทธิลีน (เตตราคลอโรเอทธิลีน)	perchloroethylene (tetrachloroethylene)	127-18-4	100 ppm	300 ppm	5 min in any 3 hr	200 ppm
246	ฟีนอล	phenol	108-95-2	5 ppm	-	-	-
247	ออโท-ฟีนิลลีนไดอะมีน	*o*-phenylenediamine	95-54-5	0.1 mg/m^3	-	-	-
248	เมตา-ฟีนิลลีนไดอะมีน	*m*-phenylene diamine	108-45-2	0.1 mg/m^3	-	-	-
249	พารา-ฟีนิลลีนไดอะมีน	*p*-phenylene diamine	106-50-3	0.1 mg/m^3	-	-	-
250	โฟเรท	phorate	298-02-2	0.05 mg/m^3	-	-	-
251	ฟอสจีน (คาร์บอนิล คลอไรด์)	phosgene (carbonyl chloride)	75-44-5	0.1 ppm	-	-	-
252	กรดฟอสฟอริค	phosphoric acid	7664-38-2	1 mg/m^3	-	-	-
253	ฟอสฟอรัส (เหลือง)	phosphorus (yellow)	7723-14-0	0.1 mg/m^3	-	-	-
254	ฟอสฟอรัส ออกซีคลอไรด์	phosphorus oxychloride	10025-87-3	0.1 ppm	-	-	-
255	ฟอสฟอรัส เพนตะคลอไรด์	phosphorus pentachloride	10026-13-8	1 mg/m^3	-	-	-

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
256	ฟอสฟอรัส เพนตะซัลไฟด์	phosphorus pentasulfide	1314-80-3	1 mg/m^3	-	-	-
257	ฟอสฟอรัส ไตรคลอไรด์	phosphorus trichloride	7719-12-2	0.5 ppm	-	-	-
258	พธาลิค แอนไฮไดรด์	phthalic anhydride	85-44-9	2 ppm	-	-	-
259	กรดพิคริค	picric acid	88-89-1	0.1 mg/m^3	-	-	-
260	พินโดน (2-ไพวาริล-1,3-อินเดนไดโอน)	pindone (2-pivalyl-1,3-indandione)	83-26-1	0.1 mg/m^3	-	-	-
261	โปแตสเซียม ไฮดรอกไซด์	potassium hydroxide	1310-58-3	-	-	-	2 mg/m^3
262	โพรพากิล แอลกอฮอล์	propargyl alcohol	107-19-7	1 ppm	-	-	-
263	1,3-โพรไพโอแลคโตน	1,3-propiolactone	57-57-8	0.5 ppm	-	-	-
264	กรดโพรพิโอนิค	propionic acid	79-09-4	10 ppm	-	-	-
265	โพรพอกเซอร์	propoxur	114-26-1	0.5 mg/m^3	-	-	-
266	นอร์มอล-โพรพิล อะซีเตท	n-propyl acetate	109-60-4	200 ppm	-	-	-
267	นอร์มอล-โพรพิล แอลกอฮอล์	n-propyl alcohol	71-23-8	200 ppm	-	-	-
268	โพรพิลีน อิมีน	propylene imine	75-55-8	2 ppm	-	-	-
269	โพรพิลีน ออกไซด์	propylene oxide	75-56-9	100 ppm	-	-	-
270	ไพริดีน	pyridine	110-86-1	5 ppm	-	-	-
271	ควิโนน	quinone	106-51-4	0.1 ppm	-	-	-
272	รีซอร์ซินอล	resorcinol	108-46-3	10 ppm	-	-	-
273	โรทีโนน	rotenone	83-79-4	5 mg/m^3	-	-	-
274	เซเลเนียม เฮกซะฟลูออไรด์ ในรูปของเซเลเนียม	selenium hexafluoride, as Se	7783-79-1	0.05 ppm	-	-	-
275	สารประกอบเซเลเนียม ในรูปของเซเลเนียม	selenium compounds ,as Se	7782-49-2	0.2 mg/m^3	-	-	-
276	ซิลิกา คริสตัลลีน	silica, crystalline					
	- คริสโตบาไลท์ อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- cristobalite, respirable dust	14464-46-1	0.025 mg/m^3	-	-	-
	- แอลฟา-ควอร์ซ อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- α-quartz, respirable dust	1317-95-9, 14808-60-7	0.025 mg/m^3	-	-	-
277	โซเดียม อะไซด์	sodium azide	26628-22-8				
	- ในรูปของโซเดียม อะไซด์	as sodium azide		-	-	-	0.29 mg/m^3
	- ในรูปไอของกรดไฮดราโซอิก	as hydrazoic acid vapour		-	-	-	0.11 ppm

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
278	โซเดียม ไบซัลไฟต์	sodium bisulfite	7631-90-5	5 mg/m^3	-	-	-
279	โซเดียม ไฮดรอกไซด์	sodium hydroxide	1310-73-2	2 mg/m^3	-	-	-
280	สตรอนเทียม โครเมท ในรูปของโครเมียม	strontium chromate, as Cr	7789-06-2	0.0005 mg/m^3	-	-	-
281	สตริคนิน	strychnine	57-24-9	0.15 mg/m^3	-	-	-
282	สไตรีน	styrene	100-42-5	100 ppm	600 ppm	5 min in any 3 hr	200 ppm
283	ซัลโฟเทพ	sulfotep	3689-24-5	0.1 mg/m^3	-	-	-
284	ซัลเฟอร์ ไดออกไซด์	sulfur dioxide	7446-09-5	5 pmm	-	-	-
285	กรดซัลฟูริก	sulfuric acid	7664-93-9	1 mg/m^3	-	-	-
286	ทัลก์	talc	14807-96-6				
	- ที่ไม่มีส่วนประกอบของเส้นใยแอสเบสทอส อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- containing no asbestos fibres, respirable dust		2 mg/m^3	-	-	-
	- ที่มีส่วนประกอบของเส้นใยแอสเบสทอส อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- containing asbestos fibres, respirable dust		0.1 f/cm^3	-	-	-
287	ทีอีพีพี (เตตระเอทธิล ไพโรฟอสเฟต)	TEPP (tetraethyl pyrophosphate)	107-49-3	0.05 mg/m^3	-	-	-
288	เทลลูเลียม เฮกซะฟลูออไรด์ ในรูปของเทลลูเลียม	tellurium hexafluoride, as Te	7783-80-4	0.02 ppm	-	-	-
289	1,1,2,2-เตตระคลอโรอีเทน	1,1,2,2-tetrachloroethane	79-34-5	5 ppm	-	-	-
290	เตตระเอทธิล เลด ในรูปของตะกั่ว	tetraethyl lead, as Pb	78-00-2	0.075 mg/m^3	-	-	-
291	เตตระไฮโดรฟิวแรน	tetrahydrofuran	109-99-9	200 ppm	-	-	-
292	เตตระเมทธิล เลด ในรูปของตะกั่ว	tetramethyl lead, as Pb	75-74-1	0.075 mg/m^3	-	-	-
293	แทลเลียม สารประกอบที่ละลายในรูปของแทลเลียม	thallium, soluble compounds, as Tl	7440-28-0	0.1 mg/m^3	-	-	-
294	กรดไธโอไกลโคลิค	thioglycolic acid	68-11-1	1 ppm	-	-	-
295	ไธโอนิล คลอไรด์	thionyl chloride	7719-09-7	-	-	-	0.2 ppm
296	ไธแรม	thiram	137-26-8	5 mg/m^3	-	-	-
297	โทลูอีน	toluene	108-88-3	200 ppm	500 ppm	10 min	300 ppm
298	โทลูอีน-2,4-ไดไอโซไซยาเนท (ทีดีไอ)	toluene - 2,4-diisocyanate (TDI)	584-84-9	-	-	-	0.02 ppm

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
299	ออโท-โทลูอิดีน	*o*-toluidine	95-53-4	5 ppm	-	-	-
300	ไตรบิวทิล ฟอสเฟต	tributyl phosphate	126-73-8	5 mg/m^3	-	-	-
301	กรดไตรคลอโรอะซิติค	trichloroacetic acid	76-03-9	0.5 ppm	-	-	-
302	1,1,1-ไตรคลอโรอีเทน (เมทธิลคลอโรฟอร์ม)	1,1,1-trichloroethane (methyl chloroform)	71-55-6	350 ppm	-	-	-
303	1,1,2-ไตรคลอโรอีเทน	1,1,2-trichloroethane	79-00-5	10 ppm	-	-	-
304	ไตรคลอโรเอทธิลีน	trichloroethylene	79-01-6	100 ppm	300 ppm	5 min in any 2 hr	200 ppm
305	1,2,3-ไตรคลอโรโพรเพน	1,2,3-trichloropropane	96-18-4	50 ppm	-	-	-
306	2,4,5 ที (กรด 2,4,5-ไตรคลอโรฟีนอกซีอะซิติค)	2,4,5 T (2,4,5,-trichlorophenoxyacetic acid)	93-76-5	10 mg/m^3	-	-	-
307	ไตรเอทธิลอะมีน	triethylamine	121-44-8	25 ppm	-	-	-
308	เทอร์เพนทีน	turpentine	8006-64-2	100 ppm	-	-	-
309	ยูเรเนียม ในรูปของยูเรเนียม	uranium, as U	7440-61-1				
	- สารประกอบที่ละลายได้	- soluble compounds		0.05 mg/m^3	-	-	-
	- สารประกอบที่ไม่ละลาย	- insoluble compounds		0.25 mg/m^3	-	-	-
310	วาเนเดียม	vanadium	1314-62-1				
	- อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้ ในรูปของไดวาเนเดียมเพนออกไซด์	- respirable dust, as V_2O_5		-	-	-	0.5 mg/m^3
	- ฟูม ในรูปของไดวาเนเดียมเพนออกไซด์	- fume, as V_2O_5		-	-	-	0.1 mg/m^3
311	ไวนิล อะซีเตท	vinyl acetate	108-05-4	10 ppm	-	-	-
312	ไวนิล โบรไมด์	vinyl bromide	593-60-2	0.5 ppm	-	-	-
313	ไวนิล คลอไรด์	vinyl chloride	75-01-4	1 ppm	5 ppm	15 min	-
314	ไวนิลิดีน คลอไรด์	vinylidene chloride	75-35-4	5 ppm	-	-	-
315	ไวนิล โทลูอีน	vinyl toluene	25013-15-4	100 ppm	-	-	-
316	วาร์ฟาริน	warfarin	81-81-2	0.1 mg/m^3	-	-	-
317	ไซลีน (ออโอ เมตา พารา ไอโซเมอร์)	xylene (*o*-, *m*-, *p*- isomers)	1330-20-7	100 ppm	-	-	-
318	ไซลิดีน	xylidine	1300-73-8	5 ppm	-	-	-
319	ฟูมของสังกะสีคลอไรด์	zinc chloride fume	7646-85-7	1 mg/m^3	-	-	-

ลำดับที่	ชื่อสารเคมีอันตราย (ไทย)	ชื่อสารเคมีอันตราย (อังกฤษ)	CAS No.	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ	ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ		ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน
					ขีดจำกัดความเข้มข้น	ระยะเวลาที่กำหนดให้ทำงานได้	
320	ซิงค์ โครเมท ในรูปของโครเมียม	zinc chromates, as Cr	13530-65-9, 11103-86-9, 37300-23-5	0.01 mg/m^3	-	-	-
321	ซิงค์ สเตียร์เรท	zinc stearate	557-05-1				
	- อนุภาคทุกขนาดที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- inhalable dust		15 mg/m^3	-	-	-
	- อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- respirable dust		5 mg/m^3	-	-	-
322	สังกะสี ออกไซด์	zinc oxide	1314-13-2				
	- อนุภาคทุกขนาดที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- inhalable dust		15 mg/m^3	-	-	-
	- อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้	- respirable dust		5 mg/m^3	-	-	-
323	ฟูมของสังกะสี ออกไซด์	zinc oxide fume	1314-13-2	5 mg/m^3	-	-	-
324	สารประกอบ เซอร์โคเนียม ในรูปของเซอร์โคเนียม	zirconium compounds, as Zr	7440-67-7	5 mg/m^3	-	-	-

หมายเหตุ

"ขีดจำกัดความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติ" หมายถึง ระดับความเข้มข้นของสารเคมีอันตรายเฉลี่ยตลอดระยะเวลาการทำงานปกติภายในสถานประกอบกิจการที่ลูกจ้างซึ่งมีสุขภาพปกติทำงานสามารถสัมผัสหรือได้รับเข้าสู่ร่างกายได้ทุกวันตลอดเวลาที่ทำงานโดยไม่เป็นอันตรายต่อสุขภาพ

"ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสำหรับการสัมผัสในระยะเวลาสั้นๆ" หมายถึง ระดับความเข้มข้นของสารเคมีอันตรายที่ลูกจ้างสัมผัสอย่างต่อเนื่องในระยะเวลาสั้นๆ ตามที่กำหนด โดยไม่มีอาการระคายเคือง เนื้อเยื่อถูกทำลายอย่างถาวรหรืออย่างเรื้อรัง มึนเมา หลับ หรือง่วงซึมจนอาจทำให้เกิดอุบัติเหตุ หรือไม่สามารถช่วยตนเองได้ หรือประสิทธิภาพการทำงานลดลงอย่างมาก

"ขีดจำกัดความเข้มข้นของสารเคมีอันตรายสูงสุดไม่ว่าเวลาใดๆ ในระหว่างทำงาน" หมายถึง ระดับความเข้มข้นของสารเคมีอันตรายสูงสุดซึ่งต้องไม่เกินกว่าค่าที่กำหนดไว้ไม่ว่าเวลาใดๆ ในระหว่างทำงาน

"อนุภาคทุกขนาดที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้ (inhalable dust)" หมายถึง อนุภาคขนาดเล็กกว่าหรือเท่ากับ ๑๐๐ ไมโครเมตร แขวนลอยในอากาศที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้

"อนุภาคขนาดเล็กที่อาจสูดเข้าสู่ระบบทางเดินหายใจได้ (respirable dust)" หมายถึง อนุภาคขนาดเล็กกว่าหรือเท่ากับ ๑๐ ไมโครเมตร แขวนลอยในอากาศที่อาจสูดเข้าสู่ระบบทางเดินหายใจ และสามารถเข้าถึงและสะสมในบริเวณพื้นที่แลกเปลี่ยนอากาศของปอด

mg/m^3	หมายถึง	มิลลิกรัมต่ออากาศหนึ่งลูกบาศก์เมตร
f/cm^3	หมายถึง	จำนวนเส้นใยต่ออากาศหนึ่งลูกบาศก์เซนติเมตร
ppm	หมายถึง	ส่วนในล้านส่วนโดยปริมาตร



ประกาศกระทรวงอุตสาหกรรม

เรื่อง มาตรการคุ้มครองความปลอดภัยในการประกอบกิจการโรงงานเกี่ยวกับสภาวะแวดล้อมในการทำงาน

พ. ศ. 2546

อาศัยอำนาจตามความในข้อ 18 แห่งกฎกระทรวงฉบับที่ 2 (พ.ศ. 2535) ออกตามความในพระราชบัญญัติโรงงาน พ.ศ. 2535 อันเป็นพระราชบัญญัติที่มีบทบัญญัติบางประการที่เกี่ยวกับการจำกัดสิทธิและเสรีภาพของบุคคล ซึ่งมาตรา 29 ประกอบกับมาตรา 35 มาตรา 48 กับมาตรา 50 ของรัฐธรรมนูญแห่งราชอาณาจักรไทย บัญญัติให้กระทำได้โดยอาศัยอำนาจตามบทบัญญัติแห่งกฎหมาย รัฐมนตรีว่าการกระทรวงอุตสาหกรรมออกประกาศไว้ดังต่อไปนี้

ข้อ 1. ในประกาศนี้

"ระดับความร้อน" หมายความว่า อุณหภูมิความร้อนในบริเวณที่ปฏิบัติงาน ตรวจวัดเป็นอุณหภูมิเวทบัลบ์โกลบ (Wet Bulb Globe Temperature : WBGT) เฉลี่ยในช่วงเวลาสองชั่วโมงที่มีอุณหภูมิเวทบัลบ์โกลบสูงสุดของการทำงานปกติ

"อุณหภูมิเวทบัลบ์โกลบ" หมายความว่า อุณหภูมิซึ่งวัดเป็นองศาเซลเซียส คำนวณได้จากสูตร ต่อไปนี้

WBGT = 0.7 NWB + 0.3 GT (ในกรณีในอาคารหรือนอกอาคารที่ไม่มีแสงแดด)

WBGT = 0.7 NWB + 0.2 GT + 0.1 DB (ในกรณีนอกอาคารที่มีแสงแดด)

โดยที่ NWB (Natural Wet Bulb Temperature) คืออุณหภูมิที่อ่านค่าจากเทอร์โมมิเตอร์กระเปาะเปียกตามธรรมชาติ วัดเป็นองศาเซลเซียส

GT (Globe Temperature) คืออุณหภูมิที่อ่านค่าจากโกลบเทอร์โมมิเตอร์ วัดเป็นองศาเซลเซียส

DB (Dry Bulb Temperature) คือ อุณหภูมิที่อ่านค่าจากเทอร์โมมิเตอร์กระเปาะแห้ง วัดเป็นองศาเซลเซียส

"งานเบา" หมายความว่า ลักษณะงานที่ใช้แรงน้อยหรือใช้กำลังงานที่ทำให้เกิดการเผาผลาญอาหารในร่างกายไม่เกิน 200 กิโลแคลอรี/ชั่วโมง เช่น งานเขียนหนังสือ งานพิมพ์ดีด งานบันทึกข้อมูล งานเย็บจักร งานนั่งตรวจสอบผลิตภัณฑ์ งานประกอบชิ้นงานขนาดเล็ก งานบังคับเครื่องจักรด้วยเท้า การยืนคุมงาน เป็นต้น หรืองานที่เทียบเคียงได้กับงานดังกล่าว

"งานปานกลาง" หมายความว่า ลักษณะงานที่ใช้แรงปานกลางหรือใช้กำลังงานที่ทำให้เกิดการเผาผลาญอาหารในร่างกายเกินกว่า 200 กิโลแคลอรี/ชั่วโมง ถึง 350 กิโลแคลอรี/ชั่วโมง เช่น

ประกาศในราชกิจจานุเบกษา ฉบับประกาศทั่วไป
เล่ม 120 ตอน พิเศษ 138ง เมื่อวันที่ 3 ธันวาคม 2546

งานยก ลาก ดัน หรือเคลื่อนย้ายสิ่งของด้วยแรงปานกลาง งานตอกตะปู งานตะไบ งานขับรถบรรทุก งานขับรถแทรกเตอร์ เป็นต้น หรืองานที่เทียบเคียงได้กับงานดังกล่าว

"งานหนัก" หมายความว่า ลักษณะงานที่ใช้แรงมาก หรือใช้กำลังงานที่ทำให้เกิดการเผาผลาญอาหารในร่างกายเกินกว่า 350 กิโลแคลอรี/ชั่วโมง ถึง 500 กิโลแคลอรี/ชั่วโมง เช่น งานที่ใช้พลั่วหรือเสียม ขุดดิน งานเลื่อยไม้ งานเจาะไม้เนื้อแข็ง งานทุบโดยใช้ฆ้อนขนาดใหญ่ งานยกหรือเคลื่อนย้ายของหนักขึ้นที่สูงหรือที่ลาดชัน เป็นต้น หรืองานที่เทียบเคียงได้กับงานดังกล่าว

หมวด 1
ความร้อน

ข้อ 2. บริเวณปฏิบัติงานต้องมีระดับความร้อนไม่เกินกว่ามาตรฐานที่กำหนดไว้ในตารางท้ายหมวดนี้

ข้อ 3. บริเวณปฏิบัติงานที่มีระดับความร้อนเกินกว่ามาตรฐานตามข้อ 2 ผู้ประกอบกิจการโรงงานต้องปิดประกาศเตือนให้ทราบถึงบริเวณที่มีความร้อนสูงเกินมาตรฐานที่กำหนด

ข้อ 4. ในกรณีที่ภายในบริเวณปฏิบัติงานมีระดับความร้อนเกินมาตรฐาน ตามข้อ 2 ผู้ประกอบกิจการโรงงานต้องดำเนินการปรับปรุงหรือแก้ไขให้บริเวณปฏิบัติงานมีระดับความร้อนอยู่ในเกณฑ์มาตรฐาน หากได้ดำเนินการปรับปรุงหรือแก้ไขแล้ว ไม่สามารถควบคุมให้เป็นไปตามมาตรฐานดังกล่าวได้ ผู้ประกอบกิจการโรงงานต้องจัดหาอุปกรณ์ป้องกันอันตรายส่วนบุคคล เช่น ชุดแต่งกาย รองเท้า และถุงมือเพื่อป้องกันความร้อน สำหรับผู้ที่จะเข้าไปในบริเวณดังกล่าว ตลอดจนต้องจัดให้มีการอบรมการใช้อุปกรณ์ป้องกันอันตรายส่วนบุคคลด้วย

ตารางแสดงมาตรฐานระดับความร้อน

ความหนักเบาของงาน	มาตรฐานระดับความร้อน ค่าเฉลี่ยอุณหภูมิเวทบัลบ์โกลบ (WBGT) กำหนดเป็นองศาเซลเซียส
เบา	34.0
ปานกลาง	32.0
หนัก	30.0

หมวด 2
แสงสว่าง

ข้อ 5. ผู้ประกอบกิจการโรงงานต้องป้องกันมิให้มีแสงตรง หรือแสงสะท้อนส่องเข้าตาคนงานในการปฏิบัติงาน

ข้อ 6. ผู้ประกอบกิจการโรงงานต้องจัดให้มีแสงสว่างเพียงพอแก่การทำงานอย่างทั่วถึง สามารถมองเห็นสิ่งกีดขวาง และส่วนที่อาจก่อให้เกิดอันตรายจากการเคลื่อนไหวของเครื่องจักร หรืออันตรายจากไฟฟ้า ตลอดจนบันไดขึ้นลงและทางออก ในเวลามีเหตุฉุกเฉินอย่างชัดเจน ตามหลักเกณฑ์ดังต่อไปนี้

(1) ลานถนนและทางเดินนอกอาคารโรงงาน ความเข้มของการส่องสว่างต้องไม่น้อยกว่า 20 ลักซ์ (LUX) หรือ 2 ฟุต-แคนเดิล (Foot Candle)

(2) บริเวณทางเดินในอาคารโรงงาน ระเบียง บันได ห้องพักผ่อน ห้องพักฟื้นของพนักงาน ห้องเก็บของที่มิได้มีการเคลื่อนย้าย ความเข้มของการส่องสว่างต้องไม่น้อยกว่า 50 ลักซ์

(3) บริเวณการปฏิบัติงานที่ไม่ต้องการความละเอียด ได้แก่ บริเวณการสีข้าว สางฝ้าย หรือการปฏิบัติงานขั้นแรกในกระบวนการอุตสาหกรรมต่าง ๆ และบริเวณจุดขนถ่ายสินค้า ป้อมยาม ลิฟท์ ห้องเปลี่ยนเสื้อผ้าและบริเวณตู้เก็บของ ห้องน้ำและห้องส้วม ความเข้มของการส่องสว่างต้องไม่น้อยกว่า 100 ลักซ์

(4) บริเวณการปฏิบัติงานที่ต้องการความละเอียดน้อยมาก ได้แก่ งานหยาบที่ทำที่โต๊ะ หรือเครื่องจักร ชิ้นงานมีขนาดใหญ่กว่า 750 ไมโครเมตร(0.75 มิลลิเมตร) การตรวจงานหยาบด้วยสายตา การนับ การตรวจเช็คสิ่งของที่มีขนาดใหญ่ และบริเวณพื้นที่ในโกดัง ความเข้มของการส่องสว่างต้องไม่น้อยกว่า 200 ลักซ์

(5) บริเวณการปฏิบัติงานที่ต้องการความละเอียดน้อย ได้แก่ บริเวณที่ปฏิบัติงานเกี่ยวกับงานรับจ่ายเสื้อผ้า การทำงานไม้ที่มีชิ้นงานขนาดปานกลาง งานบรรจุน้ำลงขวดหรือกระป๋อง งานเจาะรู ทากาว หรือเย็บเล่มหนังสือ ความเข้มของการส่องสว่างต้องไม่น้อยกว่า 300 ลักซ์

ในบริเวณการปฏิบัติงานที่มีขนาดของชิ้นงานตั้งแต่ 125 ไมโครเมตร (0.125 มิลลิเมตร) ได้แก่งานเกี่ยวกับงานประจำในสำนักงาน เช่น งานพิมพ์ดีด เขียนและอ่าน งานประกอบรถยนต์และตัวถัง การทำงานไม้อย่างละเอียด ความเข้มของการส่องสว่างต้องไม่น้อยกว่า 400 ลักซ์

(6) บริเวณการปฏิบัติงานที่ต้องการความละเอียดปานกลาง ได้แก่ งานเขียนแบบ งานระบายสี พ่นสีและตกแต่งสีอย่างละเอียด งานพิสูจน์อักษร งานตรวจสอบขั้นสุดท้ายในโรงงานผลิตรถยนต์ ความเข้มของการส่องสว่างต้องไม่น้อยกว่า 600 ลักซ์

(7) บริเวณการปฏิบัติงานที่ต้องการความละเอียดสูง โดยมีขนาดของชิ้นงานตั้งแต่ 25 ไมโครเมตร (0.025 มิลลิเมตร) ได้แก่ บริเวณที่ปฏิบัติงานเกี่ยวกับการตรวจสอบงานละเอียด เช่น การปรับเทียบมาตรฐานความถูกต้องและความแม่นยำของอุปกรณ์ การระบายสี พ่นสี และตกแต่งชิ้นงานที่ต้องการความละเอียดมากเป็นพิเศษ งานย้อมสี ความเข้มของการส่องสว่างต้องไม่น้อยกว่า 800 ลักซ์ ในบริเวณการปฏิบัติงานเกี่ยวกับการตรวจสอบ การตัดเย็บเสื้อผ้าด้วยมือ การตรวจสอบและตกแต่งสินค้าสิ่งทอ สิ่งถักหรือเสื้อผ้าที่มีสีอ่อนขั้นสุดท้ายด้วยมือ การคัดแยกและเทียบสีหนังที่มีสีเข้ม การเทียบสีในงานย้อมผ้า ความเข้มของการส่องสว่างต้องไม่น้อยกว่า 1200 ลักซ์

(8) บริเวณการปฏิบัติงานที่ต้องการความละเอียดสูงมาก ได้แก่ งานละเอียดที่ต้องทำบนโต๊ะหรือเครื่องจักร เช่น ทำเครื่องมือและแม่พิมพ์ที่มีรายละเอียดขนาดเล็กกว่า 25 ไมโครเมตร (0.025 มิลลิเมตร) งานตรวจสอบตรวจวัดชิ้นส่วนที่มีขนาดเล็กหรือชิ้นงานที่มีส่วนประกอบขนาดเล็ก งานซ่อมแซมสินค้า สิ่งทอ สิ่งถักที่มีสีอ่อน งานตรวจสอบและตกแต่งชิ้นส่วนของสินค้าสิ่งทอ สิ่งถักที่มีสีเข้มด้วยมือ ความเข้มของการส่องสว่างต้องไม่น้อยกว่า 1600 ลักซ์

(9) บริเวณการปฏิบัติงานที่ต้องการความละเอียดสูงมากเป็นพิเศษ ได้แก่ การปฏิบัติงานเกี่ยวกับการตรวจสอบชิ้นงานที่มีขนาดเล็กมาก การเจียระไนเพชร การทำนาฬิกาข้อมือในกระบวนการที่มีขนาดเล็ก การถัก ซ่อมแซมเสื้อผ้า ถุงเท้าที่มีสีเข้ม ความเข้มของการส่องสว่างต้องไม่น้อยกว่า 2400 ลักซ์

ข้อ 7. ความเข้มของการส่องสว่าง ณ ที่ปฏิบัติงานหรือลักษณะการปฏิบัติงานนอกเหนือจากที่กำหนดไว้ในข้อ 6 ผู้ประกอบกิจการโรงงานต้องจัดให้มีความเข้มของการส่องสว่าง เทียบเคียงไม่ต่ำกว่าหลักเกณฑ์ที่ได้กำหนดไว้

หมวด 3
เสียง

ข้อ 8. ผู้ประกอบกิจการโรงงานต้องควบคุมมิให้บริเวณปฏิบัติงานในโรงงานมีระดับเสียงเกินกว่ามาตรฐานที่ได้กำหนดไว้ในตารางท้ายหมวดนี้

ข้อ 9. ห้ามมิให้บุคคลเข้าไปในบริเวณที่มีเสียงดังเกินกว่า 140 เดซิเบลเอ

ข้อ 10. บริเวณปฏิบัติงานที่มีระดับเสียงเกินกว่ามาตรฐานตามข้อ 8 ผู้ประกอบกิจการโรงงานต้องปิดประกาศเตือนให้ทราบถึงบริเวณที่มีเสียงดังเกินมาตรฐานที่กำหนด

ตารางแสดงมาตรฐานเปรียบเทียบระดับเสียงเฉลี่ยที่ยอมรับได้กับเวลาการทำงานในแต่ละวัน

เวลาการทำงานที่ได้รับเสียงใน 1 วัน (ชม.)	ระดับเสียงเฉลี่ยตลอดเวลาการทำงานไม่เกิน (เดซิเบลเอ)
12	87
8	90
6	92
4	95
3	97
2	100
1 ½	102
1	105
½	110
¼ หรือน้อยกว่า	115

หมายเหตุ หากเวลาการปฏิบัติงานไม่มีค่ามาตรฐานที่กำหนดตรงตามตารางข้างต้น ให้คำนวณ โดยใช้สูตร $T = \frac{8}{2^{(L-90)/5}}$

เมื่อ T หมายถึง เวลาการทำงานที่ยอมให้ได้รับเสียง (ชั่วโมง)

L หมายถึง ระดับเสียง (เดซิเบลเอ)

ในกรณีค่าระดับเสียงเฉลี่ยตลอดเวลาการทำงาน ที่ได้จากการคำนวณมีเศษทศนิยมให้ตัดเศษทศนิยมออก

หมวด 4
การตรวจวัดและวิเคราะห์สภาวะแวดล้อมในการทำงาน

ข้อ 11. ผู้ประกอบกิจการโรงงาน ต้องจัดให้มีการตรวจวัด วิเคราะห์ และจัดทำรายงานสภาพแวดล้อมในการทำงานเกี่ยวกับระดับความร้อน แสงสว่างและเสียงอย่างน้อยปีละ 1 ครั้ง โดยมีเจ้าหน้าที่ความปลอดภัยในการทำงานระดับวิชาชีพหรือผู้สำเร็จการศึกษาไม่ต่ำกว่าปริญญาตรีทางด้านวิทยาศาสตร์เป็นผู้รับรองรายงาน และให้เก็บรายงานดังกล่าวไว้ ณ ที่ตั้งโรงงานให้พร้อมสำหรับการตรวจสอบของพนักงานเจ้าหน้าที่

ข้อ 12. การตรวจวัดความร้อน บริเวณที่ทำการตรวจวัดต้องเป็นบริเวณที่มีการปฏิบัติงานอยู่ในสภาพการทำงานปกติ การตรวจวัดต้องเป็นบริเวณที่มีระดับความร้อนสูง และต้องตรวจวัดในเดือนที่มีอากาศร้อนของปี ประเภทหรือชนิดของโรงงานที่ต้องดำเนินการตรวจวัดความร้อนตามที่กำหนดไว้ในบัญชีที่ 1 ท้ายประกาศนี้

ข้อ 13. การตรวจวัดแสงสว่าง บริเวณที่ทำการตรวจวัดต้องเป็นบริเวณที่มีการปฏิบัติงานในสภาพการทำงานปกติ การตรวจวัดต้องเป็นบริเวณที่มีความเข้มของการส่องสว่างต่ำ โดยกำหนดให้โรงงานจำพวกที่ 3 ทุกประเภทต้องทำการตรวจวัดแสงสว่าง

ข้อ 14. การตรวจวัดระดับเสียง บริเวณที่ทำการตรวจวัดต้องเป็นบริเวณที่มีการปฏิบัติงานในสภาพการทำงานปกติ การตรวจวัดต้องเป็นบริเวณที่มีระดับเสียงสูง ประเภทหรือชนิดของโรงงานที่ต้องดำเนินการตรวจวัดเสียงตามที่กำหนดไว้ในบัญชีที่ 2 ท้ายประกาศนี้

ข้อ 15. วิธีการตรวจวัดและวิเคราะห์ให้เป็นไปตามหลักมาตรฐานสากล เช่น มาตรฐานของ Occupational Safety & Health Administration (OSHA) มาตรฐานของ National Institute Occupational Safety and Health (NIOSH) เป็นต้น หรือวิธีอื่นใดที่กรมโรงงานอุตสาหกรรมเห็นชอบ

หมวด 5
เบ็ดเตล็ด

ข้อ 16. ประกาศฉบับนี้ให้ใช้บังคับเมื่อพ้นกำหนดหนึ่งร้อยแปดสิบวัน นับแต่วันที่ประกาศในราชกิจจานุเบกษา เป็นต้นไป

ประกาศ ณ วันที่ 6 พฤศจิกายน พ.ศ. 2546

(นายสมศักดิ์ เทพสุทิน)
รัฐมนตรีว่าการกระทรวงอุตสาหกรรม

บัญชีท้ายประกาศกระทรวงอุตสาหกรรม
เรื่อง มาตรการคุ้มครองความปลอดภัยในการประกอบกิจการโรงงานเกี่ยวกับสภาวะแวดล้อมในการทำงาน พ.ศ. 2546

บัญชีที่ 1 ประเภทหรือชนิดของโรงงานที่ต้องทำการตรวจวัดความร้อน

ลำดับที่	ตามประเภทหรือชนิดของโรงงานในบัญชีท้ายกฎกระทรวง (พ.ศ. 2535) ออกตามความในพระราชบัญญัติโรงงาน พ.ศ. 2535
11(3)(4)	โรงงานผลิตน้ำตาลทรายดิบ น้ำตาลทรายขาว หรือการทำให้บริสุทธิ์
22(3)	โรงงานสิ่งทอที่ทำการฟอก ย้อมสี หรือแต่งสำเร็จด้ายหรือสิ่งทอ
38(1)(2)	โรงงานผลิตเยื่อกระดาษจากไม้หรือวัสดุอื่น การทำกระดาษ กระดาษแข็ง หรือกระดาษที่ใช้ในการก่อสร้างชนิดที่ทำจากเส้นใย หรือแผ่นกระดาษไฟเบอร์
51	โรงงานผลิต ซ่อม หล่อ หรือหล่อดอกยางนอก หรือยางในสำหรับยานพาหนะที่เคลื่อนที่ด้วยเครื่องกล คน หรือสัตว์
54	โรงงานผลิตแก้ว เส้นใยแก้วหรือผลิตภัณฑ์แก้ว
57(1)	โรงงานทำซีเมนต์ ปูนขาว หรือปูนปลาสเตอร์
59	โรงงานประกอบกิจการเกี่ยวกับการถลุง หลอม หล่อ รีด ดึง ผลิตเหล็ก หรือเหล็กกล้าในขั้นต้น
60	โรงงานประกอบกิจการเกี่ยวกับการถลุง ผสมทำให้บริสุทธิ์ หลอม หล่อ รีด ดึง หรือผลิตโลหะขั้นต้น ซึ่งมิใช่เหล็กหรือเหล็กกล้า
61	โรงงานผลิต ตบแต่ง ดัดแปลง หรือซ่อมแซมเครื่องมือ หรือเครื่องใช้ที่ทำด้วยเหล็กหรือเหล็กกล้า และรวมถึงส่วนประกอบหรืออุปกรณ์ของเครื่องมือหรือเครื่องใช้ดังกล่าว
62	โรงงานผลิต ตบแต่ง ดัดแปลง หรือซ่อมแซมเครื่องเรือน หรือเครื่องตบแต่งภายในอาคารที่ทำจากโลหะหรือโลหะเป็นส่วนใหญ่ และรวมถึงส่วนประกอบหรืออุปกรณ์ของเครื่องเรือน หรือเครื่องตกแต่งดังกล่าว
63	โรงงานประกอบกิจการเกี่ยวกับผลิตภัณฑ์โลหะสำหรับใช้ในการก่อสร้าง
64	โรงงานประกอบกิจการเกี่ยวกับผลิตภัณฑ์โลหะ
65	โรงงานผลิต ประกอบ ดัดแปลง หรือซ่อมแซมเครื่องยนต์ เครื่องกังหัน และรวมถึงส่วนประกอบหรืออุปกรณ์ของเครื่องยนต์ หรือเครื่องกังหันดังกล่าว

บัญชีที่ 1 ประเภทหรือชนิดของโรงงานที่ต้องทำการตรวจวัดความร้อน

ลำดับที่	ตามประเภทหรือชนิดของโรงงานในบัญชีท้ายกฎกระทรวง (พ.ศ. 2535) ออกตามความในพระราชบัญญัติโรงงาน พ.ศ. 2535
66	โรงงานผลิต ประกอบ ดัดแปลง หรือซ่อมแซมเครื่องจักร สำหรับใช้ในการกสิกรรมหรือการเลี้ยงสัตว์ และรวมถึงส่วนประกอบหรืออุปกรณ์ของเครื่องจักรดังกล่าว
67	โรงงานประกอบกิจการเกี่ยวกับเครื่องจักร ส่วนประกอบ หรืออุปกรณ์ของเครื่องจักรสำหรับประดิษฐ์โลหะ หรือไม้
68	โรงงานผลิต ประกอบ ดัดแปลง หรือซ่อมแซมเครื่องจักรสำหรับอุตสาหกรรมกระดาษ เคมี อาหาร การปั่นทอ การพิมพ์ การผลิตซีเมนต์หรือผลิตภัณฑ์ดินเหนียว การก่อสร้าง การทำเหมืองแร่ การเจาะหาปิโตรเลียม หรือการกลั่นน้ำมัน และรวมถึงส่วนประกอบของเครื่องจักรดังกล่าว
74(1)	โรงงานประกอบกิจการเกี่ยวกับการทำหลอดไฟฟ้า หรือดวงโคมไฟฟ้า
77	โรงงานประกอบกิจการเกี่ยวกับรถยนต์ หรือรถพ่วง
78	โรงงานประกอบกิจการเกี่ยวกับจักรยานยนต์ จักรยานสามล้อ หรือจักรยานสองล้อ
79	โรงงานประกอบกิจการเกี่ยวกับอากาศยาน หรือเรือโฮเวอร์คราฟท์
80	โรงงานผลิต ประกอบ ดัดแปลง หรือซ่อมแซมล้อเลื่อน ที่ขับเคลื่อนด้วยแรงคน หรือสัตว์ ซึ่งมิใช่จักรยาน และรวมถึงส่วนประกอบหรืออุปกรณ์ของผลิตภัณฑ์ดังกล่าว
88	โรงงานผลิต ส่ง หรือจำหน่ายพลังงานไฟฟ้า
98	โรงงานซักรีด ซักแห้ง ซักฟอก รีด อัด หรือย้อมผ้า เครื่องนุ่งห่ม พรม หรือขนสัตว์
100(6)	โรงงานประกอบกิจการเกี่ยวกับการตบแต่งหรือเปลี่ยนแปลงคุณลักษณะของผลิตภัณฑ์หรือส่วนประกอบของผลิตภัณฑ์โดยไม่มีการผลิต ด้วยวิธีการอบชุบด้วยความร้อน
102	โรงงานประกอบกิจการเกี่ยวกับการผลิต และหรือจำหน่ายไอน้ำ
หมายเหตุ : โรงงานลำดับที่ 61-68 และ 77-80 เฉพาะโรงงานที่มีการหล่อหลอมโลหะเท่านั้น โรงงานลำดับที่ 98 เฉพาะโรงงานที่มีการฟอก ย้อมสีเท่านั้น	

บัญชีที่ 2 ประเภทหรือชนิดของโรงงานที่ต้องทำการตรวจวัดเสียง

ลำดับที่	ตามประเภทหรือชนิดของโรงงานในบัญชีท้ายกฎกระทรวง (พ.ศ. 2535) ออกตามความในพระราชบัญญัติโรงงาน พ.ศ. 2535
3(1)	โรงงานที่ประกอบกิจการเกี่ยวกับการโม่ บด หรือย่อยหิน
11(3)(4)	โรงงานผลิตน้ำตาลทรายดิบ น้ำตาลทรายขาว หรือการทำให้บริสุทธิ์
14	โรงงานประกอบกิจการเกี่ยวกับการทำน้ำแข็ง หรือตัด ซอย บด หรือย่อยน้ำแข็ง
20(3)	โรงงานประกอบกิจการเกี่ยวกับการทำน้ำอัดลม (เฉพาะที่บรรจุขวดแก้ว)
22(2)	โรงงานประกอบกิจการเกี่ยวกับการทอ หรือการเตรียมเส้นด้ายยืนสำหรับการทอ
34(1)(2)(3)(4)	โรงงานประกอบกิจการเกี่ยวกับการเลื่อย ไส ซอย เซาะร่อง การทำวงกบ ขอบประตู ขอบหน้าต่าง บานหน้าต่าง บานประตู หรือส่วนประกอบที่ทำด้วยไม้ของอาคาร การทำไม้วีเนียร์ หรือไม้อัดทุกชนิด การทำฝอยไม้ การบด ป่น หรือย่อยไม้
38(1)	โรงงานผลิตเยื่อจากไม้ หรือวัสดุอื่น
53(9)	โรงงานประกอบกิจการเกี่ยวกับการล้าง บด หรือย่อยพลาสติก
61	โรงงานผลิต ตบแต่ง ดัดแปลง หรือซ่อมแซมเครื่องมือ หรือเครื่องใช้ที่ทำด้วยเหล็กหรือเหล็กกล้า และรวมถึงส่วนประกอบหรืออุปกรณ์ของเครื่องมือหรือเครื่องใช้ดังกล่าว
62	โรงงานผลิต ตบแต่ง ดัดแปลง หรือซ่อมแซมเครื่องเรือน หรือเครื่องตบแต่งภายในอาคารที่ทำจากโลหะหรือโลหะเป็นส่วนใหญ่ และรวมถึงส่วนประกอบหรืออุปกรณ์ของเครื่องเรือน หรือเครื่องตกแต่งดังกล่าว
63	โรงงานประกอบกิจการเกี่ยวกับผลิตภัณฑ์โลหะสำหรับใช้ในการก่อสร้าง
64	โรงงานประกอบกิจการเกี่ยวกับผลิตภัณฑ์โลหะ
65	โรงงานผลิต ประกอบ ดัดแปลง หรือซ่อมแซมเครื่องยนต์ เครื่องกังหัน และรวมถึงส่วนประกอบหรืออุปกรณ์ของเครื่องยนต์ หรือเครื่องกังหันดังกล่าว
66	โรงงานผลิต ประกอบ ดัดแปลง หรือซ่อมแซมเครื่องจักร สำหรับใช้ในการกสิกรรมหรือการเลี้ยงสัตว์ และรวมถึงส่วนประกอบหรืออุปกรณ์ของเครื่องจักรดังกล่าว
67	โรงงานประกอบกิจการเกี่ยวกับเครื่องจักร ส่วนประกอบ หรืออุปกรณ์ของเครื่องจักรสำหรับประดิษฐ์โลหะ หรือไม้

บัญชีที่ 2 ประเภทหรือชนิดของโรงงานที่ต้องทำการตรวจวัดเสียง

ลำดับที่	ตามประเภทหรือชนิดของโรงงานในบัญชีท้ายกฎกระทรวง (พ.ศ. 2535) ออกตามความในพระราชบัญญัติโรงงาน พ.ศ. 2535
68	โรงงานผลิต ประกอบ ดัดแปลง หรือซ่อมแซมเครื่องจักรสำหรับอุตสาหกรรมกระดาษ เคมี อาหาร การปั่นทอ การพิมพ์ การผลิตซีเมนต์หรือผลิตภัณฑ์ดินเหนียว การก่อสร้าง การทำเหมืองแร่ การเจาะหาปิโตรเลียม หรือการกลั่นน้ำมัน และรวมถึงส่วนประกอบของเครื่องจักรดังกล่าว
77	โรงงานประกอบกิจการเกี่ยวกับรถยนต์ หรือรถพ่วง
78	โรงงานประกอบกิจการเกี่ยวกับจักรยานยนต์ จักรยานสามล้อ หรือจักรยานสองล้อ
79	โรงงานประกอบกิจการเกี่ยวกับอากาศยาน หรือเรือโฮเวอร์คราฟท์
80	โรงงานผลิต ประกอบ ดัดแปลง หรือซ่อมแซมล้อเลื่อน ที่ขับเคลื่อนด้วยแรงคน หรือสัตว์ ซึ่งมิใช่จักรยาน และรวมถึงส่วนประกอบหรืออุปกรณ์ของผลิตภัณฑ์ดังกล่าว
88	โรงงานผลิต ส่ง หรือจำหน่ายพลังงานไฟฟ้า
<u>หมายเหตุ</u> : โรงงานลำดับที่ 61-68 และ 77-80 เฉพาะโรงงานที่มีการปั๊มและเจียรโลหะเท่านั้น	

OSHA

Note: This table only includes occupational exposure limits (OELs) for substances listed in the OSHA Z-1 Table. OELs for hundreds of additional substances have been adopted by Cal/OSHA, NIOSH, and ACGIH. These organizations periodically make revisions to their OELs and so they should be consulted directly for their most current values and substances, as well as special notations such as for skin absorption.

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	Regulatory Limits: OSHA PEL[b] mg/m³[e]	Regulatory Limits: MIOSHA PEL 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13) Up to 10-hour TWA (ST) STEL (C) Ceiling	Recommended Limits: ACGIH® 2013 TLV®[h] 8-hour TWA (ST) STEL (C) Ceiling
Acetaldehyde	75-07-0	200	360	(TWA) 100/180 (ST) 150/270	Ca See Appendix A See Appendix C	(C) 25 ppm
Acetic acid	64-19-7	10	25	(TWA) 10/25	10 ppm (ST) 15 ppm	10 ppm (ST) 15 ppm
Acetic anhydride	108-24-7	5	20	(C) 5/20	(C) 5 ppm	1 ppm (ST) 3 ppm
Acetone	67-64-1	1000	2400	(TWA) 750/1800 (ST) 1000/2400	250 ppm	500 ppm (ST) 750 ppm
Acetonitrile	75-05-8	40	70	(TWA) 40/70 (ST) 60/105	20 ppm	20 ppm
2-Acetylaminofluorene; see 1910.1014	53-96-3			See OH Part 350 R325.35001 to R325.35011	Ca See Appendix A	
Acetylene dichloride; see 1,2-Dichloroethylene						
Acetylene tetrabromide	79-27-6	1	14	(TWA) 1/14	See Appendix D	0.1 ppm (IFV)
Acrolein	107-02-8	0.1	0.25	(TWA) 0.1/0.25 (ST) 0.3/0.8	0.1 ppm (ST) 3 ppm	(C) 0.1 ppm
Acrylamide	79-06-1		0.3	(TWA) 0.03 mg/m³	Ca 0.03 mg/m³ See Appendix A	0.03 mg/m³ (IFV)
Acrylonitrile; see	107-13-1			(TWA) 2/4.34	Ca	2 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	Regulatory Limits: OSHA PEL[b] mg/m³[e]	Regulatory Limits: MIOSHA PEL 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13) Up to 10-hour TWA (ST) STEL (C) Ceiling	Recommended Limits: ACGIH® 2013 TLV®[h] 8-hour TWA (ST) STEL (C) Ceiling
1910.1045 (MIOSHA see OH Part 307)				(ST) 10/21.7	1 ppm (C) 10 ppm [15-min] See Appendix A	
Aldrin	309-00-2		0.25	(TWA) 0.25 mg/m³	Ca 0.25 mg/m³ See Appendix A	0.05 mg/m³ (IFV)
Allyl alcohol	107-18-6	2	5	(TWA) 2/5 (ST) 4/10	2 ppm (ST) 4 ppm	0.5 ppm
Allyl chloride	107-05-1	1	3	(TWA) 1/3 (ST) 2/6	1 ppm (ST) 2 ppm	1 ppm (ST) 2 ppm
Allyl glycidyl ether (AGE)	106-92-3	(C) 10	(C) 45	(TWA) 5/22 (ST) 10/44	5 ppm (ST) 10 ppm	1 ppm
Allyl propyl disulfide	2179-59-1	2	12	(TWA) 2/12 (ST) 3/18	2 ppm	0.5 ppm
alpha-Alumina (aluminum oxide)	1344-28-1				See Appendix D	See TLV® for Aluminum, metal and insoluble compounds
Total dust			15	10 mg/m³		
Respirable fraction			5	5 mg/m³		
Aluminum Metal (as Al)	7429-90-5					
Total dust			15	15 mg/m³	10 mg/m³	
Respirable fraction; Alkls Pyro powders Soluble salts Welding fumes			5	5 mg/m³ 2 mg/m³ 5 mg/m³ 2 mg/m³ 5 mg/m³	5 mg/m³	1 mg/m³
4-Aminodiphenyl see 1910.1011	92-67-1			See OH Part 350, R325.35001 to R325.35011	Ca See Appendix A	Exposure by all routes should be carefully controlled to

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	Regulatory Limits: OSHA PEL[b] mg/m³[e]	Regulatory Limits: MIOSHA PEL 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13) Up to 10-hour TWA (ST) STEL (C) Ceiling	Recommended Limits: ACGIH® 2013 TLV®[h] 8-hour TWA (ST) STEL (C) Ceiling
						levels as low as possible
2-Aminoethanol; see Ethanolamine						
2-Aminopyridine	504-29-0	0.5	2	0.5/2	0.5 ppm	0.5 ppm
Ammonia	7664-41-7	50	35	(ST) 35/24 (ST) 35/24	25 ppm (ST) 35 ppm	25 ppm (ST) 35 ppm
Ammonium sulfamate	7773-06-0					
Total dust			15	10 mg/m³	10 mg/m³	10 mg/m³
Respirable fraction			5	5 mg/m³	5 mg/m³	
n-Amyl acetate	628-63-7	100	525	(TWA) 100/525	100 ppm	50 ppm (ST) 100 ppm
sec-Amyl acetate	626-38-0	125	650	(TWA) 125/650	125 ppm	50 ppm (ST) 100 ppm
Aniline and homologs	62-53-3	5	19	(TWA) 2/8	Ca See Appendix A	2 ppm (aniline only)
Anisidine (o-,p-isomers)	29191-52-4		0.5	(TWA) 0.5 mg/m³	Ca 0.5 mg/m³ See Appendix A	0.5 mg/m³
Antimony and compounds (as Sb)	7440-36-0		0.5	(TWA) 0.5 mg/m³	0.5 mg/m³	0.5 mg/m³
ANTU (alpha Naphthylthiourea)	86-88-4		0.3	(TWA) 0.3 mg/m³	0.3 mg/m³	0.3 mg/m³
Arsenic, inorganic compounds (as As) see 1910.1018	7440-38-2			(TWA) 0.01 mg/m³ See OH Part 308, R325.51601 to R325.51628	Ca (C) 0.002 mg/m³ [15-min] See Appendix A	0.01 mg/m³
Arsenic, organic compounds (as As)	7440-38-2		0.5	(TWA) 0.5 mg/m³	None	
Arsine	7784-42-1	0.05	0.2	(TWA) 0.05/0.2	Ca 0.002 mg/m³ [15-min] See Appendix A	0.005 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	Regulatory Limits: OSHA PEL[b] mg/m³[e]	Regulatory Limits: MIOSHA PEL 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13) Up to 10-hour TWA (ST) STEL (C) Ceiling	Recommended Limits: ACGIH® 2013 TLV®[h] 8-hour TWA (ST) STEL (C) Ceiling
Asbestos; see 1910.1001	Varies with compound			(TWA) 0.1 f/cc See OH Part 305	Ca 0.1 f/cm³ See Appendix A See Appendix C	0.1 f/cc (resp. fiber)
Azinphos-methyl	86-50-0		0.2	(TWA) 0.2 mg/m³	0.2 mg/m³	0.2 mg/m³ (IFV)
Barium, soluble compounds (as Ba)	7440-39-3		0.5	(TWA) 0.5 mg/m³	0.5 mg/m³	0.5 mg/m³
Barium sulfate	7727-43-7					
Total dust			15	(TWA) 10 mg/m³	10 mg/m³	10 mg/m³ (no asbestos and < 1% crystalline silica)
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Benomyl	17804-35-2				See Appendix D	1 mg/m³ (IHL)
Total dust			15	(TWA) 10 mg/m³		
Respirable fraction			5	(TWA) 5 mg/m³		
Benzene; See 1910.1028; See Table Z-2 for the limits applicable in the operations or sectors excluded in 1910.1028(i)	71-43-2			(TWA) 1/3.19 (ST) 5/15.97 See OH Part 311	Ca 0.1 ppm (ST) 1 ppm See Appendix A	0.5 ppm (ST) 2.5 ppm
Benzidine; See 1910.1010	92-87-5			See OH Part 350, R325.35001 to R325.35011	Ca See Appendix A See Appendix C	Exposure by all routes should be carefully controlled to levels as low as possible
p-Benzoquinone; see Quinone						

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Benzo(a)pyrene; see Coal tar pitch volatiles						
Benzoyl peroxide	94-36-0		5	(TWA) 5 mg/m³	5 mg/m³	5 mg/m³
Benzyl chloride	100-44-7	1	5	(TWA) 1/5	(C) 1 ppm [15 min]	1 ppm
Beryllium and beryllium compounds (as Be)	7440-41-7	See Annotated Z-2			See Annotated Z-2 See MIOSHA table G-2	
Biphenyl; see Diphenyl						
Bismuth telluride, Undoped	1304-82-1					
Total dust			15	(TWA) 15 mg/m³	10 mg/m³	10 mg/m³
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Boron oxide	1303-86-2					
Total dust			15	(TWA) 10 mg/m³	10 mg/m³	10 mg/m³
Boron trifluoride	7637-07-2	(C) 1	(C) 3	(C) 1/3	(C) 1 ppm	(C) 1 ppm
Bromine	7726-95-6	0.1	0.7	(TWA) 0.1/0.7 (ST) 0.3/2	0.1 ppm ST) 0.3 ppm	0.1 ppm (ST) 0.2 ppm
Bromoform	75-25-2	0.5	5	(TWA) 0.5/5	0.5 ppm	0.5 ppm
Butadiene (1,3-Butadiene); See 29 CFR 1910.1051; 29 CFR 1910.19(l)	106-99-0	1 ppm / 5 ppm STEL		(TWA) 1/2.2 (ST) 5/11/1 See OH Part 312	Ca See Appendix A	2 ppm
Butanethiol; see Butyl mercaptan						
2-Butanone (Methyl ethyl ketone)	78-93-3	200	590	(TWA) 200/590 (ST) 300/885	200 ppm (ST) 300 ppm	200 ppm (ST) 300 ppm
2-Butoxyethanol	111-76-2	50	240	(TWA) 25/120	5 ppm	20 ppm
n-Butyl-acetate	123-86-4	150	710	(TWA) 150/710 (ST) 200/950	150 ppm (ST) 200 ppm	150 ppm (ST) 200 ppm
sec-Butyl acetate	105-46-4	200	950	(TWA) 200/950	200 ppm	200 ppm
tert-Butyl-acetate	540-88-5	200	950	(TWA) 200/950	200 ppm	200 ppm
n-Butyl alcohol	71-36-3	100	300	(C) 50/150	(C) 50 ppm	20 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
sec-Butyl alcohol	78-92-2	150	450	(TWA) 100/305	100 ppm (ST) 150 ppm	100 ppm
tert-Butyl alcohol	75-65-0	100	300	(TWA) 100/300 (ST) 150/450	100 ppm (ST) 150 ppm	100 ppm
Butylamine	109-73-9	(C) 5	(C) 15	(C) 5/15	(C) 5 ppm	(C) 5 ppm
tert-Butyl chromate (as CrO_3)[m]; see 1910.1026	1189-85-1			(TWA) 0.005 mg/m³ See OH Part 315	Ca 0.001 mg/m³ CR (VI) See Appendix A See Appendix C	(C) 0.1 mg/m³
n-Butyl glycidyl ether (BGE)	2426-08-6	50	270	(TWA) 25/135	(C) 5.6 ppm [15-min]	3 ppm
Butyl mercaptan	109-79-5	10	35	(TWA) 0.5/1.5	(C) 0.5 ppm [15-min]	0.5 ppm
p-tert-Butyltoluene	98-51-1	10	60	(TWA) 10/60 (ST) 20/120	10 ppm (ST) 20 ppm	1 ppm
Cadmium (as Cd); see 1910.1027	7440-43-9			0.005 mg/m³ See OH Part 309	Ca See Appendix A	0.01 mg/m³ (total) 0.002 mg/m³ (resp.)
Calcium Carbonate	1317-65-3					See TLV® book Appendix G
Total dust			15	(TWA) 15 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Calcium hydroxide	1305-62-0					
Total dust			15	(TWA) 5 mg/m³	5 mg/m³	5 mg/m³
Respirable fraction			5			
Calcium oxide	1305-78-8		5	(TWA) 5 mg/m³	2 mg/m³	2 mg/m³
Calcium silicate	1344-95-2					
Total dust			15	(TWA) 15 mg/m³	10 mg/m³	10 mg/m³, synthetic non-fibrous (no asbestos and < 1%

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
						crystalline silica)
Respirable fraction			5	5 mg/m³	5 mg/m³	
Calcium sulfate	7778-18-9					10 mg/m³ (IHL)
Total dust			15	(TWA) 15 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Camphor, synthetic	76-22-2		2	(TWA) 2 mg/m³	2 mg/m³	2 ppm (ST) 3 ppm
Carbaryl (Sevin)	63-25-2		5	(TWA) 5 mg/m³	5 mg/m³	0.5 mg/m³ (IFV)
Carbon black	1333-86-4		3.5	(TWA) 3.5 mg/m³	3.5 mg/m³ (without PAHs); when PAHs are present, NIOSH considers carbon black to be a potential occupational carcinogen. See Appendix A, See Appendix C	3 mg/m³ (IHL)
Carbon dioxide	124-38-9	5000	9000	(TWA) 10,000/18,000 (ST) 30,000/54,000	5000 ppm (ST) 30,000 ppm	5000 ppm (ST) 30,000 ppm
Carbon disulfide	75-15-0	See Annotated Z-2		(TWA) 4/12 (ST) 12/36	See Annotated Z-2	
Carbon monoxide	630-08-0	50	55	(TWA) 35/40 (C) 200/229	35 ppm (C) 200 ppm	25 ppm
Carbon tetrachloride	56-23-5	See Annotated Z-2		(TWA) 2/12.6	See Annotated Z-2	
Cellulose	9004-34-6					
Total dust			15	(TWA) 15 mg/m³	10 mg/m³	10 mg/m³
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Chlordane	57-74-9		0.5	(TWA) 0.5 mg/m³	Ca 0.5 mg/m³ See Appendix A	0.5 mg/m³
Chlorinated camphene	8001-35-2		0.5	(TWA) 0.5 mg/m³	Ca	0.5 mg/m³

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
				(ST) 1 mg/m³	See Appendix A	(ST) 1 mg/m³
Chlorinated diphenyl oxide	55720-99-5		0.5	(TWA) 0.5 mg/m³	0.5 mg/m³	0.5 mg/m³ (ortho isomer)
Chlorine	7782-50-5	(C) 1	(C) 3	(TWA) 0.5/1.5 (ST) 1/3	(C) 0.5 ppm [15-min]	0.5 ppm (ST) 1 ppm
Chlorine dioxide	10049-04-4	0.1	0.3	(TWA) 0.1/0.3 (ST) 0.3.0.9	0.1 ppm (ST) 0.3 ppm	0.1 ppm (ST) 0.3 ppm
Chlorine trifluoride	7790-91-2	(C) 0.1	(C) 0.4	(C) 0.1/0.4	(C) 0.1 ppm	(C) 0.1 ppm
Chloroacetaldehyde	107-20-0	(C) 1	(C) 3	(C) 1/3	(C) 1 ppm	(C) 1 ppm
a-Chloroacetophenone (Phenacyl chloride)	532-27-4	0.05	0.3	(TWA) 0.05/0.3	0.05 ppm	0.05 ppm
Chlorobenzene	108-90-7	75	350	(TWA) 75/350	See Appendix D	10 ppm
o-Chlorobenzylidene malononitrile	2698-41-1	0.05	0.4	(C) 0.05/0.4	(C) 0.05 ppm	(C) 0.05 ppm
Chlorobromomethane	74-97-5	200	1050	(TWA) 200/1050	200 ppm	200 ppm
2-Chloro-1,3-butadiene; See beta-Chloroprene						
Chlorodiphenyl (42% Chlorine) (PCB)	53469-21-9		1	(TWA) 1 mg/m³	Ca 0.001 mg/m³ See Appendix A	1 mg/m³
Chlorodiphenyl (54% Chlorine) (PCB)	11097-69-1		0.5	(TWA) 0.5 mg/m³	Ca 0.001 mg/m³ See Appendix A	0.5 mg/m³
1-Chloro-2,3-epoxypropane; See Epichlorohydrin						
2-Chloroethanol; See Ethylene chlorohydrin						
Chloroethylene; see Vinyl chloride						
Chloroform	67-66-3	(C) 50	(C)	(TWA) 2/9.78	Ca	10 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
(Trichloromethane)			240		(ST) 2 ppm [60-min] See Appendix A	
bis(Chloromethyl) ether; see 1910.1008	542-88-1			See OH Part 350	Ca See Appendix A	0.001 ppm
Chloromethyl methyl ether see 1910.1006	107-30-2			See OH Part 350	Ca See Appendix A	Exposure by all routes should be carefully controlled to levels as low as possible.
1-Chloro-1-nitropropane	600-25-9	20	100	(TWA) 4/10	2 ppm	2 ppm
Chloropicrin	76-06-2	0.1	0.7	(TWA) 0.1/0.7	0.1 ppm	0.1 ppm
beta-Chloroprene	126-99-8	25	90	(TWA) 10/35	Ca (C) 1 ppm [15-min] See Appendix A	10 ppm
2-Chloro-6-(trichloromethyl)pyridine	1929-82-4					
Total dust			15	(TWA) 15 mg/m³	10 mg/m³ (ST) 20 mg/m³	10 mg/m³ (ST) 20 mg/m³
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Chromium (II) compounds (as Cr)	7440-47-3		0.5	(TWA) 0.5 mg/m³	0.5 mg/m³ See Appendix C	
Chromium (III) compounds (as Cr)	7440-47-3		0.5	(TWA) 0.5 mg/m³	0.5 mg/m³ See Appendix C	0.5 mg/m³
Chromium (VI) compounds See 1910.1026[k]				(TWA) 0.005 mg/m³ as Cr See OH Part 315	Ca 0.001 mg/m³ See Appendix A See Appendix C	0.05 mg/m³, water soluable (includes chromic acid and chromates)

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Chromium metal and insol. salts (as Cr)	7440-47-3		1	(TWA) 1 mg/m³	0.5 mg/m³ See Appendix C	0.01 mg/m³, CrVI, insoluble
Chrysene; see Coal tarpitch volatiles						Exposure by all routes should be carefully controlled to levels as low as possible.
Clopidol	2971-90-6					3 mg/m³ (IFV)
Total dust			15	(TWA) 15 mg/m³	10 mg/m³ (ST) 20 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Coal dust (less than 5% SiO_2, respirable fraction)		See Annotated Z-3		(TWA) 2 mg/m³	See Annotated Z-3	
Coal dust (greater than or equal to 5% SiO_2 respirable fraction)		See Annotated Z-3		(TWA) 0.1mg/m³	See Annotated Z-3	
Coal tar pitch volatiles (benzene soluble fraction), anthracene, BaP, phenanthrene, acridine, chrysene, pyrene)	65966-93-2		0.2	(TWA) 0.2 mg/m³	Ca 0.1 mg/m³ (cyclohexane-extractable fraction) See Appendix A See Appendix C	0.2 mg/m³(as benzene soluble aerosol)
Cobalt metal, dust, and fume (as Co)	7440-48-4		0.1	(TWA) 0.05 mg/m³	0.05 mg/m³	0.02 mg/m³
Coke oven emissions; see 1910.1029				(TWA) 0.15 mg/m³ See OH Part 314, R325.50101 to R325.50136	Ca 0.2 mg/m³(benzene-soluble fraction) See Appendix A See Appendix C	
Copper	7440-50-8					

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Fume (as Cu)			0.1	(TWA) 0.1 mg/m³	0.1 mg/m³	0.2 mg/m³
Dusts and mists (as Cu)			1	(TWA) 1 mg/m³	1 mg/m³	1 mg/m³
Cotton dust[f], see 1910.1043			1	(TWA) 1 mg/m³	< 0.200 mg/m³ See Appendix C	0.1 mg/m³ (Thor.) (raw untreated)
Crag herbicide (Sesone)	136-78-7					
Total dust			15	(TWA) 10 mg/m³	10 mg/m³	10 mg/m³
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Cresol, all isomers	1319-77-3	5	22	(TWA) 5/22	2.3 ppm	20 mg/m³ (IFV)
Crotonaldehyde	123-73-9 / 4170-30-3	2	6	(TWA) 2/6	2 ppm See Appendix C (Aldehydes)	(C) 0.3 ppm
Cumene	98-82-8	50	245	(TWA) 50/245	50 ppm	50 ppm
Cyanides (as CN)	Varies with compound		5	(TWA) 5 mg/m³	(C) 5 mg/m³ [10-min]	(C) 5 mg/m³, salts
Cyclohexane	110-82-7	300	1050	(TWA) 300/1050	300 ppm	100 ppm
Cyclohexanol	108-93-0	50	200	(TWA) 50/200	50 ppm	50 ppm
Cyclohexanone	108-94-1	50	200	(TWA) 25/100	25 ppm	20 ppm (ST) 50 ppm
Cyclohexene	110-83-8	300	1015	(TWA) 300/1015	300 ppm	300 ppm
Cyclopentadiene	542-92-7	75	200	(TWA) 75/200	75 ppm	75 ppm
2,4-D (Dichlorophen-oxyacetic acid)	94-75-7		10	(TWA) 10 mg/m³	10 mg/m³	10 mg/m³ (IHL)
Decaborane	17702-41-9	0.05	0.3	(TWA) 0.05/0.3 (ST) 0.15/0.9	0.05 ppm (ST) 0.15 ppm	0.05 ppm (ST) 0.15 ppm
Demeton (Systox)	8065-48-3		0.1	(TWA) 0.1 mg/m³	0.1 mg/m³	0.05 mg/m³ (IFV)
Diacetone alcohol (4-Hydroxy-4-methyl-2-pentanone)	123-42-2	50	240	(TWA) 50/240	50 ppm	50 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
1,2-Diaminoethane; see Ethylenediamine						
Diazomethane	334-88-3	0.2	0.4	(TWA) 0.2/0.4	0.2 ppm	0.2 ppm
Diborane	19287-45-7	0.1	0.1	(TWA) 0.1/0.1	0.1 ppm	0.1 ppm
1,2-Dibromo-3-chloropropane (DBCP); see 1910.1044	96-12-8				Ca See Appendix A	
1,2-Dibromoethane; see Ethylene dibromide						
Dibutyl phosphate	107-66-4	1	5	(TWA) 1/5 (ST) 2/10	1 ppm (ST) 2 ppm	5 mg/m³ (IFV)
Dibutyl phthalate	84-74-2		5	(TWA) 5 mg/m³	5 mg/m³	5 mg/m³
o-Dichlorobenzene	95-50-1	(C) 50	(C) 300	(C) 50/300	(C) 50 ppm	25 ppm (C) 50 ppm
p-Dichlorobenzene	106-46-7	75	450	(TWA) 75/450 (ST) 110/675	Ca See Appendix A	10 ppm
3,3'-Dichlorobenzidine; see 1910.1007	91-94-1			See OH Part 350, R325.35001 to R325.35011	Ca See Appendix A	Exposure by all routes should be carefully controlled to levels as low as possible.
Dichlorodifluoromethane	75-71-8	1000	4950	(TWA) 1000/4950	1000 ppm	1000 ppm
1,3-Dichloro-5,5-dimethyl hydantoin	118-52-5		0.2	(TWA) 0.2 mg/m³ (ST) 0.4 mg/m³	0.2 mg/m³ (ST) 0.4 mg/m³	0.2 mg/m³ (ST) 0.4 mg/m³
Dichlorodiphenyltrichloroethane (DDT)	50-29-3		1	(TWA) 1 mg/m³	Ca 0.5 mg/m³ See Appendix A	1 mg/m³
1,1-Dichloroethane	75-34-3	100	400	(TWA) 100/400	100 ppm See Appendix C (Chloroethanes)	100 ppm
1,2-Dichloroethane;						

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
see Ethylene dichloride						
1,2-Dichloroethylene	540-59-0	200	790	(TWA) 200/790	200 ppm	200 ppm
Dichloroethyl ether	111-44-4	(C) 15	(C) 90	(TWA) 5/30 (ST) 10/60	Ca 5 ppm (ST) 10 ppm See Appendix A	5 ppm (ST) 10 ppm
Dichloromethane; see Methylene chloride						
Dichloromono fluoromethane	75-43-4	1000	4200	(TWA) 10/40	10 ppm	10 ppm
1,1-Dichloro-1-nitroethane	594-72-9	(C) 10	(C) 60	(TWA) 2/10	2 ppm	2 ppm
1,2-Dichloropropane; see Propylene dichloride						
Dichlorotetrafluoroethane	76-14-2	1000	7000	(TWA) 1000/7000	1000 ppm	1000 ppm
Dichlorvos (DDVP)	62-73-7		1	(TWA) 1 mg/m³	1 mg/m³	0.1 mg/m³ (IFV)
Dicyclopentadienyl iron	102-54-5					
Total dust			15	(TWA) 10 mg/m³	10 mg/m³	10 mg/m³ as Fe
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Dieldrin	60-57-1		0.25	(TWA) 0.25 mg/m³	Ca 0.25 mg/m³ See Appendix A	0.1 mg/m³ (IFV)
Diethylamine	109-89-7	25	75	(TWA) 10/30 (ST) 25/75	10 ppm (ST) 25 ppm	5 ppm (ST) 15 ppm
2-Diethylaminoethanol	100-37-8	10	50	(TWA) 10/50	10 ppm	2 ppm
Diethyl ether; see Ethyl ether						
Difluorodibromomethane	75-61-6	100	860	(TWA) 100/860	100 ppm	100 ppm
Diglycidyl ether (DGE)	2238-07-5	(C) 0.5	(C)	(TWA) 0.1/0.5	Ca	0.01 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
			2.8		0.1 ppm See Appendix A	
Dihydroxybenzene; see Hydroquinone						
Diisobutyl ketone	108-83-8	50	290	(TWA) 25/150	25 ppm	25 ppm
Diisopropylamine	108-18-9	5	20	(TWA) 5/20	5 ppm	5 ppm
4-Dimethylaminoazobenzene; see 1910.1015	60-11-7			See OH Part 350, R325.5001 to R325.35011	Ca See Appendix A	
Dimethoxymethane; see Methylal						
Dimethyl acetamide	127-19-5	10	35	(TWA) 10/35	10 ppm	10 ppm
Dimethylamine	124-40-3	10	18	(TWA) 10/18	10 ppm	5 ppm (ST) 15 ppm
Dimethylaminobenzene; see Xylidine						
Dimethylaniline (N,N-Dimethylaniline)	121-69-7	5	25	(TWA) 5/25 (ST) 10/50	5 ppm (ST) 10 ppm	5 ppm (ST) 10 ppm
Dimethylbenzene; see Xylene						
Dimethyl-1,2-dibromo-2,2-dichloroethylphosphate	300-76-5		3	(TWA) 3 mg/m³	3 mg/m³	0.1 mg/m³ (IFV)
Dimethylformamide	68-12-2	10	30	(TWA) 10/30	10 ppm	10 ppm
2,6-Dimethyl-4-heptanone; see Diisobutyl ketone						
1,1-Dimethylhydrazine	57-14-7	0.5	1	(TWA) 0.5/1	Ca (C) 0.06 ppm [2-hr] See Appendix A	0.01 ppm
Dimethylphthalate	131-11-3		5	(TWA) 5 mg/m³	5 mg/m³	5 mg/m³
Dimethyl sulfate	77-78-1	1	5	(TWA) 0.1/0.5	Ca 0.1 ppm See Appendix A	0.1 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Dinitrobenzene (all isomers)			1	(TWA) 1 mg/m³	1 mg/m³	0.15 ppm
(ortho)	528-29-0					
(meta)	99-65-0					
(para)	100-25-4					
Dinitro-o-cresol	534-52-1		0.2	(TWA) 0.2 mg/m³	0.2 mg/m³	0.2 mg/m³
Dinitrotoluene	25321-14-6		1.5	(TWA) 0.15 mg/m³	Ca 1.5 mg/m³ See Appendix A	0.2 mg/m³
Dioxane (Diethylene dioxide)	123-91-1	100	360	(TWA) 25/90	Ca (C) 1 ppm [30-min] See Appendix A	20 ppm
Diphenyl (Biphenyl)	92-52-4	0.2	1	(TWA) 0.2/1	0.2 ppm	0.2 ppm
Diphenylmethane diisocyanate; see Methylene bisphenylisocyanate						
Dipropylene glycol methyl ether	34590-94-8	100	600	(TWA) 100/600 (ST) 150/900	100 ppm (ST) 150 ppm	100 ppm (ST) 150 ppm
Di-sec octyl phthalate (Di-(2-ethylhexyl) phthalate)	117-81-7		5	(TWA) 5 mg/m³ (ST) 10 mg/m³	Ca 5 mg/m³ (ST) 10 mg/m³ See Appendix A	5 mg/m³
Emery	12415-34-8				See Appendix D	See TLV® for Aluminum metal and insoluble compounds
Total dust			15	(TWA) 10 mg/m³		
Respirable fraction			5	(TWA) 5 mg/m³		
Endrin	72-20-8		0.1	(TWA) 0.1 mg/m³	0.1 mg/m³	0.1 mg/m³
Epichlorohydrin	106-89-8	5	19	(TWA) 2/8	Ca	0.5 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
					See Appendix A	
EPN	2104-64-5		0.5	(TWA) 0.5 mg/m³	0.5 mg/m³	0.1 mg/m³ (IHL)
1,2-Epoxypropane; see Propylene oxide						
2,3-Epoxy-1-propanol; see Glycidol						
Ethanethiol; see Ethyl mercaptan						
Ethanolamine	141-43-5	3	6	(TWA) 3/6 (ST) 6 ppm	3 ppm (ST) 6 ppm	3 ppm (ST) 6 ppm
2-Ethoxyethanol (Cellosolve)	110-80-5	200	740	(TWA) 200/740	0.5 ppm	5 ppm
2-Ethoxyethyl acetate (Cellosolve acetate)	111-15-9	100	540	(TWA) 100/540	0.5 ppm	5 ppm
Ethyl acetate	141-78-6	400	1400	(TWA) 400/1400	400 ppm	400 ppm
Ethyl acrylate	140-88-5	25	100	(TWA) 5/20 (ST) 25/100	Ca See Appendix A	5 ppm (ST) 15 ppm
Ethyl alcohol (Ethanol)	64-17-5	1000	1900	(TWA) 1000/1900	1000 ppm	(ST) 1000 ppm
Ethylamine	75-04-7	10	18	(TWA) 10/18	10 ppm	5 ppm (ST) 15 ppm
Ethyl amyl ketone (5-Methyl-3-heptanone)	541-85-5	25	130	(TWA) 25/130	25 ppm	10 ppm
Ethyl benzene	100-41-4	100	435	(TWA) 100/435 (ST) 125/545	100 ppm (ST) 125 ppm	20 ppm
Ethyl bromide	74-96-4	200	890	(TWA) 200/890 (ST) 250/1100	See Appendix D	5 ppm
Ethyl butyl ketone (3-Heptanone)	106-35-4	50	230	(TWA) 50/230	50 ppm	50 ppm (ST) 75 ppm
Ethyl chloride	75-00-3	1000	2600	(TWA) 1000/2600	See Appendix C (Chloroethanes)	100 ppm
Ethyl ether	60-29-7	400	1200	(TWA) 400/1200 (ST) 500/1500	See Appendix D	400 ppm (ST) 500

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	Regulatory Limits: MIOSHA PEL 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13) Up to 10-hour TWA (ST) STEL (C) Ceiling	Recommended Limits: ACGIH® 2013 TLV®[h] 8-hour TWA (ST) STEL (C) Ceiling
						ppm
Ethyl formate	109-94-4	100	300	(TWA) 100/300	100 ppm	(ST) 100 ppm
Ethyl mercaptan	75-08-1	(C) 10	(C) 25	(TWA) 0.5/1	(C) 0.5 ppm [15-min]	0.5 ppm
Ethyl silicate	78-10-4	100	850	(TWA) 10/85	10 ppm	10 ppm
Ethylene chlorohydrin	107-07-3	5	16	(C) 1/3	(C) 1 ppm	(C) 1 ppm
Ethylenediamine	107-15-3	10	25	(TWA) 10/25	10 ppm	10 ppm
Ethylene dibromide	106-93-4	See Annotated Z-2		See table G-2	See Annotated Z-2	
Ethylene dichloride (1,2-Dichloroethane)	107-06-2	See Annotated Z-2		(TWA) 1/4 (ST) 2/8	See Annotated Z-2	
Ethylene glycol dinitrate	628-96-6	(C) 0.2	(C) 1	(ST) 0.1 mg/m³	(ST) 0.1 mg/m³	0.05 ppm
Ethylene glycol methylacetate; see Methylcellosolve acetate						
Ethyleneimine; see 1910.1012	151-56-4			See OH Part 350, R325.35001 to R325.35011	Ca See Appendix A	0.05 ppm (ST) 0.1 ppm
Ethylene oxide; see 1910.1047	75-21-8			(TWA) 1/1.8 (ST) 5/9 See OH Part 304	Ca < 0.1 ppm (C) 5 ppm [10-min/day] See Appendix A	1 ppm
Ethylidene chloride; see 1,1-Dichlorethane						
N-Ethylmorpholine	100-74-3	20	94	(TWA) 5/23	5 ppm	5 ppm
Ferbam	14484-64-1					
Total dust		.....	15	(TWA) 10 mg/m³	10 mg/m³	5 mg/m³ (IHL)
Ferrovanadium dust	12604-58-9	.....	1	(TWA) 1 mg/m³ (ST) 3 mg/m³	1 mg/m³ (ST) 3 mg/m³	1 mg/m³ (ST) 3 mg/m³
Fluorides (as F)	Varies with compound	.....	2.5	(TWA) 2.5 mg/m³	2.5 mg/m³	2.5 mg/m³
Fluorine	7782-41-4	0.1	0.2	(TWA) 0.1/0.2	0.1 ppm	1 ppm (ST) 2 ppm
Fluorotrichloromethane (Trichlorofluoromethane)	75-69-4	1000	5600	(C) 1000/5600	(C) 1000 ppm	(C) 1000 ppm
Formaldehyde; see 1910.1048	50-00-0			(TWA) 0.75/0.9 (ST) 2/2.5 See OH Part 306	Ca 0.016 ppm (C) 0.1 ppm [15-min] See Appendix A	(C) 0.3 ppm
Formic acid	64-18-6	5	9	(TWA) 5/9	5 ppm	5 ppm (ST) 10 ppm
Furfural	98-01-1	5	20	(TWA) 2/8	See Appendix D	2 ppm
Furfuryl alcohol	98-00-0	50	200	(TWA) 10/40 (ST) 15/60	10 ppm (ST) 15 ppm	10 ppm (ST) 15 ppm
Grain dust (oat, wheat barley)			10	(TWA) 10 mg/m³	4 mg/m³	4 mg/m³
Glycerin (mist)	56-81-5				See Appendix D	
Total dust			15	(TWA) 10 mg/m³		
Respirable fraction			5	(TWA) 5 mg/m³		
Glycidol	556-52-5	50	150	(TWA) 25/75	25 ppm	2 ppm
Glycol monoethyl ether; see 2-Ethoxyethanol						
Graphite, natural respirable dust	7782-42-5	See Annotated Z-3		(TWA) 2.5 mg/m³	See Annotated Z-3	
Graphite, synthetic						
Total dust			15	(TWA) 10 mg/m³	See Appendix D	
Respirable Fraction			5	(TWA) 5 mg/m³		2 mg/m³ (all forms except fibers)
Guthion; see Azinphos methyl						
Gypsum	13397-24-5					See calcium sulfate
Total dust			15	(TWA) 15 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Hafnium	7440-58-6		0.5	(TWA) 0.5 mg/m³	0.5 mg/m³	0.5 mg/m³
Heptachlor	76-44-8		0.5	(TWA) 0.5 mg/m³	Ca 0.5 mg/m³ See Appendix A	0.05 mg/m³
Heptane (n-Heptane)	142-82-5	500	2000	(TWA) 400/1600 (ST) 500/2000	85 ppm (ST) 440 ppm [15-min]	400 ppm (ST) 500 ppm
Hexachloroethane	67-72-1	1	10	(TWA) 1/10	Ca 1 ppm See Appendix A See Appendix C (Chloroethanes)	1 ppm
Hexachloronaphthalene	1335-87-1		0.2	(TWA) 0.2 mg/m³	0.2 mg/m³	0.2 mg/m³
n-Hexane	110-54-3	500	1800	(TWA) 50/180	50 ppm	50 ppm
2-Hexanone (Methyl n-butyl ketone)	591-78-6	100	410	(TWA) 5/20	1 ppm	5 ppm (ST) 10 ppm
Hexone (Methyl isobutyl ketone)	108-10-1	100	410	(TWA) 50/205 (ST) 75/300	50 ppm (ST) 75 ppm	20 ppm (ST) 75 ppm
sec-Hexyl acetate	108-84-9	50	300	(TWA) 50/300	50 ppm	50 ppm
Hydrazine	302-01-2	1	1.3	(TWA) 0.1/0.1	Ca (C) 0.03 ppm [2-hr] See Appendix A	0.01 ppm
Hydrogen bromide	10035-10-6	3	10	(C) 3/10	(C) 3 ppm	(C) 2 ppm
Hydrogen chloride	7647-01-0	(C) 5	(C) 7	(C) 5/7	(C) 5 ppm	(C) 2 ppm
Hydrogen cyanide	74-90-8	10	11	(ST) 4.7/5	(ST) 4.7 ppm	(C) 4.7 ppm
Hydrogen fluoride (as F)	7664-39-3	See Annotated Z-2		(TWA) 3 ppm (ST) 6 ppm	See Annotated Z-2	
Hydrogen peroxide	7722-84-1	1	1.4	(TWA) 1/1.4	1 ppm	1 ppm
Hydrogen selenide (as Se)	7783-07-5	0.05	0.2	(TWA) 0.05/0.2	0.05 ppm	0.05 ppm
Hydrogen sulfide	7783-06-4	See Annotated Z-2		(TWA) 10/14 (ST) 15/21	See Annotated Z-2	
Hydroquinone	123-31-9	.....	2	(TWA) 2 mg/m³	(C) 2 mg/m³ [15-min]	1 mg/m³
Iodine	7553-56-2	(C) 0.1	(C) 1	(C) 0.1/1	(C) 0.1 ppm	0.01 ppm (IFV) (ST) 0.1 ppm (V)
Iron oxide	1309-37-1		10 (fume)	(TWA) 10 mg/m³ (fume)	5 mg/m³ (dust and fume)	5 mg/m³ (resp.)
Isoamyl acetate	123-92-2	100	525	(TWA) 100/525	100 ppm	50 ppm (ST) 100 ppm
Isoamyl alcohol (primary and secondary)	123-51-3	100	360	(TWA) 100/360 (ST) 125/450	100 ppm (ST) 125 ppm	100 ppm (ST) 125 ppm
Isobutyl acetate	110-19-0	150	700	(TWA) 150/700	150 ppm	150 ppm
Isobutyl alcohol	78-83-1	100	300	(TWA) 50/270	50 ppm	50 ppm
Isophorone	78-59-1	25	140	(TWA) 4/23	4 ppm	(C) 5 ppm
Isopropyl acetate	108-21-4	250	950	(TWA) 250/950 (ST) 310/1185	See Appendix D	100 ppm (ST) 200 ppm
Isopropyl alcohol	67-63-0	400	980	(TWA) 400/980 (ST) 500/1225	400 ppm (ST) 500 ppm	200 ppm (ST) 400 ppm
Isopropylamine	75-31-0	5	12	(TWA) 5/12 (ST) 10/24	See Appendix D	5 ppm (ST) 10 ppm
Isopropyl ether	108-20-3	500	2100	(TWA) 500/2100	500 ppm	250 ppm (ST) 310 ppm
Isopropyl glycidyl ether (IGE)	4016-14-2	50	240	(TWA) 50/240 (ST) 75/360	(C) 50 ppm [15-min]	50 ppm (ST) 75 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Kaolin	1332-58-7					
Total dust			15	(TWA) 10 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³ (no asbestos, < 1% crystalline silica)	5 mg/m³	2 mg/m³ (no asbestos and < 1% crystalline silica)
Ketene	463-51-4	0.5	0.9	(TWA) 0.5/0.9 (ST) 1.5/3	0.5 ppm (ST) 1.5 ppm	0.5 ppm (ST) 1.5 ppm
Lead inorganic (as Pb); see 1910.1025	7439-92-1			0.05 mg/m³ See OH Part 310	0.05 mg/m³ See Appendix C	0.05 mg/m³
Limestone (calcium carbonate)	1317-65-3					See calcium carbonate
Total dust			15	(TWA) 15 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Lindane	58-89-9		0.5	(TWA) 0.5 mg/m³	0.5 mg/m³	0.5 mg/m³
Lithium hydride	7580-67-8		0.025	(TWA)0.025 mg/m³	0.025 mg/m³	0.025 mg/m³
L.P.G. (Liquified petroleum gas)	68476-85-7	1000	1800	(TWA) 1000/1800	1000 ppm	See See TLV® book Appendix F
Magnesite	546-93-0					See See TLV® book Appendix G
Total dust			15	(TWA) 15 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Magnesium oxide fume - Total Particulate	1309-48-4		15	(TWA) 10 mg/m³	See Appendix D	10 mg/m³ (IHL)
Malathion - Total dust	121-75-5		15	(TWA) 10 mg/m³	10 mg/m³	1 mg/m³ (IFV)
Maleic anhydride	108-31-6	0.25	1	(TWA) 1 ppm	1 mg/m³	0.01 mg/m³ (IFV)
Manganese compounds (as Mn)	7439-96-5		(C) 5	(C) 5 mg/m³	1 mg/m³ (ST) 3 mg/m³	0.02 mg/m³ (resp.) 0.1 mg/m³

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
						(IHL) (for elemental and inorganic compounds)
Manganese fume (as Mn)	7439-96-5		(C) 5	(TWA) 1 mg/m³ (ST) 3 mg/m³	1 mg/m³ (ST) 3 mg/m³	0.02 mg/m³ (resp.) 0.1 mg/m³ (IHL) (for elemental and inorganic compounds)
Marble	1317-65-3					
Total dust			15	(TWA) 15 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Mercury (aryl and inorganic) (as Hg)	7439-97-6	See Annotated Z-2		(C) 0.1 mg/m³	See Annotated Z-2	
Mercury (organo) alkylcompounds (as Hg)	7439-97-6	See Annotated Z-2		(TWA) 0.01mg/m³ (ST) 0.03 mg/m³	See Annotated Z-2	
Mercury (vapor) (as Hg)	7439-97-6	See Annotated Z-2		(TWA) 0.05 mg/m³	See Annotated Z-2	
Mesityl oxide	141-79-7	25	100	(TWA) 15/60 (ST) 25/100	10 ppm	15 ppm (ST) 25 ppm
Methanethiol; see Methyl mercaptan						
Methoxychlor - Total dust	72-43-5		15	(TWA) 10 mg/m³	Ca See Appendix A	10 mg/m³
2-Methoxyethanol; (Methyl cellosolve)	109-86-4	25	80	(TWA) 25/80	0.1 ppm	0.1 ppm
2-Methoxyethyl acetate (Methyl cellosolve acetate)	110-49-6	25	120	(TWA) 25/120	0.1 ppm	0.1 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Methyl acetate	79-20-9	200	610	(TWA) 200/610 (ST) 250/760	200 ppm (ST) 250 ppm	200 ppm (ST) 250 ppm
Methyl acetylene (Propyne)	74-99-7	1000	1650	(TWA) 1000/1650	1000 ppm	1000 ppm
Methyl acetylene propadiene mixture (MAPP)		1000	1800	(TWA)1000/1800 (ST) 1250/2250	1000 ppm (ST) 1250 ppm	1000 ppm (ST) 1250 ppm
Methyl acrylate	96-33-3	10	35	(TWA) 10/35	10 ppm	2 ppm
Methylal (Dimethoxy-methane)	109-87-5	1000	3100	(TWA) 1000/3100	1000 ppm	1000 ppm
Methyl alcohol	67-56-1	200	260	(TWA) 200/260 (ST) 250/325	200 ppm (ST) 250 ppm	200 ppm (ST) 250 ppm
Methylamine	74-89-5	10	12	(TWA) 10/12	10 ppm	5 ppm (ST) 15 ppm
Methyl amyl alcohol; see Methyl Isobutylcarbinol						
Methyl n-amyl ketone	110-43-0	100	465	(TWA) 100/465	100 ppm	50 ppm
Methyl bromide	74-83-9	(C) 20	(C) 80	(TWA) 5/20	Ca See Appendix A	1 ppm
Methyl butyl ketone; see 2-Hexanone						
Methyl cellosolve; see 2-Methoxyethanol						
Methyl cellosolve acetate; see 2-Methoxyethylacetate						
Methyl chloride	74-87-3	See Annotated Z-2		(TWA) 50/105 (ST) 100/210	See Annotated Z-2	
Methyl chloroform (1,1,1-Trichloro-ethane)	71-55-6	350	1900	(TWA) 350/1900 (ST) 450/2450	(C) 350 ppm [15-min] See Appendix C (Chloroethanes)	350 ppm (ST) 450 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Methylcyclohexane	108-87-2	500	2000	(TWA) 400/1600	400 ppm	400 ppm
Methylcyclohexanol	25639-42-3	100	470	(TWA) 50/235	50 ppm	50 ppm
o-Methylcyclohexanone	583-60-8	100	460	(TWA) 50/230 (ST) 75/345	50 ppm (ST) 75 ppm	50 ppm (ST) 75 ppm
Methylene chloride	75-09-2	See Annotated Z-2		(TWA) 25/87 (ST) 125/434 See OH Part 313	See Annotated Z-2	
Methyl ethyl ketone (MEK); see 2-Butanone						
Methyl formate	107-31-3	100	250	(TWA) 100/250 (ST) 150/375	100 ppm (ST) 150 ppm	100 ppm (ST) 150 ppm
Methyl hydrazine (Monomethylhydrazine)	60-34-4	(C) 0.2	(C) 0.35	(C) 0.2/0.35	Ca (C) 0.04 ppm [2-hr] See Appendix A	0.01 ppm
Methyl iodide	74-88-4	5	28	(TWA) 2/10	Ca 2 ppm See Appendix A	2 ppm
Methyl isoamyl ketone	110-12-3	100	475	(TWA) 50/240	50 ppm	20 ppm (ST) 50 ppm
Methyl isobutyl carbinol	108-11-2	25	100	(TWA) 25/100 (ST) 40/165	25 ppm (ST) 40 ppm	25 ppm (ST) 40 ppm
Methyl isobutyl ketone; see Hexone						
Methyl isocyanate	624-83-9	0.02	0.05	(TWA) 0.02/0.05	0.02 ppm	0.02 ppm
Methyl mercaptan	74-93-1	(C) 10	(C) 20	(TWA) 0.5/1	(C) 0.5 ppm [15-min]	0.5 ppm
Methyl methacrylate	80-62-6	100	410	(TWA) 100/410	100 ppm	50 ppm (ST) 100 ppm
Methyl propyl ketone; see 2-Pentanone						
alpha-Methyl styrene	98-83-9	(C) 100	(C) 480	(TWA) 50/240 (ST) 100/485	50 ppm (ST) 100 ppm	10 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Methylene bisphenyl isocyanate (MDI)	101-68-8	(C) 0.02	(C) 0.2	(C) 0.02/0.2	0.05 mg/m³ (C) 0.2 mg/m³ [10-min]	0.005 ppm
Mica; see Silicates		See Annotated Z-3			See Annotated Z-3	
Molybdenum (as Mo)	7439-98-7					
Soluble compounds			5	(TWA) 5 mg/m³	See Appendix D	0.5 mg/m³ (resp.)
Insoluble Compounds - Total dust			15		See Appendix D	
Insoluble Compounds				(TWA) 10 mg/m³		10 mg/m³ (IHL) 3 mg/m³ (resp.)
Monomethyl aniline	100-61-8	2	9	(TWA) 0.5/2	0.5 ppm	0.5 ppm
Monomethyl hydrazine; see Methyl hydrazine						
Morpholine	110-91-8	20	70	(TWA) 20/70 (ST) 30/105	20 ppm (ST) 30 ppm	20 ppm
Naphtha (Coal tar)	8030-30-6	100	400	(TWA) 100/400	100 ppm	See TLV® book Appendix H
Naphthalene	91-20-3	10	50	(TWA) 10/50 (ST) 15/75	10 ppm (ST) 15 ppm	10 ppm (ST) 15 ppm
alpha-Naphthylamine; see 1910.1004	134-32-7			See OH Part 350, R325.35001 to R325.35011	Ca See Appendix A	
beta-Naphthylamine; see 1910.1009	91-59-8			See OH Part 350, R325.35001 to R325.35011	Ca See Appendix A	Exposure by all routes should be carefully controlled to levels as low as possible.
Nickel carbonyl (as Ni)	13463-39-3	0.001	0.007	(TWA) 0.001/0.007	Ca 0.001 ppm	0.05 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
					See Appendix A	
Nickel, metal and insoluble compounds (as Ni)	7440-02-0		1	(TWA) 1 mg/m³	Ca 0.015 mg/m³ See Appendix A	elemental: 1.5 mg/m³ (IHL); insoluble inorganic compounds: 0.2 mg/m³ (IHL)
Nickel, soluble compounds (as Ni)	7440-02-0		1	(TWA) 0.1 mg/m³	Ca 0.015 mg/m³	soluble inorganic compounds: 0.1 mg/m³ (IHL)
Nicotine	54-11-5		0.5	(TWA) 0.5 mg/m³	0.5 mg/m³	0.5 mg/m³
Nitric acid	7697-37-2	2	5	(TWA) 2/5 (ST) 4/10	2 ppm (ST) 4 ppm	2 ppm (ST) 4 ppm
Nitric oxide	10102-43-9	25	30	(TWA) 25/30	25 ppm	25 ppm
p-Nitroaniline	100-01-6	1	6	(TWA) 3 mg/m³	3 mg/m³	3 mg/m³
Nitrobenzene	98-95-3	1	5	(TWA) 1/5	1 ppm	1 ppm
p-Nitrochlorobenzene	100-00-5		1	(TWA) 1 mg/m³	Ca See Appendix A	0.1 ppm
4-Nitrodiphenyl; see 1910.1003	92-93-3			See OH Part 350, R325.35001 to R325.35011	Ca See Appendix A	Exposure by all routes should be carefully controlled to levels as low as possible.
Nitroethane	79-24-3	100	310	(TWA) 100/310	100 ppm	100 ppm
Nitrogen dioxide	10102-44-0	(C) 5	(C) 9	(ST) 1/1.8	(ST) 1 ppm	0.2 ppm
Nitrogen trifluoride	7783-54-2	10	29	(TWA) 10/29	10 ppm	10 ppm
Nitroglycerin	55-63-0	(C) 0.2	(C) 2	(ST) 0.1 mg/m³	(ST) 0.1 mg/m³	0.05 ppm
Nitromethane	75-52-5	100	250	(TWA) 100/250	See Appendix D	20 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
1-Nitropropane	108-03-2	25	90	(TWA) 25/90	25 ppm	25 ppm
2-Nitropropane	79-46-9	25	90	(TWA) 10/35	Ca See Appendix A	10 ppm
N-Nitrosodimethylamine; see 1910.1016				See OH Part 350, R325.35001 to R325.35011	Ca See Appendix A	Exposure by all routes should be carefully controlled to levels as low as possible.
Nitrotoluene (all isomers)		5	30	(TWA) 2/11	2 ppm	2 ppm
o-isomer	88-72-2					
m-isomer	99-08-1					
p-isomer	99-99-0					
Nitrotrichloromethane; see Chloropicrin						
Octachloronaphthalene	2234-13-1		0.1	(TWA) 0.1 mg/m³ (ST) 0.3 mg/m³	0.1 mg/m³ (ST) 0.3 mg/m³	0.1 mg/m³ (ST) 0.3 mg/m³
Octane	111-65-9	500	2350	(TWA) 300/1450 (ST) 375/1800	75 ppm (ST) 385 ppm [15-min]	300 ppm
Oil mist, mineral	8012-95-1		5	(TWA) 5 mg/m³	5 mg/m³ (ST) 10 mg/m³	5 mg/m³ (IHL; excluding metal working fluids, pure highly and severely refined) (For poorly and mildly refined: exposure by all routes

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
						should be carefully controlled to levels as low as possible.)
Osmium tetroxide (as Os)	20816-12-0		0.002	(TWA)0.002 mg/m³ (ST) 0.006 mg/m³	0.002 ppm (ST) 0.006 mg/m³	0.0016 mg/m³ (ST) 0.0047 mg/m³
Oxalic acid	144-62-7		1	(TWA) 1 mg/m³ (ST) 2 mg/m³	1 mg/m³ (ST) 2 mg/m³	1 mg/m³ (ST) 2 mg/m³
Oxygen difluoride	7783-41-7	0.05	0.1	(C) 0.05/0.1	(C) 0.05 ppm	(C) 0.05 ppm
Ozone	10028-15-6	0.1	0.2	(TWA) 0.1/0.2 (ST) 0.3/0.6	(C) 0.1 ppm	0.05-0.20 ppm depending on workload and time (See TLV® *Documentation on Ozone*)
Paraquat, respirable dust	4685-14-7		0.5	(TWA) 0.1 mg/m³		0.1 mg/m³, as the cation
	1910-42-5			(TWA) 0.1 mg/m³	0.1 mg/m³	
	2074-50-2			(TWA) 0.1 mg/m³		
Parathion	56-38-2		0.1	(TWA) 0.1 mg/m³	0.05 mg/m³	0.05 mg/m³ (IFV)
Particulates Not Otherwise Regulated (PNOR)[i]					See Appendix D	See TLV® book Appendix B
Total dust			15	(TWA) 15 mg/m³		
Respirable fraction			5	(TWA) 5 mg/m³		
PCB; see Chlorodiphenyl (42% and 54% chlorine)						
Pentaborane	19624-22-7	0.005	0.01	(TWA) 0.005/0.01	0.005 ppm	0.005 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
				(ST) 0.015/0.03	(ST) 0.015 ppm	(ST) 0.015 ppm
Pentachloronaphthalene	1321-64-8		0.5	(TWA) 0.5 mg/m³	0.5 mg/m³	0.5 mg/m³
Pentachlorophenol	87-86-5		0.5	(TWA) 0.5 mg/m³	0.5 mg/m³	0.5 mg/m³
Pentaerythritol	115-77-5					
Total dust			15	(TWA) 10 mg/m³	10 mg/m³	10 mg/m³
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Pentane	109-66-0	1000	2950	(TWA) 600/1800 (ST) 250/875	120 ppm (C) 610 ppm [15-min]	600 ppm
2-Pentanone (Methylpropyl ketone)	107-87-9	200	700	(TWA) 200/700 (ST) 250/875	150 ppm	(ST) 150 ppm
Perchloroethylene (Tetrachloroethylene)	127-18-4	See Annotated Z-2		(TWA) 25/170	See Annotated Z-2	
Perchloromethyl mercaptan	594-42-3	0.1	0.8	(TWA) 0.1/0.8	0.1 ppm	0.1 ppm
Perchloryl fluoride	7616-94-6	3	13.5	(TWA) 3/14 (ST) 6/28	3 ppm (ST) 6 ppm	3 ppm (ST) 6 ppm
Petroleum distillates (Naphtha) (Rubber Solvent)		500	2000	(TWA) 400/1600	350 mg/m³ (C) 1800 mg/m³ [15-min]	See TLV® book Appendix H
Phenol	108-95-2	5	19	(TWA) 5/19	5 ppm (C) 15.6 ppm [15-min]	5 ppm
p-Phenylene diamine	106-50-3		0.1	(TWA) 0.1 mg/m³	0.1 mg/m³	0.1 mg/m³
Phenyl ether, vapor	101-84-8	1	7	(TWA) 1/7	1 ppm	1 ppm (ST) 2 ppm
Phenyl ether-biphenylmixture, vapor		1	7	(TWA) 1/7	1 ppm	
Phenylethylene; see Styrene						
Phenyl glycidyl ether (PGE)	122-60-1	10	60	(TWA) 1/6	Ca (C) 1 ppm [15-min] See Appendix A	0.1 ppm
Phenylhydrazine	100-63-0	5	22	(TWA) 5/20	Ca	0.1 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
				(ST) 10/45	(C) 0.14 ppm [2-hr] See Appendix A	
Phosdrin (Mevinphos)	7786-34-7		0.1	(TWA) 0.1mg/m³ (ST) 0.03 mg/m³	0.01 ppm (ST) 0.03 ppm	0.01 mg/m³ (IFV)
Phosgene (Carbonyl chloride)	75-44-5	0.1	0.4	(TWA) 0.1/0.4	0.1 ppm (C) 0.2 ppm [15-min]	0.1 ppm
Phosphine	7803-51-2	0.3	0.4	(TWA) 0.3/0.4 (ST) 1/1	0.3 ppm (ST) 1 ppm	0.3 ppm (ST) 1 ppm
Phosphoric acid	7664-38-2		1	(TWA) 1 mg/m³ (ST) 3 mg/m³	1 mg/m³ (ST) 3 mg/m³	1 mg/m³ (ST) 3 mg/m³
Phosphorus (yellow)	7723-14-0		0.1	(TWA) 0.1 mg/m³	0.1 mg/m³	0.1 mg/m³
Phosphorus pentachloride	10026-13-8		1	(TWA) 1 mg/m³	1 mg/m³	0.1 ppm
Phosphorus pentasulfide	1314-80-3		1	(TWA) 1 mg/m³ (ST) 3 mg/m³	1 mg/m³ (ST) 3 mg/m³	1 mg/m³ (ST) 3 mg/m³
Phosphorus trichloride	7719-12-2	0.5	3	(TWA) 0.2/1.5 (ST) 0.5/3	0.2 ppm (ST) 0.5 ppm	0.2 ppm (ST) 0.5 ppm
Phthalic anhydride	85-44-9	2	12	(TWA) 1/6	6 mg/m³	1 ppm
Picloram	1918-0-21					
Total dust			15	(TWA) 10 mg/m³	See Appendix D	10 mg/m³
Respirable fraction			5	(TWA) 5 mg/m³		
Picric acid	88-89-1		0.1	(TWA) 0.1 mg/m³	0.1 mg/m³ (ST) 0.3 mg/m³	0.1 mg/m³
Pindone (2-Pivalyl-1,3-indandione)	83-26-1		0.1	(TWA) 0.1 mg/m³	0.1 mg/m³	0.1 mg/m³
Plaster of paris	26499-65-0					See TLV® for calcium sulfate
Total dust			15	(TWA) 15 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Platinum (as Pt) Metal	7440-06-4			(TWA) 1 mg/m³	1 mg/m³	1 mg/m³
Soluble Salts			0.002	(TWA) 0.002mg/m³	0.002 mg/m³	0.002 mg/m³

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Portland cement	65997-15-1					
Total dust			15	(TWA) 10 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	1 mg/m³ (no asbestos and < 1% crystalline silica)
Propane	74-98-6	1000	1800	(TWA) 1000/1800	1000 ppm	See See TLV® book Appendix F
beta-Propriolactone; see 1910.1013	57-57-8			See OH Part 350, R325.35001 to R325.35011	Ca See Appendix A	0.5 ppm
n-Propyl acetate	109-60-4	200	840	(TWA) 200/840 (ST) 250/1050	200 ppm (ST) 250 ppm	200 ppm (ST) 250 ppm
n-Propyl alcohol	71-23-8	200	500	(TWA) 200/500 (ST) 250/625	200 ppm (ST) 250 ppm	100 ppm
n-Propyl nitrate	627-13-4	25	110	(TWA) 25/105 (ST) 40/170	25 ppm (ST) 40 ppm	25 ppm (ST) 40 ppm
Propylene dichloride	78-87-5	75	350	(TWA) 75/350 (ST) 110/510	Ca See Appendix A	10 ppm
Propylene imine	75-55-8	2	5	(TWA) 2/5	Ca 2 ppm See Appendix A	0.2 ppm (ST) 0.4 ppm
Propylene oxide	75-56-9	100	240	(TWA) 20/50	Ca See Appendix A	2 ppm
Propyne; see Methylacetylene						
Pyrethrum	8003-34-7		5	(TWA) 5 mg/m³	5 mg/m³	5 mg/m³
Pyridine	110-86-1	5	15	(TWA) 5/15	5 ppm	1 ppm
Quinone	106-51-4	0.1	0.4	(TWA) 0.1/0.4	0.4 mg/m³	0.1 ppm
RDX: see Cyclonite						

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Rhodium (as Rh), metal fume and insoluble compounds	7440-16-6		0.1	(TWA) 0.1 mg/m³	0.1 mg/m³	1 mg/m³
Rhodium (as Rh), soluble compounds	7440-16-6		0.001	(TWA) 0.001mg/m³	0.001 mg/m³	0.01 mg/m³
Ronnel	299-84-3		15	(TWA) 10 mg/m³	10 mg/m³	5 mg/m³ (IFV)
Rotenone	83-79-4		5	(TWA) 5 mg/m³	5 mg/m³	5 mg/m³
Rouge					See Appendix D	See iron oxide
Total dust			15	(TWA) 10 mg/m³		
Respirable fraction			5	(TWA) 5 mg/m³		
Selenium compounds (as Se)	7782-49-2		0.2	(TWA) 0.2 mg/m³	0.2 mg/m³	0.2 mg/m³
Selenium hexafluoride (as Se)	7783-79-1	0.05	0.4	(TWA) 0.05/0.4	0.05 ppm	0.05 ppm
Silica, amorphous, precipitated and gel	112926-00-8	See Annotated Z-3		(TWA) 6 mg/m³	See Annotated Z-3	
Silica, amorphous, diatomaceous earth, containing less than 1% crystalline silica	61790-53-2	See Annotated Z-3		(TWA) 6 mg/m³	See Annotated Z-3	
Silica, crystalline cristobalite, respirable dust	14464-46-1	See Annotated Z-3		0.05 mg/m³	See Annotated Z-3	
Silica, crystalline quartz, respirable dust	14808-60-7	See Annotated Z-3		0.1 mg/m³	See Annotated Z-3	
Silica, crystalline tripoli (as quartz), respirable dust	1317-95-9	See Annotated Z-3		0.1 mg/m³	See Annotated Z-3	
Silica, crystalline tridymite, respirable dust	15468-32-3	See Annotated Z-3		0.05 mg/m³	See Annotated Z-3	
Silica, fused, respirable	60676-86-0	See Annotated		0.1 mg/m³	See Annotated	

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
dust		Z-3			Z-3	
Silicates (less than 1% crystalline silica)						
Mica (respirable dust)	12001-26-2	See Annotated Z-3		3 mg/m³	See Annotated Z-3	
Soapstone, total dust		See Annotated Z-3		6 mg/m³	See Annotated Z-3	
Soapstone, respirable dust		See Annotated Z-3		3 mg/m³	See Annotated Z-3	
Talc (containing asbestos): use asbestos limit; see 29 CFR 1910.1001		See Annotated Z-3		See OH Part 305, R 325.51311 to R325.51312	See Annotated Z-3	
Talc (containing no asbestos), respirable dust	14807-96-6	See Annotated Z-3		2 mg/m³	See Annotated Z-3	
Tremolite, asbestiform; see 1910.1001		See Annotated Z-3		See OH Part 305, R325.51311 to R325.51312	See Annotated Z-3	
Silicon	7440-21-3					See TLV® book Appendix G
Total dust			15	(TWA) 10 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Silicon carbide	409-21-2					Fibrous (including whiskers) 0.1 f/cc Nonfibrous: 10 mg/m³ (IHL) (no asbestos and < 1% crystalline silica)

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Total dust			15	(TWA) 10 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	3 mg/m³ (resp., no asbestos and < 1% crystalline silica)
Silver, metal and soluble compounds (as Ag)	7440-22-4		0.01	(TWA) 0.01 mg/m³	0.01 mg/m³	Metal, dust, and fume: 0.1 mg/m³; Soluble compounds, as Ag: 0.01 mg/m³
Soapstone		See Annotated Z-3		See Silicates	See Annotated Z-3	
Sodium fluoroacetate	62-74-8		0.05	(TWA) 0.05 mg/m³ (ST) 0.15 mg/m³	0.05 mg/m³ (ST) 0.15 mg/m³	0.05 mg/m³
Sodium hydroxide	1310-73-2		2	(C) 2 mg/m³	(C) 2 mg/m³	(C) 2 mg/m³
Starch	9005-25-8					
Total dust			15	(TWA) 15 mg/m³	10 mg/m³	10 mg/m³
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Stibine	7803-52-3	0.1	0.5	(TWA) 0.1/0.5	0.1 ppm	0.1 ppm
Stoddard solvent	8052-41-3	500	2900	(TWA) 100/525	350 mg/m³ (C) 1800 mg/m³ [15-min]	100 ppm
Strychnine	57-24-9		0.15	(TWA) 0.15 mg/m³	0.15 mg/m³	0.15 mg/m³
Styrene	100-42-5	See Annotated Z-2		(TWA) 50/215 (ST) 100/425	See Annotated Z-2	
Sucrose	57-50-1					
Total dust			15	(TWA) 15 mg/m³	10 mg/m³	10 mg/m³
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Sulfur dioxide	7446-09-5	5	13	(TWA) 2/5 (ST) 5/10	2 ppm (ST) 5 ppm	(ST) 0.25 ppm
Sulfur hexafluoride	2551-62-4	1000	6000	(TWA) 1000/6000	1000 ppm	1000 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Sulfuric acid	7664-93-9		1	(TWA) 1 mg/m³	1 mg/m³	0.2 mg/m³ (Thor.)
Sulfur monochloride	10025-67-9	1	6	(C) 1/6	(C) 1 ppm	(C) 1 ppm
Sulfur pentafluoride	5714-22-7	0.025	0.25	(C) 0.01/0.1	(C) 0.01 ppm	(C) 0.01 ppm
Sulfuryl fluoride	2699-79-8	5	20	(TWA) 5/20 (ST) 10/40	5 ppm (ST) 10 ppm	5 ppm (ST) 10 ppm
Systox; see Demeton						
2,4,5-T (2,4,5-trichlorophenoxyacetic acid)	93-76-5		10	(TWA) 10 mg/m³	10 mg/m³	10 mg/m³
Talc; see Silicates		See Annotated Z-3		See Silicates	See Annotated Z-3	
Tantalum, metal and oxide dust	7440-25-7		5	(TWA) 5 mg/m³	5 mg/m³ (ST) 10 mg/m³	See TLV® book Appendix G
TEDP (Sulfotep)	3689-24-5		0.2	(TWA) 0.2 mg/m³	0.2 mg/m³	0.1 mg/m³ (IFV)
Tellurium and compounds (as Te)	13494-80-9		0.1	(TWA) 0.1 mg/m³	0.1 mg/m³	0.1 mg/m³ (excluding hydrogen telluride)
Tellurium hexafluoride (as Te)	7783-80-4	0.02	0.2	(TWA) 0.02/0.2	0.02 ppm	0.02 ppm
Temephos	3383-96-8					1 mg/m³ (IFV)
Total dust			15	(TWA) 10 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
TEPP (Tetraethyl pyrophosphate)	107-49-3		0.05	0.004 ppm	0.05 mg/m³	0.01 mg/m³ (IFV)
Terphenyls	26140-60-3	(C) 1	(C) 9	(C) 0.5/5	(C) 0.5 ppm	(C) 5 mg/m³
1,1,1,2-Tetrachloro-2,2-difluoroethane	76-11-9	500	4170	(TWA) 500/4170	500 ppm	100 ppm
1,1,2,2-Tetrachloro-1,2-difluoroethane	76-12-0	500	4170	(TWA) 500/4170	500 ppm	50 ppm

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
1,1,2,2-Tetrachloroethane	79-34-5	5	35	(TWA) 1/7	Ca 1 ppm See Appendix A See Appendix C (Chloroethanes)	1 ppm
Tetrachoroethylene; see Perchloroethylene						
Tetrachloromethane; see Carbon tetrachloride						
Tetrachloronaphthalene	1335-88-2		2	(TWA) 2 mg/m³	2 mg/m³	2 mg/m³
Tetraethyl lead (as Pb)	78-00-2		0.075	(TWA) 0.075 mg/m³	0.075 mg/m³	0.1 mg/m³
Tetrahydrofuran	109-99-9	200	590	(TWA) 200/590 (ST) 250/735	200 ppm (ST) 250 ppm	50 ppm (ST) 100 ppm
Tetramethyl lead, (as Pb)	75-74-1		0.075	(TWA) 0.075 mg/m³	0.075 mg/m³	0.15 mg/m³
Tetramethyl succinonitrile	3333-52-6	0.5	3	(TWA) 0.5/3	3 mg/m³	0.5 ppm
Tetranitromethane	509-14-8	1	8	(TWA) 1/8	1 ppm	0.005 ppm
Tetryl (2,4,6-Trinitrophenylmethylnitramine)	479-45-8		1.5	(TWA) 1.5 mg/m³	1.5 mg/m³	1.5 mg/m³
Thallium, soluble compounds (as Tl)	7440-28-0		0.1	(TWA) 0.1 mg/m³	0.1 mg/m³	0.02 mg/m³ (IHL)
4,4'-Thiobis (6-tert,Butyl-m-cresol)	96-69-5					1 mg/m³ (IHL)
Total dust			15	(TWA) 10 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Thiram	137-26-8		5	(TWA) 5 mg/m³	5 mg/m³	0.05 mg/m³ (IFV)
Tin, inorganic	7440-31-5		2	(TWA) 2 mg/m³; also tin	2 mg/m³; except tin oxides	metal, oxide

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
compounds (except oxides) (as Sn)				oxide; except SnH_4		and inorganic compounds, except tin hydride: 2 mg/m³
Tin, organic compounds (as Sn)	7440-31-5		0.1	(TWA) 0.1 mg/m³	0.1 mg/m³ except Cyhexatin	0.1 mg/m³ (ST) 0.2 mg/m³
Titanium dioxide - Total dust	13463-67-7		15	(TWA) 10 mg/m³	Ca (ultrafine particles) 2.4 mg/m³ (fine) 0.3 mg/m³ (ultrafine) See Appendix A See Appendix C	10 mg/m³
Toluene	108-88-3	See Annotated Z-2		(TWA) 100/375 (ST) 150/560	See Annotated Z-2	
Toluene-2,4-diisocyanate (TDI)	584-84-9	(C) 0.02	(C) 0.14	(TWA) 0.005/0.04 (ST) 0.02/0.15	Ca See Appendix A	0.005 ppm (ST) 0.02 ppm
o-Toluidine	95-53-4	5	22	(TWA) 5/22	Ca See Appendix A	2 ppm
Toxaphene; see Chlorinated camphene						
Tremolite		See Annotated Z-3		See Silicates	See Annotated Z-3	
Tributyl phosphate	126-73-8		5	(TWA) 0.2/2.5	0.2 ppm	5 mg/m³ (IFV)
1,1,1-Trichloroethane; see Methyl chloroform						
1,1,2-Trichloroethane	79-00-5	10	45	(TWA) 10/45	Ca 10 ppm See Appendix A See Appendix C (Chloroethanes)	10 ppm
Trichloroethylene	79-01-6	See Annotated		(TWA) 50/270	See Annotated Z-2	

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
			Z-2	(ST) 200/1080		
Trichloromethane; see Chloroform						
Trichloronaphthalene	1321-65-9		5	(TWA) 5 mg/m³	5 mg/m³	5 mg/m³
1,2,3-Trichloropropane	96-18-4	50	300	(TWA) 10/60	Ca 10 ppm See Appendix A	10 ppm
1,1,2-Trichloro-1,2,2-trifluoroethane	76-13-1	1000	7600	(TWA) 1000/7600 (ST) 1250/9500	1000 ppm (ST) 1250 ppm	1000 ppm (ST) 1250 ppm
Triethylamine	121-44-8	25	100	(TWA) 10/40 (ST) 15/60	See Appendix D	1 ppm (ST) 3 ppm
Trifluorobromomethane	75-63-8	1000	6100	(TWA)1000/6100	1000 ppm	1000 ppm
2,4,6-Trinitrophenol;see Picric acid						
2,4,6-Trinitrophenyl-methyl nitramine; see Tetryl						
2,4,6-Trinitrotoluene (TNT)	118-96-7		1.5	(TWA) 0.5 mg/m³	0.5 mg/m³	0.1 mg/m³
Triorthocresyl phosphate	78-30-8		0.1	(TWA) 0.1 mg/m³	0.1 mg/m³	0.1 mg/m³
Triphenyl phosphate	115-86-6		3	(TWA) 3 mg/m³	3 mg/m³	3 mg/m³
Turpentine	8006-64-2	100	560	(TWA) 100/560	100 ppm	20 ppm
Uranium (as U)	7440-61-1					
Soluble compounds			0.05	(TWA) 0.05 mg/m³	Ca 0.05 mg/m³, See Appendix A	0.2 mg/m³ (ST) 0.6 mg/m³
Insoluble compounds			0.25	(TWA) 0.2 mg/m³ (ST) 0.6 mg/m³	Ca 0.2 mg/m³ (ST) 0.6 mg/m³ See Appendix A	0.2 mg/m³ (ST) 0.6 mg/m³

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Vanadium	1314-62-1					0.05 mg/m³ (IHL) Vanadium pentoxide as V
Respirable dust (as V_2O_5)			(C) 0.5	(TWA) 0.05 mg/m³, vanadium pentoxide	(C) 0.05 mg V/m³ [15-min], except Vanadium metal and Vanadium carbide	
Fume (as V_2O_5)			(C) 0.1	(TWA) 0.05 mg/m³	(C) 0.05 mg V/m³ [15-min]	
Vegetable oil mist				Vegetable oil mists		See TLV® book Appendix G
Total dust			15	(TWA) 15 mg/m³	10 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Vinyl benzene; see Styrene						
Vinyl chloride; see 1910.1017	75-01-4			(TWA) 1/2.5 (ST) 20/60 See OH Part 302	Ca See Appendix A	1 ppm
Vinyl cyanide; see Acrylonitrile						
Vinyl toluene	25013-15-4	100	480	(TWA) 100/480	100 ppm	50 ppm (ST) 100 ppm
Warfarin	81-81-2		0.1	(TWA) 0.1 mg/m³	0.1 mg/m³	0.1 mg/m³
Xylenes (o-, m-, p-isomers)	1330-20-7	100	435	(TWA) 100/435 (ST) 150/655	100 ppm (ST) 150 ppm	100 ppm (ST) 150 ppm
Xylidine	1300-73-8	5	25	(TWA) 2/10	2 ppm	0.5 ppm (IFV)
Yttrium	7440-65-5		1	(TWA) 1 mg/m³	1 mg/m³	1 mg/m³
Zinc chloride fume	7646-85-7		1	(TWA) 1 mg/m³ (ST) 2 mg/m³	1 mg/m³ (ST) 2 mg/m³	1 mg/m³ (ST) 2 mg/m³

OSHA Annotated Table Z-1[a]

*Go to list of all footnotes

Substance	CAS No.[c]	Regulatory Limits: OSHA PEL[b] ppm[d]	OSHA PEL[b] mg/m³[e]	MIOSHA PEL: 8-hour TWA (ppm/mg/m³) (ST) STEL (C) Ceiling	Recommended Limits: NIOSH REL[g] (as of 4/26/13): Up to 10-hour TWA (ST) STEL (C) Ceiling	ACGIH® 2013 TLV®[h]: 8-hour TWA (ST) STEL (C) Ceiling
Zinc oxide fume	1314-13-2		5	(TWA) 5 mg/m³ (ST) 10 mg/m³	5 mg/m³ (ST) 10 mg/m³	5 mg/m³ (ST) 10 mg/m³
Zinc oxide	1314-13-2					
Total dust			15	(TWA) 10 mg/m³	5 mg/m³ (C) 15 mg/m³	
Respirable fraction			5	(TWA) 5 mg/m³		2 mg/m³ (ST) 10 mg/m³
Zinc stearate	557-05-1					See TLV® Documentation on Stearates
Total dust			15	(TWA) 10 mg/m³	10 mg/m³	10 mg/m³
Respirable fraction			5	(TWA) 5 mg/m³	5 mg/m³	
Zirconium compounds (as Zr)	7440-67-7		5	(TWA) 5 mg/m³ (ST) 10 mg/m³	5 mg/m³ (ST) 10 mg/m³	5 mg/m³ (ST) 10 mg/m³

Back to top

Annotated Z-1 Table Footnotes, Abbreviations, References

Footnotes

(a) The unshaded area on this page lists PELs from OSHA Table Z-1 in 29 CFR 1910.1000. The shaded area of this page lists other occupational exposure limits (OELs) from Cal/OSHA, NIOSH, and ACGIH®.

(b) Occupational Safety and Health Administration (OSHA) Permissible Exposure Limits (PELS) from 29 CFR 1910.1000 Z-1 Table [58 FR 35340, June 30, 1993; 58 FR 40191, July 27, 1993, as amended at 61 FR 56831, Nov. 4, 1996; 62 FR 1600, Jan 10,1997; 62 FR 42018, Aug. 4,1997; 71 FR 10373, Feb. 28, 2006; 71 FR 16673, Apr. 3, 2006; 71 FR 36008, June 23, 2006.]. PELs are 8-hour time weighted averages (TWAs) unless otherwise indicated. OSHA enforces these limits under section 5(a)(2) of the OSH Act. In addition to the values listed in this table, the Z tables in 29 CFR 1910.1000 list skin absorption designations.

(c) The CAS number is for information only. Enforcement is based on the substance name. For an entry covering more than one metal compound measured as the metal, the CAS number for the metal is given - not CAS numbers for the individual compounds.

(d) Parts of vapor or gas per million parts of contaminated air by volume at 25 degrees C and 760 torr.

(e) Milligrams of substance per cubic meter of air. When entry is in this column only, the value is exact; when listed with a ppm entry, it is approximate.

(f) California Division of Occupational Safety and Health (Cal/OSHA) Permissible Exposure Limits (PELs) from Table AC-1 last updated March 17, 2012, viewable at http://www.dir.ca.gov/title8/5155table_ac1.html. Cal/OSHA enforces its PELs in workplaces under its jurisdiction. Cal/OSHA has established occupational exposure limits for compounds not included in the OSHA Z Tables. Please see Cal/OSHA Table AC-1 for additional limits, the most current limits, and other designations such as skin absorption. The Cal/OSHA AC-1 table and regulations should be consulted for explanations.

(g) National Institute for Occupational Safety and Health (NIOSH) Recommended Exposure Limits (RELs) from the NIOSH Pocket Guide to Chemical Hazards (http://www.cdc.gov/niosh/npg) (NIOSH 2007). RELs are for up to 10-hour time weighted averages (TWAs) during a 40-hour work week unless otherwise indicated. NIOSH has established occupational exposure limits for compounds not included in the OSHA Z Tables. Please see the NIOSH Pocket Guide for additional limits, skin absorption and other designations, and explanations.

(h) ACGIH® Threshold Limit Values (TLVs®) (ACGIH® 2013). TLVs® are listed in the order of 8-hour time weighted averages (TWAs), STELs (ST), and Ceilings (C), if available. ACGIH® has established TLVs® for compounds not included in the OSHA Z Tables. Please see ACGIH® Documentation for additional limits, skin absorption and other designations, and explanations. The 2013 TLV® and BEI® Book and Documentation of the Threshold Limit Values on Chemical Substances, 7th Edition are available through the ACGIH® website at http://www.acgih.org.

(i) In 29 CFR 1000, all inert or nuisance dusts, whether mineral, inorganic, or organic, not listed specifically by substance name are covered by the Particulates Not Otherwise Regulated (PNOR) limit which is the same as the inert or nuisance dust limit of Table Z-3.

(j) The final benzene standard in 1910.1028 applies to all occupational exposures to benzene except in some circumstances the distribution and sale of fuels, sealed containers and pipelines, coke production, oil and gas drilling and production, natural gas processing, and the percentage exclusion for liquid mixtures; for the excepted subsegments, the benzene limits in Table Z-2 apply. See 1910.1028 for specific circumstances.

(k) See Table Z-2 for the exposure limits for any operations or sectors where the exposure limits in 1910.1026 are stayed or are otherwise not in effect.

(l) This 8-hour TWA applies to respirable dust as measured by a vertical elutriator cotton dust sampler or equivalent instrument. The time-weighted average applies to the cotton waste processing operations of waste recycling (sorting, blending, cleaning and willowing) and garnetting. See also 1910.1043 for cotton dust limits applicable to other sectors.

(m) If the exposure limit in §1910.1026 is stayed or is otherwise not in effect, the exposure limit is a ceiling of 0.1 mg/m³.

Abbreviations

- C = Ceiling limit
- Ca = Potential occupational carcinogens
- CAS No. = Chemical Abstract Service Number
- f/cm³ = fibers/cubic centimeter
- f/cc = fibers/cubic centimeter
- hr = hour
- IHL = Inhalable
- IFV = Inhalable Fraction and Vapor
- m³ = cubic meters
- min = Minute
- mg/m³ = milligrams/meter cubed
- PAH = Polycyclic aromatic hydrocarbons
- PNOR = Particulates not otherwise regulated
- ppm = parts per million
- resp. = respirable
- ST = Short Term Exposure Limit
- Thor. = Thoracic fraction
- TLV® = Threshold Limit Value
- TWA – Time weighted average
- V = Vapor and aerosol

References

ACGIH® 2013 Threshold Limit Values for Chemical Substances in the Work Environment. Adopted by ACGIH® with Intended Changes. See http://www.acgih.org/.

California Division of Occupational Safety and Health (Cal/OSHA) Table AC-1, Permissible Exposure Limits (PELs), in California Code of Regulations (CCR) Title 8 Section 5155, last updated March 17, 2012. Viewable at http://www.dir.ca.gov/title8/5155table_ac1.html.

National Institute for Occupational Safety and Health (NIOSH) (2007) NIOSH Pocket Guide to Chemical Hazards. Department of Health and Human Services. Centers for Disease Control and Prevention. National Institute for Occupational Safety and Health (NIOSH). September 2007. DHHS (NIOSH) Publication No. 2005-149. Available at http://www.cdc.gov/niosh/docs/2005-149/pdfs/2005-149.pdf

Occupational Safety and Health Administration (OSHA) (2006) Air Contaminants. 29 CFR 1910.1000 [71 FR 16673, April 3, 2006]. Web site accessed on January 30, 2012. Available at http://www.osha.gov/pls/oshaweb/owadisp.show_document?p_table=STANDARDS&p_id=9991

ภาคผนวก ง

เอกสารสอบเทียบเครื่องมือ

JNAC
JIRANATEE ASSOCIATES CO.,LTD.

Jiranatee Associates Co.,Ltd.
63/14-15, 6/175-76
Petchkasem 7,7/7, Rd. Wattharu, Bangkokyai,
Bangkok 10600(Thailand)
Tel: +66(0)8000812
Mobile: +66(0)3399453
E-mail: jnac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Flow measurement laboratory
Calibration services department.

ilac-MRA
NSC – TISI – TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : COF-040-68

MEASUREMENT ITEM	: Top Load Orifice
MANUFACTURER	: TISCH
MODEL/TYPE	: TE-5025A
SERIAL NUMBER	: 3383
ID NUMBER	: UAE.EFM.063/2560
CONDITION AS-RECEIVED	: Used Item
CUSTOMER	: United Analyst and Engineering Consultant Co., Ltd. 81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
RECEIVED DATE	: 29 Aug 2025
MEASUREMENT DATE	: 29 Sep 2025
ISSUE DATE	: 30 Sep 2025

Calibration procedure:
The Orifice gas flow device was calibrated against Standard Rotary Displacement Meter (Roots Meter) Model G65/IMC/M2-03. The WI-CL-004 was used as a calibration guideline.

Traceability:
This certificate provides a traceability of the measurement to recognized the national standards and to realization of the International system of units (SI) through the NIMT (National Metrology Institute of Thailand) via Certificate number: Mw.0016-25.

Uncertainty of Measurement:
The reported uncertainty of measurement is based on the standard uncertainty multiplied by a coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty has been determined in accordance with the GUM 'Evaluation of measurement data - Guide to the expression of uncertainty in measurement'

ENVIRONMENTAL CONDITIONS:
Ambient condition in the laboratory are as follow:

Temperature	: 23.0 ± 3.0	°C
Relative Humidity	: 55.0 ± 15.0	%RH
Atmospheric Pressure	: 1010 ± 10	hPa

CALIBRATION CONDITION:

Preconditioning	: 24 hours at ambient conditions.
Measurement Condition	: The average values during measurement are 23.2 °C and 55.9 %RH.

NOTED: The certificate is valid only to the item calibrated on date and place of calibration.

TABULATION OF RESULTS:
The table on next page give the measured values.

Calibrated by:
☐ Mr. Sorawit Thachalad
☑ Miss Jittrasorn Lertsomphol

NAC JIRANATEE ASSOCIATES CO.,LTD.

Approved signatory: .....
Mr. Parinya Boonchanoen
Calibration Department Manager

THIS CERTIFICATE OF CALIBRATION MAY NOT BE REPRODUCED EXCEPT IN FULL UNLESS PERMISSION FOR RE... IN WRITING FROM THE LABORATORY

เอกสารไม่ควบคุม

Jiranatee Associates Co., Ltd.

TECHNOLOGY PROMOTION ASSOCIATION (THAILAND-JAPAN)
CORPORATE SERVICES 3: EQUIPMENT CALIBRATION AND TESTING SERVICES
53/4/4 PATTANAKARN ROAD SOI 18, SUANLUANG, SUANLUANG, BANGKOK 10250
TEL. 0-2717-3000-24 FAX. 0-2719-9484

Certificate of Calibration

Certificate No. : 25P3508

Equipment :	U Tube Manometer
Manufacturer:	Dwyer
Model :	1221-36-WM
Serial No.:	-
ID No.:	UAE.EFM.1802961
Condition As-Received:	Used Item
Received Date:	03 September 2025
Calibration Date:	09 September 2025
Reference:	2509-0144WSC
Ambient Temperature:	(23 ± 2) °C
Relative Humidity:	(60 ± 15) %
Atmospheric Pressure:	1006 mbar

This certificate may not be reproduced other than in full, except with the prior written approval of the head of Corporate Services 3: Equipment Calibration and Testing Services.

Submitted by: United Analyst and Engineering Consultant Co.,Ltd.
81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

Procedure used: The calibration was conducted by direct comparison method against Pressure Measuring Instruments Standard according to calibration procedure CP-P04, using " DKD-R 6-1 ; Calibration of Pressure Gauges " as a guidelines.

Condition of this result of calibration

1.Reference standards instruments :

Instrument	Model	Serial No.	Certificate No.	Due Date
1) Pressure Calibrator	PC106P	1169	MP-0218-24	24 Sep 2025

2.This result of calibration was made on requested at the point specified by customer.
3.Scale and conversion factor is 1 kPa = 4.0146293 inH₂O
4.This instrument was used clean air as pressure media.
5.This instrument was calibrated by applied pressure to high-port (+) side and low-port (-) side open to atmospheric pressure.
6.This instrument was installed in vertical orientation and top of the pressure port was used as the reference level.
7.The certificate is valid only to the item calibrated on date and place of calibration.
8.This measurement result is traceable to the International System of Unit maintained through:-
-National Institute of Metrology (Thailand), NSC-ONSC Accredited No. Calibration 0144

Calibrated by : Suksan Khankaew
Issue Date : 10 September 2025

Approved Signatory : Attapol P.
[ ] Phalinee Prabpalpat
[ ] Sura Suwannasri
[√] Attapol Panunsch

เอกสารไม่ควบคุม

JNAC
JIRANATEE ASSOCIATES CO.,LTD.

MEASUREMENT RESULTS:

The Orifice gas flow device was calibrated by direct comparison method with the Standard Rotary Displacement Meter (Roots Meter). The Humid air was used as a medium in the system. The standard conditions are 25°C (298.15 K) and 760 mmHg for standard temperature and standard pressure respectively.

Table 1: The results of @ Standard calibration data

Plate	Flow rate [Qs] m³/min	Pressure [Ps] mmHg	Temperature [Ta] °C	Temperature [Tm] °C	Δp_meter mmHg	Δp_Orifice inH₂O	Y	Standard Flow [Qs] m³/min
1	0.704	753.311	22.97	22.08	56.514	1.512	1.229	0.652
2	1.001	753.266	22.99	22.37	62.412	3.014	1.734	0.918
3	1.116	753.254	23.08	22.48	41.501	3.969	1.990	1.054
4	1.164	753.258	23.09	22.55	29.909	4.424	2.101	1.117
5	1.410	753.191	23.04	22.66	28.108	6.537	2.514	1.356

Slope (m): 1.87959
Intercept (b): 0.00567
Correlation coefficient (r): 0.99982
Uncertainty (k=2): 0.015 m³/min

Table 2: The results of @ actual calibration data

Plate	Flow rate [Qa] m³/min	Pressure [Pa] mmHg	Temperature [Ta] °C	Temperature [Tm] °C	Δp_meter mmHg	Δp_Orifice inH₂O	Y	Standard Flow [Qa] m³/min
1	0.704	753.311	22.97	22.08	56.514	1.512	0.771	0.653
2	1.001	753.266	22.99	22.37	62.412	3.014	1.088	0.920
3	1.116	753.254	23.08	22.48	41.501	3.969	1.249	1.056
4	1.164	753.258	23.09	22.55	29.909	4.424	1.319	1.120
5	1.410	753.191	23.04	22.66	28.108	6.537	1.603	1.359

Slope (m): 1.17726
Intercept (b): 0.00356
Correlation coefficient (r): 0.99982
Uncertainty (k = 2): 0.015 m³/min

End of Certificate of Calibration

NAC JIRANATEE ASSOCIATES CO.,LTD.

เอกสารไม่ควบคุม

Jiranatee Associates Co., Ltd.

Result of calibration:- Without adjustment
Function:- Pressure Measurement
Increasing Pressure

Range : 0 inH₂O to 36 inH₂O
Scale Interval : 0.1 inH₂O (The Second Estimate)

Applied Pressure	UUC Indication High-port side	UUC Indication Low-port side	ΔP	Error
0.00	0.00	0.00	0.00	0.00
2.00	0.95	-0.95	1.90	-0.10
4.00	1.95	-1.95	3.90	-0.10
6.00	2.95	-3.00	5.95	-0.05
8.00	3.95	-4.00	7.95	-0.05
10.00	4.95	-5.00	9.95	-0.05
12.00	6.00	-6.00	12.00	0.00
14.00	7.00	-7.00	14.00	0.00
16.00	8.00	-8.00	16.00	0.00
18.00	9.00	-9.00	18.00	0.00
20.00	10.00	-10.05	20.05	0.05
22.00	11.00	-11.05	22.05	0.05
24.00	12.00	-12.05	24.05	0.05
26.00	13.00	-13.05	26.05	0.05
28.00	14.00	-14.10	28.10	0.10
30.00	15.00	-15.10	30.10	0.10
32.00	16.05	-16.10	32.15	0.15
34.00	17.05	-17.10	34.15	0.15
35.90	18.00	-18.00	36.00	0.10

The uncertainty of measurement was ± 0.11 inH₂O
* ΔP = High-port side - Low-port side
* UUC = Unit Under Calibration
The reported uncertainty of measurement was based on a standard uncertainty multiplied by a coverage factor k = 2, providing a level of confidence of approximately 95 %.

-o0o-

เอกสารไม่ควบคุม

JIRANATEE ASSOCIATES CO.,LTD.

Jiranatee Associates Co.,Ltd.
63/14-15, 67/35-36
Petchkasem 7,7/1, Rd. Watthapra, Bangkokyai,
Bangkok 10600 (Thailand)
Tel: +66659080812
Mobile: +66863999453
E-mail: jeac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Flow measurement laboratory
Calibration services department.

CERTIFICATE OF CALIBRATION

Certificate No. : CGF-009-68

MEASUREMENT ITEM	: Volumetric Air Flow Calibrator
MANUFACTURER	: BGI Incorporated
MODEL/TYPE	: DeltaCal DC1
SERIAL NUMBER	: 158850
ID NUMBER	: UAE.EFM.038/2561
CONDITION AS-RECEIVED	: Used item
CUSTOMER	: United Analyst and Engineering Consultant Co., Ltd. 81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
RECEIVED DATE	: 08 Jul 2025
MEASUREMENT DATE	: 23 Jul 2025
ISSUE DATE	: 23 Jul 2025

Calibration procedure:
The Gas flow meter was calibrated against Standard Gas Flow Meter (Piston Prover) Model ML-800-44. The WI-CL005 was used as a calibration guideline.

Traceability:
This certificate provides a traceability of The measurement to recognized the national standards, and to realization of the International system of units (SI) through NIMT (National Institute of Metrology Thailand) via Certificate number: MIW-0046-24.

Uncertainty of Measurement:
The reported uncertainty of measurement is based on the standard uncertainty multiplied by a coverage factor k=2, Which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty has been determined in accordance with the GUM 'Evaluation of measurement data - Guide to the expression of uncertainty in measurement'

CONDITION OF THIS RESULT OF CALIBRATION:

1.The Unit Under Calibration was preconditioning 24 hours at ambient conditions prior to calibration test is performed.

2.The Unit Under Calibration was reading under actual conditions.

3.Calibration condition:

Flow transmitting medium	: Air	
t_{DUC} average during calibration	: (23.6±0.1)	°C
H_{DUC} average during calibration	: (53.7±5.0)	%RH
P_{DUC} average during calibration	: (1004.0±0.5)	hPa

4.The certificate is valid only to the item calibrated on date and place of calibration.

TABULATION OF RESULTS:
The table on next page give the measured values.

Calibrated by:
☐ Mr. Sorawit Thachalad
☑ Miss Pittraporn Lertsomphol

Approved signatory: .....
Mr. Parinya Booncharoen
Calibration Department Manager

เอกสารไม่ควบคุม

THIS CERTIFICATE OF CALIBRATION MAY NOT BE REPRODUCED EXCEPT IN FULL UNLESS PERMISSION FOR REPRODUCTION HAS BEEN OBTAINED IN WRITING FROM THE LABORATORY

JIRANATEE ASSOCIATES CO.,LTD.

Jiranatee Associates Co.,Ltd.
63/14-15, 67/35-36
Petchkasem 7,7/1, Rd. Watthapra, Bangkokyai,
Bangkok 10600 (Thailand)
Tel: +66659080812
Mobile: +66863999453
E-mail: jeac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Temperature measurement laboratory
Calibration services department.

NSC – TISI – TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : CDT-118-68

MEASUREMENT ITEM	: Temperature sensor with display
MANUFACTURER	: BGI Incorporated
MODEL/TYPE	: DeltaCal DC1
SERIAL NUMBER	: 158850
ID NUMBER	: UAE.EFM.038/2561
CONDITION AS-RECEIVED	: Used item
CUSTOMER	: United Analyst and Engineering Consultant Co., Ltd. 81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
RECEIVED DATE	: 08 Jul 2025
MEASUREMENT DATE	: 23 Jul 2025
ISSUE DATE	: 23 Jul 2025

Calibration procedure:
The temperature calibration was done by In-House calibration method as WI-CL-001 according to comparison method with standard digital temperature indicator and standard temperature probe. The temperature scale use was based on ITS-90.

Traceability:
The measurement results are traceable to the International system of units (SI) through National Institute of Metrology Thailand (NIMT) Certificate number: TT-1013-25, Certificate number: EA-0113-24

Reference Used During Calibration:
1. Standard Temperature Probe
Model: STS-100 A500, Serial No.: 667682-09, Due date: 9 Apr 2026
2. Digital Temperature Indicator
Model: DTI-1000-A MK II, Serial No.: 671407-00591 Due date: EA-0061-25.

Uncertainty of Measurement:
The reported uncertainty of measurement is based on the standard uncertainty multiplied by a coverage factor k=2, Which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty has been determined in accordance with the GUM 'Evaluation of measurement data - Guide to the expression of uncertainty in measurement'

ENVIRONMENTAL CONDITIONS:
Ambient condition in the laboratory are as follow:

Temperature	: 23.0 ± 3.0	°C
Relative Humidity	: 55.0 ± 15.0	%RH

NOTED: *The certificate is valid only to the item calibrated on date and place of calibration.*

TABULATION OF RESULTS:
The table on next page give the measured values.

Calibrated by:
☐ Mr. Sorawit Thachalad
☑ Miss Pittraporn Lertsomphol
☐ Miss Ruangrumpai Phoommit

Approved signatory: .....
Mr. Parinya Booncharoen
Calibration Department Manager

เอกสารไม่ควบคุม

THIS CERTIFICATE OF CALIBRATION MAY NOT BE REPRODUCED EXCEPT IN FULL UNLESS PERMISSION FOR REPRODUCTION HAS BEEN OBTAINED IN WRITING FROM THE LABORATORY

JIRANATEE ASSOCIATES CO.,LTD.

Continuation of Certificate of Calibration Number CGF-009-68

MEASUREMENT RESULTS:

The Gas flow meter was calibrated by comparison method with the Standard Gas Flow Meter (Piston Prover). The air was used as a medium in the system.

Calibration in the range of : 15.0 L/min to 18.3 L/min ☑ Without adjustment ☐ With adjustment

The results of calibration and associated measurement uncertainties are reported in the table below.

Standard Reading (L/min)	UUC Reading (L/min)	Error (%)	Uncertainty (k=2) (%)
14.912	15.00	0.59	0.63
15.731	15.82	0.59	0.62
16.551	16.67	0.69	0.61
17.404	17.50	0.57	0.60
18.176	18.29	0.65	0.59

End of Certificate of Calibration

Jiranatee Associates Co.,Ltd.

JIRANATEE ASSOCIATES CO.,LTD.

Continuation of Certificate of Calibration Number CDT-118-68

Result of Calibration: ☑ Without Adjustment ☐ With Adjustment

Calibration Range: 20 °C to 50 °C

Function:

Table 1: This equipment was connected with Ambient temperature sensor probe (Ta) Model: - S/N: - Dimension: Diameter 2.0 mm. Length 44.0 mm.

Immersion Depth (mm)	Standard Reading (°C)	UUC Reading (°C)	Error (°C)	Uncertainty (°C)
40	20.059	20.0	-0.1	0.099
40	30.033	30.0	0.0	0.099
40	35.021	35.2	0.2	0.099
40	40.011	40.2	0.2	0.099
40	49.997	49.8	-0.2	0.099

Table 2: This equipment was connected with Filter temperature sensor probe (Tf) Model: - S/N: - Dimension: Diameter 7.97 mm. Length 102 mm.

Immersion Depth (mm)	Standard Reading (°C)	UUC Reading (°C)	Error (°C)	Uncertainty (°C)
90	20.059	20.1	0.0	0.099
90	30.033	30.1	0.1	0.099
90	35.021	35.1	0.1	0.099
90	40.011	40.1	0.1	0.099
90	49.997	49.7	-0.3	0.099

UUC*: Unit Under Calibration

End of Certificate of Calibration

เอกสารไม่ควบคุม

JIRANATEE ASSOCIATES CO.,LTD.

Jiranatee Associates Co.,Ltd
65/34-35, 67/35-36
Petchkasem 7,7/1, Rd. Watthapra, Bangkolyai,
Bangkok 10600(Thailand)
Tel: +6628808312
Mobile: +66863989453
E-mail: jirac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Pressure measurement laboratory
Calibration services department.

NSC - TISI - TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : CPR-014-68

MEASUREMENT ITEM	: Digital barometer with display
MANUFACTURER	: BGI Incorporated
MODEL/TYPE	: DeltaCal DC1
SERIAL NUMBER	: 158850
ID NUMBER	: UAE.EFM.038/2561
CONDITION AS-RECEIVED	: Used Item
CUSTOMER	: United Analyst and Engineering Consultant Co., Ltd. 81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
RECEIVED DATE	: 08 Jul 2025
MEASUREMENT DATE	: 23 Jul 2025
ISSUE DATE	: 23 Jul 2025

Calibration procedure:
The Digital barometer was calibrated against Digital pressure calibrator. The MP-CL-003 was used as a calibration guideline.

Traceability:
The measurement results are traceable to the international system of units (SI) through the NIMT (National Metrology Institute of Thailand) via Certificate number: MP-0017-25

Reference Used During Calibration:
1. Absolute Pressure Transducer
Model: CPG2500, Serial No.: 41001269

Uncertainty of Measurement:
The reported uncertainty of measurement is based on the standard uncertainty multiplied by a coverage factor k=2, Which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty has been determined in accordance with the GUM 'Evaluation of measurement data - Guide to the expression of uncertainty in measurement'

CONDITION OF THIS RESULT OF CALIBRATION:
1. Calibration effort for calibration sequence C
2. The UUC* was installed in vertical orientation above reference standard instrument and, center of UUC* was used as the reference level.
3. Calibration conditions:
4. Condition : ☑ Normal ☐ Abnormal
   Pressure transmitting medium : Air
   ρ_a (20°C, 1 bar) : 1.19 kg/m^3
   H_{amb} : (54.0±0.2) %
   t_{amb} : (22.7±0.8) °C
   P_{amb} : (999.6±0.2) mbar
5. The certificate is valid only to the item calibrated on date and place of calibration

Calibrated by:
☑ Mr. Sirawit Thachalad
☐ Miss Jittaporn Lertsomphol

Approved signatory: .....
Mr. Parinya Booncharoen
Calibration Department Manager

เอกสารไม่ควบคุม

THIS CERTIFICATE OF CALIBRATION MAY NOT BE REPRODUCED EXCEPT IN FULL UNLESS PERMISSION FOR REPRODUCTION HAS BEEN OBTAINED IN WRITING FROM THE LABORATORY

Jiranatee Associates Co.,Ltd.

TECHNOLOGY PROMOTION ASSOCIATION (THAILAND-JAPAN)
CORPORATE SERVICES 3: EQUIPMENT CALIBRATION AND TESTING SERVICES
534/8 PATTANAKARN ROAD SOI 18, SUANLUANG, SUANLUANG, BANGKOK 10250
TEL. 0-2717-3000-24 FAX. 0-2719-9684

Certificate of Calibration

Certificate No. : 26P1519

Equipment :	Aneroid Barometer
Manufacturer:	Barigo
Model :	-
Serial No.:	-
ID No.:	UAE.ANV.123/2550
Condition As-Received:	Used Item
Received Date:	10 April 2026
Calibration Date:	22 April 2026
Reference:	2604-0316WSC
Ambient Temperature:	(23 ± 2) °C
Relative Humidity:	(50 ± 15) %

This certificate may not be reproduced other than in full, except with the prior written approval of the head of Corporate Services 3: Equipment Calibration and Testing Services.

Submitted by: United Analyst and Engineering Consultant Co.,Ltd.
81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

Procedure used: The calibration was conducted by direct comparison method against Pressure Measuring Instruments Standard according to calibration procedure CP-P10, using " DKD-R 6-1 ; Calibration of Pressure Gauges " as a guidelines.

Condition of this result of calibration

1.Reference standards instruments :

Instrument	Model	Serial No.	Certificate No.	Due Date
1) Pressure Indicator	DPI142	1422505046	MP-0150-25	20 May 2026

2.This result of calibration was made on requested at the point specified by customer.
3.The certificate is valid only to the item calibrated on date and place of calibration.
4.This measurement result is traceable to the International System of Unit maintained through:-
-National Institute of Metrology Thailand (NIMT)

Calibrated by : Somchai Chaichan
Issue Date : 24 April 2026

Approved Signatory : .....
[ ] Phalinee Prabpaipat
[✓] Sura Suwannasri
[ ] Attapol Panurach

เอกสารไม่ควบคุม

JIRANATEE ASSOCIATES CO.,LTD.

Jiranatee Associates Co.,Ltd
65/34-35, 67/35-36
Petchkasem 7,7/1, Rd. Watthapra, Bangkolyai,
Bangkok 10600(Thailand)
Tel: +6628808312
Mobile: +66863989453
E-mail: jirac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Pressure measurement laboratory
Calibration services department.

NSC - TISI - TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : CPR-014-68

MEASUREMENT RESULTS : ☐ Without adjustment ☑ With adjustment
CALIBRATION IN THE RANGE OF : 740 mmHg to 765 mmHg

The results of calibration and associated measurement uncertainties are reported in the table below.

STD (mmHg)	UUC* (mmHg)	Error (mmHg)	Uncertainty (k=2) (mmHg)
740.03	740.0	0.0	0.45
745.02	745.0	0.0	0.45
750.00	750.0	0.0	0.45
755.00	755.0	0.0	0.44
759.99	760.0	0.0	0.44
765.01	765.5	0.5	0.44

Note: UUC* Unit Under Calibration
: To convert the result in report unit to Pa should be multiply by 133.32

End of certificate

Jiranatee Associates Co.,Ltd.

เอกสารไม่ควบคุม

Technical information and UUC* settings during calibration:

Result of calibration	: Without adjustment	**Range**	: 960 hPa to 1090 hPa
Pressure type	: Absolute Pressure	**Scale Interval:**	1 hPa (The Fifth Estimate)
Installation	: Vertical Orientation	**Pressure medium**	: Clean air
Atmospheric pressure	: (1006 ± 10) mbar	**Reference level**	: at the center of the dial

Increasing Pressure

Applied Pressure (hPa)	954.50	966.01	977.33	988.29	999.06	1010.17	1021.66	1032.68
UUC* Indication (hPa)	960.0	970.0	980.0	990.0	1000.0	1010.0	1020.0	1030.0
Error (hPa)	5.50	3.99	2.67	1.71	0.92	-0.17	-1.66	-2.68

Decreasing Pressure

Applied Pressure (hPa)	1032.67	1021.79	1010.29	999.07	988.40	977.64	965.87	954.39
UUC* Indication (hPa)	1030.0	1020.0	1010.0	1000.0	990.0	980.0	970.0	960.0
Error (hPa)	-2.67	-1.79	-0.29	0.93	1.60	2.36	4.13	5.61

The uncertainty of measurement was ± 0.25 hPa

* UUC = Unit Under Calibration
The reported uncertainty of measurement was based on a standard uncertainty multiplied by a coverage factor *k* = 2, providing a level of confidence of approximately 95 %.

-oOo-

เอกสารไม่ควบคุม

TECHNOLOGY PROMOTION ASSOCIATION (THAILAND-JAPAN)
CORPORATE SERVICES 3: EQUIPMENT CALIBRATION AND TESTING SERVICES
534/4 PATTANAKARN ROAD SOI 18, SUANLUANG, SUANLUANG, BANGKOK 10250
TEL. 0-2717-3000-24 FAX. 0-2719-9484

Certificate of Calibration

Certificate No. : 26H710
Page : 1 of 2

Equipment : Dial Thermo-Hygrometer
Manufacturer: Barigo
Model : -
Serial No.: -
ID No.: UAE.ANV.004/2548
Condition As-Received: Used Item
Received Date: 10 April 2026
Calibration Date: 17 April 2026 to 22 April 2026
Reference: 2604-0315WSC
Ambient Temperature: (25 ± 3) °C
Relative Humidity: (50 ± 20) %

This certificate may not be reproduced other than in full, except with the prior written approval of the head of Corporate Services 3: Equipment Calibration and Testing Services.

Submitted by: United Analyst and Engineering Consultant Co.,Ltd.
81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

Procedure used: Calibration were conducted using in-house calibration procedure CP-H02 according to comparison with standard chilled mirror sensor for humidity measurement function and comparison with standard temperature probe for temperature measurement function into humidity / temperature chamber.

Condition of this result of calibration

1.Reference standards instruments :

Instrument	Model	Serial No.	Certificate No.	Due Date
1) Chilled-Mirror Hygrometer	Dew Master	41292	23277	06 May 2026
2) Handheld Thermometer With Sensor	1523	5717096	2511200	21 Nov 2026

2.The certificate is valid only to the item calibrated on date and place of calibration.

3.This measurement result is traceable to the International System of Unit maintained through:-
-Thunder Scientific Corporation, NVLAB Accreditation No. Calibration 200582-0
-Technology Promotion Association (Thailand-Japan), NSC-ONSC Accredited No. Calibration 0008

Calibrated by : Kraipop Onrat
Issue Date : 23 April 2026

Approved Signatory :
[ ] Chalerit Waewwarijua
[ ] Pornthippa Tarneyakul
[√] Viporn Tantiyawutti

เอกสารไม่ควบคุม

JNAC
JIRANATEE ASSOCIATES CO.,LTD.

Jiranatee Associates Co.,Ltd.
63/14-15, 67/35-36
Petchkasem 7,7/1, Rd. Wutthaprs, Bangkokyai,
Bangkok 10600 (Thailand)
Tel: +66(0)8383832
Mobile: +66(0)899999453
E-mail: jnac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0267

Flow measurement laboratory
Calibration services department.

CERTIFICATE OF CALIBRATION

Certificate No. : CGF-009-68

MEASUREMENT ITEM : Volumetric Air Flow Calibrator
MANUFACTURER : BGI Incorporated
MODEL/TYPE : DeltaCal DC1
SERIAL NUMBER : 158850
ID NUMBER : UAE.EFM.038/2561
CONDITION AS-RECEIVED : Used item
CUSTOMER : United Analyst and Engineering Consultant Co., Ltd.
81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

RECEIVED DATE : 08 Jul 2025
MEASUREMENT DATE : 23 Jul 2025
ISSUE DATE : 23 Jul 2025

Calibration procedure:
The Gas flow meter was calibrated against Standard Gas Flow Meter (Piston Prover) Model ML-800-44. The MI-CL005 was used as a calibration guideline.

Traceability:
This certificate provides a traceability of The measurement to recognized the national standards, and to realization of the International system of units (SI) through NIMT (National Institute of Metrology Thailand) via Certificate number: MW-0046-24.

Uncertainty of Measurement:
The reported uncertainty of measurement is based on the standard uncertainty multiplied by a coverage factor k=2, Which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty has been determined in accordance with the GUM 'Evaluation of measurement data - Guide to the expression of uncertainty in measurement'

CONDITION OF THIS RESULT OF CALIBRATION:
1.The Unit Under Calibration was preconditioning 24 hours at ambient conditions prior to calibration being performed.
2.The Unit Under Calibration was reading under actual conditions.
3.Calibration condition:

Flow transmitting medium	: Air	
t_{amb} average during calibration	: (25.0±0.1)	°C
H_{amb} average during calibration	: (53.7±5.0)	%RH
P_{amb} average during calibration	: (1004.0±0.5)	hPa

4.The certificate is valid only to the item calibrated on date and place of calibration.

TABULATION OF RESULTS:
The table on next page give the measured values.

Calibrated by:
☐ Mr. Sorawit Thachalad
☑ Miss Atitaporn Lertsongthai

Approved signatory:
Mr. Parinya Booncharoen
Calibration Department Manager

เอกสารไม่ควบคุม

THIS CERTIFICATE OF CALIBRATION MAY NOT BE REPRODUCED EXCEPT IN FULL UNLESS PERMISSION FOR REPRODUCTION HAS BEEN OBTAINED IN WRITING FROM THE LABORATORY

Jiranatee Associates Co.,Ltd.

Result of Calibration:- Without Adjustment
Function: Humidity Measurement.

Reference Temperature (°C)	Standard Humidity (%R.H.)	UUC* Reading (%R.H.)	UUC* Correction (%R.H.)	Uncertainty of Measurement (±%R.H.)
25.0	40.1	40	0.1	1.6
25.0	60.0	60	0.0	1.7
25.0	80.0	78	2.0	1.9

Result of Calibration:- Without Adjustment
Function: Temperature Measurement.

Standard Temperature (°C)	UUC* Reading (°C)	UUC* Correction (°C)	Uncertainty of Measurement (±°C)
20.012	20.5	-0.488	0.65
25.028	25.0	0.028	0.65
30.005	30.0	0.005	0.65
35.019	35.0	0.019	0.65
40.040	39.5	0.540	0.65

UUC* : Unit Under Calibration
The reported uncertainty of measurement was base on standard uncertainty multiplied by coverage factor k = 2.00, providing confidence level approximately 95%.

-o0o-

เอกสารไม่ควบคุม

JNAC
JIRANATEE ASSOCIATES CO.,LTD.

MEASUREMENT RESULTS:

The Gas flow meter was calibrated by comparison method with the Standard Gas Flow Meter (Piston Prover). The air was used as a medium in the system.

Calibration in the range of : 15.0 L/min to 18.3 L/min ☑ Without adjustment ☐ With adjustment

The results of calibration and associated measurement uncertainties are reported in the table below.

Standard Reading (L/min)	UUC Reading (L/min)	Error (%)	Uncertainty (k=2) (%)
14.912	15.00	0.59	0.63
15.731	15.82	0.59	0.62
16.551	16.67	0.69	0.61
17.404	17.50	0.57	0.60
18.176	18.29	0.65	0.59

End of Certificate of Calibration

Jiranatee Associates Co.,Ltd.

เอกสารไม่ควบคุม

JIRANATEE ASSOCIATES CO.,LTD.
Jiranatee Associates Co.,Ltd
63/14-15, 67/35-36
Petchkasem 7,7/1, Rd. Watthapra, Bangkolyai,
Bangkok 10600(Thailand)
Tel: +6603680812
Mobile: +66863999453
E-mail: jnac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Temperature measurement laboratory
Calibration services department.

NSC – TISI – TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : CDT-118-68

MEASUREMENT ITEM	: Temperature sensor with display
MANUFACTURER	: BGI Incorporated
MODEL/TYPE	: DeltaCal DC1
SERIAL NUMBER	: 158850
ID NUMBER	: UAE.EFM.038/2561
CONDITION AS-RECEIVED	: Used Item
CUSTOMER	: United Analyst and Engineering Consultant Co., Ltd. 81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
RECEIVED DATE	: 08 Jul 2025
MEASUREMENT DATE	: 23 Jul 2025
ISSUE DATE	: 23 Jul 2025

ENVIRONMENTAL CONDITIONS:
Ambient condition in the laboratory are as follow:

Temperature	: 23.0 ± 3.0	°C
Relative Humidity	: 55.0 ± 15.0	%RH

NOTED: *The certificate is valid only to the item calibrated on date and place of calibration.*

TABULATION OF RESULTS:
The table on next page give the measured values.

Calibration procedure:
The temperature calibration was done by In-House calibration method no. WI-CL-001 according to comparison method with standard digital temperature indicator and standard temperature probe. The temperature scale use was based on ITS-90.

Traceability:
The measurement results are traceable to the International system of units (SI) through National Institute of Metrology Thailand (NIMT) Certificate number: TT-1013-25, Certificate number: EA-0113-24

Reference Used During Calibration:
1. Standard Temperature Probe
Model: STS-100 A500, Serial No.: 667682-09, Due date: 9 Apr 2026
2. Digital Temperature Indicator
Model: DTI-1000-A MK II, Serial No.: 671407-00591 Due date: ER-0061-25.

Uncertainty of Measurement:
The reported uncertainty of measurement is based on the standard uncertainty multiplied by a coverage factor k=2, Which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty has been determined in accordance with the GUM 'Evaluation of measurement data - Guide to the expression of uncertainty in measurement'

Calibrated by:
☐ Mr. Sorawit Thachalad
☑ Miss Jittraporn Lertsomphol
☐ Miss Ruangrumpai Phoommit

Approved signatory: .....
Mr. Parinya Booncharoen
Calibration Department Manager

เอกสารไม่ควบคุม

THIS CERTIFICATE OF CALIBRATION MAY NOT BE REPRODUCED EXCEPT IN FULL UNLESS PERMISSION FOR REPRODUCTION HAS BEEN OBTAINED IN WRITING FROM THE LABORATORY

JIRANATEE ASSOCIATES CO.,LTD.
Jiranatee Associates Co.,Ltd
63/14-15, 67/35-36
Petchkasem 7,7/1, Rd. Watthapra, Bangkolyai,
Bangkok 10600(Thailand)
Tel: +6603680812
Mobile: +66863999453
E-mail: jnac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Pressure measurement laboratory
Calibration services department.

NSC - TISI - TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : CPR-014-68

MEASUREMENT ITEM	: Digital barometer with display
MANUFACTURER	: BGI Incorporated
MODEL/TYPE	: DeltaCal DC1
SERIAL NUMBER	: 158850
ID NUMBER	: UAE.EFM.038/2561
CONDITION AS-RECEIVED	: Used Item
CUSTOMER	: United Analyst and Engineering Consultant Co., Ltd. 81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
RECEIVED DATE	: 08 Jul 2025
MEASUREMENT DATE	: 23 Jul 2025
ISSUE DATE	: 23 Jul 2025

CONDITION OF THIS RESULT OF CALIBRATION:
1. Calibration effort for calibration sequence C
2. The UUC* was installed in vertical orientation above reference standard instrument and, center of UUC* was used as the reference level.
3. Calibration conditions:
4. Condition : ☑ Normal ☐ Abnormal
   Pressure transmitting medium : Air
   ρ_a (20°C, 1 bar) : 1.19 kg/m³
   H_{amb} : (54.0±0.2) %
   t_{amb} : (22.7±0.3) °C
   p_{amb} : (999.6±0.7) mbar
5. The certificate is valid only to the item calibrated on date and place of calibration

Calibration procedure:
The Digital barometer was calibrated against Digital pressure calibrator. The WI-CL-003 was used as a calibration guideline.

Traceability:
The measurement results are traceable to the international system of units (SI) through the NIMT (National Metrology Institute of Thailand) via Certificate number: MP-0017-25

Reference Used During Calibration:
1. Absolute Pressure Transducer
Model: CPD5500, Serial No.: 42001269

Uncertainty of Measurement:
The reported uncertainty of measurement is based on the standard uncertainty multiplied by a coverage factor k=2, Which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty has been determined in accordance with the GUM 'Evaluation of measurement data - Guide to the expression of uncertainty in measurement'

Calibrated by:
☑ Mr. Sorawit Thachalad
☐ Miss Jittraporn Lertsomphol

Approved signatory: .....
Mr. Parinya Booncharoen
Calibration Department Manager

เอกสารไม่ควบคุม

THIS CERTIFICATE OF CALIBRATION MAY NOT BE REPRODUCED EXCEPT IN FULL UNLESS PERMISSION FOR REPRODUCTION HAS BEEN OBTAINED IN WRITING FROM THE LABORATORY

JIRANATEE ASSOCIATES CO.,LTD.

Continuation of Certificate of Calibration Number CDT-118-68

Result of Calibration: ☑ Without Adjustment ☐ With Adjustment

Calibration Range: 20 °C to 50 °C

Function:

Table 1: This equipment was connected with Ambient temperature sensor probe (Ta) Model: - S/N: - Dimension: Diameter 2.0 mm. Length 44.0 mm.

Immersion Depth (mm)	Standard Reading (°C)	UUC Reading (°C)	Error (°C)	Uncertainty (°C)
40	20.059	20.0	-0.1	0.099
40	30.033	30.0	0.0	0.099
40	35.021	35.2	0.2	0.099
40	40.011	40.2	0.2	0.099
40	49.997	49.8	-0.2	0.099

Table 2: This equipment was connected with Filter temperature sensor probe (Tf) Model: - S/N: - Dimension: Diameter 7.97 mm. Length 102 mm.

Immersion Depth (mm)	Standard Reading (°C)	UUC Reading (°C)	Error (°C)	Uncertainty (°C)
90	20.059	20.1	0.0	0.099
90	30.033	30.1	0.1	0.099
90	35.021	35.1	0.1	0.099
90	40.011	40.1	0.1	0.099
90	49.997	49.7	-0.3	0.099

UUC*: Unit Under Calibration

End of Certificate of Calibration

JIRANATEE ASSOCIATES CO.,LTD.
Jiranatee Associates Co.,Ltd
63/14-15, 67/35-36
Petchkasem 7,7/1, Rd. Watthapra, Bangkolyai,
Bangkok 10600(Thailand)
Tel: +6603680812
Mobile: +66863999453
E-mail: jnac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Pressure measurement laboratory
Calibration services department.

NSC - TISI - TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : CPR-014-68

MEASUREMENT RESULTS : ☐ Without adjustment ☑ With adjustment

CALIBRATION IN THE RANGE OF : 740 mmHg to 765 mmHg

The results of calibration and associated measurement uncertainties are reported in the table below.

STD (mmHg)	UUC* (mmHg)	Error (mmHg)	Uncertainty (k=2) (mmHg)
740.03	740.0	0.0	0.45
745.02	745.0	0.0	0.45
750.00	750.0	0.0	0.45
755.00	755.0	0.0	0.44
759.99	760.0	0.0	0.44
765.01	765.5	0.5	0.44

Note: UUC* Unit Under Calibration
: To convert the result in report unit to Pa should be multiply by 133.32

End of certificate

JIRANATEE ASSOCIATES CO.,LTD.

เอกสารไม่ควบคุม

Jiranatee Associates Co.,Ltd.

JIRANATEE ASSOCIATES CO.,LTD.

Jiranatee Associates Co.,Ltd
69/34-35, 67/35-36
Petchkasem 7,7/1, Rd. Watthapra, Bangkokyai,
Bangkok 10600 (Thailand)
Tel: +6628808012
Mobile: +66863999453
E-mail: jnac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Flow measurement laboratory
Calibration services department.

NSC – TISI – TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : CGF-022-68

MEASUREMENT ITEM	: Volumetric Air Flow Calibrator
MANUFACTURER	: BGI Incorporated
MODEL/TYPE	: DeltaCal DC1
SERIAL NUMBER	: 163268
ID NUMBER	: UAE.EFM.174/2561
CONDITION AS-RECEIVED	: Used item
CUSTOMER	: United Analyst and Engineering Consultant Co., Ltd. 81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
RECEIVED DATE	: 08 Oct 2025
MEASUREMENT DATE	: 15 Oct 2025
ISSUE DATE	: 15 Oct 2025

Calibration procedure:
The Gas flow meter was calibrated against Standard Gas Flow Meter (Piston Prover) Model MI-800-44. The WI-CE-005 was used as a calibration guideline.

Traceability:
This certificate provides a traceability of The measurement to recognized the national standards, and to realization of the international system of units (SI) through NIMT (National Institute of Metrology Thailand) via Certificate number: MW-0051-25.

Uncertainty of Measurement:
The reported uncertainty of measurement is based on the standard uncertainty multiplied by a coverage factor k=2, Which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty has been determined in accordance with the GUM 'Evaluation of measurement data - Guide to the expression of uncertainty in measurement'

CONDITION OF THIS RESULT OF CALIBRATION:

1. The Unit Under Calibration was preconditioning 24 hours at ambient conditions prior to calibration being performed.
2. The Unit Under Calibration was reading under actual conditions.
3. Calibration condition:

Flow transmitting medium	: Air	
t_{amb} average during calibration	: (23.0±0.0)	°C
H_{amb} average during calibration	: (55.6±5.6)	%RH
P_{amb} average during calibration	: (1008.0±0.1)	hPa

4. The certificate is valid only to the item calibrated on date and place of calibration

TABULATION OF RESULTS:
The table on next page give the measured values.

Calibrated by:
☐ Mr. Sorawit Thachatad
☑ Miss Jittraporn Lertsomphol

J NAC JIRANATEE ASSOCIATES CO.,LTD.

Approved signatory: .....
Mr. Pariwa Booncharoen
Calibration Department Manager

THIS CERTIFICATE OF CALIBRATION MAY NOT BE REPRODUCED EXCEPT IN FULL UNLESS PERMISSION FOR REPRODUCTION HAS BEEN OBTAINED IN WRITING FROM THE LABORATORY

เอกสารไม่ควบคุม

JIRANATEE ASSOCIATES CO.,LTD.

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Pressure measurement laboratory
Calibration services department.

NSC - TISI - TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : CPR-026-68

MEASUREMENT ITEM	: Digital barometer with display
MANUFACTURER	: BGI Incorporated
MODEL/TYPE	: DeltaCal DC1
SERIAL NUMBER	: 163268
ID NUMBER	: UAE.EFM.174/2561
CONDITION AS-RECEIVED	: Used item
CUSTOMER	: United Analyst and Engineering Consultant Co., Ltd. 81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
RECEIVED DATE	: 08 Oct 2025
MEASUREMENT DATE	: 15 Oct 2025
ISSUE DATE	: 15 Oct 2025

Calibration procedure:
The Digital barometer was calibrated against Digital pressure calibrator. The WI-CE-007 was used as a calibration guideline.

Traceability:
The measurement results are traceable to the international system of units (SI) through the NIMT (National Metrology Institute of Thailand) via Certificate number: MP-0017-25

Reference Used During Calibration:
1. Absolute Pressure Transducer
Model: CPU2500, Serial No.: 41001269

Uncertainty of Measurement:
The reported uncertainty of measurement is based on the standard uncertainty multiplied by a coverage factor k=2, Which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty has been determined in accordance with the GUM 'Evaluation of measurement data - Guide to the expression of uncertainty in measurement'

CONDITION OF THIS RESULT OF CALIBRATION:

1. Calibration effort for calibration sequence C
2. The UUC* was installed in vertical orientation above reference standard instrument and center of UUC* was used as the reference level.
3. Calibration conditions:
4. Condition ☑ Normal ☐ Abnormal

Pressure transmitting medium	: Air	
ρ_a (20°C, 1 bar)	: 1.19	kg/m³
R_{amb}	: (63.0±4.2)	%
t_{amb}	: (23.0±0.6)	°C
p_{amb}	: (1005.910.1)	mbar

5. The certificate is valid only to the item calibrated on date and place of calibration

Calibrated by:
☑ Mr. Sorawit Thachatad
☐ Miss Jittraporn Lertsomphol

J NAC JIRANATEE ASSOCIATES CO.,LTD.

Approved signatory: .....
Mr. Pariwa Booncharoen
Calibration Department Manager

THIS CERTIFICATE OF CALIBRATION MAY NOT BE REPRODUCED EXCEPT IN FULL UNLESS PERMISSION FOR REPRODUCTION HAS BEEN OBTAINED IN WRITING FROM THE LABORATORY

เอกสารไม่ควบคุม

JIRANATEE ASSOCIATES CO.,LTD.

Continuation of Certificate of Calibration Number CGF-022-68

MEASUREMENT RESULTS:

The Gas flow meter was calibrated by comparison method with the Standard Gas Flow Meter (Piston Prover). The air was used as a medium in the system.

Calibration in the range of : 15.0 L/min to 16.3 L/min ☑ Without adjustment ☐ With adjustment

The results of calibration and associated measurement uncertainties are reported in the table below.

Standard Reading (L/min)	UUC Reading (L/min)	Error (%)	Uncertainty (k=2) (%)
15.088	14.99	-0.62	0.51
15.915	15.83	-0.54	0.51
16.754	16.67	-0.52	0.51
17.585	17.50	-0.48	0.51
18.367	18.30	-0.37	0.51

End of Certificate of Calibration

J NAC JIRANATEE ASSOCIATES CO.,LTD.

เอกสารไม่ควบคุม

JIRANATEE ASSOCIATES CO.,LTD.

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Pressure measurement laboratory
Calibration services department.

NSC - TISI - TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : CPR-026-68

MEASUREMENT RESULTS : ☑ Without adjustment ☐ With adjustment

CALIBRATION IN THE RANGE OF : 740 mmHg to 765 mmHg

The results of calibration and associated measurement uncertainties are reported in the table below.

STD (mmHg)	UUC* (mmHg)	Error (mmHg)	Uncertainty (k=2) (mmHg)
740.03	739.5	-0.5	0.44
745.01	744.8	-0.3	0.49
750.02	750.0	0.0	0.44
755.02	755.0	0.0	0.44
760.02	760.0	0.0	0.44
765.02	765.0	0.0	0.44

Note: UUC* Unit Under Calibration
: To convert the result in report unit to Pa should be multiply by 133.32

End of certificate

J NAC JIRANATEE ASSOCIATES CO.,LTD.

เอกสารไม่ควบคุม

JIRANATEE ASSOCIATES CO.,LTD.

Jiranatee Associates Co.,Ltd
83/14-15, 67/35-36
Petchkasem 7,7/1, Rd. Wutthajra, Bangkokyai,
Bangkok 10600 (Thailand)
Tel: +6658808312
Mobile: +66863999453
E-mail: jiac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Temperature measurement laboratory
Calibration services department.

ilac-MRA

NSC – TISI – TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : CDT-179-68

MEASUREMENT ITEM	: Temperature sensor with display
MANUFACTURER	: BGI Incorporated
MODEL/TYPE	: DeltaCal DC1
SERIAL NUMBER	: 163268
ID NUMBER	: UAE.EFM.174/2561
CONDITION AS-RECEIVED	: Used item
CUSTOMER	: United Analyst and Engineering Consultant Co., Ltd. 81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
RECEIVED DATE	: 08 Oct 2025
MEASUREMENT DATE	: 15 Oct 2025
ISSUE DATE	: 15 Oct 2025

ENVIRONMENTAL CONDITIONS:
Ambient condition in the laboratory are as follow:

Temperature	: 23.0 ± 3.0	°C
Relative Humidity	: 55.0 ± 15.0	%RH

NOTED: The certificate is valid only to the item calibrated on date and place of calibration.

TABULATION OF RESULTS:
The table on next page give the measured values.

Calibration procedure:
The temperature calibration was done by In-House calibration method as WMC1-001 according to comparison method with standard digital temperature indicator and standard temperature probe. The temperature scale use was based on ITS-90.

Traceability:
The measurement results are traceable to the International system of units (SI) through National Institute of Metrology Thailand (NIMT) Certificate number: TT-1013-25, Certificate number: ER-0061-25.

Reference Used During Calibration:
1. Standard Temperature Probe
Model: STS-100 A500, Serial No.: 667682-09, Due date: 9 Apr 2026
2. Digital Temperature Indicator
Model: DTI-1000-A MK II, Serial No.: 671407-00591 Due date: 22 Apr 2026

Uncertainty of Measurement:
The reported uncertainty of measurement is based on the standard uncertainty multiplied by a coverage factor k=2, Which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty has been determined in accordance with the GUM 'Evaluation of measurement data - Guide to the expression of uncertainty in measurement'

Calibrated by:
☐ Mr. Sorawit Thachalad
☑ Miss Jittraporn Lertsomphol
☐ Miss Ruangrumpai Phoommit

Approved signatory: .....
Mr. Parinya Booncharoen
Calibration Department Manager

THIS CERTIFICATE OF CALIBRATION MAY NOT BE REPRODUCED EXCEPT IN FULL UNLESS PERMISSION FOR REPRODUCTION HAS BEEN OBTAINED IN WRITING FROM THE LABORATORY

เอกสารไม่ควบคุม

JIRANATEE ASSOCIATES CO.,LTD.

Jiranatee Associates Co.,Ltd
83/14-15, 67/35-36
Petchkasem 7,7/1, Rd. Wutthajra, Bangkokyai,
Bangkok 10600 (Thailand)
Tel: +6658808312
Mobile: +66863999453
E-mail: jiac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Flow measurement laboratory
Calibration services department.

CERTIFICATE OF CALIBRATION

Certificate No. : CGF-009-68

MEASUREMENT ITEM	: Volumetric Air Flow Calibrator
MANUFACTURER	: BGI Incorporated
MODEL/TYPE	: DeltaCal DC1
SERIAL NUMBER	: 158850
ID NUMBER	: UAE.EFM.038/2561
CONDITION AS-RECEIVED	: Used item
CUSTOMER	: United Analyst and Engineering Consultant Co., Ltd. 81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
RECEIVED DATE	: 08 Jul 2025
MEASUREMENT DATE	: 23 Jul 2025
ISSUE DATE	: 23 Jul 2025

Calibration procedure:
The Gas flow meter was calibrated against Standard Gas Flow Meter (Piston Prover) Model ML-800-44. The WI-CL005 was used as a calibration guideline.

Traceability:
This certificate provides a traceability of The measurement to recognized the national standards, and to realization of the International system of units (SI) through NIMT (National Institute of Metrology Thailand) via Certificate number: MW-0046-24.

Uncertainty of Measurement:
The reported uncertainty of measurement is based on the standard uncertainty multiplied by a coverage factor k=2, Which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty has been determined in accordance with the GUM 'Evaluation of measurement data - Guide to the expression of uncertainty in measurement'

CONDITION OF THIS RESULT OF CALIBRATION:
1.The Unit Under Calibration was preconditioning 24 hours at ambient conditions prior to calibration being performed.
2.The Unit Under Calibration was reading under actual conditions.
3.Calibration condition:

Flow transmitting medium	: Air	
t_{avg} average during calibration	: (25.0±0.1)	°C
H_{avg} average during calibration	: (53.7±5.0)	%RH
P_{avg} average during calibration	: (1004.0±0.5)	hPa

4.The certificate is valid only to the item calibrated on date and place of calibration.

TABULATION OF RESULTS:
The table on next page give the measured values.

Calibrated by:
☐ Mr. Sorawit Thachalad
☑ Miss Jittraporn Lertsomphol

Approved signatory: .....
Mr. Parinya Booncharoen
Calibration Department Manager

THIS CERTIFICATE OF CALIBRATION MAY NOT BE REPRODUCED EXCEPT IN FULL UNLESS PERMISSION FOR REPRODUCTION HAS BEEN OBTAINED IN WRITING FROM THE LABORATORY

เอกสารไม่ควบคุม

JIRANATEE ASSOCIATES CO.,LTD.

Continuation of Certificate of Calibration Number CDT-179-68

Result of Calibration: ☑ Without Adjustment ☐ With Adjustment

Calibration Range: 20 °C to 50 °C

Function:

Table 1: This equipment was connected with Ambient temperature sensor probe (Ta) Model: - S/N: - Dimension: Diameter 2.0 mm. Length 44.0 mm.

Immersion Depth (mm)	Standard Reading (°C)	UUC Reading (°C)	Error (°C)	Uncertainty (°C)
40	20.060	20.1	0.0	0.099
40	30.035	30.1	0.1	0.099
40	35.028	35.2	0.2	0.099
40	40.008	40.2	0.2	0.099
40	50.001	49.9	-0.1	0.099

Table 2: This equipment was connected with Filter temperature sensor probe (Tf) Model: - S/N: - Dimension: Diameter 7.97 mm. Length 102 mm.

Immersion Depth (mm)	Standard Reading (°C)	UUC Reading (°C)	Error (°C)	Uncertainty (°C)
90	20.059	19.9	-0.2	0.099
90	30.035	29.9	-0.1	0.099
90	35.028	35.0	0.0	0.099
90	40.008	40.0	0.0	0.099
90	50.001	49.8	-0.2	0.099

UUC*: Unit Under Calibration

End of Certificate of Calibration

เอกสารไม่ควบคุม

JIRANATEE ASSOCIATES CO.,LTD.

Continuation of Certificate of Calibration Number CGF-009-68

MEASUREMENT RESULTS:

The Gas flow meter was calibrated by comparison method with the Standard Gas Flow Meter (Piston Prover). The air was used as a medium in the system.

Calibration in the range of : 15.0 L/min to 18.3 L/min ☑ Without adjustment ☐ With adjustment

The results of calibration and associated measurement uncertainties are reported in the table below.

Standard Reading (L/min)	UUC Reading (L/min)	Error (%)	Uncertainty (k=2) (%)
14.912	15.00	0.59	0.63
15.731	15.82	0.59	0.62
16.551	16.67	0.69	0.61
17.404	17.50	0.57	0.60
18.176	18.29	0.65	0.59

End of Certificate of Calibration

เอกสารไม่ควบคุม

JIRANATEE ASSOCIATES CO.,LTD.
Jiranatee Associates Co.,Ltd
63/14-15, 67/35-36
Petchkasem 7,7/1, Rd. Watthapra, Bangkolyai,
Bangkok 10600(Thailand)
Tel: +6603680812
Mobile: +66863999453
E-mail: jnac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Temperature measurement laboratory
Calibration services department.

NSC – TISI – TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : CDT-118-68

MEASUREMENT ITEM	: Temperature sensor with display
MANUFACTURER	: BGI Incorporated
MODEL/TYPE	: DeltaCal DC1
SERIAL NUMBER	: 158850
ID NUMBER	: UAE.EFM.038/2561
CONDITION AS-RECEIVED	: Used Item
CUSTOMER	: United Analyst and Engineering Consultant Co., Ltd. 81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
RECEIVED DATE	: 08 Jul 2025
MEASUREMENT DATE	: 23 Jul 2025
ISSUE DATE	: 23 Jul 2025

ENVIRONMENTAL CONDITIONS:
Ambient condition in the laboratory are as follow:

Temperature	: 23.0 ± 3.0	°C
Relative Humidity	: 55.0 ± 15.0	%RH

NOTED: *The certificate is valid only to the item calibrated on date and place of calibration.*

TABULATION OF RESULTS:
The table on next page give the measured values.

Calibration procedure:
The temperature calibration was done by In-House calibration method no. WI-CL-001 according to comparison method with standard digital temperature indicator and standard temperature probe. The temperature scale use was based on ITS-90.

Traceability:
The measurement results are traceable to the International system of units (SI) through National Institute of Metrology Thailand (NIMT) Certificate number: TT-1013-25, Certificate number: EA-0113-24

Reference Used During Calibration:
1. Standard Temperature Probe
Model: STS-100 A500, Serial No.: 667682-09, Due date: 9 Apr 2026
2. Digital Temperature Indicator
Model: DTI-1000-A MK II, Serial No.: 671407-00591 Due date: ER-0061-25.

Uncertainty of Measurement:
The reported uncertainty of measurement is based on the standard uncertainty multiplied by a coverage factor k=2, Which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty has been determined in accordance with the GUM 'Evaluation of measurement data - Guide to the expression of uncertainty in measurement'

Calibrated by:
☐ Mr. Sorawit Thachalad
☑ Miss Jittraporn Lertsomphol
☐ Miss Ruangrumpai Phoommit

Approved signatory: .....
Mr. Parinya Booncharoen
Calibration Department Manager

เอกสารไม่ควบคุม

THIS CERTIFICATE OF CALIBRATION MAY NOT BE REPRODUCED EXCEPT IN FULL UNLESS PERMISSION FOR REPRODUCTION HAS BEEN OBTAINED IN WRITING FROM THE LABORATORY

JIRANATEE ASSOCIATES CO.,LTD.
Jiranatee Associates Co.,Ltd
63/14-15, 67/35-36
Petchkasem 7,7/1, Rd. Watthapra, Bangkolyai,
Bangkok 10600(Thailand)
Tel: +6603680812
Mobile: +66863999453
E-mail: jnac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Pressure measurement laboratory
Calibration services department.

NSC - TISI - TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : CPR-014-68

MEASUREMENT ITEM	: Digital barometer with display
MANUFACTURER	: BGI Incorporated
MODEL/TYPE	: DeltaCal DC1
SERIAL NUMBER	: 158850
ID NUMBER	: UAE.EFM.038/2561
CONDITION AS-RECEIVED	: Used Item
CUSTOMER	: United Analyst and Engineering Consultant Co., Ltd. 81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
RECEIVED DATE	: 08 Jul 2025
MEASUREMENT DATE	: 23 Jul 2025
ISSUE DATE	: 23 Jul 2025

CONDITION OF THIS RESULT OF CALIBRATION:
1. Calibration effort for calibration sequence C
2. The UUC* was installed in vertical orientation above reference standard instrument and, center of UUC* was used as the reference level.
3. Calibration conditions:
4. Condition : ☑ Normal ☐ Abnormal
   Pressure transmitting medium : Air
   ρ_a (20°C, 1 bar) : 1.19 kg/m³
   H_{amb} : (54.0±0.2) %
   t_{amb} : (22.7±0.3) °C
   p_{amb} : (999.6±0.7) mbar
5. The certificate is valid only to the item calibrated on date and place of calibration

Calibration procedure:
The Digital barometer was calibrated against Digital pressure calibrator. The WI-CL-003 was used as a calibration guideline.

Traceability:
The measurement results are traceable to the international system of units (SI) through the NIMT (National Metrology Institute of Thailand) via Certificate number: MP-0017-25

Reference Used During Calibration:
1. Absolute Pressure Transducer
Model: CPD5500, Serial No.: 42001269

Uncertainty of Measurement:
The reported uncertainty of measurement is based on the standard uncertainty multiplied by a coverage factor k=2, Which for a normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty has been determined in accordance with the GUM 'Evaluation of measurement data - Guide to the expression of uncertainty in measurement'

Calibrated by:
☑ Mr. Sorawit Thachalad
☐ Miss Jittraporn Lertsomphol

Approved signatory: .....
Mr. Parinya Booncharoen
Calibration Department Manager

เอกสารไม่ควบคุม

THIS CERTIFICATE OF CALIBRATION MAY NOT BE REPRODUCED EXCEPT IN FULL UNLESS PERMISSION FOR REPRODUCTION HAS BEEN OBTAINED IN WRITING FROM THE LABORATORY

JIRANATEE ASSOCIATES CO.,LTD.

Continuation of Certificate of Calibration Number CDT-118-68

Result of Calibration: ☑ Without Adjustment ☐ With Adjustment

Calibration Range: 20 °C to 50 °C

Function:

Table 1: This equipment was connected with Ambient temperature sensor probe (Ta) Model: - S/N: - Dimension: Diameter 2.0 mm. Length 44.0 mm.

Immersion Depth (mm)	Standard Reading (°C)	UUC Reading (°C)	Error (°C)	Uncertainty (°C)
40	20.059	20.0	-0.1	0.099
40	30.033	30.0	0.0	0.099
40	35.021	35.2	0.2	0.099
40	40.011	40.2	0.2	0.099
40	49.997	49.8	-0.2	0.099

Table 2: This equipment was connected with Filter temperature sensor probe (Tf) Model: - S/N: - Dimension: Diameter 7.97 mm. Length 102 mm.

Immersion Depth (mm)	Standard Reading (°C)	UUC Reading (°C)	Error (°C)	Uncertainty (°C)
90	20.059	20.1	0.0	0.099
90	30.033	30.1	0.1	0.099
90	35.021	35.1	0.1	0.099
90	40.011	40.1	0.1	0.099
90	49.997	49.7	-0.3	0.099

UUC*: Unit Under Calibration

End of Certificate of Calibration

JIRANATEE ASSOCIATES CO.,LTD.
Jiranatee Associates Co.,Ltd
63/14-15, 67/35-36
Petchkasem 7,7/1, Rd. Watthapra, Bangkolyai,
Bangkok 10600(Thailand)
Tel: +6603680812
Mobile: +66863999453
E-mail: jnac-calibration@jiranatee.com
Web site: www.jiranatee.com

Accredited calibration laboratory
ISO/IEC 17025:2017
NSC-TISI-TIS 17025
CALIBRATION 0367

Pressure measurement laboratory
Calibration services department.

NSC - TISI - TIS 17025
CALIBRATION 0367

CERTIFICATE OF CALIBRATION

Certificate No. : CPR-014-68

MEASUREMENT RESULTS : ☐ Without adjustment ☑ With adjustment

CALIBRATION IN THE RANGE OF : 740 mmHg to 765 mmHg

The results of calibration and associated measurement uncertainties are reported in the table below.

STD (mmHg)	UUC* (mmHg)	Error (mmHg)	Uncertainty (k=2) (mmHg)
740.03	740.0	0.0	0.45
745.02	745.0	0.0	0.45
750.00	750.0	0.0	0.45
755.00	755.0	0.0	0.44
759.99	760.0	0.0	0.44
765.01	765.5	0.5	0.44

Note: UUC* Unit Under Calibration
: To convert the result in report unit to Pa should be multiply by 133.32

End of certificate

JIRANATEE ASSOCIATES CO.,LTD.

เอกสารไม่ควบคุม

Jiranatee Associates Co.,Ltd.

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel. 0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

MULTI-POINT GAS TEST REPORT

Test Date : Feb 17,2026


Equipment :	Gas Analyzer (NO_2)	**Model :**	42i
Manufacturer :	Thermo Scientific	**Serial Number :**	1180540063

Standard Gas Concentration			**Dilutor Detail**	
Sulphur Dioxide (SO_2)	42.89	PPM	Manufacturer :	Thermo Scientific
Nitric Oxide (NO)	46.77	PPM	Model :	146i
Methane (CH_4)	-	PPM	Serial Number :	1180540071
Carbon Monoxide (CO)	965.9			
Cylinder No. :	EB0159156			
Expiration Date :	Nov 6,2026			

Multi-point gas test data

Reference Value (ppb)			Analyzer Display (ppb)	Difference Error	Percent Error	[% Error]
Level 1	Zero	0.0	0.0	0.00	0.00	0.00
Level 2	20.00%	100.0	100.6	0.60	0.60	0.60
Level 3	40.00%	200.0	201.8	1.80	0.89	0.89
Level 4	60.00%	300.0	300.7	0.70	0.23	0.23
Level 5	80.00%	400.0	400.0	0.00	0.00	0.00
Remark : Measuring Range 500.0 ppb				Average Difference (%)		0.34

:Acceptable Limit ± 5%



Calculate by ..... 17 / 02 / 2569

Approve by ..... 17 / Feb / 2026

เอกสารไม่ควบคุม

THAI METEOROLOGICAL DEPARTMENT

4353 Sukhumvit, Bangna, Bangkok 10260 Tel. 081-454-2804,0-2399-0469

Calibration Certificate

Issued by : Calibration & Test Section : Meteorological Instruments Bureau

Date of Issue 2 March, 2026 Certification No. 131/26

Object : Wind Speed & Wind Direction Data Logger

Manufacturer : SCARLET/TECH

Type : WL-21

Mfg Code : Wireless Receiver 2111DR0041
Wind Sensor 2111DT0041

Customer : United Analyst and Engineering Consultant Co.,Ltd.
81 Soi Udomsuk 41, Sukhumvit Road,
Bangchak, Prakanong, Bangkok 10260.

Calibration Condition : Temperature 25.1 °C Barometric Pressure 1004.8 hPa

NATIONAL STANDARD WIND TUNNEL : Wind Aloft Plotting Board
: Micromanometer Theodor Friedrichs FC014 Serial No. 9310119 : HOOK GAGE NO 1425
N.I.S.T. Test Reference Number 731/241460 : Standard Velocity at 20 - 30 m/sec
: Ultrasonic Anemometer Model DA-650-3TV (sensor TR-90AH)
Serial Number 110730029 (sensor 120629686)
JAPAN QUALITY ASSURANCE ORGANIZATION : Standard Velocity at 0 - 20 m/sec
STANDARD THERMOMETER : Theodor Friedrich : Dry No.8390/94 Wet No. 8389/94
: testo, testo 645 Serial No. 02848057 : Thermoschneider No.918802
STANDARD BAROMETER : Digital Barometer Vaisala Type PTB226 No. V1220015
: Digital Barometer Vaisala Type PTB330 No. K1320001

Calibrated by : Mr. Watcharapol Subwat, Mechanical Engineer

Signed : Mr. Pisood Promsut

(Authorised Signatory)
for the Chief
Sub-Standard Instrument

เอกสารไม่ควบคุม

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel. 0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

MULTI-POINT GAS TEST REPORT

Test Date : Mar 3,2026


Equipment :	Gas Analyzer (SO_2)	**Model :**	43i
Manufacturer :	Thermo SCIENTIFIC	**Serial Number :**	1201778113

Standard Gas Concentration			**Dilutor Detail**	
Sulphur Dioxide (SO_2)	42.89	PPM	Manufacturer :	Thermo SCIENTIFIC
Nitric Oxide (NO)	46.77	PPM	Model :	146i
Methane (CH_4)	-	PPM	Serial Number :	1180540071
Carbon Monoxide (CO)	965.9			
Cylinder No. :	EB0159156			
Expiration Date :	Nov 06,2026			

Multi-point gas test data

Reference Value (ppb)			Analyzer Display (ppb)	Difference Error	Percent Error	[% Error]
Level 1	Zero	0.0	0.0	0.00	0.00	0.00
Level 2	20.00%	100.0	100.5	0.50	0.50	0.50
Level 3	40.00%	200.0	200.6	0.60	0.30	0.30
Level 4	60.00%	300.0	300.7	0.70	0.23	0.23
Level 5	80.00%	400.0	400.0	0.00	0.00	0.00
Remark : Measuring Range 500.0 ppb				Average Difference (%)		0.21

:Acceptable Limit ± 5%



Calculate by ..... 3 / 03 / 2569

Approve by ..... 3 / Mar / 2026

เอกสารไม่ควบคุม

THAI METEOROLOGICAL DEPARTMENT

4353 Sukhumvit, Bangna, Bangkok 10260 Tel. 081-454-2804,0-2399-0469

The Result of Calibration

Certification No. 131/26

2 March, 2026

Standard	HOOK GAGE NO. 1425			TESTED ANEMOMETER	
Ultrasonic Anemometer	Pressure	Vacuum	Velocity	Velocity	Correction
m/sec	inches H2O	inches H2O	m/sec	m/sec	m/sec
1.00	-	-	-	1.0	0.00
3.02	-	-	-	3.0	0.02
5.00	-	-	-	5.0	0.00
7.04	-	-	-	7.0	0.04
9.02	-	-	-	9.0	0.02
11.02	-	-	-	11.0	0.02
13.01	-	-	-	13.0	0.01
15.01	-	-	-	15.0	0.01
17.02	-	-	-	17.0	0.02
20.02	-	-	-	20.0	0.02

Vane Angel Bench Stand Model 18112
Young Meteorological Instruments

WIND DIRECTION	TESTED WIND DIRECTION
0	0
90	90
180	180
270	270

Calibrated by : Mr. Watcharapol Subwat, Mechanical Engineer

Calibration & Test Section
Meteorological Instruments Bureau

เอกสารไม่ควบคุม

THAI METEOROLOGICAL DEPARTMENT
4353 Sukhumvit, Bangna, Bangkok 10260 Tel. 081-454-2804,0-2399-0469

The Result of Calibration

Certification No. 131/26

2 March, 2026 Page : 3 of 5

Standard Barometer Pressure	Tested Barometer Pressure	Correction mbar
1005.83	1005	0.83
1006.10	1006	0.10
1006.34	1006	0.34
1006.69	1006	0.69
1007.09	1007	0.09
1007.43	1008	-0.57
1007.93	1008	-0.07
1008.57	1009	-0.43
1008.05	1008	0.05
1008.94	1009	-0.06
1009.34	1009	0.34
1009.06	1009	0.06
1008.75	1009	-0.25
1008.54	1008	0.54
1007.98	1008	-0.02
1007.62	1008	-0.38
1006.87	1007	-0.13
1006.48	1006	-0.52
1004.81	1005	-0.19
1003.82	1004	-0.18

Average

Calibrated by :
Mr. Watcharapol Subwat
Mechanical Engineer

Calibration & Test Section
Meteorological Instruments Bureau

เอกสารไม่ควบคุม

THAI METEOROLOGICAL DEPARTMENT
4353 Sukhumvit, Bangna, Bangkok 10260 Tel. 081-454-2804,0-2399-0469

The Result of Calibration

Certification No. 131/26

2 March, 2026 Page : 5 of 5

Standard Temp. °C	Temperature Sensor Reading	
	Reading °C	Correction °C
45.2	45	0.2
30.2	30	0.2
15.4	15	0.4

Calibrated by :
Mr. Watcharapol Subwat
Mechanical Engineer

Calibration & Test Section
Meteorological Instruments Bureau

เอกสารไม่ควบคุม

THAI METEOROLOGICAL DEPARTMENT
4353 Sukhumvit, Bangna, Bangkok 10260 Tel. 081-454-2804,0-2399-0469

The Result of Calibration

Certification No. 131/26

2 March, 2026 Page : 4 of 5

Standard Barometer Pressure	Tested Barometer Pressure	Correction mmHg
754.43	754	0.43
754.64	755	-0.36
754.82	755	-0.18
755.08	755	0.08
755.38	755	0.38
755.63	755	0.63
756.01	756	0.01
756.49	757	-0.51
756.10	756	0.10
756.77	757	-0.23
757.07	757	0.07
756.86	757	-0.14
756.62	757	-0.38
756.47	757	-0.53
756.05	756	0.05
755.78	756	-0.22
756.21	755	0.21
754.17	754	0.17
753.67	754	-0.33
752.93	753	-0.07

Average

Calibrated by :
Mr. Watcharapol Subwat
Mechanical Engineer

Calibration & Test Section
Meteorological Instruments Bureau

เอกสารไม่ควบคุม

THAI METEOROLOGICAL DEPARTMENT
4353 Sukhumvit, Bangna, Bangkok 10260 Tel. 081-454-2804,0-2399-0469

Calibration Certificate

Issued by : Calibration & Test Section : Meteorological Instruments Bureau

Date of Issue 20 January, 2026 Certification No. 034/26

Page : 1 of 5

Object : Wind Speed & Wind Direction Data Logger

Manufacturer : SCARLET/TECH

Type : WL-21

Mfg Code : Wireless Receiver 2311DR0037
Wind Sensor 2112DT0102

Customer : United Analyst and Engineering Consultant Co.,Ltd.
81 Soi Udomsuk 41, Sukhumvit Road,
Bangchak, Prakanong, Bangkok 10260.

Calibration Condition : Temperature 25.1 °C Barometric Pressure 1010.1 hPa

NATIONAL STANDARD WIND TUNNEL : Vane Angel Bench Stand Model 18112
: Micromanometer Theodor Friedrichs FC014 Serial No. 9310119 : HOOK GAGE NO 1425
N.I.S.T. Test Reference Number 731/241460 : Standard Velocity at 20 - 30 m/sec
: Ultrasonic Anemometer Model OA-650-3TV (sensor TR-90AH)
Serial Number 110730029 (sensor 120629586)
JAPAN QUALITY ASSURANCE ORGANIZATION : Standard Velocity at 0 - 20 m/sec
STANDARD THERMOMETER : Theodor Friedrich : Dry No.8390/94 Wet No. 8389/94
: Thermoschneider No.9188 : testo, testo 645 Serial No. 02848057
STANDARD BAROMETER : Digital Barometer Vaisala Type PTB220 No. K2230015

Calibrated by :
Mr. Watcharapol Subwat
Mechanical Engineer

Signed :
Mr. Pisod Promsut
(Authorised Signatory)
for the Chief
Sub-Standard Instrument

เอกสารไม่ควบคุม

THAI METEOROLOGICAL DEPARTMENT

4353 Sukhumvit, Bangna, Bangkok 10260 Tel. 081-454-2804,0-2399-0469

The Result of Calibration

Certification No. 034/26

20 January, 2026 Page : 2 of 5

Standard	HOOK GAGE NO. 1425			TESTED ANEMOMETER	
Ultrasonic Anemometer	Pressure	Vacumm	Velocity	Velocity	Correction
m/sec	inches H2O	inches H2O	m/sec	m/sec	m/sec
1.00	-	-	-	1.0	0.00
3.02	-	-	-	3.0	0.02
5.00	-	-	-	5.0	0.00
7.04	-	-	-	7.0	0.04
9.02	-	-	-	9.0	0.02
11.02	-	-	-	11.0	0.02
13.01	-	-	-	13.0	0.01
15.01	-	-	-	15.0	0.01
17.02	-	-	-	17.0	0.02
20.02	-	-	-	20.1	-0.08

Vane Angel Bench Stand Model 18112 Young Meteorological Instruments	
WIND DIRECTION	TESTED WIND DIRECTION
0	0
90	90
180	180
270	270

Calibrated by :

Mr. Watcharapol Subwat

Mechanical Engineer

Calibration & Test Section

Meteorological Instruments Bureau

เอกสารไม่ควบคุม

THAI METEOROLOGICAL DEPARTMENT

4353 Sukhumvit, Bangna, Bangkok 10260 Tel. 081-454-2804,0-2399-0469

The Result of Calibration

Certification No. 034/26

20 January, 2026 Page : 4 of 5

Standard Barometer Pressure	Tested Barometer Pressure	Correction mmHg
757.82	758	-0.18
757.60	758	-0.40
757.38	757	0.38
757.13	757	0.13
756.92	757	-0.08
756.69	757	-0.31
756.47	756	0.47
756.24	756	0.24
756.14	756	0.14
755.72	756	-0.28
756.18	756	0.18
756.45	756	0.45
756.74	757	-0.26
757.00	757	0.00
757.28	757	0.28
757.46	758	-0.54
757.60	758	-0.40
757.96	758	-0.04
758.27	758	0.27
758.45	758	0.45

Average

Calibrated by :

Mr. Watcharapol Subwat

Mechanical Engineer

Calibration & Test Section

Meteorological Instruments Bureau

เอกสารไม่ควบคุม

THAI METEOROLOGICAL DEPARTMENT

4353 Sukhumvit, Bangna, Bangkok 10260 Tel. 081-454-2804,0-2399-0469

The Result of Calibration

Certification No. 034/26

20 January, 2026 Page : 3 of 5

Standard Barometer Pressure	Tested Barometer Pressure	Correction mbar
1010.35	1010	0.35
1010.05	1010	0.05
1009.76	1009	0.76
1009.43	1009	0.43
1009.14	1009	0.14
1008.84	1009	-0.16
1008.55	1009	-0.45
1008.24	1008	0.24
1008.11	1008	0.11
1007.54	1008	-0.46
1008.16	1008	0.16
1008.52	1008	0.52
1008.91	1009	-0.09
1009.25	1009	0.25
1009.62	1010	-0.38
1009.86	1010	-0.14
1010.05	1010	0.05
1010.53	1010	0.53
1010.94	1011	-0.06
1011.18	1011	0.18

Average

Calibrated by :

Mr. Watcharapol Subwat

Mechanical Engineer

Calibration & Test Section

Meteorological Instruments Bureau

เอกสารไม่ควบคุม

THAI METEOROLOGICAL DEPARTMENT

4353 Sukhumvit, Bangna, Bangkok 10260 Tel. 081-454-2804,0-2399-0469

The Result of Calibration

Certification No. 034/26

20 January, 2026 Page : 5 of 5

Standard Temp. °C	Temperature Sensor Reading	
	Reading °C	Correction °C
45.6	45	0.6
30.1	30	0.1
15.7	16	-0.3

Calibrated by :

Mr. Watcharapol Subwat

Mechanical Engineer

Calibration & Test Section

Meteorological Instruments Bureau

เอกสารไม่ควบคุม

CALIBRATION LABORATORY CO., LTD.
2/10-11,14,55 Soi Prasert Manukit 29 Yaek 4, Prasert Manukit Road, Ladphrao, Bangkok 10230
Tel. 02-578-0353-4 Fax. 02-578-2672 www.cal-laboratory.com E-mail: sale@cal-laboratory.com

CERTIFICATE OF CALIBRATION

FOR

NOMENCLATURE	:	VIBRATION METER
MANUFACTURER	:	INSTANTEL
MODEL / TYPE	:	721A2501/721A3301
SERIAL NO.	:	UM11230/UM11230[UAE.EFM.029/2559]
CLID. NO.	:	251701315
JOB CONTROL NO.	:	251222149760
CALIBRATION SERVICE	:	☑ IN-LABORATORY ☐ ON-SITE

CUSTOMER : UNITED ANALYST AND ENGINEERING CONSULTANT CO., LTD.
81 SOI UDOMSUK 41, SUKHUMVIT ROAD.
BANGCHAK, PHRAKHANONG, BANGKOK 10260

DATE OF RECEIVED : 22 December 2025 DATE OF ISSUED : 25 December 2025

The report of calibration shall not be reproduced except in full without approval of the Calibration Laboratory Co., Ltd.

Calibrated By : Suwit Phuanbusabong
Calibration Engineer

Approved By : Mongkol Yotsoontorn
Authorized Signatory
25 December 2025

This Calibration Certificate documents the traceability to national standards, which realize the units of measurement according to the International System of Units (SI)

Certificate No. Q25149760
F3-011-05/12-23

เอกสารไม่ควบคุม

CALIBRATION LABORATORY CO., LTD.
2/10-11,14,55 Soi Prasert Manukit 29 Yaek 4, Prasert Manukit Road, Ladphrao, Bangkok 10230
Tel. 02-578-0353-4 Fax. 02-578-2672 www.cal-laboratory.com E-mail: sale@cal-laboratory.com

CONDITION OF CALIBRATION ITEM : RECEIVED IN GOOD OPERATIONAL CONDITION

MEASUREMENT RESULTS : (X) without adjustment ( ) adjustment

CALIBRATION DATA

1. ACCELERATION RESULT

Test point		Mode	STD Reading	DUC Reading	Correction	Uncertainty
(g)	(frequency)		(g)	(g)	(g)	± (% of rdg.)
0.3	50 Hz	peak	0.300	0.304	-0.004	1.9
0.4	50 Hz		0.400	0.406	-0.006	1.6
0.5	50 Hz		0.500	0.507	-0.007	1.6
0.6	50 Hz		0.600	0.608	-0.008	2.5
0.7	50 Hz		0.700	0.710	-0.010	2.5
0.3	100 Hz	peak	0.300	0.302	-0.002	1.9
0.4	100 Hz		0.400	0.404	-0.004	1.6
0.5	100 Hz		0.500	0.506	-0.006	1.6
0.6	100 Hz		0.600	0.608	-0.008	2.5
0.7	100 Hz		0.700	0.709	-0.009	2.5

2. VELOCITY RESULT

Test point		Mode	STD Reading	DUC Reading	Correction	Uncertainty
(mm/s)	(frequency)		(mm/s)	(mm/s)	(mm/s)	± (% of rdg.)
3	50 Hz	peak	3.000	3.029	-0.029	1.8
4	50 Hz		4.000	4.038	-0.038	1.8
5	50 Hz		5.000	5.067	-0.067	1.8
6	50 Hz		6.000	6.076	-0.076	1.8
7	50 Hz		7.000	7.089	-0.089	1.8
3	100 Hz	peak	3.000	3.029	-0.029	1.6
4	100 Hz		4.000	4.039	-0.039	1.6
5	100 Hz		5.000	5.045	-0.045	1.6
6	100 Hz		6.000	6.059	-0.059	1.5
7	100 Hz		7.000	7.068	-0.068	1.5

Certificate No. Q25149760
F3-011-05/12-23

เอกสารไม่ควบคุม

CALIBRATION LABORATORY CO., LTD.
2/10-11,14,55 Soi Prasert Manukit 29 Yaek 4, Prasert Manukit Road, Ladphrao, Bangkok 10230
Tel. 02-578-0353-4 Fax. 02-578-2672 www.cal-laboratory.com E-mail: sale@cal-laboratory.com

REPORT OF CALIBRATION

FOR

NOMENCLATURE	:	VIBRATION METER
MANUFACTURER	:	INSTANTEL
MODEL / TYPE	:	721A2501/721A3301
SERIAL NO.	:	UM11230/UM11230[UAE.EFM.029/2559]
DATE OF CALIBRATION	:	23 December 2025

ENVIRONMENT CONDITIONS :
Temperature : (23 ± 2) °C Relative Humidity : (55 ± 15) %RH

PROCEDURE USED :
This instrument was calibrated under procedure No. CLC-CPEE-08 based on ISO 16063-21 as calibration guideline.
The calibration was performed by using Digital Multimeter, Programmable Timer/Counter and Vibration Calibrator with Measuring Amplifier which maintained by the Calibration Laboratory Co., Ltd.

REFERENCE STANDARD USED :
1. Digital Multimeter, Keysight Technologies Model 3458A S/N. MY59352733.
2. Programmable Timer/Counter, Philips Model PM6680B S/N. SM607101.
3. Vibration Calibrator, The Modal Shop Model 9110D S/N. 11424.

TRACEABILITY :
1. The measurements are traceable to International System of Units (SI), through National Institute of Metrology (Thailand) Certificate No. EE-0090-25, Due Date 31 July 2026.
2. The measurements are traceable to International System of Units (SI), through Aeronautical Radio of Thailand Ltd. Certificate No. 07-0054/25 , Due Date 11 June 2026.
3. The measurements are traceable to International System of Units (SI), through National Institute of Metrology (Thailand) Certificate No. AV-0030-24, Due Date 22 July 2026.

UNCERTAINTY :
The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k = 2$ which for a normal distribution corresponds to a coverage probability of approximately 95 %.
It has been evaluated according to the "Evaluation of the Uncertainty of Measurement in Calibration (EA-4/02 M:2022)"

Certificate No. Q25149760
F3-011-05/12-23

เอกสารไม่ควบคุม

CALIBRATION LABORATORY CO., LTD.
2/10-11,14,55 Soi Prasert Manukit 29 Yaek 4, Prasert Manukit Road, Ladphrao, Bangkok 10230
Tel. 02-578-0353-4 Fax. 02-578-2672 www.cal-laboratory.com E-mail: sale@cal-laboratory.com

CALIBRATION DATA

3. DISPLACEMENT RESULT

Test point		Mode	STD Reading	DUC Reading	Correction	Uncertainty
(mm)	(frequency)		(mm)	(mm)	(mm)	± (% of rdg.)
0.03	50 Hz	peak	0.030	0.030	0.000	2.5
0.04	50 Hz		0.040	0.040	0.000	2.1
0.05	50 Hz		0.050	0.050	0.000	1.9
0.06	50 Hz		0.060	0.061	-0.001	1.8
0.07	50 Hz		0.070	0.071	-0.001	1.8
0.03	100 Hz	peak	0.030	0.030	0.000	2.5
0.04	100 Hz		0.040	0.040	0.000	2.1
0.05	100 Hz		0.050	0.050	0.000	1.9
0.06	100 Hz		0.060	0.061	-0.001	1.8
0.07	100 Hz		0.070	0.071	-0.001	1.8

Note. The Scope of Accredited ANAB Certificate No. ACDM-2814 Version 017 Page 1,2 of 73

This report is valid for the above stated instrument/s only.

End of Certificate

Certificate No. Q25149760
F3-011-05/12-23

เอกสารไม่ควบคุม

CALIBRATION LABORATORY CO., LTD.
2/10-11,14,55 Soi Prasert Manukit 29 Yaek 4, Prasert Manukit Rd., Ladphrao, Bangkok 10230
Tel. 02-578-0353-4 Fax: 02-578-2672 www.cal-laboratory.com E-mail:sale@cal-laboratory.com

CERTIFICATE OF CALIBRATION

FOR

NOMENCLATURE	:	VIBRATION METER
MANUFACTURER	:	INSTANTEL
MODEL / TYPE	:	721A2501/721A2901
SERIAL NO.	:	UM11356/UM11356 [UAE.EFM.003/2560]
CLID. NO.	:	251701398
JOB CONTROL NO.	:	250719084762
CALIBRATION SERVICE	:	☑ IN-LABORATORY ☐ ON-SITE

CUSTOMER : UNITED ANALYST AND ENGINEERING CONSULTANT CO., LTD.
81 SOI UDOMSUK 41, SUKHUMVIT ROAD,
BANGCHAK, PHRAKHANONG, BANGKOK 10260

DATE OF RECEIVED : 19 July 2025 DATE OF ISSUED : 24 July 2025

The report of calibration shall not be reproduced except in full without approval of the Calibration Laboratory Co., Ltd.

Calibrated By : Suwit Phuanbusabong
Calibration Engineer

Approved By : Mongkol Yotsoontorn
Authorized Signatory
24 July 2025

This Calibration Certificate documents the traceability to national standards, which realize the units of measurement according to the International System of Units (SI)

เอกสารไม่ควบคุม

CALIBRATION LABORATORY CO., LTD.
2/10-11,14,55 Soi Prasert Manukit 29 Yaek 4, Prasert Manukit Rd., Ladphrao, Bangkok 10230
Tel. 02-578-0353-4 Fax: 02-578-2672 www.cal-laboratory.com E-mail:sale@cal-laboratory.com

CONDITION OF CALIBRATION ITEM : RECEIVED IN GOOD OPERATIONAL CONDITION

MEASUREMENT RESULTS : (X) without adjustment ( ) adjustment

CALIBRATION DATA

1. ACCELERATION RESULT

Test point		Mode	STD Reading	DUC Reading	Correction	Uncertainty
(g)	(frequency)		(g)	(g)	(g)	± (% of rdg.)
0.3	50 Hz		0.300	0.306	-0.006	1.9
0.4	50 Hz		0.400	0.408	-0.008	1.3
0.5	50 Hz	peak	0.500	0.509	-0.009	1.3
0.6	50 Hz		0.600	0.611	-0.011	2.5
0.7	50 Hz		0.700	0.713	-0.013	2.5
0.3	100 Hz		0.300	0.304	-0.004	1.9
0.4	100 Hz		0.400	0.406	-0.006	1.3
0.5	100 Hz	peak	0.500	0.507	-0.007	1.3
0.6	100 Hz		0.600	0.609	-0.009	2.5
0.7	100 Hz		0.700	0.710	-0.010	2.5

2. VELOCITY RESULT

Test point		Mode	STD Reading	DUC Reading	Correction	Uncertainty
(mm/s)	(frequency)		(mm/s)	(mm/s)	(mm/s)	± (% of rdg.)
3	50 Hz		3.000	3.041	-0.041	1.8
4	50 Hz		4.000	4.053	-0.053	1.8
5	50 Hz	peak	5.000	5.061	-0.061	1.8
6	50 Hz		6.000	6.076	-0.076	1.8
7	50 Hz		7.000	7.088	-0.088	1.8
3	100 Hz		3.000	3.044	-0.044	2.7
4	100 Hz		4.000	4.049	-0.049	1.3
5	100 Hz	peak	5.000	5.057	-0.057	1.3
6	100 Hz		6.000	6.062	-0.062	1.0
7	100 Hz		7.000	7.071	-0.071	1.0

เอกสารไม่ควบคุม

CALIBRATION LABORATORY CO., LTD.
2/10-11,14,55 Soi Prasert Manukit 29 Yaek 4, Prasert Manukit Rd., Ladphrao, Bangkok 10230
Tel. 02-578-0353-4 Fax: 02-578-2672 www.cal-laboratory.com E-mail:sale@cal-laboratory.com

REPORT OF CALIBRATION

FOR

NOMENCLATURE	:	VIBRATION METER
MANUFACTURER	:	INSTANTEL
MODEL / TYPE	:	721A2501/721A2901
SERIAL NO.	:	UM11356/UM11356 [UAE.EFM.003/2560]
DATE OF CALIBRATION	:	19 July 2025

ENVIRONMENT CONDITIONS :
Temperature : (23 ± 2) °C Relative Humidity : (55 ± 15) %RH

PROCEDURE USED :
This instrument was calibrated under procedure No. CLC-CPEE-08 based on ISO 16063-21 as calibration guideline.
The calibration was performed by using Digital Multimeter, Programmable Timer/Counter and Accelerometer with Measuring Amplifier which maintained by the Calibration Laboratory Co., Ltd.

REFERENCE STANDARD USED :
1. Digital Multimeter, Wavetek Model 1281 S/N. 29320.
2. Programmable Timer/Counter, Philips Model PM6680B S/N. SM607101.
3. Accelerometer with Measuring Amplifier, Bruel & Kjaer Model 8305, 2625 S/N. 397018, 2434988.

TRACEABILITY :
1. The measurements are traceable to International System of Units (SI), through Aeronautical Radio of Thailand Ltd.
Certificate No. 05-0316/23 , Due Date 21 July 2025.
2. The measurements are traceable to International System of Units (SI), through Aeronautical Radio of Thailand Ltd.
Certificate No. 07-0054/25 , Due Date 11 June 2026.
3. The measurements are traceable to International System of Units (SI), through National Institute of Metrology (Thailand)
Certificate No. AV-0056-24, Due Date 14 December 2025.

UNCERTAINTY :
The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k = 2,00$ which for a normal distribution corresponds to a coverage probability of approximately 95 %.
It has been evaluated according to the "Evaluation of the Uncertainty of Measurement in Calibration (EA-4/02 M:2022)"

เอกสารไม่ควบคุม

CALIBRATION LABORATORY CO., LTD.
2/10-11,14,55 Soi Prasert Manukit 29 Yaek 4, Prasert Manukit Rd., Ladphrao, Bangkok 10230
Tel. 02-578-0353-4 Fax: 02-578-2672 www.cal-laboratory.com E-mail:sale@cal-laboratory.com

CALIBRATION DATA

3. DISPLACEMENT RESULT

Test point		Mode	STD Reading	DUC Reading	Correction	Uncertainty
(mm)	(frequency)		(mm)	(mm)	(mm)	± (% of rdg.)
0.03	50 Hz		0.030	0.030	0.000	2.1
0.04	50 Hz		0.040	0.040	0.000	1.7
0.05	50 Hz	peak	0.050	0.051	-0.001	1.4
0.06	50 Hz		0.060	0.061	-0.001	1.3
0.07	50 Hz		0.070	0.071	-0.001	1.1
0.03	100 Hz		0.030	0.030	0.000	2.1
0.04	100 Hz		0.040	0.040	0.000	1.7
0.05	100 Hz	peak	0.050	0.051	-0.001	1.4
0.06	100 Hz		0.060	0.061	-0.001	1.3
0.07	100 Hz		0.070	0.071	-0.001	1.1

Note. The Scope of Accredited ANAB Certificate No. ACDM-2814 Version 015 Page 1.2 of 68

This report is valid for the above stated instrument/s only.

End of Certificate

เอกสารไม่ควบคุม

INNOVATIVE INSTRUMENT CALIBRATION LAB
INNOVATIVE INSTRUMENT CO., LTD. HEAD OFFICE
7/139 MOO 13, SOI SUNTINAKORN 11 TAMBON BANG KAEO,
AMPHOE BANG PHLI SAMUT PRAKAN PROVINCE 10540 THAILAND
TEL: 0660-2130-5860-1 FAX: 0660-2116-7140

Certificate of Calibration

Customer

Name : UNITED ANALYST AND ENGINEERING CONSULTANT CO.,LTD.
Address : 81 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Prakanong, Bangkok 10260

Certificate No : 25-SLM-242
Request No : Req-2025-1241

Unit Under Calibration Details

Measurement item : Sound Level Meter
Manufacturer : LARSON DAVIS
Model : LxT2
Serial Number : 0005288
ID : UAE.EFM.104/2582
Resolution : 0.1 dB

Microphone Class : 2
Microphone Model : 377B02
Microphone S/N : 011731
Preamplifier Model : PRMLxT2B
Preamplifier S/N : 056075
Instrument Status : Used

Calibration Environment and Details

Temperature : 23 °C ± 2 °C
Humidity : 50 %RH ± 20 %RH
Barometric Pressure : 1013 hPa ± 10 hPa
Received Date : 16 July 2025
Calibrated Date : 29 July 2025
Calibration Procedure : In-house method CP-SLM-01 based on IEC 61672-3 : 2013 Electroacoustics - Sound level meters - Part 3: Periodic tests
Location of Calibration : Lab Acoustic

Reference Standard

Instrument	Brand	Model	SN.	Due calibration	Traceability
Multifunction Acoustic Calibrator	Bruel&Kjaer	4226	3412381	8 May 2026	NIMT
Audio Generator	Svantek	Svan401	131	15 October 2025	WK Electric

Note

The reported uncertainty is based on standard uncertainty multiplied by the Coverage Factor $k = 2$, providing a level of confidence approximately 95 %.

Calibrated By : Mr. Noppadon Laangart
Service Calibration Engineer

Approved By : Mr. Pacit Mathavern
Calibration Engineer Supervisor

Issue Date : 29 July 2025

เอกสารไม่ควบคุม

The results related only to the item calibrated. The certificate shall not be reproduced except in full, without written approval of the Innovative Instrument Co., Ltd.

INNOVATIVE INSTRUMENT CALIBRATION LAB
INNOVATIVE INSTRUMENT CO., LTD. HEAD OFFICE
7/139 MOO 13, SOI SUNTINAKORN 11 TAMBON BANG KAEO,
AMPHOE BANG PHLI SAMUT PRAKAN PROVINCE 10540 THAILAND
TEL: 0660-2130-5860-1 FAX: 0660-2116-7140

Certificate No : 25-SLM-242
Request No : Req-2025-1241

5. Electrical signal test of frequency weightings, Weighting network respone with relative to 1 kHz

UUC Setting	Deviation from various Frequency Weighting Respone curve			UNCERTAINTY
FAST / 37-139				
STD Setting	A (dB)	C (dB)	Z (dB)	(± dB)
63 Hz	-0.1	0.0	0.0	0.20
125 Hz	-0.1	0.1	0.0	
250 Hz	-0.1	0.0	0.0	
500 Hz	0.0	0.1	0.0	
1000 Hz	0.0	0.0	0.0	
2000 Hz	0.1	0.1	0.0	
4000 Hz	0.0	0.1	0.1	
8000 Hz	0.0	0.0	0.1	
16000 Hz	0.0	0.0	-0.1	

6. Frequency and time weightings at 1kHz

UUC Setting	STD	Measured		UNCERTAINTY
FAST / 37-139	REF	UUC	ERR	
UUC Weighting	(dB)	(dB)	(dB)	(± dB)
A	114.00	114.0	0.0	0.20
C	114.00	114.0	0.0	
Z	114.00	114.0	0.0	

UUC Setting	STD	Measured		UNCERTAINTY
37-139 / A	REF	UUC	ERR	
UUC Time Respone	(dB)	(dB)	(dB)	(± dB)
Fast	114.00	114.0	0.0	0.20
Slow	114.00	114.0	0.0	
Leq	114.00	114.0	0.0	

เอกสารไม่ควบคุม

The results related only to the item calibrated. The certificate shall not be reproduced except in full, without written approval of the Innovative Instrument Co., Ltd.

INNOVATIVE INSTRUMENT CALIBRATION LAB
INNOVATIVE INSTRUMENT CO., LTD. HEAD OFFICE
7/139 MOO 13, SOI SUNTINAKORN 11 TAMBON BANG KAEO,
AMPHOE BANG PHLI SAMUT PRAKAN PROVINCE 10540 THAILAND
TEL: 0660-2130-5860-1 FAX: 0660-2116-7140

Certificate No : 25-SLM-242
Request No : Req-2025-1241

1. Indication at the calibration check frequency

UUC Setting	Nominal	Before Adjust		After Adjust		UNCERTAINTY
FAST / A / 37-139	Level	UUC	ERR	UUC	ERR	
Calibrator Setting	(dB)	(dB)	(dB)	(dB)	(dB)	(± dB)
1000 Hz 114 dB	114.68	115.2	0.52	114.7	0.02	0.20

Note : Absolute sensitivity was established by the use of Sound Calibrator Brand 3M, Model AC-300, SN. AC-300001087

2. Self-generated noise, Microphone installed

UUC Setting	Measured	UNCERTAINTY
FAST / 37-139		
UUC Weighting	(dB)	(± dB)
A	30.8	0.10

3. Self-generated noise, Microphone replaced by the electrical input signal device

UUC Setting	Measured	UNCERTAINTY
FAST / 37-139		
UUC Weighting	(dB)	(± dB)
A	30.6	0.10
C	30.2	0.10
Z	34.3	0.10

4. Acoustic signal test of frequency weightings (Without Windscreen)

UUC Setting	Deviation from various Frequency Weighting Respone curve			UNCERTAINTY
FAST / 37-139	A	C	Z	
STD Setting	(dB)	(dB)	(dB)	(± dB)
125 Hz	0.1	0.1	0.1	0.60
1000 Hz	0.0	0.0	0.0	0.60
4000 Hz	1.6	1.6	1.6	0.60
8000 Hz	2.2	2.2	2.3	0.70

เอกสารไม่ควบคุม

The results related only to the item calibrated. The certificate shall not be reproduced except in full, without written approval of the Innovative Instrument Co., Ltd.

INNOVATIVE INSTRUMENT CALIBRATION LAB
INNOVATIVE INSTRUMENT CO., LTD. HEAD OFFICE
7/139 MOO 13, SOI SUNTINAKORN 11 TAMBON BANG KAEO,
AMPHOE BANG PHLI SAMUT PRAKAN PROVINCE 10540 THAILAND
TEL: 0660-2130-5860-1 FAX: 0660-2116-7140

Certificate No : 25-SLM-242
Request No : Req-2025-1241

7. Long Term Stability

UUC Setting	Measured	UNCERTAINTY
FAST / A / 37-139	UUC	
STD Setting	(dB)	(± dB)
Initial	114.0	[redacted]
Final	114.0	
Deviated	0.0	0.10

8. Level linearity on the reference level range

UUC Setting	Anticipated	Deviation		UNCERTAINTY
FAST / A / 37-139	REF	UUC	ERR	
STD dB	(dB)	(dB)	(dB)	(± dB)
139.00	139	139.0	0.0	0.30
134.00	134	134.0	0.0	
129.00	129	129.0	0.0	
124.00	124	124.0	0.0	
119.00	119	119.0	0.0	
114.00	114	114.0	0.0	
109.00	109	109.0	0.0	
104.00	104	104.0	0.0	
99.00	99	99.0	0.0	
94.00	94	94.0	0.0	
89.00	89	89.0	0.0	
84.00	84	84.0	0.0	
79.00	79	79.0	0.0	
74.00	74	74.0	0.0	
69.00	69	69.0	0.0	
64.00	64	64.0	0.0	
59.00	59	59.0	0.0	
54.00	54	54.1	0.1	
49.00	49	49.1	0.1	
44.00	44	44.2	0.2	
40.00	40	40.5	0.5	

เอกสารไม่ควบคุม

The results related only to the item calibrated. The certificate shall not be reproduced except in full, without written approval of the Innovative Instrument Co., Ltd.

Certificate No : 25-SLM-242
Request No : Req-2025-1241

9. Level linearity including the level range control

UUC Setting	STD	Measured		UNCERTAINTY
FAST / A	REF	UUC	ERR	
UUC Range	(dB)	(dB)	(dB)	(± dB)
37-139	45.20	45.4	0.2	0.30
	114	114.0	0.0	

10. Tone burst response

UUC Setting	STD	Anticipated	Measured		UNCERTAINTY
A / 37-139	Toneburst	Ref	UUC	ERR	
UUC Time Respone	(ms)	(dB)	(dB)	(dB)	(± dB)
Fast	200	135.0	134.9	-0.1	0.20
	2	118.0	117.8	-0.2	
	0.25	109.0	108.7	-0.3	
Slow	200	128.6	128.4	-0.2	
	2	109.0	108.8	-0.2	
SEL	200	129.0	129.0	0.0	
	2	109.0	108.9	-0.1	
	0.25	100.0	99.8	-0.2	

11. Peak C Sound level

UUC Setting	Anticipated	Measured		UNCERTAINTY
FAST / C / 95-142	REF	UUC	ERR	
STD Setting	(dB)	(dB)	(dB)	(± dB)
Complete cycle	137.4	136.7	-0.70	0.20
Positive half cycle	136.4	136.1	-0.30	
Negative half cycle	136.4	136.1	-0.30	

เอกสารไม่ควบคุม

The results related only to the item calibrated. The certificate shall not be reproduced except in full, without written approval of the Innovative Instrument Co., Ltd.

ELECTRICAL AND ELECTRONICS INSTITUTE
FOUNDATION FOR INDUSTRIAL DEVELOPMENT
975 Moo 4, Bangpoo Industrial Estate, Soi 8, Sukhumvit Road km 37,
Phraek Sa, Mueang Samut Prakan, Samut Prakan 10280
Tel: +66 2709 4860 Fax: +66 2324 0917

Certificate No.: CP20240341EA
Operation No.: CP2024090312

Certificate of Calibration

Equipment:	Sound Level Meter
Manufacturer:	Larson Davis (Meter), PCB (Microphone), PCB (Preamplifier)
Model/Type:	LxT2 (Meter), 375B02 (Microphone), PRMLxT2B (Preamplifier)
Serial No.:	0005298 (Meter), 011741 (Microphone), 056088 (Preamplifier)
ID No.:	UAE.EFM.113/2562
Customer:	United Analyst and Engineering Consultant Co.,Ltd.
Address:	81 Soi Udomsuk 41, Sukhumvit Road, Bangchak Phrakhanong, Bangkok 10260
Received Date:	3 September 2024
Calibrated Date:	23 - 25 September 2024
Issued Date:	26 September 2024
Calibrated by:	Ms. Juntaporn Kunhakorn

Approved by:
(Mr. Sittichai Swaksuriyawong)
Group Manager

This report was prepared electronically using applicable electronic signature. Printing or copy of file are considered as a copy of the document.
The reported uncertainty of measurement was based on standard uncertainty multiplied by a coverage factor (k) providing a level of confidence of approximately 95%. This certificate may not be reproduced other than in full except with the prior written approval of the Electrical and Electronics Institute, Foundation for Industrial Development.

F-CAL-004 Ed.1

เอกสารไม่ควบคุม

INNOVATIVE INSTRUMENT CALIBRATION LAB
INNOVATIVE INSTRUMENT CO., LTD. HEAD OFFICE
7/139 MOO 13, SOI SUNTINAKORN 11 TAMBON BANG KAEO,
AMPHOE BANG PHLI SAMUT PRAKAN PROVINCE 10540 THAILAND
TEL.: 0660-2116-5860-1 FAX: 0660-2116-7140
Page : 6/6.

Certificate No : 25-SLM-242
Request No : Req-2025-1241

12. Overload indication

UUC Setting	Measured	UNCERTAINTY
FAST / A / 37-139	UUC	
STD Setting	(dB)	(± dB)
Positive one-half cycle	142.5	
Negative one-half cycle	142.4	
Deviated	0.1	0.20

13. High Level Stability

UUC Setting	Measured	UNCERTAINTY
FAST / A / 37-139	UUC	
STD Setting	(dB)	(± dB)
Initial	138.0	
Final	138.0	
Deviated	0.0	0.10

End of Certificate

เอกสารไม่ควบคุม

The results related only to the item calibrated. The certificate shall not be reproduced except in full, without written approval of the Innovative Instrument Co., Ltd.
IM-708-SLM-01 Rev.06 Issue date 17/2/25

ELECTRICAL AND ELECTRONICS INSTITUTE
FOUNDATION FOR INDUSTRIAL DEVELOPMENT

Certificate No.: CP20240341EA

Calibration Report

Equipment: Sound Level Meter
Manufacturer: Larson Davis (Meter), PCB (Microphone), PCB (Preamplifier)
Model/Type: LxT2 (Meter), 375B02 (Microphone), PRMLxT2B (Preamplifier)
Serial No.: 0005298 (Meter), 011741 (Microphone), 056088 (Preamplifier)
ID No.: UAE.EFM.113/2562
Ambient Temperature: (23 ± 2) °C
Relative Humidity: (50 ± 15) %
Pressure: (101.3 ± 1.5) kPa
Method of Calibration :-
IEC 61672-3:2013.
Condition of this result of calibration
1. Reference standards instrument :-

	Instrument	Model	Serial No.	Cert. No.	Due Date
1)	Standard microphone	4180	2787490	AA-1012-23	12 November 2024
2)	Arbitrary Function Generator	AFG2021	C010063	CK20240048EA	23 June 2025
3)	Programmable Attenuator	PA5	2755	EF-0040-23	1 October 2024
4)	6.5 Digit precision multimeter	8846A	9610014	CB20230200EA	15 November 2024
5)	Pressure humidity and Temperature Transmitter	PTU301	F0640002	CL1-P240022 CD20240180EA	20 March 2025 7 August 2025
6)	Performance Audio Analyzer	UB903B	MY56510003	CB20240035EB CK20240069EA	13 February 2025 19 September 2025

2. This result of calibration was found accurate as shown on date and place of calibration only.
3. This certification is traceable to the international system of unit maintained at :-
Reference standards instrument for Acoustic function
- National Institute of Metrology (Thailand)
- Electrical and Electronics Institute; NSC Accredited Calibration No.0119
Reference standards instrument for Electrical function
- National Institute of Metrology (Thailand)
- Electrical and Electronics Institute; NSC Accredited Calibration No.0119

Result of Calibration:-
Function : 1. Indication at the calibration check frequency

Reference Acoustic Signal (dB)	Measured value (dB)	Deviation (dB)	Acceptance Limits (dB)
-	-	-	-

F-CAL-005 Ed.1

เอกสารไม่ควบคุม

Certificate No.: CP20240341EA

Calibration Report

Function : 2. Self-generated Noise

2.1 Microphone installed

Measured value (dB)
31.3

2.2 Microphone replaced by the electrical input signal device

Frequency Weighting	Measured value (dB)
A-weighting	31.1
C-weighting	31.0
Z-weighting	36.5

Function : 3. Acoustical signal tests of frequency weightings (Without Windscreen)

Meter free-field acoustic response at a level of 84 dB.

Frequency (Hz)	Deviation from various Frequency Weighting Response Curve			
	C-Weighting (dB)	A-Weighting (dB)	Z-Weighting (dB)	Acceptance limits (dB)
125	0.2	0.1	0.1	±1.5
1000	0.3	0.3	0.3	±1.0
8000	1.3	1.2	1.3	±5.0

Function : 4. Electrical signal tests of frequency weightings

Weighting network response with relative to 1 kHz.

Frequency (Hz)	Deviation from various Frequency Weighting Response Curve			
	C-Weighting (dB)	A-Weighting (dB)	Z-Weighting (dB)	Acceptance limits (dB)
63	0.0	0.0	0.0	±2.0
125	0.0	0.0	-0.1	±1.5
250	0.0	0.0	0.0	±1.5
500	0.1	0.0	0.0	±1.5
1000	0.0	0.0	0.0	±1.0
2000	0.1	0.0	0.0	±2.0
4000	0.0	0.0	0.0	±3.0
8000	0.0	0.0	0.0	±5.0

Function : 5. Frequency and time weighting at 1 kHz

5.1 Frequency weighting at 1 kHz

Frequency Weighting	Measured value (dB)	Deviated value (dB)	Acceptance limits (dB)
C-weighting	94.0	0.0	±0.2
A-weighting	94.0	0.0	±0.2
Z-weighting	94.0	0.0	±0.2

เอกสารไม่ควบคุม

ELECTRICAL AND ELECTRONICS INSTITUTE
FOUNDATION FOR INDUSTRIAL DEVELOPMENT

Certificate No.: CP20240341EA

Calibration Report

5.2 Time weighting at 1 kHz

Time Weighting	Measured value (dB)	Deviated value (dB)	Acceptance limits (dB)
Fast	94.0	0.0	±0.1
Slow	94.0	0.0	±0.1
LAeq	94.0	0.0	±0.1

Function : 6. Long-Term Stability

Long-term stability over 30 minutes, with steady 1 kHz signal at reference level.

Time Period to Apply Signal (min)	Reference SPL (dB)	Record SPL at Conclusion of Time Period (dB)	Deviated value (dB)	Acceptance limits (dB)
30	94.0	94.0	0.0	±0.3

Function : 7. Level Linearity on the reference level range

7.1 Level Linearity on the reference level range, Upper

Anticipated Value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limits (dB)
94.0	94.0	0.0	±1.1
99.0	99.0	0.0	±1.1
104.0	104.0	0.0	±1.1
109.0	109.0	0.0	±1.1
114.0	114.0	0.0	±1.1
119.0	119.0	0.0	±1.1
124.0	124.0	0.0	±1.1
129.0	129.0	0.0	±1.1
134.0	134.1	0.1	±1.1
139.0	139.1	0.1	±1.1
140.0	140.1	0.1	±1.1
141.0	141.1	0.1	±1.1
142.0	142.1	0.1	±1.1
143.0	143.1	0.1	±1.1

เอกสารไม่ควบคุม

ELECTRICAL AND ELECTRONICS INSTITUTE
FOUNDATION FOR INDUSTRIAL DEVELOPMENT

Certificate No.: CP20240341EA

Calibration Report

7.2 Level Linearity on the reference level range, Lower

Anticipated Value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limits (dB)
94.0	94.0	0.0	±1.1
89.0	89.0	0.0	±1.1
84.0	84.0	0.0	±1.1
79.0	79.0	0.0	±1.1
74.0	74.0	0.0	±1.1
69.0	69.0	0.0	±1.1
64.0	64.0	0.0	±1.1
59.0	59.0	0.0	±1.1
54.0	54.0	0.0	±1.1
49.0	49.0	0.0	±1.1
44.0	44.2	0.2	±1.1
43.0	43.3	0.3	±1.1
42.0	42.4	0.4	±1.1
41.0	41.5	0.5	±1.1
40.0	40.5	0.5	±1.1

Function : 8. Tone burst response

Time Weighting	Tone burst duration, Tb (ms)	Measured value (dB)	Deviated value (dB)	Acceptance limits (dB)
Fast	200	136.0	0.0	±1.0
	2	118.9	-0.1	+1.0 ; -2.5
	0.25	109.8	-0.2	+1.5 ; -5.0
Slow	200	129.5	-0.1	±1.0
	2	109.9	-0.1	+1.0 ; -5.0
LAE	200	130.0	0.0	±1.0
	2	110.0	0.0	+1.0 ; -2.5
	0.25	101.0	0.0	+1.5 ; -5.0

Function : 9. Peak C sound level

Number of cycles in test signal	Anticipated Value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limits (dB)
Complete cycle	135.4	134.8	-0.6	±3.0
Positive half cycle	134.4	134.1	-0.3	±2.0
Negative half cycle	134.4	134.2	-0.2	±2.0

Function : 10. Overload indication

Measured value (dB)		Deviated value (dB)	Acceptance limits (dB)
Positive one-half cycle	Negative one-half cycle		
145.0	145.2	0.2	±1.5

เอกสารไม่ควบคุม

ELECTRICAL AND ELECTRONICS INSTITUTE
FOUNDATION FOR INDUSTRIAL DEVELOPMENT

Certificate No.: CP20240341EA

Calibration Report

Function : 11. High-Level Stability

High-level stability over 5 minutes, with steady 1 kHz signal, 1 dB below upper boundary.

Time Period to Apply Signal (min)	Reference SPL (dB)	Record SPL at Conclusion of Time Period (dB)	Deviated value (dB)	Acceptance limits (dB)
5	139.0	139.0	0.0	±0.3

Uncertainty of measurement

Function	Uncertainty (dB)	Maximum-permitted uncertainty of measurement (dB)
1) Indication at the calibration check frequency	0.30	Not applicable
2) Self-generated Noise	0.10	Not applicable
3) Acoustical signal tests of frequency weightings - Free-field sound pressure response level	0.30	0.60 (10Hz to 4kHz) 0.70 (>4kHz to 10kHz)
4) Electrical signal tests of frequency weightings	0.20	0.20
5) Frequency and time weighting at 1 kHz	0.20	0.20
6) Long-Term Stability	0.10	0.10
7) Level Linearity on the reference level range	0.30	0.30
8) Tone burst response	0.20	0.30
9) Peak C sound level	0.20	0.35
10) Overload indication	0.24	0.25
11) High-Level Stability	0.10	0.10

Remarks: 1. The acceptance limit is for the deviated value.
2. Acceptance limits was IEC61672-3:2013 Class 2.
3. The coverage factor $k = 2.00$

- - End of Report - -

เอกสารไม่ควบคุม

Agilent

Agilent AA Series Spectrometers

Preventative Maintenance Checklist

[redacted]

Foreword

Agilent Preventive Maintenance provides factory recommended service for your analytical systems to assure reliable operation and the accuracy of your results.

Delivered by highly trained and certified service engineers using genuine Agilent parts and supplies, Agilent Preventive Maintenance provides everything you need to reduce unplanned downtime and keep your systems operating at their peak. This checklist will be completed at the end of the service and provided to you as a record of the installation.

NOTE While non-current production AA instrument and or accessory models are not covered specifically in this document it can be used as a basic reference.

For more information about Agilent Technologies services please visit our web site using the following URL http://www.agilent.com/en-us/services

เอกสารไม่ควบคุม

Contents

Customer information	3
Service Engineer's Responsibilities	3
Other important Customer Web links	3
System information	4
Preparation, Safe operation and Initial performance checks	4
Preventative maintenance procedures	5
Flame systems	5
Furnace systems	6
Accessories	8
Restore System	9
Guidance	9
Signature Page	9
Service Review	9
Test Results	10
AA consumable and parts list	10
Service Engineer Comments (optional)	11
Service Completion	12

Agilent

เอกสารไม่ควบคุม

Customer information

- Customers should provide all necessary operating supplies upon request of the engineer.
- A customer representative should be available to the engineer while performing the preventive maintenance procedures.
- Any parts, not included in the Parts Lists section of this document, are not part of the recommended Preventive Maintenance service, nor are they included in the price of this service.
- If a system requires the use of extra or special procedures and/or parts for the maintenance service, then these must be ordered separately and charged as a repair, which may incur additional costs.

Service Engineer's Responsibilities

- Contact the customer and ensure that all necessary supplies are available before the preventive maintenance visit.
- Confirm the ability of the instrument to deliver continued safe operation as established via the Agilent AA safe operation flow chart. **(Refer directly to the AA 55/240/280 Preventive Maintenance Scope of Work to make this decision.)**
- Only select those pages that relate to the system or module being serviced.
- Complete empty fields with the relevant information.
- Complete the relevant checkboxes in the checklist using either a "X" or tick mark "√".
- Check "Section not applicable" check boxes to indicate services/tasks not delivered, as appropriate.
- Complete the Preventive Maintenance service in the order of the tasks listed.
- Complete the Service Review section together with the customer.
- Complete the fields for page numbers at the foot of each selected page
- Complete the total number of pages field in the Service Completion section
- Ask the customer to sign the Service Completion section including the customer's and your signature.

This information is subject to change without notice.

Other important Customer Web links

- How to get information on your product: Literature Library — http://www.agilent.com/chem/library
- Need to know more? www.agilent.com/chem/education
- Need technical support, FAQs? www.agilent.com/chem/techsupp
- Need supplies? www.agilent.com/chem/supplies

Agilent

เอกสารไม่ควบคุม

System information

☐ Check this box if an instrument configuration report is attached instead of completing this table.

Instrument system name and ID	240 FS AAS
Instrument system site and location	United Analyst and Engineering Consultant
List system component product numbers	List the serial numbers of each component
1 G 8432 A	1 MY 13160001
2	2
3	3
4	4
5	5
6	6
7	7
8	8
9	9
10	10

Preparation, Safe operation and Initial performance checks

☐ Agilent AA safe operation flow chart inspections (to determine if the PM can be performed).

NOTE If by following the flow chart the instrument is deemed to be unsafe for continued use you MUST NOT continue PM work. Inform the customer immediately of the Agilent recommendation that use of the instrument be discontinued.

- ☑ Discuss any specific questions or issues with the customer prior to starting.
- ☐ For HF application systems, if standard sample introduction system was not installed, ask the customer to install it. N/A
- ☑ Review the instrument logbook for recorded problems and comments.
- ☑ Save instrument control settings before starting the procedure.
- ☑ Perform a general inspection of the system for cleanliness.
- ☑ Check for proper installation of parts, assemblies, sensors etc.
- ☑ Check system for required installation of components, settings as defined by current Service Notes

Agilent

เอกสารไม่ควบคุม

- [x] Check for required firmware updates and verify with customers if they would like them installed.
- [x] Use SVD to perform a Full Wavelength Scan for Cu HCL - "As found test_1"
- [x] Perform a Basic Cu ABS test - "As found test_2"
- [x] Print the Details page or screen captures of the test results and attach to the end of this checklist.

Preventative maintenance procedures

Flame systems

- [ ] Section NOT applicable.

Electronic components

- [x] Review and confirm instrument configuration data in SVD
- [x] Confirm power supply voltages using the **SVD Power Supply diagnostic**.
- [x] For Dual Beam instruments - Confirm RBC frequency using the **SVD RBC frequency diagnostic**.

Mechanical components

- [x] Check the burner adjuster controls for complete and free movement. If the burner adjuster needs lubrication, use Molykote 321 or mineral-based molybdenum disulphide grease.
- [x] Run SVD tests to exercise all motor drives over the full range of their travel:
  - [x] Monochromator drive
  - [x] Slit drive
  - [x] Lamp selector
  - [ ] Automatic Burner Adjuster

Optics components

- [x] Check that external optical surfaces are clean – Clean or replace as required.
- [x] Use SVD and perform **Mono Wavelength Correction**.
- [x] Use SVD and perform **Slit Calibration**.
- [x] Use SVD and perform **Grating Squareness Diagnostic**.
- [x] Use SVD and perform **Zero Order Offset/Mono Correction**.
- [x] Use SVD and perform **Wavelength Repeatability**.
- [x] Physically inspect selected HC lamps (customer to supply per their choice) and measure the % Gain for each lamp. Advise customer if lamps are showing emission degradation due to age.
- [x] Check that the signal energy of the D2 and HC lamps track properly. Advise customer if their D2 lamp is showing emission degradation due to age.

Agilent
เอกสารไม่ควบคุม

Sample introduction and Atomization

- [x] Inspect the burner interlock plate to ensure that the interlock pin is secure and correct for the burner type.
- [x] Clean the burner slot with a clean white card.
- [x] Check the uniformity of the slot width.
- [x] Clean the burner if required.
- [x] Change the burner o-ring and lubricate with PFPE grease.
- [x] Clean the nebulizer, spray chamber and liquid trap.
- [x] Change all o-rings and seals in the nebulizer, nebulizer block and spray chamber and lubricate.
- [x] Check that the pressure relief bung releases readily.
- [x] Change o-rings on the fuel and oxidant delivery barbs and lubricate.
- [x] Leave the liquid trap EMPTY and verify the flame will not ignite in this state.
- [x] Refill liquid trap and check that overfill drains freely into the drain/waste tube.
- [x] Check the drain/waste tube for good drainage. It should not have tight bends, kinks or loops and the lower end must be above the liquid level in the waste vessel.
- [x] Check and clean the igniter electrode.

Gas handling components and safety interlocks

- [x] Pressure test for leaks
- [x] Leak test gasbox internal components using gasbox leak tester G8434-67013
- [x] Check safety interlock status and operation using the **SVD interlock monitoring diagnostic**.

Analytical performance for Flame systems

- [x] Ignite a flame.
- [x] Check that you can adjust the nebulizer uptake rate from 4 to 6.5 mL per minute.
- [x] Optimize the instrument ready to perform Cu sensitivity test.
- [x] Create a manual method to perform a Basic Cu ABS test - "Final Performance Testing."
- [x] Run a PM completed sensitivity test for a 5 ppm copper sample and record the results in the AA PM Performance test results and measurements table.

Furnace systems

- [x] Section NOT applicable.

Electronic components

- [ ] Review and confirm instrument configuration data in SVD
- [ ] Confirm power supply voltages using the **SVD Power Supply diagnostic**.

Mechanical components

- [ ] Run SVD tests to exercise all motor drives over the full range of their travel:
  - [ ] Monochromator drive
  - [ ] Slit drive

Agilent
เอกสารไม่ควบคุม

- [ ] Lamp selector

Optics components

- [ ] Check that external optical surfaces are clean – Clean or replace as required.
- [ ] Use SVD and perform **Mono Wavelength Correction**.
- [ ] Use SVD and perform **Slit Calibration**.
- [ ] Use SVD and perform **Grating Squareness Diagnostic**.
- [ ] Use SVD and perform **Zero Order Offset/Mono Correction**.
- [ ] Use SVD and perform **Wavelength Repeatability**.
- [ ] Physically inspect selected HC lamps (customer to supply per their choice) and measure the % Gain for each lamp. Advise customer if lamps are showing emission degradation due to age.

Gas handling, water system, and workhead component checks

- [ ] Inspect the GTA workhead gas hoses and connections for leaks.
- [ ] Pressure test for gas leaks
- [ ] If the cooler system is accessible (stand-alone) check for correct operation and coolant/water level – this includes any temperature and pressure settings plus filter cleaning (air flow and water).
- [ ] Inspect the GTA workhead water hoses and connections for leaks.
- [ ] Check all graphite components and replace if necessary.
  - [ ] Tube
  - [ ] Electrodes
  - [ ] Shroud
- [ ] Check and clean the end windows on the workhead.
- [ ] Check safety interlock operation.

Analytical performance for Furnace systems

- [ ] Optimize the instrument ready to perform Cu sensitivity test.
- [ ] Run the sensitivity test for a 25 ppb copper sample and record the results in the results table.

PSD autosampler accessory for Furnace systems

- [x] Section NOT applicable.
- [ ] Check condition of the PSD capillary – replace if necessary
- [ ] Check condition and operation of PSD syringe – ensure it does not have air locks and bubbles.
- [ ] Change PSD rinse bottle o-ring.
- [ ] Check and clean the rinse vessel.
- [ ] Check the drain tube for good drainage. It should not have tight bends, kinks or loops and the lower end must be above the liquid level in the waste vessel.
- [ ] Ensure that the waste vessel is suitable for use with the furnace system.

Agilent
เอกสารไม่ควบคุม

Accessories

- [ ] Section NOT applicable.

Sample introduction pump system (SIPS) accessory

- [x] Section NOT Applicable.
- [ ] Re-torque screws securing the hubs, presser arms and pump rotors.
- [ ] Adjust each roller so that it rotates freely.
- [ ] Wipe clean the pump rotor rollers and pump bands with a dry clean cloth.
- [ ] Ensure that the presser arms and the surfaces near the pump are free from dirt and spills.
- [ ] Remove the pump module rear cover and check for the incursion of liquids and any signs of corrosion.
- [ ] Re-torque the nuts that fasten the motor mounting plates to the chassis.
- [ ] Check clips securing the diluents holder and replace if necessary.
- [ ] Disconnect, clean T-piece, and reassemble the tubing using the following steps.
- [ ] Remove the T-piece by disconnecting the pump tubes, the pump bands and all other tubing.
- [ ] Place the T-piece in an ultrasonic bath containing strong detergent 1-5% Decon 30 or similar, for approximately 5-10 minutes.
- [ ] Wash the T-piece under a tap with a strong flow of water.
- [ ] Rinse with distilled water through all of the inlets in the reverse direction to normal sample flow.
- [ ] Reassemble.

Sample preparation system (SPS 4) accessory

- [x] Section NOT Applicable.

The Agilent SPS 4 autosampler is designed to need minimal maintenance.

The following maintenance requirements are suggested to maintain the performance of the autosampler.

- [ ] Cleaning the spill tray, rack location mat, end frames and chassis accessories with a damp soft cloth and diluted mild detergent.
- [ ] Cleaning the autosampler cover panels with domestic window cleaner.
- [ ] Checking the X- axis and Z- axis drive belts for cracks, splits, damaged teeth, excessive fraying, color changes or degradation from fumes.
- [ ] Check the X- axis, Theta- axis and Z- axis FFC cables for cracks, incorrect positioning, damaged edge or damaged connectors.

NOTE The autosampler requires no extra lubrication throughout its lifetime.

For further details refer to the SPS 4 service manual G8410-90050.

Agilent
เอกสารไม่ควบคุม

Vapor generation accessory VGA (hydride generator)

- ☐ Section NOT Applicable.
- ☐ Inspect VGA gas supply hose.
- ☐ Inspect/replace VGA pump tubing.
- ☐ Check low gas pressure interlock setting– adjust if required.
- ☐ Check precision orifice gas flow setting – adjust if required.
- ☐ Check gas regulator pressure to 46 psi (325 kPa) – adjust if required.
- ☐ Clean the exterior surfaces of the accessory with soft lint free cloth. This cloth can be dampened with warm water or a mild detergent. Do not use organic solvents or abrasive cleaning agents.

UltrAA Lamp Accessory (external)

- ☑ Section NOT Applicable.
- ☐ Check the condition of the power cable.
- ☐ Clean the exterior surfaces of the accessory with soft lint free cloth. This cloth can be dampened with warm water or a mild detergent. Do not use organic solvents or abrasive cleaning agents.

Restore System

- ☐ If you have altered the customer's instrumentation during the course of PM, restore to the original status to allow the customer to conduct their normal activities (e.g., reload the customer's method.)

Guidance

If the PM service is performed prior to a qualification service, then use the qualification procedure as a guide for final instrument set up and checkout.

Signature Page

Service Review

- ☐ Attach available reports/printouts of all tests to this documentation.
- ☐ Record the Preventive Maintenance service activity in the customer's records/logbook.
- ☐ Update/reset instrument maintenance counters as appropriate.
- ☐ Affix the PM sticker to the system or instrument logbook based on the customer's request.
- ☐ Complete the Service Engineer Comments section if there are additional comments.
- ☐ Review this service, parts replaced, and test results obtained with the customer.
- ☐ If the instrument firmware was updated, record the details of the change in the Service Engineer's Comments box or if necessary, in the customer's IQ records.

Agilent
เอกสารไม่ควบคุม

Teflon impact beads (5/pk): (organics only)	9910053300	55 240 280	consumable	Flame
Burner cleaning strip (100/pk)	9910053900	55 240 280	consumable	Flame
Window UV silica – round (right side)	2010082600	55 240 280	PM supplied	Common
Window UV silica – rectangular (left side)	2010082500	55 240 280	PM supplied	Common
Pad adhesive window (round)	4910012700	55 240 280	PM supplied	Common
Pad adhesive window (rectangular)	4910012800	55 240 280	PM supplied	Common
Electrode kit (1 pr) (D2)	6310003400	GTA120	PM supplied	Furnace
Shroud (D2)	6310003100	GTA120	PM supplied	Furnace
Zeeman electrode kit (1 pr)	6310003500	GTA120	PM supplied	Furnace
Zeeman shroud	6310003600	GTA120	PM supplied	Furnace
O-ring PSD rinse bottle	6910025900	PSD120	PM supplied	Furnace

* For engineers who only service AA instruments 5190-8279 can be used as a cheaper alternative for 6610030100.

Items classified as PM supplied in the above table are included in the standard PM.

Those classified as consumable should be provided by the customer or charged to the customer if supplied by the Agilent service engineer.

Service Engineer Comments (optional)

If there are any specific points you wish to note as part of performing the installation or other items of interest for the customer, please write them in this box.

Agilent
เอกสารไม่ควบคุม

Test Results

Test description	Expected test result	Actual test result
Flame optics PMT Gain test		
For copper at 324.8 nm, 4 mA, 0.5 nm slit width	< 55 %	46 %
Flame performance test with 5 ppm copper sample		
Air /acetylene, mixing paddle removed	Abs value > 0.5	0.6331
Air /acetylene, mixing paddle installed. 10 replicates	%RSD < 1.0	0.7 %
Deuterium furnace optics PMT Gain test		
For copper at 324.8 nm, 4 mA, 0.5 nm slit width	< 55 %	-
Deuterium furnace performance test with 25 ppb copper sample (324.8 nm)		
Precision %RSD	≤ 4.0%	-
Abs value	≥ 0.15	-
Zeeman furnace analytical performance: 25 ppb copper sample (324.8 nm)		
Precision %RSD	≤ 4.0%	-
Abs value	≥ 0.15	-
MSR% (327.4 nm)	≥70 %	-

AA consumable and parts list

Part Description	Part Number	Product/Model # where used	PM supplied or Consumable	Instrument-Type
Test Solution – Cu 5ppm solution	6610030100	55 240 280	PM supplied	Common
Test Solution - Blank solution	5190-7001	55 240 280	PM supplied	Common
Copper, 1000 ug/ml, 100ml	5190-8279	55 240 280	*	Common
Kit, Mk 7 O-rings, aqueous, complete set	9910093400	55 240 280	PM supplied	Flame
Organic Kit	9910093500	55 240 280	PM supplied	Flame
Wire Nebulizer Cleaning	9910024700	55 240 280	consumable	Flame
Tubing-Capillary Std Nebs	9910024800	55 240 280	consumable	Flame
Capillary Tube Hivac Neb (3) (organics only)	9910044000	55 240 280	consumable	Flame
Glass impact beads (5/pk)	9910025700	55 240 280	consumable	Flame

Agilent
เอกสารไม่ควบคุม

Service Completion

Service Request Number: 6008088466
Service Engineer Name: Kanyakorn S.
Service Engineer Signature: Kanyakorn S.

Date of Service Completion: 26 Jan 2026
Customer Name: Chanida Thanoi
Customer Signature:

Agilent
เอกสารไม่ควบคุม

SVD Results Report

VARIAN

Report ID:3 *Diagnostic Start Time:1/26/2026 8:39:56 AM* *Diagnostic End Time:1/26/2026 9:05:49 AM*

Customer: UAE *Service Engineer:* Kanyakorn S.

Address: *Contact Details:* 0263763631

Instrument Configuration

Configuration:

Serial Number: MY13160001
Instrument Model: Varian AA140/240/280
Flame Instrument: True
Furnace Instrument: True
Zeeman Present: False
Internal Zeeman: False
Internal UltrAA: False
Optics Type: Double Beam
D2 BG Correction Fitted: True
Boot Block Version: 1.09

Turret Type: Automatic
Number Of Lamps: 4
Mono Type: Automatic
Gasbox Type: 'Y' Gas Box
Auto Burner Adjuster: False
Mains Frequency: 50
Firmware Version: 2.11
Photomultiplier Type: Normal(900nm)
PWB Version: 45

EEPROM Data:

Instrument Run Hours: 79270.602
Zero Wavelength Offset: 30.095
Mono Correction: 0.765
Flame Hours: 35125.582

D2 Run Hours: 58906.000
D2 Serial Number: not set !
D2 Install Date: 1/1/1970
D2 Original Intensity: 1.000
D2 Last Intensity: 475.000

Frequency:

Averaging Period: 30.0
Datapoint Count: 20

Upper Limit: 51.00
Average Frequency: 50.00
Lower Limit: 49.00
Highest Measured Frequency: 50.00
Lowest Measured Frequency: 50.00

Result: Passed


เอกสารไม่ควบคุม

Optics

Beam Balance:


Lamp Type: Copper
Lamp Socket Used: 3
Peak Selected: 324.80
Lamp Alignment: Performed

'X' Lamp Screw



X Lamp Screw Result: Passed

'Y' Lamp Screw



Y Lamp Screw Result: Passed

Grating Squareness:

Lamp Element(s): Copper
Lamp Turret Position: 3
Lamp Current(mA): 4.00
Slit Width(nm): 0.5
1st Order Wavelength(nm): 324.80
Lamp Alignment: Performed

	Lower Limit (nm)	Actual (nm)	Upper Limit (nm)	Result:
Zero Order	-0.10	0.00	0.10	Passed
First Order	324.45	324.74	325.15	Passed
Second Order	649.23	649.50	649.97	Passed

เอกสารไม่ควบคุม

Power Supply:

Averaging Period: 30.0
Datapoint Count: 20

	Lower Limit (V)	Actual (V)	Upper Limit (V)	Result:
12.00 V Rail	10.80	12.20	13.20	Passed
-12.00 V Rail	-13.20	-11.90	-10.80	Passed
5.00 V Rail	4.50	5.02	5.50	Passed
310.00 V Rail	279.00	320.00	341.00	Passed

เอกสารไม่ควบคุม

Wavelength Repeatability:

Lamp Used: Copper
Peak Used(nm): 324.750
Connected to Socket: 3
Lamp Current(mA): 4
Slit Width(nm): 0.2
Slit Height: Normal
Lamp Alignment: Performed

Lower Limit(nm) 324.768 324.888 **Upper Limit(nm)**

(Approach from Zero Order)	*(Approach from end)*
Sample 1: 324.828	Sample 2: 324.823
Sample 3: 324.823	Sample 4: 324.823
Sample 5: 324.823	Sample 6: 324.819
Sample 7: 324.823	Sample 8: 324.819
Sample 9: 324.819	Sample 10: 324.819

Mean: 324.823 **Standard Deviation:** 0.003

Result: Passed

เอกสารไม่ควบคุม

Mechanical

Wavelength Drive: Passed

Slit Drive: Passed

Turret Drive: Passed

Auto Burner Adjuster Drive: Untested

Miscellaneous

Signal Processing Linearity:

Calculate Mode: New Calc Mode

	Lower Limit	Actual	Upper Limit	Result:
S0	114	261	297	Passed
S1	156	165	191	Passed
S2	271	296	332	Passed
S3	474	508	579	Passed
S4	825	919	1008	Passed
S5	1435	1529	1754	Passed
S6	2498	2771	3053	Passed
S7	4347	4755	5313	Passed

Interlocks:

Burner Fitted:	Working	Flame Detect:	Working
N2O Burner Fitted:	Untested	GCU Active:	Working
Flame Shield Closed:	Working	Oxidant Pressure:	Working
Gas Control Fitted:	Untested	Oxidant Changeover:	Untested
Pressure Release Bung Fitted:	Working	Ignition:	Working
Liquid Trap Fitted:	Working		

เอกสารไม่ควบคุม

Analyst
Date Started 1/26/2026 9:07 AM GMT: 1/26/2026 2:07 AM
Worksheet Sensitivity Test
Comment
Methods Cu
Computer name DESKTOP-R9UIFRS
Serial Number: MY13160001

Method: Cu (Flame)

Sample ID	Exp Abs	%RSD	Mean Abs			
5 ppm Cu	0.633	1.4	0.6331			
	Readings					
	0.6413	0.6340	0.6241	1/26/2026		

เอกสารไม่ควบคุม

Auto Lamp Recognition:

Lamp 1: 87 - Silver/Cadmium/Lead/Zinc(UltrAA) (Ag/C	Lamp 5: Not Supported
Lamp 2: 68 - Zinc (Zn)	Lamp 6: Not Supported
Lamp 3: 14 - Copper (Cu)	Lamp 7: Not Supported
Lamp 4: Uncoded Lamp/Not Connected	Lamp 8: Not Supported

Result: Passed

GTA Temperature Monitoring:

Not Performed

Notes:

Signatures:

UAE	Date	Kanyakorn S.	Date
	26 Jan 26		26 Jan 2026

เอกสารไม่ควบคุม

Analyst
Date Started 1/26/2026 9:07 AM GMT: 1/26/2026 2:07 AM
Worksheet Precision Test
Comment
Methods Cu
Computer name DESKTOP-R9UIFRS
Serial Number: MY13160001

Method: Cu (Flame)

Sample ID	Exp Abs	%RSD	Mean Abs				
5 ppm Cu	0.618	0.7	0.6180				
	Readings						
	0.6145	0.6187	0.6081	0.6168	0.6253	0.6196	
	0.6197	0.6195	0.6188	0.6189	1/26/2026		

เอกสารไม่ควบคุม

ARCHEMICA

Certificate of Calibration

Inuvion : (Anion System ID#1248)

This certificate is to verify that instrument below are calibrated

by Archemica International Co.,Ltd.

Inuvion S/N : 250451070

AS-DV S/N : 25027024

for

UAE Consultant Co.,Ltd.

ARCHEMICA

Operator Signature : Date : Mar 19, 2026

(Mr.Itsaraphap Bumrungjeam)

Applications Chemist

เอกสารไม่ควบคุม

PM

Preventive Maintenance Check List

เอกสารไม่ควบคุม

Qualification Report

PM_Checklist : CM_OQ and PQ
Inuvion: Anion (ID#1248)

For
UAE Consultant Co.,Ltd.
(1st Warranty)

เอกสารไม่ควบคุม

Dionex Ion Chromatography
Preventive Maintenance Report

Customer Organization	Name/ Department
UAE Consultant Co.,Ltd.	K.Suwan
Engineer	**Date**
Mr.Itsaraphap Bumrungjeam	19/Mar/26

Instrument Detail

Instrument Model	Application
Inuvion (ID#1248)	Anion
Instrument components	**Serial Number**
Inuvion	250451070
AS-DV	25027024

Consumable Detail

Columns	Guard Columns	Suppressors	Concentrators	Etc.
AS22	AG22	ASRS300		

Remark:

Perform By Archemica

ARCHEMICA

Archemica

19/3/26

Date

Customer

19/3/26

Date

เอกสารไม่ควบคุม

General ICS Maintenance Checklist

No.	Description	Result			
	Power Cord Connection	Checked	Cleaned	Replaced	N/A
1	Instrument power on	☒	-	-	☐
2	Instrument connection	☒	-	-	☐
	Injection Valve (Optional)	Checked	Cleaned	Replaced	N/A
3	Rebuilt injection valve 6 port	☐	☒	☐	☐
4	- Rotor seal	☐	☒	☐	☐
5	- Stator face	☐	☒	☐	☐
	Optional Auxiliary Valve	Checked	Cleaned	Replaced	N/A
6	Rebuilt auxiliary valve port	☐	☐	☐	☒
7	- Rotor seal	☐	☐	☐	☒
8	- Stator face	☐	☐	☐	☒
	Check Valves Ending	Checked	Cleaned	Replaced	N/A
9	Inlet check valve assembly	☐	☒	☐	☐
10	Outlet check valve assembly	☐	☒	☐	☐
11	Verified correct flow orientation	☒	-	-	☐
	Pump Head Rinse Seal Piston Seal and Piston	Checked	Cleaned	Replaced	N/A
12	Piston rinse seal in *primary* pump head	☐	☒	☐	☐
13	Piston seal in *primary* pump head	☐	☒	☐	☐
14	Piston in *primary* pump head	☐	☒	☐	☐
15	Piston rinse seal in *secondary* pump head	☐	☒	☐	☐
16	Piston seal in *secondary* pump head	☐	☒	☐	☐
17	Piston in *secondary* pump head	☐	☒	☐	☐
	Waste Valve, Priming Valve	Checked	Cleaned	Replaced	N/A
18	Waste valve	☒	☐	☐	☐
19	Priming valve	☒	☐	☐	☐
	Conductivity Cell	Checked	Cleaned	Replaced	N/A
20	Check conductivity cell	☒	☐	☐	☐
21	Check electrochemical cell	☐	☐	☐	☒
22	- Working electrode	☐	☐	☐	☒
23	- Reference electrode	☐	☐	☐	☒
24	- Gasket	☐	☐	☐	☒
25	- Cell body	☐	☐	☐	☒
	Other	Checked	Cleaned	Replaced	N/A
26	Sample Loop Size 25 uL	☐	☒	☐	☐
27	End-line filter	☒	-	☐	☐
28	Leak sensor	☒	☐	☐	☐
29	Lubricate pump mechanic	☒	☐ Lubricated	-	☐
30	Reconnected liquid lines to the valve	☒	-	-	☐
31	Reconnected liquid lines to pump heads	☒	-	-	☐
32	Primed pump	☒	-	-	☐
33	Checked pump for leaks	☒	-	-	☐
34	Checked gas for leaks	☒	-	-	☐

เอกสารไม่ควบคุม

CM OQ

Chromeleon
Operation Qualification

เอกสารไม่ควบคุม

AS-DV Autosampler Preventive Maintenance Checklist

Model	Serial number	Firmware Version
☒ AS-DV	25027024	1.6.0

No.	Description	Result			
	Power Cord Connection	Checked	Cleaned	Replaced	N/A
1.	AS-DV power on	☒	-	-	☐
2.	AS-DV connection	☒	-	-	☐
	Sampling Tip	Checked	Cleaned	Replaced	N/A
3.	Sampling needle	☐	☒	☐	☐
4.	Sampling tubing (Transfer line)	☐	☒	☐	☐
5.	Reconnect sampling needle & tubing	☒	-	-	☐
	Drive Unit	Checked	Cleaned	Replaced	N/A
6.	Check carousel movement	☒	-	-	☐
7.	Check needle movement	☒	-	-	☐
8.	Lubricate needle drive	☒	☐ Lubricated	-	☐
9.	AS-DV cover	☒	☐	☐	☐
	Optional High Pressure Valve	Checked	Cleaned	Replaced	N/A
10.	High pressure valve Port	☐	☐	☐	☒
11.	- Rotor seal	☐	☐	☐	☒
12.	- Stator face	☐	☐	☐	☒
13.	- Reconnected liquid line to the valve	☐	☐	☐	☒

Others / comments

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Chromeleon Operational Qualification

General Information

	Computer Name	Version Number:
Instrument Controller:	DESKTOP-SQDHP9U	7.3.2 Build 14225
Client:	DESKTOP-SQDHP9U	7.3.2.14225
Operator:	Mr.Itsaraphap Bumrungjeam	

Overall Test Result: ***Passed***

Comparison Format:

All Parameters:	Significant Digits:	10

ARCHEMICA บริษัท อาร์เคมีก้า อินเตอร์เนชั่นแนล จำกัด ARCHEMICA INTERNATIONAL CO.,LTD.

19/3/26
Reviewer's Signature // Date

19/3/26
Operator's Signature // Date

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Chromeleon Operational Qualification, Part 1

Verification of Selected Results

Detection Algorithm: Cobra
Calibration Type: Lin, WithOffset
Evaluation Type: Area
Standard Method: External
Calibration Mode: Total

Report Variable	Peak Name	Status
Offset (c0)	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok
Slope (c1)	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok
Correlation Coeffi.	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok
Variance	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok
Std. Deviation	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok
Rel. Std. Dev.	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok
Variance Coeff.	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Chromeleon Operational Qualification, Part 1

Verification of Selected Results

Report Variable	Peak Name	Status
Theoretical Plates (EP)	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok
Theoretical Plates (USP)	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok
Theoretical Plates (JP)	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok

Test Result: ***Passed***

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Chromeleon Operational Qualification, Part 1

Verification of Selected Results

Report Variable	Peak Name	Status
Calibration Point X	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok
Calibration Point Y	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok
Amount [ng]	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok
Resolution (EP)	Acetanilide	ok
	Acetophenone	ok
Resolution (USP)	Acetanilide	ok
	Acetophenone	ok
Peak Asymmetry (EP/USP)	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok
Peak Asymmetry (AIA)	Acetanilide	ok
	Acetophenone	ok
	Propiophenone	ok

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Chromeleon Operational Qualification, Part 2

Most Frequently Used Parameters: Comparison with Expected Results

Detection Algorithm: Cobra
Calibration Type: Lin, WithOffset
Evaluation Type: Area
Standard Method: External
Calibration Mode: Total

Variable Category	Report Variable	Peak Name	Status
Injection	No.		ok
	Name		ok
	Type		ok
	Position		ok
	Status		ok
	Volume		ok
	Dilution Factor		ok
	Weight		ok
	IntStd		ok
	InstrumentMethod		ok
	ProcessingMethod		ok
Chromatogram	Channel		ok
	No. of Peaks		ok
	Chromatogram Start Time		ok
	Signal Min.		ok
	Signal Max.		ok
	Unit		ok
	Noise		ok
Peak Results	No.	Acetanilide	ok
	No.	Acetophenone	ok
	No.	Propiophenone	ok
	Peak Name	Acetanilide	ok
	Peak Name	Acetophenone	ok
	Peak Name	Propiophenone	ok
	Ret.Time	Acetanilide	ok
	Ret.Time	Acetophenone	ok
	Ret.Time	Propiophenone	ok

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Chromeleon Operational Qualification, Part 2

Most Frequently Used Parameters: Comparison with Expected Results

Variable Category	Report Variable	Peak Name	Status
Peak Results	Abs.Ret.Dev.	Acetanilide	ok
	Ret.Dev.(abs)	Acetophenone	ok
	Ret.Dev.(abs)	Propiophenone	ok
	Rel.Ret.Dev.	Acetanilide	ok
	Ret.Dev.(rel)	Acetophenone	ok
	Ret.Dev.(rel)	Propiophenone	ok
	Area	Acetanilide	ok
	Area	Acetophenone	ok
	Area	Propiophenone	ok
	Rel.Area	Acetanilide	ok
	Rel.Area (Total)	Acetophenone	ok
	Rel.Area (Total)	Propiophenone	ok
	Height	Acetanilide	ok
	Height	Acetophenone	ok
	Height	Propiophenone	ok
	Rel.Height (Total)	Acetanilide	ok
	Rel.Height (Total)	Acetophenone	ok
	Rel.Height (Total)	Propiophenone	ok
	Amount	Acetanilide	ok
	Amount	Acetophenone	ok
	Amount	Propiophenone	ok
	Concentration	Acetanilide	ok
	Concentration	Acetophenone	ok
	Concentration	Propiophenone	ok
	Rel.Amount	Acetanilide	ok
	Rel.Amount	Acetophenone	ok
	Rel.Amount	Propiophenone	ok
	Peak Width (0%)	Acetanilide	ok
	Peak Width (0%)	Acetophenone	ok
	Peak Width (0%)	Propiophenone	ok
	Peak Width (5%)	Acetanilide	ok
	Peak Width (5%)	Acetophenone	ok
	Peak Width (5%)	Propiophenone	ok
	Peak Width (10%)	Acetanilide	ok
	Peak Width (10%)	Acetophenone	ok
	Peak Width (10%)	Propiophenone	ok

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Chromeleon Operational Qualification, Part 2

Most Frequently Used Parameters: Comparison with Expected Results

Variable Category	Report Variable	Peak Name	Status
Peak Results	Peak Width (50%)	Acetanilide	ok
	Peak Width (50%)	Acetophenone	ok
	Peak Width (50%)	Propiophenone	ok
	Left Width (0%)	Acetanilide	ok
	Left Width (0%)	Acetophenone	ok
	Left Width (0%)	Propiophenone	ok
	Right Width (0%)	Acetanilide	ok
	Right Width (0%)	Acetophenone	ok
	Right Width (0%)	Propiophenone	ok
	Peak Start	Acetanilide	ok
	Peak Start	Acetophenone	ok
	Peak Start	Propiophenone	ok
	Peak Stop	Acetanilide	ok
	Peak Stop	Acetophenone	ok
	Peak Stop	Propiophenone	ok
	Peak Start Value	Acetanilide	ok
	Peak Start Value	Acetophenone	ok
	Peak Start Value	Propiophenone	ok
	Peak Stop Value	Acetanilide	ok
	Peak Stop Value	Acetophenone	ok
	Peak Stop Value	Propiophenone	ok
	BL-Value Peak Start	Acetanilide	ok
	BL-Value Peak Start	Acetophenone	ok
	BL-Value Peak Start	Propiophenone	ok
	BL-Value Peak Stop	Acetanilide	ok
	BL-Value Peak Stop	Acetophenone	ok
	BL-Value Peak Stop	Propiophenone	ok
	Type	Acetanilide	ok
	Type	Acetophenone	ok
	Type	Propiophenone	ok
	Resolution (EP)	Acetanilide	ok
	Resolution(EP)	Acetophenone	ok
	Resolution(USP)	Acetanilide	ok
	Resolution(USP)	Acetophenone	ok
	Asymmetry(EP)	Acetanilide	ok
	Asymmetry(EP)	Acetophenone	ok
	Asymmetry(EP)	Propiophenone	ok

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Chromeleon Operational Qualification, Part 2

Most Frequently Used Parameters: Comparison with Expected Results

Variable Category	Report Variable	Peak Name	Status
Peak Results	Asymmetry(AIA)	Acetanilide	ok
	Asymmetry(AIA)	Acetophenone	ok
	Asymmetry(AIA)	Propiophenone	ok
	Theor. Plates(EP)	Acetanilide	ok
	Theor. Plates(EP)	Acetophenone	ok
	Theor. Plates(EP)	Propiophenone	ok
	Theor. Plates(USP)	Acetanilide	ok
	Theor. Plates(USP)	Acetophenone	ok
	Theor. Plates(USP)	Propiophenone	ok
	Theor.Plates (JP)	Acetanilide	ok
	Theor. Plates(JP)	Acetophenone	ok
	Theor. Plates(JP)	Propiophenone	ok
Peak Calibration	Cal.Mode	Acetanilide	ok
	Cal.Mode	Acetophenone	ok
	Cal.Mode	Propiophenone	ok
	Cal.Type	Acetanilide	ok
	Cal.Type	Acetophenone	ok
	Cal.Type	Propiophenone	ok
	Weights	Acetanilide	ok
	Weights	Acetophenone	ok
	Weights	Propiophenone	ok
	Calibr. Coefficient C0	Acetanilide	ok
	Calibr. Coefficient C0	Acetophenone	ok
	Calibr. Coefficient C0	Propiophenone	ok
	Calibr. Coefficient C1	Acetanilide	ok
	Calibr. Coefficient C1	Acetophenone	ok
	Calibr. Coefficient C1	Propiophenone	ok
	RF-Value	Acetanilide	ok
	RF-Value	Acetophenone	ok
	RF-Value	Propiophenone	ok
	No. of Points	Acetanilide	ok
	No. of Points	Acetophenone	ok

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Chromeleon Operational Qualification, Part 2

Most Frequently Used Parameters: Comparison with Expected Results

Variable Category	Report Variable	Peak Name	Status
Peak Calibration	No. of Points	Propiophenone	ok
	No. of Points(disabled)	Acetanilide	ok
	No. of Points(disabled)	Acetophenone	ok
	No. of Points(disabled)	Propiophenone	ok
	Variance	Acetanilide	ok
	Variance	Acetophenone	ok
	Variance	Propiophenone	ok
	Var.Coeff	Acetanilide	ok
	Var.Coeff	Acetophenone	ok
	Var.Coeff	Propiophenone	ok
	Std.Dev.	Acetanilide	ok
	Std.Dev.	Acetophenone	ok
	Std.Dev.	Propiophenone	ok
	Rel.Std.Dev.	Acetanilide	ok
	Rel.Std.Dev.	Acetophenone	ok
	Rel.Std.Dev.	Propiophenone	ok
	Corr.Coeff.	Acetanilide	ok
	Corr.Coeff.	Acetophenone	ok
	Corr.Coeff.	Propiophenone	ok
	R-Square	Acetanilide	ok
	R-Square	Acetophenone	ok
	R-Square	Propiophenone	ok
	Adj. R-Square	Acetanilide	ok
	Adj. R-Square	Acetophenone	ok
	Adj. R-Square	Propiophenone	ok
	X	Acetanilide	ok
	X	Acetophenone	ok
	X	Propiophenone	ok
	Y	Acetanilide	ok
	Y	Acetophenone	ok
	Y	Propiophenone	ok
	W	Acetanilide	ok
	W	Acetophenone	ok
	W	Propiophenone	ok
	F(X)	Acetanilide	ok
	F(X)	Acetophenone	ok
	F(X)	Propiophenone	ok

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Chromeleon Operational Qualification, Part 2

Most Frequently Used Parameters: Comparison with Expected Results

Variable Category	Report Variable	Peak Name	Status
Peak Calibration	Residual for Cal.Point X	Acetanilide	ok
	Residual for Cal.Point X	Acetophenone	ok
	Residual for Cal.Point X	Propiophenone	ok
	Calibration Point Status	Acetanilide	ok
	Calibration Point Status	Acetophenone	ok
	Calibration Point Status	Propiophenone	ok
	Amount	Acetanilide	ok
	Amount	Acetophenone	ok
	Amount	Propiophenone	ok
Component	Cal.Type	Acetanilide	ok
	Peak Type	Acetanilide	ok
	Left Limit	Acetophenone	ok
	Right Limit	Acetanilide	ok
	Group	Acetanilide	ok
	Factor	Acetophenone	ok
	Amount	Acetanilide	ok
	Conc.Unit	Acetophenone	ok

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Chromeleon Operational Qualification, Part 3

System Suitability Test: Comparison with Expected Results

Variable Category	Report Variable	Status
System Suitability Test Case	Number	ok
	Name	ok
	Inj.Condition	ok
	Eval. Formula	ok
	Operator	ok
	Statistics	ok
	Rounding	ok
	MinimumNumberOfInjections	ok
	MaximumNumberOfInjections	ok
	Channel	ok
	Peak	ok
	Ref. Value Formula 1	ok
	Ref. Value Formula 2	ok
	N.A.	ok
System Suitability Test Case Result	Inj. Eval. Result	ok
	Eval. Result	ok
	Peak Result	ok
	Injection Condition Result	ok
	Ref. Value 1	ok
	Ref. Value 2	ok
	Result	ok
	Message	ok
	Average	ok
	Count	ok
	Maximum	ok
	Minimum	ok
	Range	ok
	Rel. Range	ok
	Rel. Std. Dev.	ok
	Std. Dev.	ok
	Sum	ok

Test Result: ***Passed***

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Chromeleon Operational Qualification, Part 2

Most Frequently Used Parameters: Comparison with Expected Results

Variable Category	Report Variable	Peak Name	Status
Peak Purity	PPI	Acetanilide	ok
	PPI	Acetophenone	ok
	PPI	Propiophenone	ok
	RSD PPI	Acetanilide	ok
	RSD PPI	Acetophenone	ok
	RSD PPI	Propiophenone	ok
	Match	Acetanilide	ok
	Match	Acetophenone	ok
	Match	Propiophenone	ok
	RSD Match	Acetanilide	ok
	RSD Match	Acetophenone	ok
	RSD Match	Propiophenone	ok
	Rel.Max at	Acetanilide	ok
	Rel.Max at	Acetophenone	ok
	Rel.Max at	Propiophenone	ok

Test Result: ***Passed***

เอกสารไม่ควบคุม

PQ

Performance Qualification

เอกสารไม่ควบคุม

Service Summary

These IQOQ Results should be reviewed by the Customer. If the IQOQ is accepted, both the Customer and the Service Representative should sign the IQOQ Results, below.

IQOQ Results

Based upon the actual results obtained, this IQOQ **PASSED** the acceptance criteria described in the Installation Qualification and Operational Qualification procedure.

Service Representative

A Field Service Representative signature below confirms the completion of all aspects of the Installation Qualification and Operational Qualification and have concluded that the system has been successfully verified to be operating as required.

Customer

A Customer signature below confirms the completion of all aspects of the Installation Qualification and Operational Qualification have been completed and that the system has been successfully verified to be operating as required.

ARCHEMICA
บริษัท อาร์คีมีกา อินเตอร์เนชั่นแนล จำกัด
ARCHEMICA INTERNATIONAL CO.,LTD.

Thermo Representative			
Signature:		Date:	19/3/26
Customer			
Signature:		Date:	19/3/26

เอกสารไม่ควบคุม

Service Details

System Repeatability OQ Autosampler AS-DV 1 Test 1	PASSED
Carryover OQ Autosampler AS-DV 1 Test 1	PASSED
Flow Rate Repeatability OQ Pump Inuvion Core 1 Test 1	PASSED
Noise Drift OQ Detector (Inuvion CD) Conductivity Detector 1 Test 1	PASSED
Detector Linearity OQ Detector (Inuvion CD) Conductivity Detector 1 Test 1	PASSED
Oven Temperature Accuracy OQ Column Compartment Inuvion Core 1 Test 1	PASSED
Service Review and Completion	PASSED

เอกสารไม่ควบคุม

Test Equipment and Standards

Test Equipment

Equipment	Manufacturer	Model	Serial Number	Cal Ver Date	Good Until
Multimeter	FLUKE	289	59270015	19 Dec 2025	19 Dec 2026
Thermocouple	FLUKE	K Type	59270015	22 Dec 2025	22 Dec 2026

Test Standards and Solvents

Description	Manufacturer	Conc. / Grade	Part Number	Lot Number	Expiration Date
Nitrate	Thermo Scientific	5 ppm	060254	250414	Apr 2026
Nitrate	Thermo Scientific	10 ppm	060254	250414	Apr 2026
Nitrate	Thermo Scientific	25 ppm	060254	250414	Apr 2026
Nitrate	Thermo Scientific	50 ppm	060254	250414	Apr 2026
Nitrate	Thermo Scientific	100 ppm	060254	250414	Apr 2026
Nitrate	Thermo Scientific	1000 ppm	060254	250414	Apr 2026

เอกสารไม่ควบคุม

Autosampler AS-DV 1

Autosampler Information

Autosampler Model	AS-DV
Serial Number	25027024
Firmware Version	
Instrument Assigned	Instrument 1
Tray Type	10.0 mL Vials
Syringe Volume	N/A
Loop Volume	25 µL
Connection	USB
Powered On Successfully?	Yes

เอกสารไม่ควบคุม

System Repeatability OQ Autosampler AS-DV 1 Test 1

ThermoFisher SCIENTIFIC

System Information

Model	AS-DV	Acquisition Date	19/3/26
Serial Number	25027024	Sequence	OQ_IC_IVN_ASDV_CD
System Name	Inuvion_Anion		
Test Configuration	Default		

Data Entry Mode

Data Entry Mode	Import

Peak Results

Sample Name	Injection Volume (uL)	Retention Time (min)	Area (µS*min)
Repeatability 01	25	0.5017	3.048
Repeatability 02	25	0.5017	3.066
Repeatability 03	25	0.5017	3.063
Repeatability 04	25	0.5	3.08
Repeatability 05	25	0.5	3.08
Repeatability 06	25	0.5017	3.084

Repeatability Results

Test	Measured	OQ Limit	Result
Retention Time Result	0.2 % RSD	≤ 5.0 % RSD	PASSED
Area Result	0.4 % RSD	≤ 1.0 % RSD	PASSED

เอกสารไม่ควบคุม

Pump Inuvion Core 1

ThermoFisher SCIENTIFIC

Pump Information

Pump Model	Inuvion Core
Serial Number	250451070
Firmware Version	
Pump Position	Single Unit
Seal Type	N/A
Pressure Units	psi
Connection	USB
Powered On Successfully?	Yes

เอกสารไม่ควบคุม

Carryover OQ Autosampler AS-DV 1 Test 1

ThermoFisher SCIENTIFIC

System Information

Model	AS-DV	Acquisition Date	19/3/26
Serial Number	25027024	Sequence	OQ_IC_IVN_ASDV_CD
System Name	Inuvion_Anion		
Test Configuration	Default		

Data Entry Mode

Data Entry Mode	Import

Peak Results

	Sample Name	Injection Volume (uL)	Retention Time (min)	Area (µS*min)
Blank	Reference Blank	25	0.5033	0.006
High	High Standard	25	0.5017	58.096
Carryover	Carryover	25	0.4983	0.009

Carryover Area Results

Test	Measured	OQ Limit	Result
Carryover Area Result	0.01 %	≤ 0.10 %	PASSED

เอกสารไม่ควบคุม

Flow Rate Repeatability OQ Pump Inuvion Core 1 Test 1

ThermoFisher SCIENTIFIC

System Information

Model	Inuvion Core	Acquisition Date	19/3/26
Serial Number	250451070	Sequence	OQ_IC_IVN_ASDV_CD
System Name	Inuvion_Anion	Pump Position	Single Unit
Test Configuration	Default		

Data Entry Mode

Data Entry Mode	Import

Peak Results

Sample Name	Injection Volume (uL)	Retention Time (min)
Repeatability 01	25	0.5017
Repeatability 02	25	0.5017
Repeatability 03	25	0.5017
Repeatability 04	25	0.5
Repeatability 05	25	0.5
Repeatability 06	25	0.5017

Repeatability Results

Test	Measured	OQ Limit	Result
Retention Time Result	0.2 % RSD	≤ 5.0 % RSD	PASSED

เอกสารไม่ควบคุม

Detector (Inuvion CD) Conductivity Detector 1

ThermoFisher SCIENTIFIC


Detector Information

Detector Model	Inuvion CD
Serial Number	250452051
Powered On Successfully?	Yes

เอกสารไม่ควบคุม

Noise Drift OQ Detector (Inuvion CD) Conductivity Detector 1 Test 1

ThermoFisher SCIENTIFIC



System Information

Model	Inuvion CD	Acquisition Date	19/3/26
Serial Number	250452051	Sequence	OQ_IC_IVN_ASDV_CD
System Name	Inuvion_Anion		
Test Configuration	Default		

Data Entry Mode

Data Entry Mode	Import


Noise Drift Results

Test	Measured	OQ Limit	Result	Conversion Factor
Noise Result	0.3 nS	≤ 2.0 nS	PASSED	1000
Drift Result	18.7 nS/hr	≤ 20.0 nS/hr	PASSED	1000

เอกสารไม่ควบคุม

Detector Linearity OQ Detector (Inuvion CD) Conductivity Detector 1 Test 1

ThermoFisher SCIENTIFIC



System Information

Model	Inuvion CD	Acquisition Date	19/3/26
Serial Number	250452051	Sequence	OQ_IC_IVN_ASDV_CD
System Name	Inuvion_Anion		
Test Configuration	Default		

Data Entry Mode

Data Entry Mode	Import

Peak Results

Sample Name	Concentration (ppm)	Peak Height (µS)	Calculated
IC Detector Linearity 01	5	4.522	4.782503
IC Detector Linearity 02	10	8.769	9.884257
IC Detector Linearity 03	25	21.525	25.207537
IC Detector Linearity 04	50	42.422	50.310279
IC Detector Linearity 05	100	83.633	99.815428

Linearity Results

Test	Measured	OQ Limit	Result
R^2	1.000	≥ 0.999	PASSED

เอกสารไม่ควบคุม

Column Compartment Inuvion Core 1

ThermoFisher SCIENTIFIC

Compartment Information

Compartment Model	Inuvion Core
Serial Number	250451070
Firmware Version	
Active Preheater?	N/A
Post Column Cooler?	N/A
Powered On Successfully?	Yes

เอกสารไม่ควบคุม

SYSTRONICS INSLAB COMPANY LIMITED

19/11-12, Sukhumvit Rd., Nernphins, Muang Rayong, Rayong 21150, Thailand

Tel.+66(38) 884 146-8, Email : calibration@systronics.co.th

CERTIFICATE OF CALIBRATION

Certificate No. TL258437

Page. 2 of 2

Result of Calibration :

(Without Adjustment)

Sensor of UUC* : Thermocouple Wire Type : K Serial No.: - ID/Tag No.: 59270015

Dimension : Length : 930 mm Diameter : 1.5 mm

Immersion Depth	Standard Reading	UUC* Reading	Correction Value	Uncertainty of Measurement (±)	Coverage Factor
mm	°C	°C	°C	°C	k =
150	-0.0039	0.6	-0.6	0.50	2.00
150	50.0058	50.3	-0.3	0.50	2.00
150	99.9944	100.3	-0.3	0.50	2.00

UUC* : Unit Under Calibration

END OF CERTIFICATE

ARCHEMICA บริษัท อาร์เคมีก้า อินเตอร์เนชั่นแนล จำกัด ARCHEMICA INTERNATIONAL CO.,LTD. 19/9/26

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Certificate of Completion

This certifies that

Itsaraphap Bumrungjeam

Has successfully completed

eLearn: RPG IC-Specific Qualification Service Training

Valid for 3 years from: Nov/25/2025

Issued electronically and approved by:

Thermo Fisher University LMS
Certification Management and Compliance Group
tmc.training@thermofisher.com

ARCHEMICA บริษัท อาร์เคมีก้า อินเตอร์เนชั่นแนล จำกัด ARCHEMICA INTERNATIONAL CO.,LTD. 19/9/26

Important note: This certificate is only valid during employment with the Thermo Fisher Scientific including its subsidiaries and certified contractors.

The world leader in serving science

เอกสารไม่ควบคุม

ThermoFisher SCIENTIFIC

Certificate of Analysis

Dionex Nitrate OQ/PQ IC Standards Kit
(Set of 6)

Product Number 060254
Certificate of Analysis

Lot Number 250414

Expiration of Certification
April 2026

The Dionex Nitrate Standard was developed to aid the analysis of anions by Ion Chromatography (IC). The single-ion standard was prepared by the dissolution of high-purity salt in ≥18.2 megohm deionized water, which was tested by IC for ionic contaminants. The bottle label states the nominal concentration value of the ionic component for informational purposes only. The actual ion concentration value was determined by Ion Chromatography. The IC system was standardized using the National Institute of Standards & Technology (NIST), Standard Reference Material, SRM 3185 (Nitrate Standard Solution). Actual concentration values determined for the single-ion is listed below.

Dionex Nitrate Standard

Vial #	Concentration (mg/L)	
1	5.10	± 0.03
2	10.15	± 0.04
3	25.49	± 0.05
4	50.03	± 0.06
5	99.7	± 0.3
6	993	± 18

ARCHEMICA บริษัท อาร์เคมีก้า อินเตอร์เนชั่นแนล จำกัด ARCHEMICA INTERNATIONAL CO.,LTD. 19/9/26

The concentration value is based a proven reliable method of analysis. The estimated uncertainties are two standard deviations of the concentration value. The concentration value is warranted to be stable for one year from the date of manufacture.

The preparation and analyses of the Dionex Nitrate Standard was performed with extreme care by Thermo Scientific Corporation Consumables Manufacturing Department in Sunnyvale California.

Document No. 078690-01 20-Dec-2011

Learn more at thermofisher.com/documents

thermoscientific

Research Use Only. Not for Clinical, Patient or Diagnostic Use. © 2024 Thermo Fisher Scientific Inc. All rights reserved. All trademarks are the property of Thermo Fisher Scientific and its subsidiaries unless otherwise specified. This information is presented as an example of the capabilities of Thermo Fisher Scientific products. It is not intended to encourage use of these products in any manner that might infringe the intellectual property rights of others. Specifications, terms and pricing are subject to change. Not all products are available in all countries. Please consult your local sales representative for details. COA 60-031318-B

เอกสารไม่ควบคุม

UAE United Analyst and Engineering Consultant Co., Ltd.

3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

ilac-MRA ISO/IEC 17025 CALIBRATION 0416

Certificate of Calibration

Certificate No.: 260417-1-BL010-26

Code No.: BL010-26

Page: 1 of 3

Customer Name:	United Analyst and Engineering Consultant Co., Ltd.				
Address:	3 Soi Udom suk 41, Sukhumvit Rd., Bang Chak, Phar Khanong, Bangkok 10260				
Equipment:	Electronic Balance				
Manufacturer:	Mettler Toledo				
Model:	MX204				
Serial No.:	C511670418				
Asset No. :	UAE.AIR.011/2568				
Building :	UAE NO.3	Floor : 2		Room : 206	
Received Date:	April 27, 2026				
Date of Calibation :	April 27, 2026				
Calibration Conditions:	Temperature	start	20.0 °C	end	17.7 °C
	Humidity	start	51.3 %	end	53.8 %
	Pressure	start	755.4 mmHg	end	754.2 mmHg
Calibrated by:	Thanachat Chatpahol				
Approved by:	Suwit Chotnok		Signature:		
Issued Date:	April 30, 2026				

Note : 1) The Uncertainties are for a confidence probability of approximately 95%

2) This Certificate is valid only to the item calibrated on date and place of calibration.

3) This Certificate is issued in accordance with the conditions of accreditation granted by the Thai Laboratory Accreditation Scheme which has assessed the measurement capability of the laboratory and its traceability to recognized national standards and to the units of measurement realized at the corresponding national standards laboratory. This certificate may not be reproduced other than in full except with the prior written approval of the United Analyst and Engineering Consultant Co.,Ltd. (UAE)

เอกสารไม่ควบคุม

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

Certificate No.: 260417-1-BL010-26
Code No.: BL010-26

Equipment: Electronic Balance | Manufacturer: Mettler Toledo
Model: MX204 | Readability: 0.0001 g
Serial No.: C511670418 | ID No.: UAE.AIR.011/2568
Max. Capacity: 220 g
Calibration Date: April 27, 2026
Condition As-Received: In Condition

Condition of Equipment:

Condition of This Result of Calibration:

1. Calibration Method: This instrument was calibrated by method UAE.CP.CAL.006 In-House Method based on UKAS Lab 14 : 2022
2. Reference Standrads:

Reference Standard:	Model	Serial No.	Calibrated By	Certificate No.	Traceability	Due Date
Standard Weight Class E2 (OIML)	1 mg to 1 kg	B749109122	TCS	M26031975	TCS	23-Mar-28

Instrument	Model	Serial No.	Calibrated By	Certificate No.	Traceability	Due Date
Thermo-Hygro-Baro Meter	MHB-382SD	AK.66457	SG	SG-H-00992/68	SG	26-Nov-26
Thermo-Hygro-Baro Meter	MHB-382SD	AK.66457	TPA	2SP4464	TPA	17-Dec-26

3. This certification is traceable to SI Unit
4. This certification was certified only for the indtrument we calibrated
5. This result of calibration wae found accurate as show on date and place of calibration only.
6. Through the reference standard laboratory of Thai Calibration Services Co.,Ltd. (TCS), NSC-TISI-TIS 17025, Calibration 0189


Calibraton Result:

1. Repeatability of Reading:

Nominal Value (g)	Standard Deviation of Reading (g)
200*	0.000045

2. Eccentric or off-center loading

A mass of 100 g was placed and moved to various position on pan
The Balance reading obtained is given in the table.



1 (g)	2 (g)	3 (g)	4 (g)	5 (g)	Maximum Difference (g)
100.0002	100.0002	100.0000	100.0002	100.0003	0.0002

เอกสารไม่ควบคุม

TECHNOLOGY PROMOTION ASSOCIATION (THAILAND-JAPAN)
CORPORATE SERVICES 3: EQUIPMENT CALIBRATION AND TESTING SERVICES
534/4 PATTANAKARN ROAD SOI 18, SUANLUANG, SUANLUANG BANGKOK 10250
TEL.0-2717-3000-29 FAX.0-2719-9484

Certificate of Calibration

Cert.No.: 25CH1053

Equipment :	Turbidity Meter
Manufacturer :	Oakton
Model :	T100IR
Serial No. :	1120501017
ID. No. :	UAE.WAT.056/2563
Condition As-Received:	Used Item
Received Date :	05 September 2025
Calibration Date :	08 September 2025
Reference :	2509-0212DSC-1
Submitted by :	United Analyst and Engineering Consultant Co.,Ltd. 3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Ambient Temperature :	(23 ± 3.0) °C
Relative Humidity :	(50 ± 20) %
Calibration Procedure :	In - house method : CP-CH11 Direct measurement by using Formazin standard solution
Calibrated by :	Walalak Sirithean
Approved by :	Saithip Approved Signatory

( ) Chakrit Waewwanjua
( ) Ponpan Palpim
(✓) Saithip Meangmai

Issue Date : 9 September 2025

The Uncertainties are for a confidence probability of approximately 95%

This certificate may not be reproduced other than in full, except with the prior written Approval of the head of Calibration and Testing Equipment Services.

เอกสารไม่ควบคุม

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

Certificate No.: 260417-1-BL010-26
Code No.: BL010-26

Equipment: Electronic Balance | Manufacturer: Mettler Toledo
Model: MX204 | Readability: 0.0001 g
Serial No.: C511670418 | ID No.: UAE.AIR.011/2568
Max. Capacity: 220 g
Calibration Date: April 27, 2026

Calibraton Result: (Continued)
Calibraton Range: 0 - 200 g
Calibraton Adjustment: Internal Calibration

3. Error of indication from nominal or conventional mass value:

Nominal Value (g)	Reference Value (g)	Indication (g)	Correction (g)	Uncertainty (± mg)	Coverage Factor k
Unload	0.000000	0.0000	0.0000	0.10	2.05
0.1	0.100002	0.1000	0.0000	0.10	2.05
1	1.000011	1.0000	0.0000	0.10	2.05
3	3.000023	3.0000	0.0000	0.11	2.04
5	5.000011	5.0000	0.0000	0.11	2.05
10	10.000007	10.0000	0.0000	0.11	2.04
20	20.000013	20.0001	-0.0001	0.11	2.04
40	40.000028	40.0001	-0.0001	0.14	2.00
50	50.000052	50.0001	0.0000	0.13	2.00
80	80.000072	80.0002	-0.0001	0.18	2.00
100	100.000071	100.0001	-0.0001	0.17	2.00
120	120.000086	120.0001	0.0000	0.21	2.00
140	140.000099	140.0003	-0.0002	0.25	2.00
160	160.000130	160.0001	0.0000	0.26	2.00
200	200.000140	200.0004	-0.0003	0.30	2.00

4. Effect of Tare test:

Tare Load (g)	Test Load (g)	Indication (g)	Correction (g)
100	20.000013	20.0002	-0.0002
	40.000028	40.0001	-0.0001
	60.000059	60.0001	0.0000
	80.000072	80.0001	0.0000
	100.000071	100.0002	-0.0001

Remark:
The report uncertainty of measurement was based on standard uncertainty multiplied by coverage factor k, providing a level of confidence of approximately 95%

o---o-End-o---o

เอกสารไม่ควบคุม

Cert.No.: 25CH1053

Condition of this calibration result

1. Reference Standard Instruments :

Instruments	ID No.	Certificate No.	Due date
1) Data Logger	130EC012	24H2043	23 Sep 2025
2) Liquid-in Glass Thermometer	130RC003	25I440	16 Apr 2026

- This measurement result is traceable to SI through Technology Promotion Association (Thailand - Japan)

2. Certified Reference Materials : Turbidity Standard solution (Formzin)
- The measurement results are traceable to SI through CPA chem Ltd.,

Turbidity Solution	Manufacturer	Lot No.	Exp. date
20.0 NTU	CPA Chem	1088008	18 Mar 2026
100.0 NTU	CPA Chem	1088007	18 Mar 2026
400 NTU	CPA Chem	1088018	18 Mar 2026
800 NTU	CPA Chem	1088017	18 Mar 2026

3. This certificate is valid only to the item calibrated on date and place of calibration.

Calibration result
Performing five - Formazin suspension standard curve by using 0. 20. 100. 400. 800 NTU
Tubidity Meter serial number : 1120501017

Standard Formazine suspension (NTU)	UUC* Reading (NTU)	Uncertainty of Measurement (± NTU)	Coverage Factor k
0	0.00	0.026	2.00
20.0	20.2	0.20	2.00
100.0	100	1.2	2.00
400	403	2.4	2.00
800	799	4.3	2.00

Remark - UUC* = Unit Under Calibration
- NTU = Nephelometric Turbidity Units

The reported uncertainty of measurement was based on a standard uncertainty multiplied by a coverage factor *k*, providing a level of confidence of approximately 95 %.

-o0o-

เอกสารไม่ควบคุม

Agilent CrossLab
From Insight to Outcome

Agilent CrossLab Start Up Services

Agilent 5100 5110 ICP-OES Preventive Maintenance

Agilent Preventive Maintenance provides factory recommended service for your analytical instruments to assure reliable operation and the accuracy of your results

Delivered by highly trained and certified service engineers using genuine Agilent parts and supplies, Agilent Preventive Maintenance provides what you need to reduce unplanned downtime and keep your systems operating at their peak performance.

This checklist is used as a guide for completing the preventive maintenance tasks. A signed copy of this checklist is provided for your records.

© Agilent Technologies, Inc. 2022

Agilent

เอกสารไม่ควบคุม

Agilent CrossLab
From Insight to Outcome

Important Customer Web Links

- To access **Agilent University**, visit http://www.agilent.com/crosslab/university/ to learn about training options, which include online, classroom and onsite delivery. A training specialist can work directly with you to help determine your best options.
- To access the **Agilent Resource Center** web page, visit https://www.agilent.com/en-us/agilentresources. The following information topics are available:
  - Sample Prep and Containment
  - Chemical Standards
  - Analysis
  - Service and Support
  - Application Workflows
- The **Agilent Community** is an excellent place to get answers, collaborate with others about applications and Agilent products, and find in-depth documents and videos relevant to Agilent technologies. Visit https://community.agilent.com/welcome
- Videos about specific preparation requirements for your instrument can be found by searching the **Agilent YouTube** channel at https://www.youtube.com/user/agilent
- **Need to place a service call?** Flexible Repair Options | Agilent

© Agilent Technologies, Inc. 2022

Agilent

เอกสารไม่ควบคุม

Agilent CrossLab
From Insight to Outcome

Introduction

Customer Information

- Customers should provide all necessary operating supplies upon request of the engineer.
- A customer representative should be available to the engineer while performing the preventive maintenance procedures. Customers are responsible for regular maintenance and are encouraged to observe the service representative.
- Any parts not included in the Parts Lists section of this document are not part of the recommended Preventive Maintenance service nor are they included in the price of this service.
- If a system requires the use of extra or special procedures and/or parts for the maintenance service, then these must be ordered separately and charged as a repair, which may incur additional costs.
- For customers using HF applications, the instrument should be returned to its standard sample introduction system.

© Agilent Technologies, Inc. 2022

Agilent

เอกสารไม่ควบคุม

Agilent CrossLab
From Insight to Outcome

Service Engineer's Responsibilities

- Contact the customer and ensure that all necessary supplies are available before the preventive maintenance visit.
- Only select those pages that relate to the system or module being serviced.
- Complete empty fields with the relevant information.
- Complete the relevant checkboxes in the checklist using either a "**X**" or tick mark "✓".
- Check **"Service not applicable"** check boxes to indicate services/tasks not delivered, as appropriate.
- Complete the Preventive Maintenance services in the most logical order relevant to the individual system service in the order of the tasks listed.
- Complete the **Service Review** section together with the customer.
- Complete the fields for page numbers at the foot of each selected page
- Add relevant page numbers to selected pages and complete the total number of pages field in the Service Completion section
- **Ask the customer to sign the Service Verification section including the customer's and your signature.**

© Agilent Technologies, Inc. 2022

Agilent

เอกสารไม่ควบคุม

Instrument Maintenance

System Information

☐ Check this box if an instrument configuration report is attached instead of completing the table.

Instrument System Name and ID	5110 VDV ICP-OES
Instrument System Site and Location	UAE Consultant

List System Component Product Numbers	List the Serial Numbers of each Component
1. G 8019 A	MY 18030001
2.	
3.	
4.	
5.	
6.	
7.	
8.	
9.	

ICP-OES Configuration Table	Circle the type or write in the type if other
Nebulizer Type	SeaSpray | OneNeb | Conikal | Other
Spray Chamber	Cyclonic Single Pass | Cyclonic Double Pass | Other
Torch	Radial | Dual View | Other
Torch Type	One Piece | Semi Demountable | Fully Demountable | Other
Injector Diameter	2.4mm | 1.8mm | 1.4mm | 0.8mm | Other
Injector Material	Quartz | Ceramic | Other

เอกสารไม่ควบคุม

Preventive Maintenance Procedures

Record Pre-PM instrument performance

☑ Run Instrument Performance test.
☑ Record results in Instrument Performance Test Results Table – Pre-PM.

Clean and inspect ICP-OES system

☑ Look for any obvious external damage or problems.
☑ Inspect water cooling hoses, gas lines and power cord for excessive wear or damage.
☑ Perform a general internal inspection of the system for excessive dust accumulation, clean if necessary.
☑ Inspect sample introduction components and record any required maintenance in the Service Engineer Comments and notify the customer as the required actions required.
☑ Record the instrument operating conditions in the ICP-OES Status Results Table.
☑ Replace the polychromator purge filter.
☑ Replace the radial pre-optics window
☑ Replace the axial pre-optics window for SVDV and VDV instruments.
☑ Check exhaust flow for the correct positive extraction at the exhaust duct to insure they meet minimum specifications.
☑ Replace air inlet dust filter.
☐ Replace high capacity air inlet dust filter element if installed. N/A
☑ Remove and clean instrument water inlet filter.

Agilent Water Recirculator

☐ **Service not applicable**
☑ Drain cooling fluid and remove any particles from the chiller reservoir
☑ Remove, clean and reinstall water inlet metal mesh filter if present.
☑ Re fill with Agilent Cool Clear cooling fluid.
☑ Clean the cooling system Air filter and the condenser.

เอกสารไม่ควบคุม

Preparation

☑ Discuss any specific issues with the customer before starting.
☑ Review the instrument logbook for recorded problems and comments.
☑ Save instrument control settings before starting the procedure.
☑ Perform a general inspection of the system for cleanliness.
☑ Check for proper installation of parts, assemblies, sensors etc.
☑ Check system for required installation of components and implementation of Service Notes
☑ Check for required firmware/software updates and verify with customers if they would like them installed.
☐ For HF application systems, if standard sample introduction system was not installed, ask the customer to install it. N/A
☑ Ask the customer to remove any samples from the ICP-OES sample introduction area, auto sampler or around the ICP-OES.

เอกสารไม่ควบคุม

SPS 3 Auto Sampler

☑ **Service not applicable**
☐ Power cycle the autosampler and verify successful initialization.
☐ Inspect X and Z axis belts for wear. Replace is necessary.
☐ Clean X and Z axis slide shafts.
☐ Using customer's racks and the Agilent software move the sample probe to the 4 outermost corners and rinse port, ensure that the probe is approximately centered in the vial.

SPS 4 Auto sampler

☑ **Service not applicable**
☐ Clean the spill tray, rack location mat, end frames and chassis with a damp soft cloth and diluted mild detergent.
☐ Clean the auto sampler cover panels, if cover kit is installed, with domestic window cleaner.
☐ Check the X-axis and Z-axis drive belts for cracks, splits, damaged teeth, excessive fraying, color changes or degradation from fumes.
☐ Check the X-axis, Theta-axis and Z-axis FFC cables for cracks, incorrect positioning, damaged edges or damaged connectors.
☐ Pump Tubing Replacement. Replace peristaltic pump tubing. Replace all tubing that goes from the rinse station to the pump and from the pump to the waste/rinse bottles
☐ Test using customer's tray and move the sample probe to the sample vial 1, wash vial and rinse port and ensure that the probe is centered in the vial. If not use calibration wizard and calibrate the position.

AVS 4, 6, 7 Advanced Valve System

☑ **Service not applicable**
☐ Replace valve rotor seal
☐ Check fittings for signs of leaks
☐ Check tubing including autosampler tubing for kinks or excessive wear
☐ Check high flow pump for signs of leaks

เอกสารไม่ควบคุม

ICP-OES adjustment

- ☑ Check position of Zn peak, adjust if required.
- ☑ Check Argon Ratio, adjust to specified value if required.
- ☑ Perform Detector Calibration.
- ☑ Perform Instrument Calibration.

Record Post-PM instrument performance

- ☑ Run Instrument Performance test.
- ☑ Record results in Instrument Performance Test Results Table - Post PM.
- ☑ For systems using ICP Expert version 7.3 and above, run the following Instrument tests
  - ☑ Subsystem Communications Test
  - ☑ Air Flow
  - ☑ Water Flow
  - ☑ Gas Flows
  - ☑ RF Generator
  - ☑ Camera Test
  - ☑ Optics Test
  - ☑ Nebulizer Test
- ☑ Record the result in the Instrument Test Results Table

เอกสารไม่ควบคุม

Test Results

Instrument Performance Test Results Table

Note: These measurements do not form part of any specification and are for reference only.

	Pre PM Sensitivity Check		Post PM Sensitivity Check	
	Radial	Axial *	Radial	Axial*
Zn 213.857 nm SRBR	17883.8	25792	22108	35629
Mn 257.610 nm SRBR	94670.5	196149	108830	178844
Al 396.152 nm SBR	5.2	8.0	7.0	7.4
K 766.491 nm SBR	3.0	14.6	3.4	5.7

* Axial result is not applicable for G8016AA, G8012AA Radial View instruments.

Instrument Test Results Table

Note: The Instrument Test results are for systems using ICP Expert version 7.3 and above only.

Instrument Test	Result
Subsystem Communications Test	Pass
Air Flow	Pass
Water Flow	Pass
Gas Flows	Pass
RF Generator	Pass
Camera Test	Pass
Optics Test	Pass
Nebulizer test	Pass

เอกสารไม่ควบคุม

Restore Instrument

- ☐ For HF applications, ask the customer to reinstall their sample introduction system. N/A
- ☑ Leave system in an idle state: on and purging.
- ☑ Guidance: If the PM service is performed prior to a qualification service, then use the qualification procedure as a guide for final instrument set up and checkout.

Service Review

- ☑ Attach available reports/printouts of all tests to this documentation.
- ☑ Record the Preventive Maintenance service activity in the customer's records/logbook.
- ☑ Record the PM event in the Smart Alerts logbook, if applicable.
- ☑ Update/reset instrument maintenance counters as appropriate.
- ☑ Affix the PM sticker to the system or instrument logbook based on the customer's request.
- ☑ Complete the Service Engineer Comments section if there are additional comments.
- ☑ Review this service, parts replaced, and test results obtained with the customer.
- ☑ If the instrument firmware was updated, record the details of the change in the Service Engineer's Comments box. Systems in a compliant environment may need additional documentation.
- ☑ **Complete the Signature Page with both Service Engineer and Customer signatures.**

เอกสารไม่ควบคุม

ICP-OES Status Results Table

Note: These measurements do not form part of any specification and are for reference only.

Measurement	Standby Mode		Plasma On	
Mains Voltage	231.238	VAC	226.380	VAC
Mains Current	0.083	A	0.100	A
Instrument Temperature	21.1	°C	21.6	°C
RF Air Flow (sensor speed)	44.0	Hz	41.1	Hz
Plasma Exhaust Temperature	No measurement		47.1	°C
Water Flow Oscillator	No measurement		1.14	L/min
Water Flow Detector	0.92	L/min	0.90	L/min
Water Inlet Temperature	19.5	°C	19.5	°C
Polychromator Temperature	35.4	°C	35.4	°C
CCD Temperature	-40.1	°C	-39.9	°C
Thermal Stabilizer	35.0	°C	35.0	°C
Argon Supply Pressure	634.43	kPa	583.77	kPa
Purge Gas Supply Pressure*1	631.28	kPa	604.02	kPa
Option Gas Supply Pressure*1	–	kPa	–	kPa
Nebulizer Flow	No measurement		0.90	L/min
Nebulizer Back Pressure	No measurement		273.61	kPa
Plasma Gas Flow	No measurement		1196	L/min
Auxiliary Gas Flow	No measurement		1.00	L/min
RF Power	No measurement		1200.4	W
RF Supply Current	No measurement		8.228	A
RF Supply Voltage	No measurement		194.529	V

*1 If option installed

เอกสารไม่ควบคุม

Consumed PM Parts

Part Description	Part Number	Product or Model# where used	Quantity consumed
Axial Pre-Optic Window	G8010-68014	G8010A, G8011A, G8014A/G8015A	1
Radial Pre-Optic Window	G8010-68015	All	1
Agilent Cool Clear Coolant Fluid	5799-0037	Agilent Water Recirculator	–
Purge Gas Filter	G8010-60136	All	1
Air inlet filter	G8000-68002	All	1
High Capacity Air Filter	G8010-60189	Optional	–
Rotor seal for 6-7 port valve for AVS6/7	G8494-60002	G8494A/G8495	–
Rotor seal for 4 port valve for AVS4	G8493-60002	G8493A	–
Rinse solution to rinse station 2.5mm id x 1m	G8410-80123	SPS 4	–
Barb connector 2.5mm-1.5mm ID	G8410-80124	SPS 4	–
PVC waste tubing,8mm od x 5mm id, 2m	G8410-80122	SPS 4	–
Additional Parts may be required from engineer's stock:			
X axis drive belt	5410047500	SPS 3	–
Z axis drive belt	5410047400	SPS 3	–
Peristaltic pump tubing, PVC SolvaFlex, 3 bridged,	3710049000	SPS 4	–

Consumed Parts Reference
(Purchased by customer, not included as part of PM)

☐ Section Not Applicable

Part Description	Part Number	Product or Model# where used	Quantity consumed

Agilent

เอกสารไม่ควบคุม

Signature Page

Service Engineer Comments (optional)

If there are any specific points you wish to note as part of performing the installation or other items of interest for the customer, please write in this box.

Service Verification

Service Request Number: 6008 006610
Service Engineer Name: Worawit T.
Service Engineer Signature: Worawit T.
Total number of pages in this document: 14

Date Service Completed: 3 Nov 2025
Customer Name: Aphasn O.
Customer Signature: Aphasn O.

Agilent

เอกสารไม่ควบคุม

TECHNOLOGY PROMOTION ASSOCIATION (THAILAND-JAPAN)
CORPORATE SERVICES 3 : EQUIPMENT CALIBRATION AND TESTING SERVICES
534/4 PATTANAKARN ROAD SOI 18, SUANLUANG, SUANLUANG BANGKOK 10250
TEL. 0-2717-3000 FAX. 0-2719-9484

Certificate of Testing

Equipment :	DO Meter
Manufacturer :	Horiba
Model :	LAQUA-DO210
Serial No. :	HE9M0013
ID No. :	UAE.EFM.016/2563 (EFM.DO.05/63)
Received Date :	18 November 2025
Test Date :	20 November 2025
Reference :	2511-0529WSC-1
Submitted by :	United Analyst and Engineering Consultant Co.,Ltd. 3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Laboratory Condition :	Temperature (25 ± 5) °C Humidity (50 ± 20) %
Test Procedure :	In - house method : CP-CH9 by Comparison Technique with Azide Modification Method
Tested by :	Walalak Sirithean
Approved by :	Saithip Approved Signatory

( ) Chakrit Waewwanjua
( ) Ponpan Paipim
(✓) Saithip Meangmai

Issue Date : 21 November 2025

Condition of this result of calibration

1. Reference Standard Instruments :
This measurement result is traceable to the International System of Unit through the reference standards laboratory of Industrial Calibration Center, Technology Promotion Association (Thailand-Japan).

Instruments	ID No.	Certificate No.	Due Date
1. Burette	130BU10	25CG1126	18 Mar 2027
2. Balance	110RC001	25MM316	02 July 2026

2. Standard Material :-

Material	Manufacturer	Lot.No.	Assay
Sodium Thiosulfate 5-Hydrate AR	KEMAUS	2203162447	99.6%

Result : **Dissolved Oxygen Meter Adjustment With Air 100 %**
Dissolved Oxygen Probe No.: 9K9M0021

Titration Method (Azide Modification Method) (mg/L)	DO Meter Reading (mg/L)	Standard Deviation (mg/L)
8.22	8.20	0.0055

This report was certified only for the instrument we tested.It is allowable to use for study Intend to use for advertising and referral purpose is prohibited.This report may not be reproduced other in full, without written approval of the laboratory

-o0o-

TECHNOLOGY PROMOTION ASSOCIATION (THAILAND-JAPAN)
CORPORATE SERVICES 3: EQUIPMENT CALIBRATION AND TESTING SERVICES
534/4 PATTANAKARN ROAD SOI 18, SUANLUANG, SUANLUANG BANGKOK 10250
TEL.0-2717-3000-29 FAX.0-2719-9484

Certificate of Calibration

Cert. No.: 25LM172

Equipment :	DO Meter with Sensor
Manufacturer :	Horiba
Model :	LAQUA-DO210
Serial No. :	HE9M0013
ID No. :	UAE.EFM.016/2563(EFM.DO.05/63)
Submitted by :	United Analyst and Engineering Consultant Co.,Ltd. 3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Location :	TPA On Site Calibration Laboratory
Received Order :	18 November 2025
Calibrated Date :	21 November 2025
Ambient Temperature :	(26 ± 10) °C
Relative Humidity :	(50 ± 30) %
AC Line Voltage :	(220 ± 22) V
Calibrated by :	Warakorn Lerngagtrakul
Approved by :	Kunchit Approved Signatory

( ) Chakrit Waewwanjua
( ) Suwit Imjai
(✓) Kunchit Promprat

Issue Date : 24 November 2025

The Uncertainties are for a confidence probability of approximately 95%

This certificate may not be reproduced other than in full, except with the prior written Approval of the head of Corporate Services 3 : Equipment Calibration and Testing Services.

PerkinElmer
For the Better

PinAAcle 900F
Preventive Maintenance Report

Company Name: UAE Consultant Co., LTD.

Instrument Location: 41 Sukumvhit Rd.,

Phra Khanong, Bangkok 10260

Instrument Serial No.: PFBS20031902

Date: 27 Oct 2025

เอกสารไม่ควบคุม

Equipment : DO Meter with Sensor **Cert. No.:** 25LM172
Condition As-Received : Used Item
Reference : 2511-0529WSC-2

Procedure Used :-

Calibration were conducted using in-house calibration procedure CP-OT01 according to comparison with Industrial Platinum Resistance Thermometer (IPRT) into Temperature Bath.

The temperature scale used was based on ITS-90.

Condition of this result of calibration

1. Reference standard instrument:-

Instrument	Serial No.	Cert. No.	Traceable	Due Date
1) Digital Thermometer	A7B843	25I17	TPA	06 Jan 2026

2. This certificate is valid only to the item calibrated on date and place of calibration.
3. This measurement result is traceable to the International System of Unit maintained through :

Remark : TPA : Technology Promotion Association (Thailand - Japan)

Result of Calibration :- (*) Without Adjustment

Function : Temperature measurement.

This instrument was connected with temperature sensor, S/N.: 9K9M0021

Calibration Point (°C)	Immersion Depth (mm)	Standard Temperature (°C)	UUC* Reading (°C)	Error (°C)	Uncertainty (± °C)	Coverage Factor *k*
15.0	80	14.998	15.0	0.002	0.16	2.00
30.0	80	30.003	29.9	-0.103	0.16	2.00
45.0	80	45.000	44.8	-0.200	0.16	2.00

UUC* : Unit Under Calibration

The reported uncertainty of measurement was based on a standard uncertainty multiplied by a coverage factor ***k***, providing a level of confidence of approximately 95 %.

-o0o-

PinAAcle 900F Preventive Maintenance (PM)

Company Name:	United Analyst and Engineering Consultant Co., LTD.		
Address (Instrument Location):	41 Sukumvhit Rd., Phra Khanong, Bangkok 10260		
Serial Number:	PFBS20031902	**PM Number:**	1 of 2
Customer Name (if applicable):	K. Yainda	**Telephone Number:**	095-5580049
Customer Support Engineer Name:	K. Chayanan	**Service Order Number:**	WO-06332081
Date PM Performed: (DD-MMM-YYYY)	27 Oct 2025	**Next PM Due Date:** (DD-MMM-YYYY)	27 Apr 2026
Standard Labor Hours to Complete PM :		**5 hours**	

Part Number	Release	Publication Date	PerkinElmer
09370145 Rev.9	A	January 2018	

Scope
The purpose of this PM is to ensure the continued functionality of the PinAAcle 900F by inspecting and replacing any worn or damaged parts. This service should only be performed by a trained representative of PerkinElmer.
The customer should save their method before the PM begins.

General Instructions:
The customer must provide the engineer operational data to demonstrate recent instrument performance prior to starting the PM.
Always check with the customer before making any changes that may affect the customer's analysis or calibration, including a current back-up of system software and/or data files.
The completed document should be signed by an authorized PerkinElmer and customer representative and left with the customer.
Update the PM sticker and instrument logbook as required.

Copyright Information
This document contains proprietary information that is protected by copyright. All rights are reserved.
No part of this publication may be reproduced in any form whatsoever or translated into any language without the prior, written permission of PerkinElmer, Inc.
Copyright © 2013 PerkinElmer, Inc.

Trademarks
Registered names, trademarks, etc. used in this document, even when not specifically marked as such, are protected by law. PerkinElmer is a registered trademark of PerkinElmer, Inc. All other trademarks and registered trademarks not owned by PerkinElmer, Inc. or its subsidiaries that are depicted herein are the property of their respective owners.
Except as specifically set forth in its terms and conditions of sale, PerkinElmer makes no Warranty of any kind with regard to this document, including, but not limited to, the implied warranties of merchantability and fitness for a particular purpose.
PerkinElmer shall not be liable for incidental or consequential damages in connection with the furnishing or use of this document.

เอกสารไม่ควบคุม

Component List

Component / Specific Model	Serial #	Configuration Notes
PinAACle900F	PFBS20031902	Syngistix V.4.0.1.1935
FIAS100	100524040501	

Parts Lists

Parts Included with the PM		
Part Number (if applicable)	**Description**	**Quantity**
B0501696	Fan Filters	1
N3160156	O-Ring Kits for Sampling Introduction (Stainless Steels Nebulizer)	N/A
N3160157	O-Ring Kits for Sampling Introduction (Plastic Nebulizer)	1
N9301714	Replacement Acetylene Filter Cartridge	1
TH001022	Replacement Air Filter Cartridge	1

Additional Reagents and Standards Required for PM				
Part Number (if applicable)	**Description**	**Quality**	**Batch/Lot #**	**Expired Date (MM/YY)**
N9300183	1000 mg/L Copper Standard	AR	28-83CUY1	Nov 2026

Additional Reagents and Standards Required for PM (Customer Support Solution)				
Part Number (if applicable)	**Description**	**Quantity**	**Batch/Lot #**	**Expiration Date (MM/YY)**
N/A	DI Water	250 mL	AR	AR
N/A	0.5% HNO_3	250 mL	AR	AR

เอกสารไม่ควบคุม

Additional Tools Required for PM			
Part Number (if applicable)	**Description**	**Quantity**	**Serial #**
N1013000	0.2A Neutral density filter	1	101N0089015
N1013002	1.0A Neutral density filter	1	101N0089015
03030997	System 2 EDL Driver	1	03030997
N3050605	As System 2 EDL	1	16148
N3050121	Cu Lumina HCL	1	060419-030180
N3050109	Ba Lumina HCL	1	061219-020041
N3050139	K Lumina HCL	1	030819-010130
N3050152	Ni Lumina HCL	1	052719-020020

เอกสารไม่ควบคุม

Procedure Checklist

Use (✓) to check off those steps in the checklist that have been completed.

1. **General:**
   - ☑ Review the instrument performance with the customer and document any recent problems.
   - ☑ Inspect the customer log book and make any appropriate PM entries.
   - ☑ Perform general inspection of system for cleanliness.
2. **PC Instrument Software:**
   - ☑ Instrument Software user files/databases archived, packed, and/or deleted as needed.
3. **Mechanical:**
   - ☑ Inspect and clean all fans and filters. Replace filters if necessary
   - ☑ Inspect all gas lines for leaks and/or wear. Replace if needed.
   - ☑ Clean exterior of the instrument.
   - ☑ Inspect the burner head, burner chamber, and nebulizer. Clean if needed as stated in the Hardware Guide.
   - ☑ Check burner head dimensions with the feeler gauge as stated in the Hardware Guide in the Maintenance chapter section on cleaning the burner head and checking sloth width. Replace if out of specification
   - ☑ Check the condition of the end cap, burner head, and nebulizer O-rings. Replace if necessary.
   - ☑ Check the drain system for signs of wear. Replace worn or damaged parts.
   - ☑ Visually check for proper flame conditions when igniting the Air-C2H2 and N20-C2H2 flames (if applicable).
4. **Electrical:**
   - ☑ Inspect PC boards. Clean if necessary.
   - ☑ Carefully check all internal and external cable connections.
   - ☑ Check instrument firmware revisions upgrade to current levels (if necessary)
   - ☑ Run Diagnostics Test within the Advanced function of the Spectrometer page. Check the results in the service log folder in the Spectrometer BM Log Viewer.
5. **Optics:**
   - ☑ Inspect and clean the sample compartment windows, if needed.
   - ☑ Inspect optics. Clean or replace if necessary,
6. **Gasses:**
   - ☑ Verify that the Gasses supplied to the instrument are within the pressure and purity specifications found in the PinAAcle 900 Series Pre-installation Checklist SDB.
   - ☑ Verify that the acetylene filter and air filter element is dry. Replace if necessary.

เอกสารไม่ควบคุม

7. **Flame Interlock Check:**

   Description: Check to ensure that all safety interlocks are closed.

Parameter	Specification	Test Results	Pass/Fail
Flame Sensor	Air/C_2H_2 Flame correctly shuts down	Active	Passed
Drain Sensor	Air/C_2H_2 Flame correctly shuts down	Active	Passed
Nebulizer Sensor	Air/C_2H_2 Flame correctly shuts down	Active	Passed
C_2H_2 Pressure Sensor	Air/C_2H_2 Flame correctly shuts down	Active	Passed
Air Pressure Sensor	Air/C_2H_2 Flame correctly shuts down	Active	Passed
Burner Head Sensor	Choosing Nitrous Oxide as the oxidant should trigger an interlock shuts down	Active	Passed

8. **After PM Performance tests:**

   8.1 Detector Linearity with Barium

   Description: Ensures that the detector is linear in the Visible Range.

Parameter	Specification	Certificate Value at 553.6 nm (Abs.)	Test Results	Pass/Fail
1.0 A ND Filter	± 5% from Cert.	0.9995	0.9887	Passed
0.2 A ND Filter	± 5% from Cert.	0.1936	0.1896	Passed

   8.2 Baseline Noise at 1.0 Absorbance with Barium

   Description: Ensures that a high absorbance will not produce excessive noise.

Parameter	Specification	Results	Pass/Fail
Standard Deviation	≤ 0.010	0.001	Passed

   8.3 AA Baseline Noise with Copper

   Description: Check baseline noise.

Parameter	Specification	Results	Pass/Fail
Standard Deviation	≤ 0.001	0.0001	Passed

เอกสารไม่ควบคุม

8.4 D_2 Background Compensation with Copper

Description: Verifies the instruments ability to compensate for Background absorption.

Parameter	Specification	Results	Pass/Fail
Standard Deviation	≤ 0.010	0.0001	Passed

8.5 AA-BG Baseline Noise with Copper

Description: Ensures that background correction does not produce excessive noise.

Parameter	Specification	Results	Pass/Fail
Standard Deviation	≤ 0.005	0.0001	Passed

8.6 AA-BG Baseline Noise with Arsenic

Description: Ensures that background correction does not produce excessive noise at a low wavelength.

Parameter	Specification	Results	Pass/Fail
Standard Deviation	≤ 0.005	0.0004	Passed

8.7 Flame Sensitivity

Description: Instrument Sensitivity checked against Copper standard.

Standard Copper Sensitivity	Specification	Results (Abs.)	Pass/Fail
5 mg/L Sensitivity SS Neb (if applicable)	> 0.250 Abs.	N/A	Not Applicable
2 mg/L Sensitivity HS Neb (if applicable)	> 0.250 Abs.	N/A	Not Applicable

10. **Review:**
    - ☑ Review with the customer PM work performed.
    - ☑ Review with the customer routine maintenance procedures.
    - ☑ Discuss recommended customer supplied materials to have on hand.
    - ☑ Attach PM sticker.

เอกสารไม่ควบคุม

Additional Comments

Additional Comments Regarding the PM

Review

The preventive maintenance checks and if applicable performance tests for PinAAcle 900F have been completed. *This PinAAcle 900F Passes ☑ Fails ☐ the preventive maintenance.*	
Review of Preventive Maintenance:	
Authorized PerkinElmer Representative: Chayanan K.	Date: 27 Oct 2025 (DD-MMM-YYYY)
Authorized Customer Representative:	Date: 27 Oct 2025 (DD-MMM-YYYY)

เอกสารไม่ควบคุม

Atomic Absorption/FIAS 100/400 Preventive Maintenance (PM)

Company Name:	United Analyst and Engineering Consultant Co., LTD.		
Address (Instrument Location):	41 Sukumvhit Rd., Phra Khanong, Bangkok 10260		
Room Number:	Lab		
Asset Number (If applicable):	1 of 2	**Customer System ID:**	K. Yanida
Service Engineer Name:	K. Chayanan	**Service Order Number:**	WO-06332087
Date PM Performed: (DD-MMM-YYYY)	27-Oct-2025	**Next PM Due Date:** (DD-MMM-YYYY)	27-Apr-2026

Part Number	Release	Publication Date	PerkinElmer®
09370005	C	January 2013	

Scope
The purpose of this PM is to ensure the continued functionality of the Atomic Absorption/FIAS 100/400 by inspecting and replacing any worn or damaged parts. This service should only be performed by a trained representative of PerkinElmer.
The customer should save their method before the PM begins.

General Instructions:
Always check with the customer before making any changes that may affect the customer's analysis or calibration.
The completed document should be signed by an authorized PerkinElmer and customer representative and left with the customer.
Update the PM sticker and instrument logbook as required.

Copyright Information
This document contains proprietary information that is protected by copyright. All rights are reserved.
No part of this publication may be reproduced in any form whatsoever or translated into any language without the prior, written permission of PerkinElmer, Inc. **Copyright © 2013 PerkinElmer, Inc.**

Trademarks
Registered names, trademarks, etc. used in this document, even when not specifically marked as such, are protected by law. PerkinElmer is a registered trademark of PerkinElmer, Inc. All other trademarks and registered trademarks not owned by PerkinElmer, Inc. or its subsidiaries that are depicted herein are the property of their respective owners.
Except as specifically set forth in its terms and conditions of sale, PerkinElmer makes no warranty of any kind with regard to this document, including, but not limited to, the implied warranties of merchantability and fitness for a particular purpose.
PerkinElmer shall not be liable for incidental or consequential damages in connection with the furnishing or use of this document.

เอกสารไม่ควบคุม

Component List

Component / Specific Model	Serial #	Firmware Version	Configuration Notes
FIAS100	100S24040501	2.20	Syngistix V4.0.1.1935

Parts Lists

Parts Included with the PM				
Part Number (If applicable)	**Description**	**Quantity**	**Batch/Lot #**	**Expiration Date** (MM/YY)
B050 2706	Fan Filter	1	N/A	N/A

Additional Tools Required for PM				
Part Number (If applicable)	**Description**	**Quantity**	**Serial #**	**Calibration Due Date** (MM/YY)
N/A	Digital Volt Meter	1	N/A	N/A
Additional Reagents and Standards Required for PM				
Part Number (If applicable)	**Description**	**Quantity**	**Batch/Lot #**	**Expiration Date** (MM/YY)
N/A	N/A	N/A	N/A	N/A

เอกสารไม่ควบคุม

Procedure Checklist

Use (✓) to check off those steps in the checklist that have been completed.

1. **General:**
   - ☑ Review the instrument performance with the customer and document any recent problems.

     _____

   - ☑ Is the Working Environment Acceptable? If not, document.

     _____

   - ☐ Visual Damage (if yes, describe)

     _____

   - ☑ Check incoming AC line voltage for proper levels and grounding.
   - ☑ Verify Voltage switch on back of instrument is correct
   - ☑ Perform general inspection of system for cleanliness. Clean if needed.
   - ☑ Gas supply cylinders secured, lines leak checked and argon or nitrogen supply pressure verified (45 – 58 psi).
   - ☑ Inspect the customer log book and make any appropriate PM entries.
   - ☑ Fan checked and filter cleaned
   - ☑ Heating mantle or Universal Cell Holder checked

2. **Instrument components**
   - ☑ Non-return valve checked/repaired/replaced if needed (B019 8111). Clean the valve if there is any liquid in it. Replace the rubber sleeve (B013 5123) if it is worn. Check the flow meter for any signs of fluid in it. Clean the flow meter if needed.
   - ☑ Verify condition of pump pressure adjustment levers (B050 7794 - look for cracks or problems with the springs), pump rollers (B300 0251 check for wear), and thumb screws (B050 7796).
   - ☑ Check the Multiport valve for proper switching, flow, and insure there are no leaks. Clean valve parts and replace o-rings if needed (large o-ring: B050 1250, small o-ring: B004 5095). Use a squirt bottle & fishing line to try to dislodge clogs.
   - ☑ Firmware Version checked. Latest is 2.20.

3. **Mixing/Separation Assembly & Pump Tubing:**
   - ☑ Mixing separator assembly checked
   - ☑ Filter/membrane checked (B050 8306)
   - ☑ Condition of the pump tubing (replace if necessary), correct pump tubing for the solutions being run. Make sure the correct magazines are being used. B050 7791 for 0.13 – 1.80 mm tubing; B050 7792 for 1.60 – 3.18 mm tubing.

เอกสารไม่ควบคุม

4. **Cell, Cell Windows, Transfer Line:**
   - ☑ Cell checked
   - ☑ Cell windows checked
   - ☑ Transfer line checked for moisture (if moisture is a problem, the Nafion dryer might be needed)

5. **Operational Tests:**
   - ☑ Run DI water through the carrier/reductant/sample system. Verify smooth flow of liquid throughout without leaks. Replace tubing & fittings if needed.

6. **Review:**
   - ☑ Review with the customer PM work performed.
   - ☑ Review with the customer routine maintenance procedures.
   - ☑ Discuss recommended customer-supplied materials to have on hand.
   - ☑ Attach PM sticker.
   - ☑ Update Logbook.

เอกสารไม่ควบคุม

Additional Comments

Additional Comments Regarding the PM

Review

The preventive maintenance checks and if applicable performance tests for FIAS 100/400 have been completed.

This FIAS 100/400 Passes ☑ ***Fails*** ☐ ***the preventive maintenance.***

Review of Preventive Maintenance:

Authorized PerkinElmer Representative: Chayanan K.	Date: 27 Oct 2025 (DD-MMM-YYYY)
Authorized Customer Representative: [illegible]	Date: 27 Oct 2025 (DD-MMM-YYYY)

เอกสารไม่ควบคุม

Document History

Revision	Description of Change	Page(s)	Date
A	First release		May 2008
B	Addition of Batch/Lot Number, Expiration Date, and Report Fields.	2,7	February 2009
C	Update to new format	All	January 2013

เอกสารไม่ควบคุม

PerkinElmer

PerkinElmer TruQ

PerkinElmer Number: N9300183
Element and Matrix: 1000 µg/mL Copper in 2% HNO3
Starting Material: Copper Metal
Starting Material Lot No: 10221A
Density: 1.011 g/mL @ 20°C

Lot No: 2B-83CUY1
Certification Date: MAY - - 2025
Expiration Date: NOV 30 2026

Trace Metallic Impurities in the Actual Solution via ICP / ICP-MS Analysis:

Element	µg/mL	Element	µg/mL	Element	µg/mL	Element	µg/mL	Element	µg/mL
Ag	0.005	Dy	<0.001	Li	<0.001	Pr	<0.001	Tb	<0.001
Al	<0.002	Er	<0.001	Lu	<0.001	Rb	<0.001	Te	<0.001
As	<0.001	Eu	<0.001	Mg	<0.001	Re	<0.001	Th	<0.001
Au	<0.001	Fe	0.02	Mn	<0.001	Rh	0.002	Ti	<0.001
B	<0.001	Ga	<0.001	Mo	<0.001	Ru	<0.001	Tl	<0.001
Ba	<0.001	Gd	<0.001	Na	0.004	Sb	<0.001	Tm	<0.001
Be	<0.001	Ge	<0.001	Nb	<0.001	Sc	<0.001	U	<0.001
Bi	<0.001	Hf	<0.001	Nd	<0.001	Se	<0.002	V	<0.001
Ca	<0.01	Hg	<0.001	Ni	<0.001	Si	<0.1	W	<0.001
Cd	<0.001	Ho	<0.001	P	<0.2	Sm	<0.001	Y	<0.001
Ce	<0.001	In	<0.001	Pb	0.005	Sn	0.003	Yb	<0.001
Co	<0.001	Ir	<0.001	Pd	<0.001	Sr	<0.001	Zn	0.02
Cr	<0.001	K	<0.1	Pr	<0.001	Ta	<0.001	Zr	<0.001
Cs	<0.001	La	<0.001						

Traceability Documentation for Solution Standard:

Certified Value: 998 µg/mL ±5 µg/mL (refer to side 2)
Certified Value is Traceable to: NIST SRM #3114
*** Classical Wet Assay:** 997 µg/mL
Method: EDTA titration using PAN as indicator. EDTA standardized against $Pb(NO_3)_2$ NIST SRM #928.

***Instrument Analysis using ICP Spectrometer:** 1001 µg/mL
via NIST SRM #3114

We guarantee that our PerkinElmer TruQ Atomic Spectroscopy Standards are stable and accurate to ±0.5% of certified concentration until the expiration date, provided the standards are kept tightly capped and stored under normal laboratory conditions. This value is the sum of cumulative errors associated with the analytical determinations, pipetting, and diluting to final volume. For these solutions we use high purity acids, ASTM Type 1 water (18 megohm double deionized), and leached, triple-rinsed bottles. All glassware used is class A.

Certifying Officer: Y. Parikh
Yogesh Parikh, Senior Spectroscopist

www.perkinelmer.com

เอกสารไม่ควบคุม

Terms & Conditions

Customer Acknowledgment of receipt of the above repair / replacement.

Special Terms and Conditions: This is not an invoice.

Taxes will be applied in your invoice if applicable.

เอกสารไม่ควบคุม

PerkinElmer
For the Better

PerkinElmer Scientific (Thailand) Co., Ltd.
260 Soi Soonvijai 4
Khwang Bangkapi, Khet Huay Kwang
Bangkok 10310
Thailand
Tel: 66 2719 6420 ; Fax: +66 2 319 7900
http://www.perkinelmer.com

Service Report

Work Order Number	Activity Code	Billing Type	Requested Start Date	Model	Serial Number
WO-06332881	Planned Maintenance	Contract	28/04/2568 10:27 น.	AAN3200851	PTB520031602
Service Representative Name	**Contract Number**		**Expiry Date**	**Equipment ID**	**System ID**
Kanan, Chayanan	SC-0035964108		31/10/2025	N/A	N/A
UDI Number					
N/A					
Equipment Location			**Bill To Name**		
บริษัท คูโบต้า แอดวานซ์ เอนด์ เอนจิเนียริ่ง (ประเทศไทย) กรุงเทพมหานคร 51 10260 TH			บริษัท คูโบต้า แอดวานซ์ เอนด์ เอนจิเนียริ่ง (ประเทศไทย) กรุงเทพมหานคร 51 10260 TH		
Customer Contact	**Phone Number**	**Fax Number**	**Email**		**Purchase Order**
ฐานันดา ลอยเลิศ(ไอแอน)	095-5580949	N/A	yanindachanlek@gmail.com		HPO-259180002

Work Description

- PM 1/2 (AAnalyst)
- Cleaning Cell, Chamber, Filter
- Wavelength Calibrate ; Pass
- Wavelength Scan As,Cu,Ba,K,Ni ; Pass
- Align cell with Hg. ; OK

Start Date	End Date	Work Description
27/10/2025	27/10/2025	
27/10/2025	27/10/2025	

Tools Used

Quantity	Calibrated Tool	Description	Serial Number	Last Calibration Date	Next Calibration Date
*** No Calibrated Tools Used ***					

Material Used

Part Number	Part Description	Note	Lot/Serial Number	Quantity
N9301714	Bellston C2H2 Filter Cartridge			1

Labour Details

Part Number	Part Description	Start Date	Quantity
SV000913	Preventative maintenance	27/10/2025	4
SV000902	Service Travel	27/10/2025	2

Work Complete	Customer Signature	Technician Signature
Yes ☑ No ☐	ฐานันดา	Chayanan k.
PM/OQ/IPV Left with Customer	2/11/2568 ฐานันดา ลอยเลิศ(ไอแอน)	2/11/2568 Kanan, Chayanan
Yes ☐ No ☑		

เอกสารไม่ควบคุม

PerkinElmer
For the Better

PerkinElmer Scientific (Thailand) Co., Ltd.
260 Soi Soonvijai 4
Khwang Bangkapi, Khet Huay Kwang
Bangkok 10310
Thailand
Tel: 66 2719 6420 ; Fax: +66 2 319 7900
http://www.perkinelmer.com

Service Report

100S24040501

Work Order Number	Activity Code	Billing Type	Requested Start Date	Model	Serial Number
WO-06332887	Planned Maintenance	Contract	28/04/2568 10:29 น.	FIA5100	400528040204
Service Representative Name	**Contract Number**		**Expiry Date**	**Equipment ID**	**System ID**
Kanan, Chayanan	SC-0035964108		31/10/2025	N/A	N/A
UDI Number					
N/A					
Equipment Location			**Bill To Name**		
บริษัท คูโบต้า แอดวานซ์ เอนด์ เอนจิเนียริ่ง (ประเทศไทย) กรุงเทพมหานคร 51 10260 TH			บริษัท คูโบต้า แอดวานซ์ เอนด์ เอนจิเนียริ่ง (ประเทศไทย) กรุงเทพมหานคร 51 10260 TH		
Customer Contact	**Phone Number**	**Fax Number**	**Email**		**Purchase Order**
ฐานันดา ลอยเลิศ(ไอแอน)	095-5580949	N/A	yanindachanlek@gmail.com		HPO-259180002

Work Description

- PM 1of 2 (S/N_100S24040501)
- Cleaning Port Vials, Manifold, Tuning
- Run Hg test ; Pass

Start Date	End Date	Work Description
27/10/2025	27/10/2025	
27/10/2025	27/10/2025	

Tools Used

Quantity	Calibrated Tool	Description	Serial Number	Last Calibration Date	Next Calibration Date
*** No Calibrated Tools Used ***					

Material Used

Part Number	Part Description	Note	Lot/Serial Number	Quantity
B0194049	Sample Loop, 500UL			1
B0521252	O-Ring 16.77 x 1.78			1
B0503748	O-RING 16 X 1.75 VITON			2

Labour Details

Part Number	Part Description	Start Date	Quantity
SV000913	Preventative maintenance	27/10/2025	3
SV000902	Service Travel	27/10/2025	2

Work Complete	Customer Signature	Technician Signature
Yes ☑ No ☐	ฐานันดา	Chayanan k.
PM/OQ/IPV Left with Customer	2/11/2568 ฐานันดา ลอยเลิศ(ไอแอน)	2/11/2568 Kanan, Chayanan
Yes ☐ No ☑		

เอกสารไม่ควบคุม

Terms & Conditions
Customer Acknowledgment of receipt of the above repair / replacement.
Special Terms and Conditions: This is not an invoice.
Taxes will be applied to your invoice if applicable.

เอกสารไม่ควบคุม

Contents

Customer information 3
Service Engineer's Responsibilities 3
Other important Customer Web links 3
System information 4
Preparation, Safe operation and Initial performance checks 4
Preventative maintenance procedures 5
- Flame systems 5
- Furnace systems 6
- Accessories 8
- Restore System 9
- Guidance 9

Signature Page 9
- Service Review 9
- Test Results 10
- AA consumable and parts list 10
- Service Engineer Comments (optional) 11

Service Completion 12

Revision: 12.0, Issued: November 2025
Document Number: D0140117
© Agilent Technologies, Inc. 2025

เอกสารไม่ควบคุม

Agilent

Agilent AA Series Spectrometers

Preventative Maintenance Checklist

[redacted]

Foreword

Agilent Preventive Maintenance provides factory recommended service for your analytical systems to assure reliable operation and the accuracy of your results.

Delivered by highly trained and certified service engineers using genuine Agilent parts and supplies, Agilent Preventive Maintenance provides everything you need to reduce unplanned downtime and keep your systems operating at their peak. This checklist will be completed at the end of the service and provided to you as a record of the installation.

NOTE While non-current production AA instrument and or accessory models are not covered specifically in this document it can be used as a basic reference.

For more information about Agilent Technologies services please visit our web site using the following URL http://www.agilent.com/en-us/services

เอกสารไม่ควบคุม

Customer information

- Customers should provide all necessary operating supplies upon request of the engineer.
- A customer representative should be available to the engineer while performing the preventive maintenance procedures.
- Any parts, not included in the Parts Lists section of this document, are not part of the recommended Preventive Maintenance service, nor are they included in the price of this service.
- If a system requires the use of extra or special procedures and/or parts for the maintenance service, then these must be ordered separately and charged as a repair, which may incur additional costs.

Service Engineer's Responsibilities

- Contact the customer and ensure that all necessary supplies are available before the preventive maintenance visit.
- Confirm the ability of the instrument to deliver continued safe operation as established via the Agilent AA safe operation flow chart. **(Refer directly to the AA 55/240/280 Preventive Maintenance Scope of Work to make this decision.)**
- Only select those pages that relate to the system or module being serviced.
- Complete empty fields with the relevant information.
- Complete the relevant checkboxes in the checklist using either a "X" or tick mark "√".
- Check "Section not applicable" check boxes to indicate services/tasks not delivered, as appropriate.
- Complete the Preventive Maintenance service in the order of the tasks listed.
- Complete the Service Review section together with the customer.
- Complete the fields for page numbers at the foot of each selected page
- Complete the total number of pages field in the Service Completion section
- Ask the customer to sign the Service Completion section including the customer's and your signature.

This information is subject to change without notice.

Other important Customer Web links

- How to get information on your product: Literature Library — http://www.agilent.com/chem/library
- Need to know more? www.agilent.com/chem/education
- Need technical support, FAQs? www.agilent.com/chem/techsupp
- Need supplies? www.agilent.com/chem/supplies

Revision: 12.0, Issued: November 2025
Document Number: D0140117
© Agilent Technologies, Inc. 2025

เอกสารไม่ควบคุม

System information

☐ Check this box if an instrument configuration report is attached instead of completing this table.

Instrument system name and ID	240FS AAS
Instrument system site and location	United Analyst and Engineering Consultant
List system component product numbers	**List the serial numbers of each component**
1 G8432A	1 MY13160001
2	2
3	3
4	4
5	5
6	6
7	7
8	8
9	9
10	10

Preparation, Safe operation and Initial performance checks

☐ Agilent AA safe operation flow chart inspections (to determine if the PM can be performed).

NOTE If by following the flow chart the instrument is deemed to be unsafe for continued use you MUST NOT continue PM work. Inform the customer immediately of the Agilent recommendation that use of the instrument be discontinued.

☑ Discuss any specific questions or issues with the customer prior to starting.
☐ For HF application systems, if standard sample introduction system was not installed, ask the customer to install it. N/A
☑ Review the instrument logbook for recorded problems and comments.
☑ Save instrument control settings before starting the procedure.
☑ Perform a general inspection of the system for cleanliness.
☑ Check for proper installation of parts, assemblies, sensors etc.
☑ Check system for required installation of components, settings as defined by current Service Notes

Agilent
เอกสารไม่ควบคุม

Sample introduction and Atomization

☑ Inspect the burner interlock plate to ensure that the interlock pin is secure and correct for the burner type.
☑ Clean the burner slot with a clean white card.
☑ Check the uniformity of the slot width.
☑ Clean the burner if required.
☑ Change the burner o-ring and lubricate with PFPE grease.
☑ Clean the nebulizer, spray chamber and liquid trap.
☑ Change all o-rings and seals in the nebulizer, nebulizer block and spray chamber and lubricate.
☑ Check that the pressure relief bung releases readily.
☑ Change o-rings on the fuel and oxidant delivery barbs and lubricate.
☑ Leave the liquid trap EMPTY and verify the flame will not ignite in this state.
☑ Refill liquid trap and check that overfill drains freely into the drain/waste tube.
☑ Check the drain/waste tube for good drainage. It should not have tight bends, kinks or loops and the lower end must be above the liquid level in the waste vessel.
☑ Check and clean the igniter electrode.

Gas handling components and safety interlocks

☑ Pressure test for leaks
☑ Leak test gasbox internal components using gasbox leak tester G8434-67013
☑ Check safety interlock status and operation using the SVD interlock monitoring diagnostic.

Analytical performance for Flame systems

☑ Ignite a flame.
☑ Check that you can adjust the nebulizer uptake rate from 4 to 6.5 mL per minute.
☑ Optimize the instrument ready to perform Cu sensitivity test.
☑ Create a manual method to perform a Basic Cu ABS test - "Final Performance Testing "
☑ Run a PM completed sensitivity test for a 5 ppm copper sample and record the results in the AA PM Performance test results and measurements table.

Furnace systems

☑ Section NOT applicable.

Electronic components

☐ Review and confirm instrument configuration data in SVD
☐ Confirm power supply voltages using the SVD Power Supply diagnostic.

Mechanical components

☐ Run SVD tests to exercise all motor drives over the full range of their travel:
  ☐ Monochromator drive
  ☐ Slit drive

Agilent
เอกสารไม่ควบคุม

☑ Check for required firmware updates and verify with customers if they would like them installed.
☑ Use SVD to perform a Full Wavelength Scan for Cu HCL - "As found test_1"
☑ Perform a Basic Cu ABS test - "As found test_2"
☑ Print the Details page or screen captures of the test results and attach to the end of this checklist.

Preventative maintenance procedures

Flame systems

☐ Section NOT applicable.

Electronic components

☑ Review and confirm instrument configuration data in SVD
☑ Confirm power supply voltages using the SVD Power Supply diagnostic.
☑ For Dual Beam instruments - Confirm RBC frequency using the SVD RBC frequency diagnostic.

Mechanical components

☑ Check the burner adjuster controls for complete and free movement. If the burner adjuster needs lubrication, use Molykote 321 or mineral-based molybdenum disulphide grease.
☑ Run SVD tests to exercise all motor drives over the full range of their travel:
  ☑ Monochromator drive
  ☑ Slit drive
  ☑ Lamp selector
  ☐ Automatic Burner Adjuster

Optics components

☑ Check that external optical surfaces are clean – Clean or replace as required.
☑ Use SVD and perform Mono Wavelength Correction.
☑ Use SVD and perform Slit Calibration.
☑ Use SVD and perform Grating Squareness Diagnostic.
☑ Use SVD and perform Zero Order Offset/Mono Correction.
☑ Use SVD and perform Wavelength Repeatability.
☑ Physically inspect selected HC lamps (customer to supply per their choice) and measure the % Gain for each lamp. Advise customer if lamps are showing emission degradation due to age.
☑ Check that the signal energy of the D2 and HC lamps track properly. Advise customer if their D2 lamp is showing emission degradation due to age.

Agilent
เอกสารไม่ควบคุม

  ☐ Lamp selector

Optics components

☐ Check that external optical surfaces are clean – Clean or replace as required.
☐ Use SVD and perform Mono Wavelength Correction.
☐ Use SVD and perform Slit Calibration.
☐ Use SVD and perform Grating Squareness Diagnostic.
☐ Use SVD and perform Zero Order Offset/Mono Correction.
☐ Use SVD and perform Wavelength Repeatability.
☐ Physically inspect selected HC lamps (customer to supply per their choice) and measure the % Gain for each lamp. Advise customer if lamps are showing emission degradation due to age.

Gas handling, water system, and workhead component checks

☐ Inspect the GTA workhead gas hoses and connections for leaks.
☐ Pressure test for gas leaks
☐ If the cooler system is accessible (stand-alone) check for correct operation and coolant/water level – this includes any temperature and pressure settings plus filter cleaning (air flow and water).
☐ Inspect the GTA workhead water hoses and connections for leaks.
☐ Check all graphite components and replace if necessary.
  ☐ Tube
  ☐ Electrodes
  ☐ Shroud
☐ Check and clean the end windows on the workhead.
☐ Check safety interlock operation.

Analytical performance for Furnace systems

☐ Optimize the instrument ready to perform Cu sensitivity test.
☐ Run the sensitivity test for a 25 ppb copper sample and record the results in the results table.

PSD autosampler accessory for Furnace systems

☑ Section NOT applicable.
☐ Check condition of the PSD capillary – replace if necessary
☐ Check condition and operation of PSD syringe – ensure it does not have air locks and bubbles.
☐ Change PSD rinse bottle o-ring.
☐ Check and clean the rinse vessel.
☐ Check the drain tube for good drainage. It should not have tight bends, kinks or loops and the lower end must be above the liquid level in the waste vessel.
☐ Ensure that the waste vessel is suitable for use with the furnace system.

Agilent
เอกสารไม่ควบคุม

Accessories

☐ Section NOT applicable.

Sample introduction pump system (SIPS) accessory

☑ Section NOT Applicable.

☐ Re-torque screws securing the hubs, presser arms and pump rotors.

☐ Adjust each roller so that it rotates freely.

☐ Wipe clean the pump rotor rollers and pump bands with a dry clean cloth.

☐ Ensure that the presser arms and the surfaces near the pump are free from dirt and spills.

☐ Remove the pump module rear cover and check for the incursion of liquids and any signs of corrosion.

☐ Re-torque the nuts that fasten the motor mounting plates to the chassis.

☐ Check clips securing the diluents holder and replace if necessary.

☐ Disconnect, clean T-piece, and reassemble the tubing using the following steps.

☐ Remove the T-piece by disconnecting the pump tubes, the pump bands and all other tubing.

☐ Place the T-piece in an ultrasonic bath containing strong detergent 1-5% Decon 30 or similar, for approximately 5-10 minutes.

☐ Wash the T-piece under a tap with a strong flow of water.

☐ Rinse with distilled water through all of the inlets in the reverse direction to normal sample flow.

☐ Reassemble.

Sample preparation system (SPS 4) accessory

☑ Section NOT Applicable.

The Agilent SPS 4 autosampler is designed to need minimal maintenance.

The following maintenance requirements are suggested to maintain the performance of the autosampler.

☐ Cleaning the spill tray, rack location mat, end frames and chassis accessories with a damp soft cloth and diluted mild detergent.

☐ Cleaning the autosampler cover panels with domestic window cleaner.

☐ Checking the X- axis and Z- axis drive belts for cracks, splits, damaged teeth, excessive fraying, color changes or degradation from fumes.

☐ Check the X- axis, Theta- axis and Z- axis FFC cables for cracks, incorrect positioning, damaged edge or damaged connectors.

NOTE The autosampler requires no extra lubrication throughout its lifetime.

For further details refer to the SPS 4 service manual G8410-90050.

Agilent
เอกสารไม่ควบคุม

Test Results

Test description	Expected test result	Actual test result
Flame optics PMT Gain test		
For copper at 324.8 nm, 4 mA, 0.5 nm slit width	< 55 %	46 1.
Flame performance test with 5 ppm copper sample		
Air /acetylene, mixing paddle removed	Abs value > 0.5	0.6331
Air /acetylene, mixing paddle installed. 10 replicates	%RSD < 1.0	0.71.
Deuterium furnace optics PMT Gain test		
For copper at 324.8 nm, 4 mA, 0.5 nm slit width	< 55 %	-
Deuterium furnace performance test with 25 ppb copper sample (324.8 nm)		
Precision %RSD	≤ 4.0%	-
Abs value	≥ 0.15	-
Zeeman furnace analytical performance: 25 ppb copper sample (324.8 nm)		
Precision %RSD	≤ 4.0%	-
Abs value	≥ 0.15	-
MSR% (327.4 nm)	≥70 %	-

AA consumable and parts list

Part Description	Part Number	Product/Model # where used	PM supplied or Consumable	Instrument-Type
Test Solution – Cu 5ppm solution	6610030100	55 240 280	PM supplied	Common
Test Solution - Blank solution	5190-7001	55 240 280	PM supplied	Common
Copper, 1000 ug/ml, 100ml	5190-8279	55 240 280	*	Common
Kit, Mk 7 O-rings, aqueous, complete set	9910093400	55 240 280	PM supplied	Flame
Organic Kit	9910093500	55 240 280	PM supplied	Flame
Wire Nebulizer Cleaning	9910024700	55 240 280	consumable	Flame
Tubing-Capillary Std Nebs	9910024800	55 240 280	consumable	Flame
Capillary Tube Hivac Neb (3) (organics only)	9910044000	55 240 280	consumable	Flame
Glass impact beads (5/pk)	9910025700	55 240 280	consumable	Flame

Agilent
เอกสารไม่ควบคุม

Vapor generation accessory VGA (hydride generator)

☐ Section NOT Applicable.

☐ Inspect VGA gas supply hose.

☐ Inspect/replace VGA pump tubing.

☐ Check low gas pressure interlock setting– adjust if required.

☐ Check precision orifice gas flow setting – adjust if required.

☐ Check gas regulator pressure to 46 psi (325 kPa) – adjust if required.

☐ Clean the exterior surfaces of the accessory with soft lint free cloth. This cloth can be dampened with warm water or a mild detergent. Do not use organic solvents or abrasive cleaning agents.

UltrAA Lamp Accessory (external)

☑ Section NOT Applicable.

☐ Check the condition of the power cable.

☐ Clean the exterior surfaces of the accessory with soft lint free cloth. This cloth can be dampened with warm water or a mild detergent. Do not use organic solvents or abrasive cleaning agents.

Restore System

☐ If you have altered the customer's instrumentation during the course of PM, restore to the original status to allow the customer to conduct their normal activities (e.g., reload the customer's method.)

Guidance

If the PM service is performed prior to a qualification service, then use the qualification procedure as a guide for final instrument set up and checkout.

Signature Page

Service Review

☐ Attach available reports/printouts of all tests to this documentation.

☐ Record the Preventive Maintenance service activity in the customer's records/logbook.

☐ Update/reset instrument maintenance counters as appropriate.

☐ Affix the PM sticker to the system or instrument logbook based on the customer's request.

☐ Complete the Service Engineer Comments section if there are additional comments.

☐ Review this service, parts replaced, and test results obtained with the customer.

☐ If the instrument firmware was updated, record the details of the change in the Service Engineer's Comments box or if necessary, in the customer's IQ records.

Agilent
เอกสารไม่ควบคุม

Teflon impact beads (5/pk): (organics only)	9910053300	55 240 280	consumable	Flame
Burner cleaning strip (100/pk)	9910053900	55 240 280	consumable	Flame
Window UV silica – round (right side)	2010082600	55 240 280	PM supplied	Common
Window UV silica – rectangular (left side)	2010082500	55 240 280	PM supplied	Common
Pad adhesive window (round)	4910012700	55 240 280	PM supplied	Common
Pad adhesive window (rectangular)	4910012800	55 240 280	PM supplied	Common
Electrode kit (1 pr) (D2)	6310003400	GTA120	PM supplied	Furnace
Shroud (D2)	6310003100	GTA120	PM supplied	Furnace
Zeeman electrode kit (1 pr)	6310003500	GTA120	PM supplied	Furnace
Zeeman shroud	6310003600	GTA120	PM supplied	Furnace
O-ring PSD rinse bottle	6910025900	PSD120	PM supplied	Furnace

* For engineers who only service AA instruments 5190-8279 can be used as a cheaper alternative for 6610030100.

Items classified as PM supplied in the above table are included in the standard PM.

Those classified as consumable should be provided by the customer or charged to the customer if supplied by the Agilent service engineer.

Service Engineer Comments (optional)

If there are any specific points you wish to note as part of performing the installation or other items of interest for the customer, please write them in this box.

Agilent
เอกสารไม่ควบคุม

Agilent AA Series Spectrometers Preventative Maintenance Checklist

Service Completion

Service Request Number: 6008058466
Service Engineer Name: Kanyakorn S.
Service Engineer Signature: Kanyakorn S.

Date of Service Completion: 26 Jan 2026
Customer Name: Monida Hamad
Customer Signature:

เอกสารไม่ควบคุม

Power Supply:

Averaging Period: 30.0
Datapoint Count: 20

	Lower Limit (V)	Actual (V)	Upper Limit (V)	Result:
12.00 V Rail	10.80	12.20	13.20	Passed
-12.00 V Rail	-13.20	-11.90	-10.80	Passed
5.00 V Rail	4.50	5.02	5.50	Passed
310.00 V Rail	279.00	320.00	341.00	Passed

เอกสารไม่ควบคุม

SVD Results Report

VARIAN

Report ID:3 Diagnostic Start Time:1/26/2026 8:39:56 AM Diagnostic End Time:1/26/2026 9:06:49 AM
Customer: UAE Service Engineer: Kanyakorn S.
Address: Contact Details: 026376363#1

Instrument Configuration

Configuration:

Serial Number:	MY13160001	Turret Type:	Automatic
Instrument Model:	Varian AA140/240/280	Number Of Lamps:	4
Flame Instrument:	True	Mono Type:	Automatic
Furnace Instrument:	True	Gasbox Type:	'Y' Gas Box
Zeeman Present:	False	Auto Burner Adjuster:	False
Internal Zeeman:	False	Mains Frequency:	50
Internal UltrAA:	False	Firmware Version:	2.11
Optics Type:	Double Beam	Photomultiplier Type:	Normal(900nm)
D2 BG Correction Fitted:	True	PWB Version:	45
Boot Block Version:	1.09		

EEPROM Data:

Instrument Run Hours:	79270.602	D2 Run Hours:	58906.000
Zero Wavelength Offset:	30.095	D2 Serial Number:	not set !
Mono Correction:	0.765	D2 Install Date:	1/1/1970
Flame Hours:	35125.582	D2 Original Intensity:	1.000
		D2 Last Intensity:	475.000

Frequency:

Averaging Period: 30.0
Datapoint Count: 20

Upper Limit: 51.00
Lower Limit: 49.00
Average Frequency: 50.00
Highest Measured Frequency: 50.00
Lowest Measured Frequency: 50.00

Result: Passed


เอกสารไม่ควบคุม

Optics

Beam Balance:


Lamp Type: Copper
Lamp Socket Used: 3
Peak Selected: 324.80
Lamp Alignment: Performed

'X' Lamp Screw



X Lamp Screw Result: Passed

'Y' Lamp Screw



Y Lamp Screw Result: Passed

Grating Squareness:

Lamp Element(s): Copper
Lamp Turret Position: 3
Lamp Current(mA): 4.00
Slit Width(nm): 0.5
1st Order Wavelength(nm): 324.80
Lamp Alignment: Performed

	Lower Limit (nm)	Actual (nm)	Upper Limit (nm)	Result:
Zero Order	-0.10	0.00	0.10	Passed
First Order	324.45	324.74	325.15	Passed
Second Order	649.23	649.50	649.97	Passed

เอกสารไม่ควบคุม

Wavelength Repeatability:

Lamp Used: Copper
Lamp Current(mA): 4
Peak Used(nm): 324.750
Slit Width(nm): 0.2
Connected to Socket: 3
Slit Height: Normal

Lamp Alignment: Performed

Lower Limit(nm) 324.768 — 324.888 **Upper Limit(nm)**

(Approach from Zero Order)	(Approach from end)
Sample 1: 324.828	Sample 2: 324.823
Sample 3: 324.823	Sample 4: 324.823
Sample 5: 324.823	Sample 6: 324.819
Sample 7: 324.823	Sample 8: 324.819
Sample 9: 324.819	Sample 10: 324.819

Mean: 324.823 **Standard Deviation:** 0.003

Result: Passed

เอกสารไม่ควบคุม

Auto Lamp Recognition:

Lamp 1: 67 - Silver/Cadmium/Lead/Zinc(UltrAA) (Ag/Cd/Pb/Zn)
Lamp 2: 68 - Zinc (Zn)
Lamp 3: 14 - Copper (Cu)
Lamp 4: Uncoded Lamp/Not Connected
Lamp 5: Not Supported
Lamp 6: Not Supported
Lamp 7: Not Supported
Lamp 8: Not Supported

Result: Passed

GTA Temperature Monitoring:

Not Performed

Notes:

Signatures:

UAE	26 Jan 26	Kanyakorn S.	26 Jan 2026
	Date	Kanyakorn S.	Date

เอกสารไม่ควบคุม

Mechanical

Wavelength Drive: Passed

Slit Drive: Passed

Turret Drive: Passed

Auto Burner Adjuster Drive: Untested

Miscellaneous

Signal Processing Linearity:

Calculate Mode: New Calc Mode

	Lower Limit	Actual	Upper Limit	Result:
S0	114	261	297	Passed
S1	156	165	191	Passed
S2	271	296	332	Passed
S3	474	508	579	Passed
S4	825	919	1008	Passed
S5	1435	1529	1754	Passed
S6	2498	2771	3053	Passed
S7	4347	4755	5313	Passed

Interlocks:

Burner Fitted: Working
N2O Burner Fitted: Untested
Flame Shield Closed: Working
Gas Control Fitted: Untested
Pressure Release Bung Fitted: Working
Liquid Trap Fitted: Working
Flame Detect: Working
GCU Active: Working
Oxidant Pressure: Working
Oxidant Changeover: Untested
Ignition: Working

เอกสารไม่ควบคุม

Sequential by time report 1/26/2026 9:54 AM Page 1 of 1 SpectrAA

Analyst
Date Started 1/26/2026 9:07 AM GMT: 1/26/2026 2:07 AM
Worksheet Sensitivity Test
Comment
Methods Cu
Computer name DESKTOP-R9UFRS
Serial Number: MY13160301

Method: Cu (Flame)

Sample ID	Exp Abs	%RSD	Mean Abs	
5 ppm Cu	0.633	1.4	0.6301	
	Readings			
	0.6413	0.6340	0.6241	1/26/2026

เอกสารไม่ควบคุม

Sequential by time report 1/26/2026 10:15 AM SpectrAA
Page 1 of 1

Analyst
Date Started 1/26/2026 9:07 AM GMT: 1/26/2026 2:07 AM
Worksheet Precision Test
Comment
Methods Cu
Computer name DESKTOP-R9UIFRS
Serial Number: MY13160001

Method: Cu (Flame)

Sample ID	Exp Abs	%RSD	Mean Abs			
5 ppm Cu	0.618	0.7	0.6180			
	Readings					
	0.6145	0.6187	0.6081	0.6168	0.6253	0.6196
	0.6197	0.6195	0.6188	0.6189	1/26/2026	

เอกสารไม่ควบคุม

Condition of this result of calibration

1. Reference Standard Instrument :-

Instrument	Serial No.	ID No.	Certificate No.	Due date
1) Thermometer	9549224	130RC003	25I440	16 Apr 2026
2) Ref. Std.Thermometer	4982054	110RC044	25I708	03 July 2026

- This measurement result is traceable to SI throught Technology Promotion Association (Thailand - Japan)

2. Certified Reference Materials :-
- Conductivity calibration solution, CPA chem Ltd., The measurement results are traceable to SI through CPA chem Ltd., ANSI-ASQ National Accreditation Board, Accredited No. AR-1835

Conductivity Solution	Manufacturer	Lot No.	Exp. date
1413.5 µS/cm	CPA Chem	1150497	30 Oct 2026
12.881 mS/cm	CPA Chem	1081099	11 Mar 2026

- Control Conductivity calibration solution temperature by Water bath (25 ± 0.1) °C

3. This certificate is valid only to the item calibrated on date and place of calibration.

Calibration results

Function : Conductivity Measurement
(*) After Adjustment at 1413.5 µS/cm
Conductivity Electrode Serial No.: 9B1J0042

Standard Conductivity Solution	Before Adjustment UUC* Reading	After Adjustment UUC* Reading	Uncertainty of Measurement (±)	Coverage factor *k*
1413.5 µS/cm	1330 µS/cm	1413 µS/cm	9.2 µS/cm	2.00
12.881 mS/cm	12.17 mS/cm	12.91 mS/cm	0.086 mS/cm	2.00

Remark : - UUC* = Unit Under Calibration

TECHNOLOGY PROMOTION ASSOCIATION (THAILAND-JAPAN)
CORPORATE SERVICES 3: EQUIPMENT CALIBRATION AND TESTING SERVICES
534/4 PATTANAKARN ROAD SOI 18, SUANLUANG, SUANLUANG BANGKOK 10250
TEL.0-2717-3000-29 FAX.0-2719-9484

Certificate of Calibration

Equipment :	Conductivity Meter
Manufacturer :	Horiba
Model :	LAQUA-EC210
Serial No. :	HC1L0016
ID No. :	UAE.EFM.014/2565(EFM.SCT.01/65)
Condition As-Received:	Used Item
Received Date :	02 February 2026
Calibration Date :	03 February 2026
Reference :	2602-0038WSC-4
Submitted by :	United Analyst and Engineering Consultant Co.,Ltd. 3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Ambient Temperature :	(25 ± 2.5) °C
Relative Humidity :	(50 ± 15) %
Calibration Procedure:	In -house method : - CP-CH6 by direct measurement with certified reference material (CRM) - CP-CH8 by comparison with temperature standard
Calibrated by :	Walalak Sirithean
Approved by :	Approved Signatory

( ) Chakrit Waewwanjua
( ) Ponpan Paipim
(✓) Saithip Meangmai

Issue Date : 04 February 2026

The Uncertainties are for a confidence probability of approximately 95%

This certificate may not be reproduced other than in full, except with the prior written Approval of the head of Corporate Services 3 : Equipment Calibration and Testing Services.

Calibration Results

Function : Temperature Measurement
(*) Without adjustment

This equipment was connected with Temperature Probe;
- Model : 9383
- Serial No. : 9B1J0042

Dimension of probe;
- Length : 110 mm
- Diameter : 16 mm
- Immersion Depth : 100 mm

Calibration Point (°C)	Standard Temperature (°C)	UUC* Reading (°C)	Error (°C)	Uncertainty of Measurement (± °C)	Coverage factor *k*
15.0	15.002	15.0	-0.002	0.13	2.00
30.0	30.001	30.0	-0.001	0.13	2.00
45.0	45.001	45.0	-0.001	0.13	2.00

Remark : - UUC* = Unit Under Calibration

The reported uncertainty of measurement was based on a standard uncertainty multiplied by a coverage factor *k*, providing a level of confidence of approximately 95 %.

-o0o-

TECHNOLOGY PROMOTION ASSOCIATION (THAILAND-JAPAN)
CORPORATE SERVICES 3 : EQUIPMENT CALIBRATION AND TESTING SERVICES
534/4 PATTANAKARN ROAD SOI 18, SUANLUANG, SUANLUANG BANGKOK 10250
TEL. 0-2717-3000 FAX. 0-2719-9484

Certificate of Testing

Cert.No.: 25TW213
Page.: 1 of 2

Equipment :	DO Meter
Manufacturer :	YSI
Model :	4010-2W
Serial No. :	20260326
ID No. :	UAE.WAO.060/2563
Received Date :	17 October 2025
Test Date :	22 October 2025
Reference :	2510-0505DSC-1
Submitted by :	United Analyst and Engineering Consultant Co.,Ltd. 3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Laboratory Condition :	Temperature (25 ± 5) °C Humidity (50 ± 20) %
Test Procedure :	In - house method : CP-CH9 by Comparison Technique with Azide Modification Method
Tested by :	Walalak Sirithean
Approved by :	Saithip Approved Signatory

( ) Chakrit Waewwanjua
( ) Ponpan Paipim
(✓) Saithip Meangmai

Issue Date : 23 October 2025

เอกสารไม่ควบคุม

TECHNOLOGY PROMOTION ASSOCIATION (THAILAND-JAPAN)
CORPORATE SERVICES 3: EQUIPMENT CALIBRATION AND TESTING SERVICES
534/4 PATTANAKARN ROAD SOI 18, SUANLUANG, SUANLUANG BANGKOK 10250
TEL.0-2717-3000-29 FAX.0-2719-9484

Certificate of Calibration

Cert.No.: 26CH231
Page.: 1 of 3

Equipment :	pH Meter
Manufacturer :	Horiba
Model :	LAQUA-PH210
Serial No. :	HA9M0047
ID No. :	UAE.EFM.005/2563 (EFM.pH.05/63)
Condition As-Received:	Used Item
Received Date :	24 February 2026
Calibration Date :	26 February 2026
Reference :	2602-0796WSC-2
Submitted by :	United Analyst and Engineering Consultant Co.,Ltd. 3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Ambient Temperature :	(25 ± 2.5) °C
Relative Humidity :	(50 ± 15) %
Calibration Procedure :	In - house method : - CP-CH5 by direct measurement with DC voltage standard and direct measurement with certified reference material (CRM) - CP-CH8 by comparison with temperature standard
Calibrated by :	Walalak Sirithean
Approved by :	Approved Signatory

( ) Chakrit Waewwanjua
( ) Ponpan Paipim
(✓) Saithip Meangmai

Issue Date : 27 February 2026

The Uncertainties are for a confidence probability of approximately 95%

This certificate may not be reproduced other than in full, except with the prior written Approval of the head of Corporate Services 3 : Equipment Calibration and Testing Services.

Cert.No.: 25TW213
Page.: 2 of 2

Condition of this result of calibration

1. Reference Standard Instruments :
This measurement result is traceable to the International System of Unit through the reference standards laboratory of Industrial Calibration Center, Technology Promotion Association (Thailand-Japan).

Instruments	ID No.	Certificate No.	Due Date
1. Burette	130BU10	25CG1126	18 Mar 2027
2. Balance	110RC001	25MM316	02 July 2026

2. Standard Material :-

Material	Manufacturer	Lot.No.	Assay
Sodium Thiosulfate 5-Hydrate AR	KEMAUS	2203162447	99.6%

Result : **Dissolved Oxygen Meter Adjustment With Air 100 %**
Dissolved Oxygen Probe No.: 22M102385

Titration Method (Azide Modification Method) (mg/L)	DO Meter Reading (mg/L)	Standard Deviation (mg/L)
8.22	8.31	0.0055

This report was certified only for the instrument we tested.It is allowable to use for study Intend to use for advertising and referral purpose is prohibited.This report may not be reproduced other in full, without written approval of the laboratory

-o0o-

เอกสารไม่ควบคุม

Cert.No.: 26CH231
Page.: 2 of 3

Condition of this calibration result

1. Reference Standard Instrument

Instrument	Serial No.	ID No.	Cert. No.	Due Date
1) Document Process Calibrator	54030049	130RC116	25E2743	25 Aug 2026
2) Ref. Standard Thermometer	4982054	110RC044	25I708	03 July 2026

- This measurement result is traceable to SI throught Technology Promotion Association (Thailand - Japan)

2. Certified Reference Materials :The measurement results are traceable to SI through Hach Lenge GmbH Ltd., Deutsche Akkreditierungsstelle, Accredited No.D-RM-15184-01-00
:The measurement results are traceable to SI through CPA chem Ltd., ANSI-ASQ National Accreditation Board, Accredited No. AR-1835

Buffer Solution	Manufacturer	Lot No.	Exp. date
pH 4.008	CPA chem	1187328	18 Jan 2028
pH 7.000	Hach Lenge GmbH	C03319	17 Oct 2027
pH 10.010	CPA chem	1187332	18 Jan 2027

3. This certificate is valid only to the item calibrated on date and place of calibration.

Calibration Results

Function : mV Measurement

Performing standard curve by Document Process Calibrator at pH (4,7)(7,10)

Unit Under Calibration	Nominal Value	Standard Voltage Input	Actual Reading		Uncertainty of Measurement (±mV)	Coverage factor k
	pH	mV	mV	pH		
pH Meter	4.00	177.48	177.3	4.01	0.058	2.00
S/N.: HA9M0047	7.00	0.00	0.0	7.02	0.058	2.00
	7.00	0.00	0.0	7.02	0.058	2.00
	10.00	-177.48	-177.2	10.01	0.058	2.00

Calibration Results

Function : pH Measurement

Performing three buffers standard curve by using buffer nominal pH (4,7)(7,10)

Unit Under Calibration	Standard pH Buffer Solution	Actual pH Reading	Actual mV Reading (mV)	Uncertainty of pH Measurement (±)	Coverage factor *k*
pH Electrode	4.008	4.01	161.1	0.0079	2.00
S/N.: -	7.000	7.00	-10.4	0.0096	2.00
	7.000	7.00	-9.9	0.0095	2.00
	10.010	10.02	-177.9	0.0095	2.00

Function : Temperature Measurement

(*) Without adjustment

This equipment was connected with Temperature Probe;

- Model : -
- Serial No. : -

Dimension of probe

- Length : 103 mm.
- Diameter : 16 mm.
- Immersion Depth : 90 mm.

Calibration Point (°C)	Standard Temperature (°C)	UUC* Reading (°C)	Error (°C)	Uncertainty of measurement (± °C)	Coverage factor *k*
15.0	15.001	15.0	-0.001	0.13	2.00
30.0	30.001	30.0	-0.001	0.13	2.00
45.0	45.001	44.9	-0.101	0.13	2.00

Remark - UUC* = Unit Under Calibration

The reported uncertainty of measurement was based on a standard uncertainty multiplied by a coverage factor *k*, providing a level of confidence of approximately 95 %.

-o0o-

Condition of this result of calibration

1. Reference Standard Instrument :-

Instrument	Serial No.	ID No.	Certificate No.	Due date
1) Thermometer	9549224	130RC003	25I440	16 Apr 2026
2) Ref. Std.Thermometer	4982054	110RC044	25I708	03 July 2026

- This measurement result is traceable to SI throught Technology Promotion Association (Thailand - Japan)

2. Certified Reference Materials :-

- Conductivity calibration solution, CPA chem Ltd., The measurement results are traceable to SI through CPA chem Ltd., ANSI-ASQ National Accreditation Board, Accredited No. AR-1835

Conductivity Solution	Manufacturer	Lot No.	Exp. date
1413.3 µS/cm	CPA Chem	1187337	18 Jan 2027
12.882 mS/cm	CPA Chem	1135362	16 Aug 2026

- Control Conductivity calibration solution temperature by Water bath (25 ± 0.1) °C

3. This certificate is valid only to the item calibrated on date and place of calibration.

Calibration results

Function : Conductivity Measurement

(*) After Adjustment at 1413.3 µS/cm

Conductivity Electrode Serial No.: 9B1J0077

Standard Conductivity Solution	Before Adjustment UUC* Reading	After Adjustment UUC* Reading	Uncertainty of Measurement (±)	Coverage factor *k*
1413.3 µS/cm	1400 µS/cm	1413 µS/cm	9.3 µS/cm	2.00
12.882 mS/cm	12.78 mS/cm	12.81 mS/cm	0.086 mS/cm	2.00

Remark : - UUC* = Unit Under Calibration

TECHNOLOGY PROMOTION ASSOCIATION (THAILAND-JAPAN)
CORPORATE SERVICES 3: EQUIPMENT CALIBRATION AND TESTING SERVICES
534/4 PATTANAKARN ROAD SOI 18, SUANLUANG, SUANLUANG BANGKOK 10250
TEL.0-2717-3000-29 FAX.0-2719-9484

Certificate of Calibration

Equipment :	Conductivity Meter
Manufacturer :	Horiba
Model :	LAQUA-EC210
Serial No. :	HC1L0026
ID No. :	UAE.EFM.015/2565(EFM.SCT.02/65)
Condition As-Received:	Used Item
Received Date :	24 February 2026
Calibration Date :	26 February 2026
Reference :	2602-0799WSC-3
Submitted by :	United Analyst and Engineering Consultant Co.,Ltd. 3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Ambient Temperature :	(25 ± 2.5) °C
Relative Humidity :	(50 ± 15) %
Calibration Procedure:	In -house method : - CP-CH6 by direct measurement with certified reference material (CRM) - CP-CH8 by comparison with temperature standard
Calibrated by :	Walalak Sirithean
Approved by :	Approved Signatory

( ) Chakrit Waewwanjua
( ) Ponpan Paipim
(✓) Saithip Meangmai

Issue Date : 27 February 2026

The Uncertainties are for a confidence probability of approximately 95%

This certificate may not be reproduced other than in full, except with the prior written Approval of the head of Corporate Services 3 : Equipment Calibration and Testing Services.

Calibration Results

Function : Temperature Measurement

(*) Without adjustment

This equipment was connected with Temperature Probe;

- Model : 9383
- Serial No. : 9B1J0077

Dimension of probe;

- Length : 110 mm
- Diameter : 16 mm
- Immersion Depth : 90 mm

Calibration Point (°C)	Standard Temperature (°C)	UUC* Reading (°C)	Error (°C)	Uncertainty of Measurement (± °C)	Coverage factor *k*
15.0	15.002	15.0	-0.002	0.13	2.00
30.0	30.001	30.1	0.099	0.13	2.00
45.0	45.001	45.1	0.099	0.13	2.00

Remark : - UUC* = Unit Under Calibration

The reported uncertainty of measurement was based on a standard uncertainty multiplied by a coverage factor *k*, providing a level of confidence of approximately 95 %.

-o0o-

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

Certificate of Calibration

Certificate No.: 260311-2-BL002-26
Code No.: BL002-26
Page: 1 of 4

Customer Name: United Analyst and Engineering Consultant Co., Ltd.
Address: 3 Soi Udom suk 41, Sukhumvit Rd., Bang Chak, Phar Khanong, Bangkok 10260

Equipment: Electronic Balance
Manufacturer: Mettler Toledo
Model: XSR205DU
Serial No.: C009071872
Asset No. : UAE.WAO.012/2563
Building : UAE number 3 Floor : 2 Room : 208

Received Date: March 11, 2026
Date of Calibation : March 12, 2026
Calibration Conditions: Temperature 23.8 °C to 24.1 °C
Humidity 50.0 % to 59.0 %
Pressure 755.5 mmHg to 755.6 mmHg

Calibrated by: Thanachat Chatpahol
Approved by: Suwit Chotnok Signature:

Issued Date: March 16, 2026

Note : 1) The Uncertainties are for a confidence probability of approximately 95%
2) This Certificate is valid only to the item calibrated on date and place of calibration.
3) This Certificate is issued in accordance with the conditions of accreditation granted by the Thai Laboratory Accreditation Scheme which has assessed the measurement capability of the laboratory and its traceability to recognized national standards and to the units of measurement realized at the corresponding national standards laboratory. This certificate may not be reproduced other than in full except with the prior written approval of the United Analyst and Engineering Consultant Co.,Ltd. (UAE)

เอกสารไม่ควบคุม

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

Equipment: Electronic Balance
Manufacturer: Mettler Toledo
Model: XSR205DU
Readability: 0 to 81 (g): 0.01 mg > 80 to 200 (g) : 01 mg
Serial No.: C009071872
ID No.: UAE.WAO.012/2563
Max. Capacity: 81 g / 220 g
Calibration Date: March 12, 2026

Calibraton Result: (Continued)
Calibraton Range: 0 to 80 (g)
Calibraton Adjustment: Internal Calibration

3. Error of Indication from nominal or conventional mass value: (Range: 0 to 81 (g) ; Resolution: 0.00001 g)

Nominal Value (g)	Reference Value (g)	Indication (g)	Correction (g)	Uncertainty (± mg)	Coverage Factor k
Unload	0.0000000	0.0000	0.0000	0.015	2.25
0.001	0.0010020	0.0010	0.00000	0.015	2.23
0.005	0.0050025	0.0050	-0.00002	0.015	2.23
0.01	0.0100005	0.0100	-0.00002	0.015	2.23
0.05	0.0500003	0.0500	-0.00001	0.015	2.21
0.10	0.1000083	0.1000	-0.00001	0.015	2.20
0.50	0.5000121	0.5000	-0.00002	0.016	2.15
1	1.0000119	1.0000	0.00000	0.016	2.12
2	2.0000125	2.0000	-0.00001	0.017	2.09
5	5.0000146	5.0000	-0.00002	0.020	2.05
10	10.0000330	10.0001	-0.00002	0.023	2.00
20	20.000028	20.0001	-0.00005	0.033	2.00
30	30.000061	30.0001	-0.00004	0.051	2.00
40	40.000054	40.0001	-0.00004	0.063	2.00
50	50.000037	50.0001	-0.00005	0.064	2.00
60	60.000070	60.0001	-0.00004	0.081	2.00
80	80.000098	80.0001	-0.00001	0.11	2.00

เอกสารไม่ควบคุม

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

Equipment: Electronic Balance
Manufacturer: Mettler Toledo
Model: XSR205DU
Readability: 0 to 81 (g): 0.01 mg > 80 to 200 (g) : 01 mg
Serial No.: C009071872
ID No.: UAE.WAO.012/2563
Max. Capacity: 81 g / 220 g
Calibration Date: March 12, 2026
Condition As-Received: In Condition
Condition of Equipment:
Condition of This Result of Calibration:
1. Calibration Method: This instrument was calibrated by method ULECP.CAL.006 In-House Method based on OIML Lab 14 : 2022
2. Reference Standards:

Reference Standard:	Model	Serial No.	Calibrated By	Certificate No.	Traceability	Due Date
Standard Weight Class E2 (OIML)	1 mg to 1 kg	CS10641605	METTLER TOLEDO GmbH	CS10641605	Mettler-Toledo GmbH	3-Mar-27
Standard Weight Class E2 (OIML)	1 mg to 1 kg	B749109122	AMARC	25-009559	Mettler-Toledo	21-Jan-27


Instrument	Model	Serial No.	Calibrated By	Certificate No.	Traceability	Due Date
Thermo-Hygro-Baro Meter	MHB-382SD	AK46457	SUCCESS	SG-H-00992/68	Success Gateway	26-Nov-26
Thermo-Hygro-Baro Meter	MHB-382SD	AK46457	TPA	25P9868	TPA	18-Dec-26

3. This certification is traceable to SI Unit.
4. This certification was certified only for the instrument we calibrated.
5. This result of calibration was found accurate as show on date and place of calibration only.
6. Through the reference standard laboratory of Mettler-Toledo GmbH CS10641605, SAS accreditation number SCS 0032
7. Through the reference standard laboratory of AMARC 25-009559, TISI accreditation number 0152

Calibraton Result:
1. Repeatability of Reading:

Nominal Value (g)	Standard Deviation of Reading (g)
80	0.000008
200*	0.000045

2. Eccentric or off-center loading
A mass of 100 g was placed and moved to various position on pan
The Balance reading obtained is given in the table.



1 (g)	2 (g)	3 (g)	4 (g)	5 (g)	Maximum Difference (g)
100.0000	100.0000	100.0000	100.0000	100.0000	0.0000

เอกสารไม่ควบคุม

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

Equipment: Electronic Balance
Manufacturer: Mettler Toledo
Model: XSR205DU
Readability: 0 to 81 (g): 0.01 mg > 80 to 200 (g) : 01 mg
Serial No.: C009071872
ID No.: UAE.WAO.012/2563
Max. Capacity: 81 g / 220 g
Calibration Date: March 12, 2026

Calibraton Result: (Continued)
Calibraton Range: > 80 to 200 (g)
Calibraton Adjustment: Internal Calibration

3. Error of Indication from nominal or conventional mass value: (Range: > 80 to 200 (g) ; Resolution: 0.0001 g)

Nominal Value (g)	Reference Value (g)	Indication (g)	Correction (g)	Uncertainty (± mg)	Coverage Factor k
Unload	0.0000000	0.0000	0.0000	0.02	2.25
90	90.0000910	90.0000	0.0000	0.16	2.00
100	100.0000420	100.0000	0.0000	0.16	2.00
110	110.0000750	110.0000	0.0000	0.17	2.00
120	120.0000680	120.0000	0.0001	0.18	2.00
130	130.0001010	130.0000	0.0000	0.20	2.00
140	140.0000960	140.0000	0.0001	0.21	2.00
150	150.0000790	150.0003	0.0001	0.21	2.00
160	160.0001120	160.0003	0.0001	0.23	2.00
170	170.0001050	170.0003	-0.0002	0.24	2.00
200	200.0001460	200.0004	-0.0002	0.26	2.00

4. Effect of Tare test:

Tare Load (g)	Test Load (g)	Indication (g)	Correction (g)
100	20.000028	20.0000	0.0000
	40.000054	40.0002	-0.0001
	60.000070	60.0002	-0.0001
	80.000098	80.0002	-0.0001
	100.000042	100.0003	-0.0002

Remark:
The report uncertainty of measurement was based on standard uncertainty multiplied by coverage factor k, providing a level of confidence of approximately 95%

o---o-End-o---o

เอกสารไม่ควบคุม

สถาบันวิจัยและพัฒนาอุตสาหกรรมอาหาร
ศูนย์บริการห้องปฏิบัติการอุตสาหกรรมอาหาร
Foundation for Industrial Development National Food Institute
Food Industrial Laboratory Service Center

ilac-MRA

MC 0051 NSC-TISI-TIS 17025 CALIBRATION 0051

Calibration Certificate

Certificate No.: 2602303-006-01
Page : 1 of 2

Equipment:	CHAMBER (Incubator)		
Manufacturer:	BINDER	Customer Name:	UNITED ANALYST AND ENGINEERING CONSULTANT CO.,LTD
Model:	KB 400	Address:	3 Soi Udomsuk 41, Sukhumvit Road,
Serial No.:	20200000015535		Bangchack, Prakhanong, Bangkok 10260
ID No.:	UAE.MIC.016/2564		
Order No.:	2602303		
Operation No.:	2602303-006		
Date of Receipt:	11 March 2026		
Date of Calibration:	11 March 2026		

Metrological traceability:

1. Calibration Method:
   - This instrument was calibrated by inserting 9 standard thermometers into its chamber, in accordance with W-TE-014, based on TLAS G-20-1/02-08 (E): Guidelines for Calibration and Checks of Temperature Controlled Enclosures.
   - The temperature scale used in this laboratory is the International Temperature Scale of 1990 (ITS-90).
   - All data shown below are final values, and the initial data may be obtained upon request.
2. Reference Standard Instrument:

Instrument	Model/Type	Serial No./ID No.	Certificate No.	Due Date	Through
Digital Thermometer with sensor	DAQ973A RTD	MY59008984 CH6001-208/RTD6001-208	2502244-001-01	29 March 2026	NATIONAL FOOD INSTITUTE

3. This certificate is traceable to the International System of Units (SI).
4. This certificate is valid only for the instrument that was calibrated.
5. The result of this calibration was found to be accurate only on the date and at the place of calibration shown.

Calibrated by	Mr.Nuttapol Niyomchat Specialist	Approved by	(Mr.Pheraphat Tuanjit) Manager, Division of Calibration Laboratory Responsible for the Technical Management Team
Date of Issue:	19 March 2026		

This Certificate is issued in accordance with the conditions of accreditation granted by the Thai Laboratory Accreditation scheme which has assessed the measurement capability of the laboratory and its traceability to recognized national standards and to the units of measurement realized at the corresponding national standards laboratory. This certificate may not be reproduced other than in full except with the prior written approval of the National Food Institute.

2008 ซอยอรุณอมรินทร์ 36 ถนนอรุณอมรินทร์ แขวงบางยี่ขัน เขตบางพลัด กรุงเทพมหานคร
2008 Soi 36, Arun Amarin Road, Bang Yi Khan Subdistrict, Bang Phlat District, Bangkok 10700, Thailand
Tel. +66(0) 2422 6666 Fax: +66(0) 2422 6545
nfi.or.th
เอกสาร ไม่ควบคุม

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

NSC-TISI-TIS 17025 CALIBRATION 0410

Certificate of Calibration

Certificate No.: 260311-2-BL001-26
Code No.: BL001-26
Page: 1 of 4

Customer Name:	United Analyst and Engineering Consultant Co., Ltd.				
Address:	3 Soi Udom suk 41, Sukhumvit Rd., Bang Chak, Phar Khanong, Bangkok 10260				
Equipment:	Electronic Balance				
Manufacturer:	Mettler Toledo				
Model:	XSR205DU				
Serial No.:	C210685394				
Asset No. :	UAE.WAO.010/2565				
Building :	UAE number 3	Floor : 2		Room : 208	
Received Date:	March 11, 2026				
Date of Calibation :	March 12, 2026				
Calibration Conditions:	Temperature	23.0 °C	to	23.6 °C	
	Humidity	51.5 %	to	54.4 %	
	Pressure	755.7 mmHg	to	757.9 mmHg	
Calibrated by:	Thanachat Chatpahol				
Approved by:	Suwit Chotnok	Signature:			
Issued Date:	March 16, 2026				

Note : 1) The Uncertainties are for a confidence probability of approximately 95%
2) This Certificate is valid only to the item calibrated on date and place of calibration.
3) This Certificate is issued in accordance with the conditions of accreditation granted by the Thai Laboratory Accreditation Scheme which has assessed the measurement capability of the laboratory and its traceability to recognized national standards and to the units of measurement realized at the corresponding national standards laboratory. This certificate may not be reproduced other than in full except with the prior written approval of the United Analyst and Engineering Consultant Co.,Ltd. (UAE)

เอกสารไม่ควบคุม

สถาบันวิจัยและพัฒนาอุตสาหกรรมอาหาร
ศูนย์บริการห้องปฏิบัติการอุตสาหกรรมอาหาร
Foundation for Industrial Development National Food Institute
Food Industrial Laboratory Service Center

ilac-MRA

MC 0051 NSC-TISI-TIS 17025 CALIBRATION 0051

Calibration Certificate

Certificate No.: 2602303-006-01
Page : 2 of 2

Calibration Condition:

Equipment:	CHAMBER (Incubator)	Place of Calibration:	Microbiology Laboratory
UUC* Resolution:	0.1 °C		UNITED ANALYST AND ENGINEERING CONSULTANT CO.,LTD
Condition of the item:	Normal & Good	Environment Conditions:	Ambient Temperature (17.2 ± 1) °C
	Without adjustment / As Found		Relative Humidity (51.5 ± 4) %
	- Time of record : 1 hour 0 minute / point		Line Voltage (229 ± 2) V.

Calibration Results:

Table1 : Reporting of Temperature

Calibration Point (°C)	Measured Temperature (°C) @ Sensor No. (Sensor No.9 is REF)									Measurement Uncertainty (±°C)
	Std.#1	Std.#2	Std.#3	Std.#4	Std.#5	Std.#6	Std.#7	Std.#8	Std.#9	
35.0	34.78	34.86	34.81	34.83	35.22	35.21	35.22	35.12	34.83	0.28

Table 2 : Reporting of Characterization Results


UUC* Setting (°C)	UUC* Reading (°C)			Stability ± (°C)	Uniformity (°C)	Overall Variation (°C)
	Max	Min	Average			
35.0	35.0	35.0	35.0	0.034	0.39	0.52

Note
- UUC* : Unit Under Calibration
- The quoted uncertainty includes contributions from 'Stability' and 'Loading Effect (20% of Temperature Uniformity).
- Stability = One-half of the greatest maximum difference of measured temperatures at any one sensors, for at least half an hour after reaching steady state.
- Uniformity = The maximum difference of measured temperatures at any sensors and the measured temperature at the reference location which are observed at the same time.
- Overall Variation = The difference of The maximum and minimum measured temperatures througout observation time.

For more information, details of the sensor installation should be reported.

Fresh air Damper	-	Open	- Position
	X	Close	100% Fan speed
	-	Not Available	

Dimension of inside chamber and sensor installation location (cm)						
W x H x D	65	x	125	x	48	
a x b x c	10	x	10	x	10	



The report uncertainty of measurement was based on standard uncertainty multiplied by coverage factor k = 2, providing a level of confidence of approximately 95 %.

---------- End of Report ----------

2008 ซอยอรุณอมรินทร์ 36 ถนนอรุณอมรินทร์ แขวงบางยี่ขัน เขตบางพลัด กรุงเทพมหานคร
2008 Soi 36, Arun Amarin Road, Bang Yi Khan Subdistrict, Bang Phlat District, Bangkok 10700, Thailand
Tel. +66(0) 2422 6666 Fax: +66(0) 2422 6545
nfi.or.th
เอกสาร ไม่ควบคุม

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

ilac-MRA

NSC-TISI-TIS 17025 CALIBRATION 0410

Certificate No.: 260311-2-BL001-26
Code No.: BL001-26
Page: 2 of 4

Equipment:	Electronic Balance	Manufacturer:	Mettler Toledo
Model:	XSR205DU	Readability:	0 to 81 (g): 0.01 mg , > 80 to 200 (g) : 0.1 mg
Serial No.:	C210685394	ID No.:	UAE.WAO.010/2565
Max. Capacity:	81 g / 220 g		
Calibration Date:	March 12, 2026		
Condition As-Received:	In Condition		

Condition of Equipment:

Condition of This Result of Calibration:

1. Calibration Method: This instrument was calibrated by method UAE.CP.CAL.006 In-House Method based on UKAS Lab 14 : 2012
2. Reference Standards:

Reference Standard:	Model	Serial No.	Calibrated By	Certificate No.	Traceability	Due Date
Standard Weight Class E2 (OIML)	1 mg to 1 kg	C510641605	METTLER TOLEDO GmbH	C510641605	METTLER TOLEDO GmbH	3-Mar-27
Standard Weight Class E2 (OIML)	1 mg to 1 kg	8749109122	AMARC	25-009359	AMARC	21-Jan-27

Instrument	Model	Serial No.	Calibrated By	Certificate No.	Traceability	Due Date
Thermo-Hygro-Baro Meter	MHB-382SD	AK4645T	SUCCESS	SG-H-00992/68	Success Gateway	26-Nov-26
Thermo-Hygro-Baro Meter	MHB-382SD	AK4645T	TPA	25P4864	TPA	18-Dec-26

3. This certification is traceable to SI Unit
4. This certification was certified only for the instrument we calibrated
5. This result of calibration was found accurate as show on date and place of calibration only.
6. Through the reference standard laboratory of Mettler-Toledo GmbH C510641605, SAS accreditation number SCS 0032
7. Through the reference standard laboratory of AMARC 25-009359, TISI accreditation number 8152


Calibration Result:

1. Repeatability of Reading:

Nominal Value (g)	Standard Deviation of Reading (g)
80	0.000019
200*	0.000055

2. Eccentric or off-center loading

A mass of 100 g was placed and moved to various position on pan
The Balance reading obtained is given in the table.



1 (g)	2 (g)	3 (g)	4 (g)	5 (g)	Maximum Difference (g)
100.0002	100.0002	100.0003	100.0004	100.0003	0.0001

เอกสารไม่ควบคุม

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

Equipment:	Electronic Balance	Manufacturer:	Mettler Toledo
Model:	XSR205DU	Readability:	0 to 81 (g): 0.01 mg , > 80 to 200 (g) : 0.1 mg
Serial No.:	C210685394	ID No.:	UAE.WAO.010/2565
Max. Capacity:	81 g / 220 g		
Calibration Date:	March 12, 2026		

Calibraton Result: (Continued)
Calibraton Range: 0 to 80 (g)
Calibraton Adjustment: Internal Calibration

3. Error of Indication from nominal or conventional mass value: (Range: 0 to 81 (g) ; Resolution: 0.00001 g)

Nominal Value (g)	Reference Value (g)	Indication (g)	Correction (g)	Uncertainty (± mg)	Coverage Factor k
Unload	0.0000000	0.00000	0.00000	0.032	2.65
0.001	0.0010020	0.00101	0.00000	0.032	2.65
0.005	0.0050025	0.00501	-0.00001	0.032	2.65
0.01	0.0100005	0.01001	-0.00001	0.032	2.65
0.05	0.0500005	0.05001	-0.00001	0.032	2.65
0.10	0.1000085	0.10000	0.00001	0.033	2.65
0.50	0.5000121	0.50001	0.00000	0.033	2.65
1	1.0000119	1.00003	-0.00002	0.032	2.52
2	2.0000125	2.00003	-0.00002	0.033	2.52
5	5.0000146	5.00003	-0.00002	0.033	2.52
10	10.0000330	10.00006	-0.00003	0.034	2.21
20	20.0000028	20.00006	-0.00003	0.041	2.07
30	30.0000061	30.00017	-0.00011	0.055	2.00
40	40.0000054	40.00021	-0.00016	0.066	2.00
50	50.0000037	50.00025	-0.00019	0.068	2.00
60	60.0000070	60.00029	-0.00022	0.084	2.00
80	80.0000098	80.00039	-0.00030	0.12	2.00

e.Chit

เอกสารไม่ควบคุม

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Rd., Bang Chak, Phar Khanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

Certificate of Calibration

Customer Name:	United Analyst and Engineering Consultant Co., Ltd.				
Address:	3 Soi Udom suk 41, Sukhumvit Rd., Bang Chak, Phar Khanong, Bangkok 10260				
Equipment:	Electronic Balance				
Manufacturer:	Mettler Toledo				
Model:	AB204-S/FACT				
Serial No.:	1129361010				
Asset No. :	UAE.WAS.002/2552				
Building :	UAE No.3	Floor : 1		Room : 107	
Received Date:	April 2, 2026				
Date of Calibation :	April 3, 2026				
Calibration Conditions:	Temperature	start	21.9 °C	end	22.1 °C
	Humidity	start	60.6 %	end	60.1 %
	Pressure	start	756.6 mmHg	end	755.1 mmHg
Calibrated by:	Thanachat Chatpahol				
Approved by:	Suwit Chotnok	Signature:	e.chit		
Issued Date:	April 7, 2026				

Note : 1) The Uncertainties are for a confidence probability of approximately 95%
2) This Certificate is valid only to the item calibrated on date and place of calibration.
3) This Certificate is issued in accordance with the conditions of accreditation granted by the Thai Laboratory Accreditation Scheme which has assessed the measurement capability of the laboratory and its traceability to recognized national standards and to the units of measurement realized at the corresponding national standards laboratory. This certificate may not be reproduced other than in full except with the prior written approval of the United Analyst and Engineering Consultant Co.,Ltd. (UAE)

เอกสารไม่ควบคุม

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

Equipment:	Electronic Balance	Manufacturer:	Mettler Toledo
Model:	XSR205DU	Readability:	0 to 81 (g): 0.01 mg , > 80 to 200 (g) : 0.1 mg
Serial No.:	C210685394	ID No.:	UAE.WAO.010/2565
Max. Capacity:	81 g / 220 g		
Calibration Date:	March 12, 2026		

Calibraton Result: (Continued)
Calibraton Range: > 81 to 200 (g)
Calibraton Adjustment: Internal Calibration

3. Error of Indication from nominal or conventional mass value: (Range: > 81 - 220 (g) ; Resolution: 0.0001 g)

Nominal Value (g)	Reference Value (g)	Indication (g)	Correction (g)	Uncertainty (± mg)	Coverage Factor k
Unload	0.0000000	0.0000	0.0000	0.032	2.65
90	90.0000910	90.0004	-0.0003	0.16	2.00
100	100.0000420	100.0003	-0.0003	0.16	2.00
110	110.0000750	110.0004	-0.0003	0.18	2.00
120	120.0000680	120.0004	-0.0003	0.19	2.00
130	130.0001010	130.0005	-0.0004	0.20	2.00
140	140.0000960	140.0004	-0.0003	0.21	2.00
150	150.0000790	150.0005	-0.0004	0.22	2.00
160	160.0001120	160.0004	-0.0003	0.23	2.00
170	170.0001050	170.0003	-0.0002	0.24	2.00
200	200.0001460	200.0001	0.0000	0.26	2.00

4. Effect of Tare test:

Tare Load (g)	Test Load (g)	Indication (g)	Correction (g)
100	20.0000028	20.0001	0.0000
	40.0000054	40.0001	0.0000
	60.0000070	60.0000	0.0001
	80.0000098	80.0000	0.0001
	100.0000109	100.0000	0.0001

Remarks: -
The report uncertainty of measurement was based on standard uncertainty multiplied by coverage factor k, providing a level of confidence of approximately 95%

o---o-End-o---o

e.Cit

เอกสารไม่ควบคุม

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel.0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

Equipment:	Electronic Balance	Manufacturer:	Mettler Toledo
Model:	AB204-S/FACT	Readability:	0.0001 g
Serial No.:	1129361010	ID No.:	UAE.WAS.002/2552
Max. Capacity:	220 g		
Calibration Date:	April 3, 2026		
Condition As-Received:	In Condition		

Condition of Equipment:
Condition of This Result of Calibration:
1. Calibration Method: This instrument was calibrated by method UAE.CP.CAL.006 In-House Method based on OIML Lab 16 : 2022
2. Reference Standards:

Reference Standard:	Model	Serial No.	Calibrated By	Certificate No.	Traceability	Due Date
Standard Weight Class E2 (OIML)	1 mg to 1 kg	C510641605	METTLER TOLEDO GmbH	C510641605	Mettler-Toledo	5-Mar-27


Instrument	Model	Serial No.	Calibrated By	Certificate No.	Traceability	Due Date
Thermo-Hygro-Baro Meter	MHB-382SD	AK/46457	SUCCESS	SG-H-00992/68	Success Gateway	26-Nov-26
Thermo-Hygro-Baro Meter	MHB-382SD	AK/46457	TPA	25P4464	TPA	18-Dec-26

3. This certification is traceable to SI Unit.
4. This certification was certified only for the instrument we calibrated
5. This result of calibration was found accurate as show on date and place of calibration only.
6. Through the reference standard laboratory of Mettler-Toledo GmbH C510641605, SAS accreditation number SCS 0032

Calibraton Result:
1. Repeatability of Reading:

Nominal Value (g)	Standard Deviation of Reading (g)
200*	0.00010

2. Eccentric or off-center loading
A mass of 100 g was placed and moved to various position on pan
The Balance reading obtained is given in the table.



1 (g)	2 (g)	3 (g)	4 (g)	5 (g)	Maximum Difference (g)
100.0025	100.0022	100.0022	100.0029	100.0030	0.0005

e.Cit

เอกสารไม่ควบคุม

United Analyst and Engineering Consultant Co., Ltd.
3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260
Tel 0 2763 2828 Fax 0 2763 2800 www.uaeconsultant.com E-mail: uae@uaeconsultant.com

Certificate No.: 260318-1-BL007-26
Code No.: BL007-26
Page: 3 of 3

Equipment: Electronic Balance
Manufacturer: Mettler Toledo
Model: AB204-S/FACT
Readability: 0.0001 g
Serial No.: 1129361010
ID No.: UAE.WAS.002/2552
Max. Capacity: 220 g
Calibration Date: April 3, 2026

Calibration Result: (Continued)
Calibration Range: 0 - 200 g
Calibration Adjustment: Internal Calibration

3. Error of indication from nominal or conventional mass value:

Nominal Value (g)	Reference Value (g)	Indication (g)	Correction (g)	Uncertainty (± mg)	Coverage Factor k
Unload	0.0000000	0.0000	0.0000	0.17	2.37
0.01	0.0100005	0.0099	0.0001	0.17	2.32
0.05	0.0500003	0.0499	0.0001	0.17	2.32
0.1	0.1000085	0.0999	0.0001	0.17	2.32
0.5	0.5000121	0.5000	0.0000	0.17	2.32
1.0	1.0000119	1.0000	0.0000	0.17	2.32
10.0	10.000033	10.0003	-0.0003	0.17	2.32
40.0	40.000054	40.0010	-0.0010	0.18	2.23
50.0	50.000037	50.0013	-0.0012	0.18	2.23
80.0	80.000098	80.0020	-0.0019	0.19	2.11
100.0	100.000042	100.0025	-0.0024	0.20	2.10
120.0	120.000068	120.0028	-0.0027	0.22	2.06
150.0	150.000079	150.0035	-0.0035	0.24	2.04
160.0	160.000112	160.0036	-0.0035	0.25	2.03
200.0	200.000146	200.0049	-0.0047	0.28	2.00

4. Effect of Tare test:

Tare Load (g)	Test Load (g)	Indication (g)	Correction (g)
100	20.000028	20.0004	-0.0003
	40.000054	40.0009	-0.0008
	60.000070	60.0013	-0.0012
	80.000098	80.0017	-0.0016
	100.000042	100.0021	-0.0021

Remark: -
The report uncertainty of measurement was based on standard uncertainty multiplied by coverage factor k, providing a level of confidence of approximately 95%

o---o-End-o---o

เอกสารไม่ควบคุม

HANNA instruments

Certificate No. : C26030163
Page : 2 of 2

Condition of this calibration result :

Reference standard instrument : This Certification is traceable to the SI Unit maintained through:

Instrument	Model	Serial No.	Certificate No.	Traceable
Digital Thermo-Hygrometer	HT-771SD	AI.07155	26H106	Technology Promotion Association (Thailand-Japan).
Data Acquisition Switch Unit	34970A	MY44065265	WK2507-171-1	WK Electric Co., Ltd.

Calibration Result :

Measurement Temperature Source Accuracy for COD Reactor.

Capacity	Nominal Value	Average Value	Error	Uncertainty (±)
25 Vials	150.0 °C	150.1 °C	0.1 °C	0.53 °C

Unit : °C

(1A)	(2A)	(3A)	(4A)	(5A)
149.7	149.7	150.1	150.4	150.4
(1B)	(2B)	(3B)	(4B)	(5B)
150.4	150.3	150.2	150.2	150.1
(1C)	(2C)	(3C)	(4C)	(5C)
149.9	150.2	150.0	150.2	149.9
(1D)	(2D)	(3D)	(4D)	(5D)
150.2	150.2	150.0	150.0	150.0
(1E)	(2E)	(3E)	(4E)	(5E)
150.1	149.8	150.2	150.2	149.8

Figure: Shows the location of the temperature source.

The report uncertainty of measurement was based on a standard uncertainty multiplied by a coverage factor $k=2$, providing a level of confidence of approximately 95%

** End of certificate **

เอกสารไม่ควบคุม

Form Eff. 5/1/2026

HANNA instruments

Hanna Instruments (Thailand) Ltd.
410/67-68 Soi Ratchadapisek 24, Ratchadapisek Rd., Samsen-nok, Huaykwang, Bangkok 10310 Tel: 0-2541-4199 Fax: 0-2541-4198

ilac-MRA ANAB ACCREDITED AC-3061

Certificate No. : C26030163
Page : 1 of 2

CERTIFICATE OF CALIBRATION

Equipment	: COD Test Tube Heater		
Meter Model	: HI839800-02	**Serial No.**	: 06480019101
Tube Heater Capacity	: 25 Vial Capacity	**Resolution**	: 0.1 °C
Temperature Range	: (-10 to 160)°C	**Temperature of Reaction**	: 150°C
Manufacturer	: Hanna Instruments	**Made in**	: Romania
Condition As-Received	: Used Product	**Reference**	: RE260497
Ambient Temperature	: (25 ± 2)°C	**Relative Humidity**	: (50 ± 15)% RH
Customer name	: United Analyst and Engineering Consultant Co., Ltd. 3 Soi Udomsuk 41, Sukhumvit Rd., Bangchak Phrakhanong, Bangkok 10260		
Received date	: 12 March 2026		
Calibrate date	: 17 March 2026		
Issue date	: 18 March 2026		
Calibrated Location	: Hanna Instruments (Thailand) Ltd.		
Calibration Procedure	: This calibrator was conducted by using in-house: calibration procedure CP-04 by using certified reference standard instruments.		
Calibrated by	: Mr. Pichit Petthong	**Approved by :**	(Mr. Anan Suwanchaisakul) Authorized Signatory

HANNA instruments (Thailand) Limited

This certificate was certified only for the instrument we calibrated. This result of calibration was found accurate on date and place of calibration only.
This certificate may not be reproduced other than in full, except with the prior written approval of the issued.

เอกสารไม่ควบคุม

Form Eff. 5/1/2026

DQE Services

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

CERTIFICATE OF CALIBRATION

Certificate No. : SP26-014 Page 1 of 5

Customer : United Analyst and Engineering Consultant Co.,Ltd. (Head Office)

Address : 3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

Location of calibration : Instrument room (207)

Equipment : UV-Vis Spectrophotometer

Manufacturer : HITACHI

Model : U-5100

Serial No. : 23A4-008

ID No. : UAE.WAS.010/2567

Received Date : 18 May 2026

Calibration Date : 18 May 2026

Issue Date : 21 May 2026

Condition Instrument : Good

Calibrated by : (Mr.Pacit Mathavom) Calibration Engineer

Approved by : (Ms.Chonticha Sangngern) Quality Manager

The calibration result is applied only to the above calibrated item and was found accurate as shown on date and place of calibration only.

The measurement capability of the laboratory and its traceability to recognized national standards and to the unit of measurement realized at the corresponding national standards laboratory. This certificate may not be reproduced other than in full except with the prior written approval of the DQE Services Co., Ltd.

เอกสารไม่ควบคุม

FM-708-02 R01 1/11/2021

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

REPORT OF CALIBRATION

Certificate No. : SP26-014

Environment Condition : Ambient Temperature 25 ± 5 °C

Relative humidity 55 ± 20 %RH

Calibration method : In-house method CP-01 Based on ASTM E275-08

Certified Reference Materials :

Material	Serial No.	Certificate No.	Due date
Absobance Standard set	25760	136858	5 November 2027
Absobance Standard set	25757	136848	5 November 2027
Wavelength Standard set	25806	136824	5 November 2027
Wavelength Standard set	25758	136827	5 November 2027

Traceability : This certification is traceable to the International System of Unit maintained at National - Institute of Standards and Technology (NIST) through Starna Scientific Limited

Spectral Band Width of UUC : 5.0 nm.

Scan Speed of UUC : 40

Scan Interval of UUC : 0.1 nm.

Resolution of UUC : Photometric 0.001 Abs.

Wavelength 0.1 nm.

เอกสารไม่ควบคุม

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

REPORT OF CALIBRATION

Certificate No. : SP26-014

Photometric Accuracy :

Wavelength (nm.)	CRMs Values (Abs)	UUC Reading (Abs)	Correction (Abs)	Uncertainty (Abs)	Coverage factor k
235	0.0000	0.000	0.0000	0.0050	2.00
	0.7455	0.744	0.0015	0.0056	2.00
257	0.0000	0.000	0.0000	0.0050	2.00
	0.8656	0.863	0.0026	0.0059	2.00
313	0.0000	0.000	0.0000	0.0050	2.00
	0.2910	0.290	0.0010	0.0051	2.00
350	0.0000	0.000	0.0000	0.0050	2.00
	0.6414	0.640	0.0014	0.0055	2.00

เอกสารไม่ควบคุม

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

REPORT OF CALIBRATION

Certificate No. : SP26-014

Calibration Results : Without adjustment

Photometric Accuracy :

Wavelength (nm.)	CRMs Values (Abs)	UUC Reading (Abs)	Correction (Abs)	Uncertainty (Abs)	Coverage factor k
420	0.0000	0.000	0.0000	0.0028	2.00
	0.5772	0.574	0.0032	0.0031	2.00
	1.0478	1.043	0.0048	0.0029	2.00
	2.1879	2.182	0.0059	0.0082	2.00
440	0.0000	0.000	0.0000	0.0028	2.00
	0.5581	0.556	0.0021	0.0034	2.00
	1.0224	1.020	0.0024	0.0035	2.00
	2.1227	2.121	0.0017	0.0079	2.00
465	0.0000	0.000	0.0000	0.0028	2.00
	0.5225	0.518	0.0045	0.0029	2.00
	0.9628	0.961	0.0018	0.0028	2.00
	1.9744	1.974	0.0004	0.0070	2.00
546.1	0.0000	0.000	0.0000	0.0028	2.00
	0.5174	0.514	0.0034	0.0031	2.00
	0.9990	0.996	0.0030	0.0033	2.00
	1.9953	1.995	0.0003	0.0087	2.00
590	0.0000	0.000	0.0000	0.0028	2.00
	0.5508	0.549	0.0018	0.0030	2.00
	1.0801	1.078	0.0021	0.0029	2.00
	2.0356	2.028	0.0076	0.0079	2.00
635	0.0000	0.000	0.0000	0.0028	2.00
	0.5579	0.558	-0.0001	0.0031	2.00
	1.0512	1.050	0.0012	0.0029	2.00
	1.9257	1.923	0.0027	0.0083	2.00

เอกสารไม่ควบคุม

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

REPORT OF CALIBRATION

Certificate No. : SP26-014

Wavelength Accuracy :

CRMs Values (nm.)	UUC Reading (nm.)	Correction (nm.)	Uncertainty (nm.)	Coverage factor k
241.00	240.3	0.70	0.18	2.00
279.30	278.9	0.40	0.18	2.00
288.90	288.2	0.70	0.18	2.00
334.50	333.8	0.70	0.18	2.00
361.40	360.7	0.70	0.18	2.00
418.40	417.9	0.50	0.18	2.00
447.20	446.6	0.60	0.18	2.00
459.30	459.4	-0.10	0.18	2.00
537.00	536.5	0.50	0.18	2.00
638.00	637.3	0.70	0.18	2.00
441.29	440.6	0.69	0.18	2.00
479.88	479.2	0.68	0.18	2.00
513.75	513.0	0.75	0.18	2.00
528.59	528.1	0.49	0.18	2.00
575.10	574.5	0.60	0.18	2.00
585.56	585.0	0.56	0.20	2.00
684.70	684.2	0.50	0.18	2.00
740.51	739.9	0.61	0.20	2.00
747.61	747.0	0.61	0.18	2.00
807.04	806.5	0.54	0.18	2.00
879.68	879.0	0.68	0.18	2.00

Remark : - UUC = Unit Under Calibration

- N/A = Not Available
- The result expanded uncertainty of measurement U is stated as the standard uncertainty of measurement multiplied by the coverage factor *k* , which for a normal distribution corresponds to a coverage probability of approximately 95%
- * Indicates non TISI accredited

- End of Certificate -

เอกสารไม่ควบคุม

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

CERTIFICATE OF CALIBRATION

Certificate No. : SP26-013

Customer : United Analyst and Engineering Consultant Co.,Ltd. (Head Office)

Address : 3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

Location of calibration : Instrument room (207)

Equipment : UV-Vis Spectrophotometer

Manufacturer : Agilent Technologies

Model : Cary 60

Serial No. : MY15410009

ID No. : UAE.WAT.020/2558

Received Date : 18 May 2026

Calibration Date : 18 May 2026

Issue Date : 21 May 2026

Condition Instrument : Good

Calibrated by : (Mr.Pacit Mathavorn)
Calibration Engineer

Approved by : (Ms.Chonticha Sangngern)
Quality Manager

The calibration result is applied only to the above calibrated item and was found accurate as shown on date and place of calibration only.

The measurement capability of the laboratory and its traceability to recognized national standards and to the unit of measurement realized at the corresponding national standards laboratory. This certificate may not be reproduced other than in full except with the prior written approval of the DQE Services Co., Ltd.

เอกสารไม่ควบคุม

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

REPORT OF CALIBRATION

Certificate No. : SP26-013

Environment Condition : Ambient Temperature 25 ± 5 °C

Relative humidity 55 ± 20 %RH

Calibration method : In-house method CP-01 Based on ASTM E275-08

Certified Reference Materials :

Material	Serial No.	Certificate No.	Due date
Absobance Standard set	25760	136858	5 November 2027
Absobance Standard set	25757	136848	5 November 2027
Wavelength Standard set	25806	136824	5 November 2027
Wavelength Standard set	25758	136827	5 November 2027

Traceability : This certification is traceable to the International System of Unit maintained at National - Institute of Standards and Technology (NIST) through Starna Scientific Limited

Spectral Band Width of UUC : 1.5 nm.

Scan Speed of UUC : 60 nm/min

Scan Interval of UUC : 0.15 nm.

Resolution of UUC : Photometric 0.000 Abs.

Wavelength 0.1 nm.

เอกสารไม่ควบคุม

FM-708-02 R01 1/11/2021

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

REPORT OF CALIBRATION

Certificate No. : SP26-013

Calibration Results : Without adjustment

Photometric Accuracy :

Wavelength (nm.)	CRMs Values (Abs)	UUC Reading (Abs)	Correction (Abs)	Uncertainty (Abs)	Coverage factor k
420	0.0000	0.0001	-0.0001	0.0028	2.00
	0.5772	0.5731	0.0041	0.0031	2.00
	1.0478	1.0427	0.0051	0.0029	2.00
	2.1879	2.1782	0.0097	0.0075	2.00
440	0.0000	0.0000	0.0000	0.0028	2.00
	0.5581	0.5574	0.0007	0.0034	2.00
	1.0224	1.0210	0.0014	0.0035	2.00
	2.1227	2.1159	0.0068	0.0083	2.00
465	0.0000	0.0000	0.0000	0.0028	2.00
	0.5225	0.5184	0.0041	0.0029	2.00
	0.9628	0.9603	0.0025	0.0028	2.00
	1.9744	1.9698	0.0046	0.0073	2.00
546.1	0.0000	0.0000	0.0000	0.0028	2.00
	0.5174	0.5150	0.0024	0.0031	2.00
	0.9990	0.9964	0.0026	0.0033	2.00
	1.9953	1.9884	0.0069	0.0085	2.00
590	0.0000	0.0000	0.0000	0.0028	2.00
	0.5508	0.5491	0.0017	0.0030	2.00
	1.0801	1.0781	0.0020	0.0029	2.00
	2.0356	2.0274	0.0082	0.0078	2.00
635	0.0000	0.0000	0.0000	0.0028	2.00
	0.5579	0.5570	0.0009	0.0031	2.00
	1.0512	1.0491	0.0021	0.0029	2.00
	1.9257	1.9201	0.0056	0.0079	2.00

เอกสารไม่ควบคุม

FM-708-02 R01 1/11/2021

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

REPORT OF CALIBRATION

Certificate No. : SP26-013

Photometric Accuracy :

Wavelength (nm.)	CRMs Values (Abs)	UUC Reading (Abs)	Correction (Abs)	Uncertainty (Abs)	Coverage factor k
235	0.0000	0.0000	0.0000	0.0050	2.00
	0.7455	0.7457	-0.0002	0.0056	2.00
257	0.0000	0.0000	0.0000	0.0050	2.00
	0.8656	0.8669	-0.0013	0.0059	2.00
313	0.0000	0.0000	0.0000	0.0050	2.00
	0.2910	0.2907	0.0003	0.0051	2.00
350	0.0000	0.0000	0.0000	0.0050	2.00
	0.6414	0.6414	0.0000	0.0055	2.00

เอกสารไม่ควบคุม

FM-708-02 R01 1/11/2021

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

REPORT OF CALIBRATION

Certificate No. : SP26-013

Wavelength Accuracy :

CRMs Values (nm.)	UUC Reading (nm.)	Correction (nm.)	Uncertainty (nm.)	Coverage factor k
241.70	241.6	0.10	0.18	2.00
279.44	279.2	0.24	0.18	2.00
287.71	287.6	0.11	0.18	2.00
334.02	333.5	0.52	0.18	2.00
360.89	360.2	0.69	0.18	2.00
418.53	417.8	0.73	0.18	2.00
445.82	445.2	0.62	0.18	2.00
453.67	453.0	0.67	0.18	2.00
459.99	459.6	0.39	0.18	2.00
536.52	536.4	0.12	0.18	2.00
638.00	638.2	-0.20	0.18	2.00
431.22	430.5	0.72	0.18	2.00
472.66	472.2	0.46	0.18	2.00
513.39	513.3	0.09	0.18	2.00
528.90	528.7	0.20	0.18	2.00
572.99	573.6	-0.61	0.18	2.00
585.19	585.7	-0.51	0.20	2.00
684.50	684.5	0.00	0.18	2.00
741.02	741.2	-0.18	0.20	2.00
748.56	749.0	-0.44	0.18	2.00
807.02	806.8	0.22	0.18	2.00
879.41	879.4	0.01	0.18	2.00

Remark : - UUC = Unit Under Calibration
- N/A = Not Avaiable
- The result expanded uncertainty of measurement U is stated as the standard uncertainty of measurement multiplied by the coverage factor *k*, which for a normal distribution corresponds to a coverage probability of approximately 95%
- * Indicates non TISI accredited

- End of Certificate -

เอกสารไม่ควบคุม

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

REPORT OF CALIBRATION

Certificate No. : SP26-012

Environment Condition : Ambient Temperature 25 ± 5 °C

Relative humidity 55 ± 20 %RH

Calibration method : In-house method CP-01 Based on ASTM E275-08

Certified Reference Materials :

Material	Serial No.	Certificate No.	Due date
Absobance Standard set	25760	136858	5 November 2027
Absobance Standard set	25757	136848	5 November 2027
Wavelength Standard set	25806	136824	5 November 2027
Wavelength Standard set	25758	136827	5 November 2027

Traceability : This certification is traceable to the International System of Unit maintained at National - Institute of Standards and Technology (NIST) through Starna Scientific Limited

Spectral Band Width of UUC : 1.5 nm.

Scan Speed of UUC : 200 nm/min

Scan Interval of UUC : 0.1 nm.

Resolution of UUC : Photometric 0.001 Abs.

Wavelength 0.1 nm.

เอกสารไม่ควบคุม

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

CERTIFICATE OF CALIBRATION

Certificate No. : SP26-012

Customer : United Analyst and Engineering Consultant Co.,Ltd. (Head Office)

Address : 3 Soi Udomsuk 41, Sukhumvit Road, Bangchak, Phrakhanong, Bangkok 10260

Location of calibration : Instrument room (207)

Equipment : UV-Vis Spectrophotometer

Manufacturer : HITACHI

Model : U-2900

Serial No. : 21E22-009

ID No. : UAE.WAT.051/2564

Received Date : 18 May 2026

Calibration Date : 18 May 2026

Issue Date : 21 May 2026

Condition Instrument : Good

Calibrated by : (Mr.Pacit Mathavorn)
Calibration Engineer

Approved by : (Ms.Chonticha Sangngern)
Quality Manager

The calibration result is applied only to the above calibrated item and was found accurate as shown on date and place of calibration only.

The measurement capability of the laboratory and its traceability to recognized national standards and to the unit of measurement realized at the corresponding national standards laboratory. This certificate may not be reproduced other than in full except with the prior written approval of the DQE Services Co., Ltd.

เอกสารไม่ควบคุม

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

REPORT OF CALIBRATION

Certificate No. : SP26-012

Calibration Results : Without adjustment

Photometric Accuracy :

Wavelength (nm.)	CRMs Values (Abs)	UUC Reading (Abs)	Correction (Abs)	Uncertainty (Abs)	Coverage factor k
420	0.0000	0.000	0.0000	0.0028	2.00
	0.5772	0.575	0.0022	0.0031	2.00
	1.0478	1.043	0.0048	0.0029	2.00
	2.1879	2.197	-0.0091	0.0075	2.00
440	0.0000	0.000	0.0000	0.0028	2.00
	0.5581	0.558	0.0001	0.0034	2.00
	1.0224	1.022	0.0004	0.0035	2.00
	2.1227	2.131	-0.0083	0.0079	2.00
465	0.0000	0.000	0.0000	0.0028	2.00
	0.5225	0.518	0.0045	0.0029	2.00
	0.9628	0.961	0.0018	0.0028	2.00
	1.9744	1.981	-0.0066	0.0070	2.00
546.1	0.0000	0.000	0.0000	0.0028	2.00
	0.5174	0.515	0.0024	0.0031	2.00
	0.9990	0.997	0.0020	0.0033	2.00
	1.9953	1.995	0.0003	0.0084	2.00
590	0.0000	0.000	0.0000	0.0028	2.00
	0.5508	0.549	0.0018	0.0030	2.00
	1.0801	1.079	0.0011	0.0029	2.00
	2.0356	2.036	-0.0004	0.0079	2.00
635	0.0000	0.000	0.0000	0.0028	2.00
	0.5579	0.558	-0.0001	0.0031	2.00
	1.0512	1.050	0.0012	0.0029	2.00
	1.9257	1.928	-0.0023	0.0079	2.00

เอกสารไม่ควบคุม

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

REPORT OF CALIBRATION

Certificate No. : SP26-012

Photometric Accuracy :

Wavelength (nm.)	CRMs Values (Abs)	UUC Reading (Abs)	Correction (Abs)	Uncertainty (Abs)	Coverage factor k
235	0.0000	0.000	0.0000	0.0050	2.00
	0.7455	0.742	0.0035	0.0056	2.00
257	0.0000	0.000	0.0000	0.0050	2.00
	0.8656	0.860	0.0056	0.0059	2.00
313	0.0000	0.000	0.0000	0.0050	2.00
	0.2910	0.288	0.0030	0.0051	2.00
350	0.0000	0.000	0.0000	0.0050	2.00
	0.6414	0.635	0.0064	0.0055	2.00

เอกสารไม่ควบคุม

DQE Services Co.,Ltd.
32 Soi Ladprao-Wanghin 55, Ladprao-Wanghin Rd., Ladprao, Ladprao, Bangkok 10230
Phone : +66 (0)2 538 2054, Email : dqeservicesinfo@gmail.com

REPORT OF CALIBRATION

Certificate No. : SP26-012

Wavelength Accuracy :

CRMs Values (nm.)	UUC Reading (nm.)	Correction (nm.)	Uncertainty (nm.)	Coverage factor k
241.72	241.3	0.42	0.18	2.00
279.45	279.0	0.45	0.18	2.00
287.81	287.4	0.41	0.18	2.00
334.06	333.8	0.26	0.18	2.00
360.93	360.5	0.43	0.18	2.00
418.59	418.0	0.59	0.18	2.00
445.94	445.5	0.44	0.18	2.00
453.66	453.5	0.16	0.18	2.00
460.02	459.5	0.52	0.18	2.00
536.59	536.5	0.09	0.18	2.00
637.98	638.0	-0.02	0.18	2.00
431.38	431.0	0.38	0.18	2.00
472.50	472.5	0.00	0.18	2.00
513.47	513.3	0.17	0.18	2.00
528.88	528.5	0.38	0.18	2.00
573.17	573.0	0.17	0.18	2.00
585.35	585.0	0.35	0.20	2.00
684.40	684.0	0.40	0.18	2.00
740.72	740.5	0.22	0.20	2.00
748.55	748.5	0.05	0.18	2.00
807.03	807.0	0.03	0.18	2.00
879.28	879.3	-0.02	0.18	2.00

Remark : - UUC = Unit Under Calibration

- N/A = Not Available
- The result expanded uncertainty of measurement U is stated as the standard uncertainty of measurement multiplied by the coverage factor k , which for a normal distribution corresponds to a coverage probability of approximately 95%
- * Indicates non TISI accredited

- End of Certificate -

เอกสารไม่ควบคุม

MICROCAL COMPANY LIMITED
214 Bangwaek Rd., Bangphai, Bangkae Bangkok 10160
Tel.: 0-2865-4647-8 Fax: 0-2865-4649
http://www.microcal.in.th

CALIBRATION CERTIFICATE

Certificate No. : L202511079-0001
Date Issued : 19-Nov-25

Customer : TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mittraphab Road, T.Tubkwang, A.Kangkhoy, Saraburi 18260

Equipment	: Heat Stress Meter
Manufacturer	: Casella
Model	: HSM-100
Serial No.	: 27715
ID No./Tag No.	: -
Date Received	: 13-Nov-25
Date Calibrated	: 17-Nov-25
Calibrated by	: Apiwat Peanrungroth

Calibration Method or Calibration Procedure Used

In-house method : CP-19 by comparing against Standard Digital Humidity / Temperature Meter

This certificate is traceable to national standards, which realize the units of measurement according to the International System of Units (SI).

Result of Calibration

The reported uncertainty of measurement was based on standard uncertainty multiplied by a coverage factor k = 2, providing a level confidence approximately 95 percent.

This certificate may not be reproduced other than in full except with the prior written approval of the Miracle International Technology Company Limited.

Approved by: K. Nathapong
(Nathapong Krudaum)

Certificate No. : L202511079-0001

Environment : Ambient Temperature : (25 ± 2) °C
Relative Humidity : (50 ± 15)%RH

STD Reading (°C)	UUC Reading (°C) Before Adjusted	After Adjusted	UUC Error (°C)	Measurement Uncertainty (±°C)
20.00	WET 20.0	-	0.00	0.40
20.00	DRY 20.0	-	0.00	0.47
20.00	GLOBE 19.9	-	-0.10	0.35
29.99	WET 30.2	-	0.21	0.40
29.99	DRY 29.7	-	-0.29	0.47
29.99	GLOBE 29.9	-	-0.09	0.35
39.99	WET 40.2	-	0.21	0.40
39.99	DRY 40.4	-	0.41	0.47
39.99	GLOBE 40.3	-	0.31	0.35
50.00	WET 50.4	-	0.40	0.40
50.00	DRY 50.4	-	0.40	0.47
50.00	GLOBE 49.8	-	-0.20	0.35

Description of UUC : Range (-5) to 60 °C
Resolution 0.1 °C

Condition As-Received : New Item

The measurement results and statements of conformity with specification only relate to the item calibrated.

Measurement Standards Used & Traceability :

The International System of Units (SI) through

MIT Certificate No. L202509441-0003 for Digital Thermometer with Probe (Fluke) Serial No. 5856603, Due 25-Oct-26

End of Certificate

MICROCAL COMPANY LIMITED
214 Bangwaek Rd., Bangphai, Bangkae Bangkok 10160
Tel.: 0-2865-4647-8 Fax: 0-2865-4649
http://www.microcal.in.th

CALIBRATION CERTIFICATE

Certificate No. : L202603143-0001
Date Issued : 17-Mar-26

Customer : TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mittraphab Road, T.Tubkwang, A.Kangkhoy, Saraburi 18260

Equipment	: Heat Stress Meter
Manufacturer	: Wibget
Model	: RSS-214DL
Serial No.	: 08-DL 5051
ID No./Tag No.	: -
Date Received	: 12-Mar-26
Date Calibrated	: 13-Mar-26
Calibrated by	: Apiwat Peanrungroth

Calibration Method or Calibration Procedure Used

In-house method : CP-19 by comparing against Standard Digital Humidity / Temperature Meter

This certificate is traceable to national standards, which realize the units of measurement according to the International System of Units (SI).

Result of Calibration

The reported uncertainty of measurement was based on standard uncertainty multiplied by a coverage factor k = 2, providing a level confidence approximately 95 percent.

This certificate may not be reproduced other than in full except with the prior written approval of the Microcal Company Limited.

Approved by: K. Nathapong
(Nathapong Krudaum)

Certificate No. : L202603143-0001

Environment : Ambient Temperature : (25 ± 2) °C
Relative Humidity : (50 ± 15)%RH

STD Reading (°C)	UUC Reading (°C) Before Adjusted	After Adjusted	UUC Error (°C)	Measurement Uncertainty (±°C)
20.00	WET 19.9	-	-0.10	0.35
20.00	DRY 19.9	-	-0.10	0.35
20.00	GLOBE 20.0	-	0.00	0.35
29.98	WET 29.9	-	-0.08	0.35
29.98	DRY 30.0	-	0.02	0.35
29.98	GLOBE 30.0	-	0.02	0.35
40.00	WET 39.9	-	-0.10	0.35
40.00	DRY 39.9	-	-0.10	0.35
40.00	GLOBE 39.9	-	-0.10	0.35
50.00	WET 49.9	-	-0.10	0.35
50.00	DRY 49.9	-	-0.10	0.35
50.00	GLOBE 49.9	-	-0.10	0.35

Description of UUC : Range 0 to 65 °C
Resolution 0.1 °C

Condition As-Received : New Item

The measurement results and statements of conformity with specification only relate to the item calibrated.

Measurement Standards Used & Traceability :

The International System of Units (SI) through

MIT Certificate No. L202509441-0003 for Digital Thermometer with Probe (Fluke) Serial No. 5856603, Due 25-Oct-26

End of Certificate

MICROCAL COMPANY LIMITED
214 Bangwaek Rd., Bangphai, Bangkae Bangkok 10160
Tel.: 0-2865-4647-8 Fax: 0-2865-4649
http://www.microcal.in.th

CALIBRATION CERTIFICATE

Certificate No. : L202603143-0002
Date Issued : 17-Mar-26

Customer : TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mittraphab Road, T.Tubkwang, A.Kangkhoy, Saraburi 18260

Equipment	: Heat Stress Meter
Manufacturer	: Quest Technologies
Model	: QUESTemp 34
Serial No.	: TEL010037
ID No./Tag No.	: -
Date Received	: 12-Mar-26
Date Calibrated	: 13-Mar-26
Calibrated by	: Apiwat Peanrungroth

Calibration Method or Calibration Procedure Used

In-house method : CP-19 by comparing against Standard Digital Humidity / Temperature Meter

This certificate is traceable to national standards, which realize the units of measurement according to the International System of Units (SI).

Result of Calibration

The reported uncertainty of measurement was based on standard uncertainty multiplied by a coverage factor k = 2, providing a level confidence approximately 95 percent.

This certificate may not be reproduced other than in full except with the prior written approval of the Microcal Company Limited.

Approved by: K. Nathapong
(Nathapong Krudaum)

Certificate No. : L202603143-0002

Environment : Ambient Temperature : (25 ± 2) °C
Relative Humidity : (50 ± 15)%RH

STD Reading (°C)		UUC Reading (°C) Before Adjusted	After Adjusted	UUC Error (°C)	Measurement Uncertainty (±°C)
20.00	WET	20.0	-	0.00	0.35
20.00	DRY	20.0	-	0.00	0.35
20.00	GLOBE	20.0	-	0.00	0.35
29.98	WET	30.1	-	0.12	0.35
29.98	DRY	30.0	-	0.02	0.35
29.98	GLOBE	30.0	-	0.02	0.35
40.00	WET	40.0	-	0.00	0.35
40.00	DRY	39.9	-	-0.10	0.35
40.00	GLOBE	39.9	-	-0.10	0.35
50.00	WET	50.0	-	0.00	0.35
50.00	DRY	49.9	-	-0.10	0.35
50.00	GLOBE	50.0	-	0.00	0.35

Description of UUC : Range 0 to 65 °C
Resolution 0.1 °C

Condition As-Received : New Item

The measurment results and statements of conformity with specification only relate to the item calibrated.

Measurement Standards Used & Traceability :

The International System of Units (SI) through

MIT Certificate No. L202509441-0003 for Digital Thermometer with Probe (Fluke) Serial No. 5856603, Due 25-Oct-26

Certificate No. : L202603143-0002

Environment : Ambient Temperature : (25 ± 2) °C
Relative Humidity : (50 ± 15)%RH

Function : Humidity Measurement Temperature Control : (25 ± 5)°C

STD Reading (%RH)	UUC Reading (%RH)	UUC Error (%RH)	Measurement Uncertainty (±%RH)
11.30	18.00	6.70	1.8
29.97	36.00	6.03	1.8
49.98	55.00	5.02	1.8
70.01	74.00	3.99	2.1
89.99	95.00	5.01	2.1

STD = Standard

UUC = Unit Under Calibration

Description of UUC : Range 0 to 100 %RH
Resolution 0.01 %RH

Condition As-Received : Used Item

The measurment results and statements of conformity with specification only relate to the item calibrated.

Measurement Standards Used & Traceability :

The International System of Units (SI) through

MIT Certificate No. L202601118-0010 for Digital Humidity Meter Serial No. F4260117, Due 19-Jan-27

End of Certificate

MICROCAL COMPANY LIMITED
214 Bangwaek Rd., Bangphai, Bangkae Bangkok 10160
Tel.: 0-2865-4647-8 Fax: 0-2865-4649
http://www.microcal.in.th

CALIBRATION CERTIFICATE

Certificate No. : L202511079-0002
Date Issued : 19-Nov-25

Customer : TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mittraphab Road, T.Tubkwang, A.Kangkhoy, Saraburi 18260

Equipment	: Heat Stress Meter
Manufacturer	: QUEST Technology
Model	: QUES TEMP 34
Serial No.	: TEM120023
ID No./Tag No.	: -
Date Received	: 13-Nov-25
Date Calibrated	: 17-Nov-25
Calibrated by	: Apiwat Peanrungroth

Calibration Method or Calibration Procedure Used

In-house method : CP-19 by comparing against Standard Digital Humidity / Temperature Meter

This certificate is traceable to national standards, which realize the units of measurement according to the International System of Units (SI).

Result of Calibration

The reported uncertainty of measurement was based on standard uncertainty multiplied by a coverage factor k = 2, providing a level confidence approximately 95 percent.

This certificate may not be reproduced other than in full except with the prior written approval of the Miracle International Technology Company Limited.

Approved by: K. Nathapong
(Nathapong Krudaum)

Certificate No. : L202511079-0002

Environment : Ambient Temperature : (25 ± 2) °C
Relative Humidity : (50 ± 15)%RH

STD Reading (°C)		UUC Reading (°C) Before Adjusted	After Adjusted	UUC Error (°C)	Measurement Uncertainty (±°C)
20.00	WET	19.9	-	-0.10	0.48
20.00	DRY	19.9	-	-0.10	0.48
20.00	GLOBE	19.9	-	-0.10	0.48
29.99	WET	30.2	-	0.21	0.48
29.99	DRY	30.2	-	0.21	0.48
29.99	GLOBE	30.2	-	0.21	0.48
39.99	WET	39.8	-	-0.19	0.48
39.99	DRY	39.9	-	-0.09	0.48
39.99	GLOBE	39.8	-	-0.19	0.48
50.00	WET	50.2	-	0.20	0.48
50.00	DRY	50.0	-	0.00	0.48
50.00	GLOBE	50.2	-	0.20	0.48

Description of UUC : Range (-5) to 60 °C
Resolution 0.1 °C

Condition As-Received : New Item

The measurment results and statements of conformity with specification only relate to the item calibrated.

Measurement Standards Used & Traceability :

The International System of Units (SI) through

MIT Certificate No. L202509441-0003 for Digital Thermometer with Probe (Fluke) Serial No. 5856603, Due 25-Oct-26

MICROCAL COMPANY LIMITED
214 Bangwaek Rd., Bangphai, Bangkae Bangkok 10160
Tel.: 0-2865-4647-8 Fax: 0-2865-4649
http://www.microcal.in.th

CALIBRATION CERTIFICATE

Certificate No. : L202511079-0003
Date Issued : 19-Nov-25

Customer : TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mittraphab Road, T.Tubkwang, A.Kangkhoy, Saraburi 18260

Equipment : Heat Stress Meter
Manufacturer : QUEST Technology
Model : QUES TEMP 34
Serial No. : TEP110006
ID No./Tag No. : -
Date Received : 13-Nov-25
Date Calibrated : 17-Nov-25
Calibrated by : Apiwat Peanrungroth

Calibration Method or Calibration Procedure Used

In-house method : CP-19 by comparing against Standard Digital Humidity / Temperature Meter

This certificate is traceable to national standards, which realize the units of measurement according to the International System of Units (SI).

Result of Calibration

The reported uncertainty of measurement was based on standard uncertainty multiplied by a coverage factor k = 2, providing a level confidence approximately 95 percent.

This certificate may not be reproduced other than in full except with the prior written approval of the Miracle International Technology Company Limited.

Approved by: K. Nathapong
(Nathapong Krudaum)

Certificate No. : L202511079-0002

Environment : Ambient Temperature : (25 ± 2) °C
Relative Humidity : (50 ± 15)%RH

Function : Humidity Measurement Temperature Control : (25 ± 5)°C

STD Reading (%RH)	UUC Reading (%RH)	UUC Error (%RH)	Measurement Uncertainty (±%RH)
20.00	24	4.00	1.9
30.00	34	4.00	1.9
49.99	54	4.01	1.9
69.99	74	4.01	2.2
89.98	94	4.02	2.2

STD = Standard

UUC = Unit Under Calibration

Description of UUC : Range 20 to 95 %RH
Resolution 1 %RH

Condition As-Received : Used Item

The measurment results and statements of conformity with specification only relate to the item calibrated.

Measurement Standards Used & Traceability :

The International System of Units (SI) through

MIT Certificate No. L202412300-0025 for Digital Humidity Meter Serial No. F4260117, Due 06-Feb-26

End of Certificate

Certificate No. : L202511079-0003

Environment : Ambient Temperature : (25 ± 2) °C
Relative Humidity : (50 ± 15)%RH

STD Reading (°C)		UUC Reading (°C) Before Adjusted	After Adjusted	UUC Error (°C)	Measurement Uncertainty (±°C)
20.00	WET	20.0	-	0.00	0.35
20.00	DRY	20.0	-	0.00	0.35
20.00	GLOBE	20.0	-	0.00	0.35
29.99	WET	30.1	-	0.11	0.35
29.99	DRY	29.9	-	-0.09	0.35
29.99	GLOBE	30.1	-	0.11	0.35
39.99	WET	39.7	-	-0.29	0.35
39.99	DRY	39.8	-	-0.19	0.35
39.99	GLOBE	40.0	-	0.01	0.35
50.00	WET	49.8	-	-0.20	0.35
50.00	DRY	49.7	-	-0.30	0.35
50.00	GLOBE	49.6	-	-0.40	0.35

Marked * are not included in the NSC-ONSC accreditation schedule for our laboratory.

Description of UUC : Range (-5) to 60 °C
Resolution 0.1 °C

Condition As-Received : New Item

The measurment results and statements of conformity with specification only relate to the item calibrated.

Measurement Standards Used & Traceability :

The International System of Units (SI) through

MIT Certificate No. L202509441-0003 for Digital Thermometer with Probe (Fluke) Serial No. 5856603, Due 25-Oct-26

Certificate No. : L202511079-0003

Environment : Ambient Temperature : (25 ± 2) °C
Relative Humidity : (50 ± 15)%RH

Function : Humidity Measurement Temperature Control : (25 ± 5)°C

STD Reading (%RH)	UUC Reading (%RH)	UUC Error (%RH)	Measurement Uncertainty (±%RH)
20.00	25	5.00	1.9
30.00	35	5.00	1.9
49.99	54	4.01	1.9
69.99	74	4.01	2.2
89.98	94	4.02	2.2

STD = Standard

UUC = Unit Under Calibration

Description of UUC : Range 20 to 95 %RH
Resolution 1 %RH

Condition As-Received : Used Item

The measurement results and statements of conformity with specification only relate to the item calibrated.

Measurement Standards Used & Traceability :

The International System of Units (SI) through

MIT Certificate No. L2024123000-0025 for Digital Humidity Meter Serial No. F4260117, Due 06-Feb-26

End of Certificate

8. Power Amplifier Brüel&Kjær 2706 S/N 1517650.
9. Speaker Tannoy Limited, Great Britain British Patent No. 215300.
10. Digital Multimeter Agilent 34401A S/N MY44005560.
11. Programmable Attenuator Tamagawa TPA-303A S/N 2212.

Calibration Procedure :

This instrument was calibrated by using calibration procedures no CP-102-02 and CP-102-03, which were based on IEC 61672-3 Electroacoustics - Sound Level Meters - Part 3 : Periodic tests (2013). These calibration procedures were related to the electrical and acoustic signal tests. The electrical signal test was carried out with the direct measurement method. The acoustic signal test was performed in an anechoic room with the comparison measurement method.

This instrument has been calibrated against standards maintained at the Electrical and Electronic Standards Laboratory (EEL), which are traceable to the International System of Units through the National Institute of Metrology (Thailand).

The information on actual reading is attached herewith and the uncertainty limits quoted refer to the measured values only.

The reported expanded uncertainty is based upon a standard uncertainty multiplied by a coverage factor k=2, providing a level of confidence of approximately 95%.

Date of Calibration : 28 Apr. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9460
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

NSC-TISI-TIS 17025 CALIBRATION 0037

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0320 **MTC No.** EEL. BP. 59/0469

CALIBRATION CERTIFICATE

Submitted by : TPI POLENE PUBLIC CO., LTD.

Address : 299 Moo 5, Mittraphab Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260.

Calibrated at : Electrical and Electronic Standards Laboratory, Industrial Metrology and Testing Service Centre.
Soi 1C, Bangpoo Industrial Estate, Sukhumvit Rd., A.Muang, Samutprakan 10280.

Instrument Calibrated :

Description : Sound Level Meter
Manufacturer : Rion
Model : NL-22
Serial No. : 01252583
Microphone : UC-52 No.106158
Preamplifier : NH-21 No.18050

Ambient Environment

Temperature : (23 ± 3) °C
Relative Humidity : (50 ± 15) %
Ambient Pressure : (101.325±1.5) kPa

Standards used :

1. Band Pass Filter Stanford Research Systems SR 650 S/N 28712.
2. Condenser Microphone Brüel&Kjær 4180 S/N 2889871.
3. Decade Attenuator Ando AL-205 S/N 00464602.
4. Function/Arbitrary Waveform Generator Agilent 33220A S/N MY44042668.
5. Digital Function Synthesizer NF Electronic Instruments DF-193A S/N 122037.
6. Sound Calibrator Bruel&Kjaer 4231 S/N 3015154
7. Measuring Amplifier Brüel&Kjær 2636 S/N 1537484.

Date of Receipt : 22 Apr. 2026

Date of Calibration : 28 Apr. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

FM.BL.MTC.002 Rev.5

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9460
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

NSC-TISI-TIS 17025 CALIBRATION 0037

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0320 **MTC No.** EEL. BP. 59/0469

1. Absolute Sensitivity

Reference Acoustic Signal (dB)	Measured value (dB)		Deviation value (dB)	Acceptance limit Class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
	Before adjust	After adjust				
113.97	114.5	114.0	0.0	1.0	0.48	N/A

Note: The external calibration adjustment was firstly performed. The internal calibration adjustment was then completed at the display of 115.1 dB.

2. Self-generated noise

2.1 Normal test

Measured value (dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
19.9	0.10	N/A

2.2 The microphone of the sound level meter was replaced by electrical signal input device

Frequency Weighting	Measured value (dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
A-Weight	17.2	0.10	N/A
C-Weight	22.6	0.10	N/A
Flat	28.5	0.10	N/A

Date of Calibration : 28 Apr. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

FM.BL.MTC.002 Rev.5

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9460
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0320 **MTC No.** EEL. BP. 59/0469

3. Acoustical signal test of frequency weightings

Frequency	Deviation from frequency response (dB)			Acceptance limit	Uncertainty	Maximum-permitted uncertainty
(Hz)	A-weight	C-weight	Flat	class 2 (±dB)	(±dB)	of measurement (±dB)
125	0.6	0.8	0.7	1.5	0.45	0.6
1 000	0.1	0.1	0.1	1.0	0.45	0.6
8 000	-0.7	-0.8	-1.0	5.0	0.45	0.7

4. Electrical signal test of frequency weightings

Frequency	Deviation from frequency response (dB)			Acceptance limit	Uncertainty	Maximum-permitted uncertainty
(Hz)	A-weight	C-weight	Flat	class 2 (±dB)	(±dB)	of measurement (±dB)
63	-0.2	0.0	-0.1	2.0	0.20	0.6
125	-0.2	0.0	0.0	1.5	0.20	0.6
250	-0.2	-0.1	0.0	1.5	0.20	0.6
500	-0.1	0.0	0.0	1.5	0.20	0.6
1 000	0.0	0.0	0.0	1.0	0.20	0.6
2 000	0.1	0.0	0.0	2.0	0.20	0.6
4 000	0.1	0.1	0.1	3.0	0.20	0.6
8 000	0.1	0.0	0.0	5.0	0.20	0.7

Date of Calibration : 28 Apr. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0320 **MTC No.** EEL. BP. 59/0469

7. Level linearity on the reference level range

Anticipated	Measured Value	Deviated value	Acceptance limit	Uncertainty	Maximum-permitted uncertainty
value (dB)	(dB)	(dB)	class 2 (±dB)	(±dB)	of measurement (±dB)
125	125.0	0.0	1.1	0.30	0.3
124	124.0	0.0	1.1	0.30	0.3
123	123.0	0.0	1.1	0.30	0.3
122	122.0	0.0	1.1	0.30	0.3
121	121.0	0.0	1.1	0.30	0.3
120	120.0	0.0	1.1	0.30	0.3
119	119.0	0.0	1.1	0.30	0.3
114	114.0	0.0	1.1	0.30	0.3
109	109.0	0.0	1.1	0.30	0.3
104	104.0	0.0	1.1	0.30	0.3
99	99.0	0.0	1.1	0.30	0.3
94	94.0	0.0	1.1	0.30	0.3
89	89.1	0.1	1.1	0.30	0.3
84	84.1	0.1	1.1	0.30	0.3
79	79.0	0.0	1.1	0.30	0.3
74	74.0	0.0	1.1	0.30	0.3
69	69.1	0.1	1.1	0.30	0.3
64	64.1	0.1	1.1	0.30	0.3
59	59.0	0.0	1.1	0.30	0.3
54	54.0	0.0	1.1	0.30	0.3
49	49.0	0.0	1.1	0.30	0.3
44	44.0	0.0	1.1	0.30	0.3

Date of Calibration : 28 Apr. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0320 **MTC No.** EEL. BP. 59/0469

5. Long-term stability

Time	Measured Value	Deviated value	Acceptance limit	Uncertainty	Maximum-permitted uncertainty
	(dB)	(dB)	class 2 (±dB)	(±dB)	of measurement (±dB)
Begin	94.0	0.0	0.3	0.10	0.1
End	94.0				

6. Frequency and time weightings at 1 kHz

6.1 Frequency weightings at 1 kHz

Frequency	Measured Value	Deviated value	Acceptance limit	Uncertainty	Maximum-permitted uncertainty
Weighting	(dB)	(dB)	class 2 (±dB)	(±dB)	of measurement (±dB)
A-weight	94.0	0.0	0.2	0.20	0.2
C-weight	94.0	0.0	0.2	0.20	0.2
Flat	94.0	0.0	0.2	0.20	0.2

6.2 Time weightings at 1 kHz

Frequency	Measured Value	Deviated value	Acceptance limit	Uncertainty	Maximum-permitted uncertainty
Weighting	(dB)	(dB)	class 2 (±dB)	(±dB)	of measurement (±dB)
Fast	94.0	0.0	0.1	0.20	0.2
Slow	94.0	0.0	0.1	0.20	0.2
Leq	94.0	0.0	0.1	0.20	0.2

Date of Calibration : 28 Apr. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0320 **MTC No.** EEL. BP. 59/0469

7. Level linearity on the reference level range

Anticipated	Measured Value	Deviated value	Acceptance limit	Uncertainty	Maximum-permitted uncertainty
value (dB)	(dB)	(dB)	class 2 (±dB)	(±dB)	of measurement (±dB)
39	39.0	0.0	1.1	0.30	0.3
34	34.1	0.1	1.1	0.30	0.3
33	33.1	0.1	1.1	0.30	0.3
32	32.1	0.1	1.1	0.30	0.3
31	31.1	0.1	1.1	0.30	0.3
30	30.1	0.1	1.1	0.30	0.3
29	29.2	0.2	1.1	0.30	0.3
28	28.2	0.2	1.1	0.30	0.3

8. Level linearlity including the level range control

At reference sound level on the reference level range

Range	Anticipated value	Measured value	Deviated	Acceptance limit	Uncertainty	Maximum-permitted uncertainty
	(dB)	(dB)	value (dB)	class 2 (±dB)	(±dB)	of measurement (±dB)
40-130	94.0	94.0	0.0	1.1	0.30	0.3
30-120	94.0	94.0	0.0	1.1	0.30	0.3
20-110	94.0	94.0	0.0	1.1	0.30	0.3
20-100	94.0	94.0	0.0	1.1	0.30	0.3

Date of Calibration : 28 Apr. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0320 **MTC No.** EEL. BP. 59/0469

8. Level linearlity including the level range control

At reference level at 5 dB greater than the under-range on a level range

Range	Anticipated value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
40-130	45.0	44.9	-0.1	1.1	0.30	0.3
30-120	35.0	35.0	0.0	1.1	0.30	0.3
20-110	25.0	25.5	0.5	1.1	0.30	0.3
20-100	25.0	25.6	0.6	1.1	0.30	0.3
20-90	25.0	25.6	0.6	1.1	0.30	0.3
20-80	25.0	25.7	0.7	1.1	0.30	0.3

9. Tone burst response

Time Weighting	Toneburst Duration, Th (ms)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Fast	200	116.0	0.0	±1.0	0.20	0.3
	2	99.0	0.0	+1.0; -2.5	0.20	0.3
	0.25	89.9	-0.1	+1.5; -5.0	0.20	0.3
Slow	200	109.5	-0.1	±1.0	0.20	0.3
	2	89.9	-0.1	+1.0; -5.0	0.20	0.3
SEL	200	110.0	0.0	±1.0	0.20	0.3
	2	90.0	0.0	+1.0; -2.5	0.20	0.3
	0.25	80.9	-0.1	+1.5; -5.0	0.20	0.3

Date of Calibration : 28 Apr. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-68/0510 **MTC No.** EEL. BP. 19/0868

CALIBRATION CERTIFICATE

Submitted by : TPI POLENE PUBLIC CO., LTD.

Address : 299 Moo 5, Mittraphab Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260.

Calibrated at : Electrical and Electronic Standards Laboratory, Industrial Metrology and Testing Service Centre.
Soi 1C, Bangpoo Industrial Estate, Sukhumvit Rd., A.Muang, Samutprakan 10280.

Instrument Calibrated :

Description : Sound Level Meter
Manufacturer : Rion
Model : NL-22
Serial No. : 00614886 ID.Q100/01/240/002
Microphone : UC-52 No.136436
Preamplifier : NH-21 No.35749

Ambient Environment

Temperature : (23 ± 3) °C
Relative Humidity : (50 ± 15) %
Ambient Pressure : (101.325±1.5) kPa

Standards used :

1. Band Pass Filter Stanford Research Systems SR 650 S/N 28712.
2. Condenser Microphone Brüel&Kjær 4180 S/N 2633526.
3. Decade Attenuator Ando AL-205 S/N 00464602.
4. Function/Arbitrary Waveform Generator Agilent 33220A S/N MY44042668.
5. Digital Function Synthesizer NF Electronic Instruments DF-193A S/N 122037.
6. Pistonphone Rion NC-72 S/N 00402446.
7. Measuring Amplifier Brüel&Kjær 2636 S/N 1537484.

Date of Receipt : 13 Aug.2025

Date of Calibration : 2-3 Sep.2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0320 **MTC No.** EEL. BP. 59/0469

10. Peak C sound level

Number of cycles in test signal	Anticipated value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Complete cycle	125.4	125.2	-0.2	3.0	0.20	0.35
Positive half cycle	124.4	124.2	-0.2	2.0	0.20	0.35
Negative half cycle	124.4	124.2	-0.2	2.0	0.20	0.35

11. Overload indication

Measured value (dB)		Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Positive one-half cycle	Negative one-half cycle				
134.8	134.8	0.0	1.5	0.20	0.25

12. High-level stability

Time	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Begin	129.0	0.0	0.3	0.10	0.1
End	129.0				

Calibrated by :

(Mr. Tawikiat Iamsamran)

Approved by :

(Mr. Prawit Kitayporn)
Director
Electrical and Electronic Standards Laboratory
Industrial Metrology and Testing Service Centre

Date of Calibration : 28 Apr. 2026

Date of Issue : 30 Apr. 2026

Ref : 20712690422016640O1

End of Certificate

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-68/0510 **MTC No.** EEL. BP. 19/0868

8. Power Amplifier Brüel&Kjær 2706 S/N 1517650.
9. Speaker Tannoy Limited, Great Britain British Patent No. 215300.
10. Digital Multimeter Agilent 34401A S/N MY44005560.
11. Programmable Attenuator Tamagawa TPA-303A S/N 2212.

Calibration Procedure :

This instrument was calibrated by using calibration procedures no CP-102-02 and CP-102-03, which were based on IEC 61672-3 Electroacoustics - Sound Level Meters - Part 3 : Periodic tests (2013). These calibration procedures were related to the electrical and acoustic signal tests. The electrical signal test was carried out with the direct measurement method. The acoustic signal test was performed in an anechoic room with the comparison measurement method.

This instrument has been calibrated against standards maintained at the Electrical and Electronic Standards Laboratory (EEL), which are traceable to the International System of Units through the National Institute of Metrology (Thailand).

The information on actual reading is attached herewith and the uncertainty limits quoted refer to the measured values only.

The reported expanded uncertainty is based upon a standard uncertainty multiplied by a coverage factor k=2, providing a level of confidence of approximately 95%.

Date of Calibration : 2-3 Sep.2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-68/0510 **MTC No.** EEL. BP. 19/0868

1. Absolute Sensitivity

Reference Acoustic Signal (dB)	Measured value (dB)	Deviation value (dB)	Acceptance limit Class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
113.95	114.0	0.0	1.0	0.30	N/A

Note: No adjustment.

2. Self-generated noise

2.1 Normal test

Measured value (dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
18.1	0.10	N/A

2.2 The microphone of the sound level meter was replaced by electrical signal input device

Frequency Weighting	Measured value (dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
A-Weight	14.5	0.10	N/A
C-Weight	19.6	0.10	N/A
Flat	25.8	0.10	N/A

Date of Calibration : 2-3 Sep.2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

NSC-TISI-TIS 17025
CALIBRATION 0037

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-68/0510 **MTC No.** EEL. BP. 19/0868

5. Long-term stability

Time	Measured Value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Begin	94.0	0.0	0.3	0.10	0.1
End	94.0				

6. Frequency and time weightings at 1 kHz

6.1 Frequency weightings at 1 kHz

Frequency Weighting	Measured Value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
A-weight	94.0	0.0	0.2	0.20	0.2
C-weight	94.0	0.0	0.2	0.20	0.2
Flat	94.0	0.0	0.2	0.20	0.2

6.2 Time weightings at 1 kHz

Frequency Weighting	Measured Value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Fast	94.0	0.0	0.1	0.20	0.2
Slow	94.0	0.0	0.1	0.20	0.2
Leq	94.0	0.0	0.1	0.20	0.2

Date of Calibration : 2-3 Sep.2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

NSC-TISI-TIS 17025
CALIBRATION 0037

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-68/0510 **MTC No.** EEL. BP. 19/0868

3. Acoustical signal test of frequency weightings

Frequency (Hz)	Deviation from frequency response (dB)			Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
	A-weight	C-weight	Flat			
125	0.5	0.7	0.6	1.5	0.45	0.6
1 000	0.1	0.0	0.1	1.0	0.45	0.6
8 000	-1.0	-0.9	-1.1	5.0	0.45	0.7

4. Electrical signal test of frequency weightings

Frequency (Hz)	Deviation from frequency response (dB)			Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
	A-weight	C-weight	Flat			
63	-0.2	0.0	-0.1	2.0	0.20	0.6
125	-0.2	0.0	-0.1	1.5	0.20	0.6
250	-0.1	0.0	0.0	1.5	0.20	0.6
500	-0.1	0.0	0.0	1.5	0.20	0.6
1 000	0.0	0.0	0.0	1.0	0.20	0.6
2 000	0.0	0.0	0.0	2.0	0.20	0.6
4 000	0.1	0.1	0.1	3.0	0.20	0.6
8 000	0.1	0.1	0.0	5.0	0.20	0.7

Date of Calibration : 2-3 Sep.2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

NSC-TISI-TIS 17025
CALIBRATION 0037

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-68/0510 **MTC No.** EEL. BP. 19/0868

7. Level linearity on the reference level range

Anticipated value (dB)	Measured Value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
125	125.0	0.0	1.1	0.30	0.3
124	124.0	0.0	1.1	0.30	0.3
123	123.0	0.0	1.1	0.30	0.3
122	122.0	0.0	1.1	0.30	0.3
121	121.0	0.0	1.1	0.30	0.3
120	120.0	0.0	1.1	0.30	0.3
119	119.0	0.0	1.1	0.30	0.3
114	114.0	0.0	1.1	0.30	0.3
109	109.0	0.0	1.1	0.30	0.3
104	104.0	0.0	1.1	0.30	0.3
99	99.0	0.0	1.1	0.30	0.3
94	94.0	0.0	1.1	0.30	0.3
89	89.1	0.1	1.1	0.30	0.3
84	84.1	0.1	1.1	0.30	0.3
79	79.0	0.0	1.1	0.30	0.3
74	74.0	0.0	1.1	0.30	0.3
69	69.0	0.0	1.1	0.30	0.3
64	64.0	0.0	1.1	0.30	0.3
59	59.0	0.0	1.1	0.30	0.3
54	54.0	0.0	1.1	0.30	0.3
49	49.0	0.0	1.1	0.30	0.3
44	44.0	0.0	1.1	0.30	0.3

Date of Calibration : 2-3 Sep.2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-68/0510 **MTC No.** EEL. BP. 19/0868

7. Level linearity on the reference level range

Anticipated value (dB)	Measured Value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
39	38.9	-0.1	1.1	0.30	0.3
34	34.0	0.0	1.1	0.30	0.3
33	33.0	0.0	1.1	0.30	0.3
32	32.0	0.0	1.1	0.30	0.3
31	31.0	0.0	1.1	0.30	0.3
30	29.9	-0.1	1.1	0.30	0.3
29	28.9	-0.1	1.1	0.30	0.3
28	28.0	0.0	1.1	0.30	0.3

8. Level linearlity including the level range control

At reference sound level on the reference level range

Range	Anticipated value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
40-130	94.0	94.0	0.0	1.1	0.30	0.3
30-120	94.0	94.0	0.0	1.1	0.30	0.3
20-110	94.0	94.0	0.0	1.1	0.30	0.3
20-100	94.0	94.0	0.0	1.1	0.30	0.3

Date of Calibration : 2-3 Sep.2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-68/0510 **MTC No.** EEL. BP. 19/0868

10. Peak C sound level

Number of cycles in test signal	Anticipated value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Complete cycle	125.4	125.1	-0.3	3.0	0.20	0.35
Positive half cycle	124.4	124.1	-0.3	2.0	0.20	0.35
Negative half cycle	124.4	124.1	-0.3	2.0	0.20	0.35

11. Overload indication

Measured value (dB)		Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Positive one-half cycle	Negative one-half cycle				
133.8	133.8	0.0	1.5	0.20	0.25

12. High-level stability

Time	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Begin	129.0	0.0	0.3	0.10	0.1
End	129.0				

Calibrated by :

(Mr. Tawikiat Iamsamran)

Approved by :

(Mr. Enwase Khanpa)
Director
Electrical and Electronic Standards Laboratory
Industrial Metrology and Testing Service Centre

Date of Calibration : 2-3 Sep.2025
Date of Issue : 8 Sep.2025
Ref : 20112680813031410O1

End of Certificate

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-68/0510 **MTC No.** EEL. BP. 19/0868

8. Level linearlity including the level range control

At reference level at 5 dB greater than the under-range on a level range

Range	Anticipated value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
40-130	45.0	44.9	-0.1	1.1	0.30	0.3
30-120	35.0	35.0	0.0	1.1	0.30	0.3
20-110	25.0	25.3	0.3	1.1	0.30	0.3
20-100	25.0	25.4	0.4	1.1	0.30	0.3
20-90	25.0	25.4	0.4	1.1	0.30	0.3
20-80	25.0	25.4	0.4	1.1	0.30	0.3

9. Tone burst response

Time Weighting	Toneburst Duration, Tb (ms)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Fast	200	116.0	0.0	±1.0	0.20	0.3
	2	98.9	-0.1	+1.0; -2.5	0.20	0.3
	0.25	89.8	-0.2	+1.5; -5.0	0.20	0.3
Slow	200	109.5	-0.1	±1.0	0.20	0.3
	2	89.9	-0.1	+1.0; -5.0	0.20	0.3
SEL	200	110.0	0.0	±1.0	0.20	0.3
	2	90.0	0.0	+1.0; -2.5	0.20	0.3
	0.25	80.8	-0.2	+1.5; -5.0	0.20	0.3

Date of Calibration : 2-3 Sep.2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

FM.BL.MTC.002 Rev.5

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-68/0510 **MTC No.** EEL. BP. 20/0868

CALIBRATION CERTIFICATE

Submitted by : TPI POLENE PUBLIC CO., LTD.
Address : 299 Moo 5, Mittraphab Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260.
Calibrated at : Electrical and Electronic Standards Laboratory, Industrial Metrology and Testing Service Centre.
Soi 1C, Bangpoo Industrial Estate, Sukhumvit Rd., A.Muang, Samutprakan 10280.

Instrument Calibrated :

Description : Sound Level Meter
Manufacturer : Rion
Model : NL-42
Serial No. : 00233181 ID.Q100/01/240/003
Microphone : Type UC-52 No.144834
Preamplifier : Type NH-24 No.23229

Ambient Environment

Temperature : (23 ± 3) °C
Relative Humidity : (50 ± 15) %
Ambient Pressure : (101.325±1.5) kPa

Standards used :

1. Band Pass Filter Stanford Research Systems SR 650 S/N 28712.
2. Condenser Microphone Brüel&Kjær 4180 S/N 2633526.
3. Decade Attenuator Ando AL-205 S/N 00464602.
4. Function/Arbitrary Waveform Generator Agilent 33220A S/N MY44042668.
5. Digital Function Synthesizer NF Electronic Instruments DF-193A S/N 122037.
6. Sound Calibrator Bruel&Kjaer 4231 S/N 3015154.
7. Measuring Amplifier Brüel&Kjær 2636 S/N 1537484.

Date of Receipt : 13 Aug. 2025
Date of Calibration : 1 Sep. 2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

FM.BL.MTC.002 Rev.5

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

8. Power Amplifier Brüel&Kjær 2706 S/N 1517650.
9. Speaker Tannoy Limited, Great Britain British Patent No. 215300.
10. Digital Multimeter Agilent 34401A S/N MY44005560.
11. Programmable Attenuator Tamagawa TPA-303A S/N 2212.

Calibration Procedure :

This instrument was calibrated by using calibration procedures no CP-102-02 and CP-102-03, which ere based on IEC 61672-3 Electroacoustics - Sound Level Meters - Part 3 : Periodic tests (2013). These calibration procedures were related to the electrical and acoustic signal tests. The electrical signal test was carried out with the direct measurement method. The acoustic signal test was performed in an anechoic room with the comparison measurement method.

This instrument has been calibrated against standards maintained at the Electrical and Electronic Standards Laboratory (EEL), which are traceable to the International System of Units through the National Institute of Metrology (Thailand).

The information on actual reading is attached herewith and the uncertainty limits quoted refer to the measured values only.

The reported expanded uncertainty is based upon a standard uncertainty multiplied by a coverage factor k=2, providing a level of confidence of approximately 95%.

Date of Calibration : 1 Sep. 2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon KhKong Ha, Amphoe KhKong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-68/0510 **MTC No.** EEL. BP. 20/0868

3. Acoustical signal test of frequency weightings

Frequency	Deviation from frequency response (dB)			Acceptance limit	Uncertainty	Maximum-permitted uncertainty
(Hz)	A-weight	C-weight	Flat	class 2 (±dB)	(±dB)	of measurement (±dB)
125	0.3	0.5	0.5	1.5	0.45	0.6
1 000	-0.5	-0.5	-0.6	1.0	0.45	0.6
8 000	-1.0	-0.9	-0.8	5.0	0.45	0.7

4. Electrical signal test of frequency weightings

Frequency	Deviation from frequency response (dB)			Acceptance limit	Uncertainty	Maximum-permitted uncertainty
(Hz)	A-weight	C-weight	Flat	class 2 (±dB)	(±dB)	of measurement (±dB)
63	-0.2	-0.1	0.0	2.0	0.20	0.6
125	-0.2	0.0	0.0	1.5	0.20	0.6
250	-0.2	0.0	0.0	1.5	0.20	0.6
500	-0.1	0.0	0.0	1.5	0.20	0.6
1 000	0.0	0.0	0.0	1.0	0.20	0.6
2 000	-0.1	0.0	0.0	2.0	0.20	0.6
4 000	-0.1	0.0	0.0	3.0	0.20	0.6
8 000	0.0	0.0	0.0	5.0	0.20	0.7

Date of Calibration : 1 Sep. 2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

FM.BL.MTC.002 Rev.5

Head Office
35 Mu 3 Tambon KhKong Ha, Amphoe KhKong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-68/0510 **MTC No.** EEL. BP. 20/0868

1. Absolute Sensitivity

Reference Acoustic	Measured value (dB)		Deviation	Acceptance limit	Uncertainty	Maximum-permitted uncertainty
Signal (dB)	Before adjust	After adjust	value (dB)	Class 2 (±dB)	(±dB)	of measurement (±dB)
93.88	93.8	93.9	0.0	1.0	0.48	N/A

Note: The external calibration adjustment was firstly performed. The internal calibration adjustment was then completed at the display of 124.0 dB.

2. Self-generated noise

2.1 Normal test

Measured value	Uncertainty	Maximum-permitted uncertainty
(dB)	(±dB)	of measurement (±dB)
21.1	0.10	N/A

2.2 The microphone of the sound level meter was replaced by electrical signal input device

Frequency	Measured value	Uncertainty	Maximum-permitted uncertainty
Weighting	(dB)	(±dB)	of measurement (±dB)
A-Weight	11.9	0.10	N/A
C-Weight	17.4	0.10	N/A
Flat	23.1	0.10	N/A

Date of Calibration : 1 Sep. 2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

FM.BL.MTC.002 Rev.5

Head Office
35 Mu 3 Tambon KhKong Ha, Amphoe KhKong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-68/0510 **MTC No.** EEL. BP. 20/0868

5. Long-term stability

Time	Measured Value	Deviated value	Acceptance limit	Uncertainty	Maximum-permitted uncertainty
	(dB)	(dB)	class 2 (±dB)	(±dB)	of measurement (±dB)
Begin	94.0	0.0	0.3	0.10	0.1
End	94.0				

6. Frequency and time weightings at 1 kHz

6.1 Frequency weightings at 1 kHz

Frequency	Measured Value	Deviated value	Acceptance limit	Uncertainty	Maximum-permitted uncertainty
Weighting	(dB)	(dB)	class 2 (±dB)	(±dB)	of measurement (±dB)
A-weight	94.0	0.0	0.2	0.20	0.2
C-weight	94.0	0.0	0.2	0.20	0.2
Flat	94.0	0.0	0.2	0.20	0.2

6.2 Time weightings at 1 kHz

Frequency	Measured Value	Deviated value	Acceptance limit	Uncertainty	Maximum-permitted uncertainty
Weighting	(dB)	(dB)	class 2 (±dB)	(±dB)	of measurement (±dB)
Fast	94.0	0.0	0.1	0.20	0.2
Slow	94.0	0.0	0.1	0.20	0.2
Leq	94.0	0.0	0.1	0.20	0.2

Date of Calibration : 1 Sep. 2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

FM.BL.MTC.002 Rev.5

Head Office
35 Mu 3 Tambon KhKong Ha, Amphoe KhKong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

7. Level linearity on the reference level range

Anticipated value (dB)	Measured Value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
137	137.0	0.0	1.1	0.30	0.3
136	136.0	0.0	1.1	0.30	0.3
135	135.0	0.0	1.1	0.30	0.3
134	134.0	0.0	1.1	0.30	0.3
133	133.0	0.0	1.1	0.30	0.3
132	132.0	0.0	1.1	0.30	0.3
131	131.0	0.0	1.1	0.30	0.3
130	130.0	0.0	1.1	0.30	0.3
129	129.0	0.0	1.1	0.30	0.3
124	124.0	0.0	1.1	0.30	0.3
119	119.0	0.0	1.1	0.30	0.3
114	114.0	0.0	1.1	0.30	0.3
109	109.0	0.0	1.1	0.30	0.3
104	104.0	0.0	1.1	0.30	0.3
99	99.0	0.0	1.1	0.30	0.3
94	94.0	0.0	1.1	0.30	0.3
89	89.0	0.0	1.1	0.30	0.3
84	84.1	0.1	1.1	0.30	0.3
79	79.0	0.0	1.1	0.30	0.3
74	74.0	0.0	1.1	0.30	0.3
69	69.0	0.0	1.1	0.30	0.3
64	63.9	-0.1	1.1	0.30	0.3

Date of Calibration : 1 Sep. 2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

8. Level linearlity including the level range control

At reference level at 5 dB greater than the under-range on a level range

Range	Anticipated value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
30-130	35	35.0	0.0	1.1	0.30	0.3

9. Tone burst response

Time Weighting	Toneburst Duration, Tb (ms)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Fast	200	126.0	0.0	±1.0	0.20	0.3
	2	108.9	-0.1	+1.0; -2.5	0.20	0.3
	0.25	100.0	0.0	+1.5; -5.0	0.20	0.3
Slow	200	119.5	-0.1	±1.0	0.20	0.3
	2	100.0	0.0	+1.0; -5.0	0.20	0.3

Date of Calibration : 1 Sep. 2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

7. Level linearity on the reference level range (cont.)

Anticipated value (dB)	Measured Value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
59	58.9	-0.1	1.1	0.30	0.3
54	53.9	-0.1	1.1	0.30	0.3
49	48.9	-0.1	1.1	0.30	0.3
44	44.0	0.0	1.1	0.30	0.3
39	38.9	-0.1	1.1	0.30	0.3
34	33.9	-0.1	1.1	0.30	0.3
29	28.9	-0.1	1.1	0.30	0.3
28	28.0	0.0	1.1	0.30	0.3
27	26.9	-0.1	1.1	0.30	0.3
26	26.0	0.0	1.1	0.30	0.3
25	25.0	0.0	1.1	0.30	0.3

8. Level linearlity including the level range control

At reference sound level on the reference level range

Range	Anticipated value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
30-130	94.0	94.0	0.0	1.1	0.30	0.3

Date of Calibration : 1 Sep. 2025

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

10. Peak C sound level

Number of cycles in test signal	Anticipated value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Complete cycle	125.4	125.3	-0.1	3.0	0.20	0.35
Positive half cycle	124.4	124.1	-0.3	2.0	0.20	0.35
Negative half cycle	124.4	124.1	-0.3	2.0	0.20	0.35

11. Overload indication

Measured value (dB)		Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Positive one-half cycle	Negative one-half cycle				
136.1	136.1	0.0	1.5	0.20	0.25

12. High-level stability

Time	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Begin	131.5	0.0	0.3	0.10	0.1
End	131.5				

Calibrated by : Pannasit Pha.

(Mr. Pannasit Phasingsri)

Approved by :

(Mr. Prawale Khuypa)
Director
Electrical and Electronic Standards Laboratory
Industrial Metrology and Testing Service Centre

Date of Calibration : 1 Sep. 2025

Date of Issue : 4 Sep. 2025

Ref : 20112680813031410O2

End of Certificate

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

Request No. 21-69/0141 **MTC No.** EEL. BP. 25/0169

CALIBRATION CERTIFICATE

Submitted by : TPI POLENE PUBLIC CO., LTD.

Address : 299 Moo 5, Mittraphab Rd., T.Tubkwang, A.Kangkhoy, Saraburi, 18260.

Calibrated at : Electrical and Electronic Standards Laboratory, Industrial Metrology and Testing Service Centre, Soi 1C, Bangpoo Industrial Estate, Sukhumvit Rd., A.Muang, Samutprakan 10280.

Instrument Calibrated :

Description : Sound Level Meter
Manufacturer : Pulsa
Model : 44
Serial No. : PN2458
Microphone : PM2 No.022672A
Preamplifier : PA40 No.2503

Ambient Environment

Temperature : (23 ± 3) °C
Relative Humidity : (50 ± 15) %
Ambient Pressure : (101.325±1.5) kPa

Standards used :

1. Band Pass Filter Wavetek 752A S/N 90010494.
2. Condenser Microphone Brüel&Kjær 4180 S/N 2633526.
3. Decade Attenuator Ando AL-205 S/N 00464602.
4. Function/Arbitrary Waveform Generator Agilent 33220A S/N MY44042668.
5. Digital Function Synthesizer NF Electronic Instruments DF-193A S/N 122037.
6. Sound Calibrator Bruel&Kjaer 4231 S/N 3015154.
7. Measuring Amplifier Brüel&Kjær 2636 S/N 1537484.

Date of Receipt : 7 Jan. 2026

Date of Calibration : 17-18 Feb. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0141 **MTC No.** EEL. BP. 25/0169

1. Absolute Sensitivity

Reference Acoustic Signal (dB)	Measured value (dB)		Deviation value (dB)	Acceptance limit Class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
	Before adjust	After adjust				
93.94	92.9	93.7	-0.2	1.0	0.30	N/A

Note: The external calibration adjustment was firstly performed. The internal calibration adjustment was then completed at the display of 93.7 dB.

2. Self-generated noise

2.1 Normal test

Measured value (dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
18.1	0.10	N/A

2.2 The microphone of the sound level meter was replaced by electrical signal input device

Frequency Weighting	Measured value (dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
A-Weight	under-range	-	N/A
C-Weight	21.2	0.10	N/A
Flat	28.4	0.10	N/A

Note: The under-range means that the indicator cannot display for setting the range 20-140 dB.

Date of Calibration : 17-18 Feb. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

FM.BL.MTC.002 Rev.5

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0141 **MTC No.** EEL. BP. 25/0169

8. Power Amplifier Brüel&Kjær 2706 S/N 1517650.
9. Speaker Tannoy Limited, Great Britain British Patent No. 215300.
10. Digital Multimeter Agilent 34401A S/N MY44005560.
11. Programmable Attenuator Tamagawa TPA-303A S/N 2212.

Calibration Procedure :

This instrument was calibrated by using calibration procedures no CP-102-02 and CP-102-03, which were based on IEC 61672-3 Electroacoustics - Sound Level Meters - Part 3 : Periodic tests (2013). These calibration procedures were related to the electrical and acoustic signal tests. The electrical signal test was carried out with the direct measurement method. The acoustic signal test was performed in an anechoic room with the comparison measurement method.

This instrument has been calibrated against standards maintained at the Electrical and Electronic Standards Laboratory (EEL), which are traceable to the International System of Units through the National Institute of Metrology (Thailand).

The information on actual reading is attached herewith and the uncertainty limits quoted refer to the measured values only.

The reported expanded uncertainty is based upon a standard uncertainty multiplied by a coverage factor k=2, providing a level of confidence of approximately 95%.

Date of Calibration : 17-18 Feb. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

FM.BL.MTC.002 Rev.5

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0141 **MTC No.** EEL. BP. 25/0169

3. Acoustical signal test of frequency weightings

Frequency (Hz)	Deviation from frequency response (dB)			Acceptance limit class 2 (dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
	A-weight	C-weight	Flat			
125	0.3	0.2	0.3	±1.5	0.45	0.6
1 000	-0.3	-0.3	-0.3	±1.0	0.45	0.6
8 000	-0.9	-0.9	-1.1	±5.0	0.45	0.7

4. Electrical signal test of frequency weightings

Frequency (Hz)	Deviation from frequency response (dB)			Acceptance limit class 2 (dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
	A-weight	C-weight	Flat			
63	0.5	0.3	0.4	±2.0	0.20	0.6
125	0.1	0.2	0.2	±1.5	0.20	0.6
250	-0.1	0.0	0.0	±1.5	0.20	0.6
500	-0.1	0.0	0.0	±1.5	0.20	0.6
1 000	0.0	0.0	0.0	±1.0	0.20	0.6
2 000	0.0	0.1	0.0	±2.0	0.20	0.6
4 000	0.0	0.1	0.1	±3.0	0.20	0.6
8 000	0.4	0.4	0.3	±5.0	0.20	0.7

Date of Calibration : 17-18 Feb. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

FM.BL.MTC.002 Rev.5

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

Request No. 21-69/0141 **MTC No.** EEL. BP. 25/0169

5. Long-term stability

Time	Measured Value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Begin	114.0	0.0	0.3	0.10	0.1
End	114.0				

6. Frequency and time weightings at 1 kHz

6.1 Frequency weightings at 1 kHz

Frequency Weighting	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
A-weight	114.0	0.0	0.2	0.20	0.2
C-weight	114.0	0.0	0.2	0.20	0.2
Flat	114.0	0.0	0.2	0.20	0.2

6.2 Time weightings at 1 kHz

Frequency Weighting	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Fast	114.0	0.0	0.1	0.20	0.2
Slow	114.0	0.0	0.1	0.20	0.2
Leq	114.0	0.0	0.1	0.20	0.2

Date of Calibration : 17-18 Feb. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0141 **MTC No.** EEL. BP. 25/0169

7. Level linearity on the reference level range (cont.)

34	34.4	0.4	1.1	0.30	0.3
29	29.4	0.4	1.1	0.30	0.3
24	24.6	0.6	1.1	0.30	0.3

8. Level linearlity including the level range control

At reference sound level on the reference level range

Range	Anticipated value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
20-140	114.0	114.0	0.0	1.1	0.30	0.3

Date of Calibration : 17-18 Feb. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0141 **MTC No.** EEL. BP. 25/0169

7. Level linearity on the reference level range

Anticipated value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
140	140.1	0.1	1.1	0.30	0.3
139	139.1	0.1	1.1	0.30	0.3
134	134.1	0.1	1.1	0.30	0.3
129	129.1	0.1	1.1	0.30	0.3
124	124.0	0.0	1.1	0.30	0.3
119	119.0	0.0	1.1	0.30	0.3
114	114.0	0.0	1.1	0.30	0.3
109	109.0	0.0	1.1	0.30	0.3
104	104.0	0.0	1.1	0.30	0.3
99	99.0	0.0	1.1	0.30	0.3
94	94.0	0.0	1.1	0.30	0.3
89	89.2	0.2	1.1	0.30	0.3
84	84.1	0.1	1.1	0.30	0.3
79	79.1	0.1	1.1	0.30	0.3
74	74.2	0.2	1.1	0.30	0.3
69	69.1	0.1	1.1	0.30	0.3
64	64.1	0.1	1.1	0.30	0.3
59	59.4	0.4	1.1	0.30	0.3
54	54.2	0.2	1.1	0.30	0.3
49	49.3	0.3	1.1	0.30	0.3
44	44.2	0.2	1.1	0.30	0.3
39	39.6	0.6	1.1	0.30	0.3

Date of Calibration : 17-18 Feb. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0141 **MTC No.** EEL. BP. 25/0169

8. Level linearlity including the level range control

At reference level at 5 dB greater than the under-range on a level range

Range	Anticipated value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
20-140	25	25.0	0.0	1.1	0.30	0.3

9. Tone burst response

Time Weighting	Toneburst Duration, Tb (ms)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Fast	200	136.0	0.0	±1.0	0.20	0.3
	2	119.0	0.0	+1.0; -2.5	0.20	0.3
	0.25	109.9	-0.1	+1.5; -5.0	0.20	0.3
Slow	200	129.6	0.0	±1.0	0.20	0.3
	2	110.0	0.0	+1.0; -5.0	0.20	0.3
SEL	200	130.0	0.0	±1.0	0.20	0.3
	2	110.0	0.0	+1.0; -2.5	0.20	0.3
	0.25	100.9	-0.1	+1.5; -5.0	0.20	0.3

Date of Calibration : 17-18 Feb. 2026

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9440
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

THAILAND INSTITUTE OF SCIENTIFIC AND TECHNOLOGICAL RESEARCH (TISTR)

Request No. 21-69/0141 **MTC No.** EEL. BP. 25/0169

10. Peak C sound level

Number of cycles in test signal	Anticipated value (dB)	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Complete cycle	135.4	135.6	0.2	3.0	0.20	0.35
Positive half cycle	134.4	134.2	-0.2	2.0	0.20	0.35
Negative half cycle	134.4	134.2	-0.2	2.0	0.20	0.35

11. Overload indication

Measured value (dB)		Deviated value (dB)	Acceptance limit class (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Positive one-half cycle	Negative one-half cycle				
139.1	139.1	0.0	1.5	0.20	0.25

12. High-level stability

Time	Measured value (dB)	Deviated value (dB)	Acceptance limit class 2 (±dB)	Uncertainty (±dB)	Maximum-permitted uncertainty of measurement (±dB)
Begin	139.0	0.0	0.3	0.10	0.1
End	139.0				

Calibrated by : (Mr. Pannasit Phasingsri)

Approved by : (Mr. Prasarate Khuypa)
Director
Electrical and Electronic Standards Laboratory
Industrial Metrology and Testing Service Centre

Date of Calibration : 17-18 Feb. 2026

Date of Issue : 19 Feb. 2026

Ref : 20112680925038070O1

End of Certificate 9 / 9

The results relate only to the items tested/calibrated or value assigned.
Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the governor of TISTR.

Head Office
35 Mu 3 Tambon Khlong Ha, Amphoe Khlong Luang, Changwat Pathumthani 12120, Thailand
Tel. (66) 0 2577 9036
Fax. (66) 0 2577 9009

Office/Laboratory
668 Mu 2 Tambon Bangpoomai, Amphoe Muang Samutprakan, Changwat Samutprakan 10280, Thailand
Tel. (66) 0 2323 1672-80 ext. 115, 116
(66) 08 3219 9460
E-mail : mtc@tistr.or.th Website : www.tistr.or.th

Office
196 Phahonyothin Road, Ladyao, Chatuchak, Bangkok 10900, Thailand
Tel. (66) 0 2579 1121-30 ext. 5219, 5225, 5217
(66) 08 1889 6827

INNOVATIVE INSTRUMENT CALIBRATION LAB
INNOVATIVE INSTRUMENT CO., LTD. HEAD OFFICE
7/139 MOO 13, SOI SUNTINAKORN 11 TAMBON BANG KAEO,
AMPHOE BANG PHLI SAMUT PRAKAN PROVINCE 10540 THAILAND
TEL: (66)0-2116-5860-1 FAX: (66)0-2116-7140

Certificate No : 25-SLM-391 Rev.1
Request No : Req-2025-2620

1. Indication at the calibration check frequency

UUC Setting	Nominal	Before Adjust		After Adjust		UNCERTAINTY
FAST / A / 30-130	Level	UUC	ERR	UUC	ERR	
Calibrater Setting	(dB)	(dB)	(dB)	(dB)	(dB)	(± dB)
1000 Hz 114 dB	113.75	113.6	-0.15	113.8	0.05	0.20

Note : Absolute sensitivity was established by the use of Sound Calibrator Brand SVANTEK, Model SV 35A, SN 58079

2. Self-generated noise, Microphone installed

UUC Setting	Measured	UNCERTAINTY
FAST / 30-130		
UUC Weighting	(dB)	(± dB)
A	15.3	0.10

3. Self-generated noise, Microphone replaced by the electrical input signal device

UUC Setting	Measured	UNCERTAINTY
FAST / 30-130		
UUC Weighting	(dB)	(± dB)
A	-	0.10
C	15.4	0.10
Z	19.2	0.10

4. Acoustic signal test of frequency weightings (Without Windscreen)

UUC Setting	Deviation from various Frequency Weighting Respone curve			UNCERTAINTY
FAST / 30-130	A	C	Z	
STD Setting	(dB)	(dB)	(dB)	(± dB)
125 Hz	0.1	0.2	0.2	0.60
1000 Hz	0.0	0.0	0.0	0.60
4000 Hz	0.5	0.5	0.5	0.60
8000 Hz	0.1	0.1	0.1	0.70

The results related only to the item calibrated. The certificate shall not be reproduced except in full, without written approval of the Innovative Instrument Co., Ltd

INNOVATIVE INSTRUMENT CALIBRATION LAB
INNOVATIVE INSTRUMENT CO., LTD. HEAD OFFICE
7/139 MOO 13, SOI SUNTINAKORN 11 TAMBON BANG KAEO,
AMPHOE BANG PHLI SAMUT PRAKAN PROVINCE 10540 THAILAND
TEL: (66)0-2116-5860-1 FAX: (66)0-2116-7140

Certificate of Calibration

Customer

Name : TPI POLENE CO., LTD.
Address : 299 Moo 5 , Mittraphab Road, Tambol Tublkwang, Amphur Kangkhoy, Saraburi 18260 Thailand

Certificate No : 25-SLM-391 Rev.1
Request No : Req-2025-2620

Unit Under Calibration Details

Measurement item : Sound Level Meter
Manufacturer : RION
Model : NL-43
Serial Number : 01142135
ID : -
Resolution : 0.1 dB
Microphone Class : 2
Microphone Model : UC-52
Microphone S/N : 208051
Preamplifier Model : NH-24
Preamplifier S/N : 35108
Instrument Status : Used

Calibration Environment and Details

Temperature : 23 °C ± 2 °C
Humidity : 50 %RH ± 20 %RH
Barometric Pressure : 1013 hPa ± 10 hPa
Received Date : 3 December 2025
Calibrated Date : 9 December 2025
Calibration Procedure : In-house method CP-SLM-01 based on IEC 61672-3 : 2013 Electroacoustics - Sound level meters - Part 3: Periodic tests
Location of Calibration : Lab Acoustic

Reference Standard

Instrument	Brand	Model	SN.	Due calibration	Traceability
Multifunction Acoustic Calibrator	Bruel&Kjaer	4226	3412381	8 May 2026	NIMT
Audio Generator	Svantek	Svan901	131	27 September 2026	WK Electric

Note

The reported uncertainty is based on standard uncertainty multiplied by the Coverage Factor $k = 2$, providing a level of confidence approximately 95 %.

This Certificate was issued to replace to Calibration Certificate No. 25-SLM-391

Calibrated By : Mr. Noppadon Luangart
Service Calibration Engineer

Approved By : Mr. Pacit Mathavorn
Calibration Engineer Supervisor

Issue Date : 22 December 2025

The results related only to the item calibrated. The certificate shall not be reproduced except in full, without written approval of the Innovative Instrument Co., Ltd

INNOVATIVE INSTRUMENT CALIBRATION LAB
INNOVATIVE INSTRUMENT CO., LTD. HEAD OFFICE
7/139 MOO 13, SOI SUNTINAKORN 11 TAMBON BANG KAEO,
AMPHOE BANG PHLI SAMUT PRAKAN PROVINCE 10540 THAILAND
TEL: (66)0-2116-5860-1 FAX: (66)0-2116-7140

Certificate No : 25-SLM-391 Rev.1
Request No : Req-2025-2620

5. Electrical signal test of frequency weightings, Weighting network respone with relative to 1 kHz

UUC Setting	Deviation from various Frequency Weighting Respone curve			UNCERTAINTY
FAST / 30-130				
STD Setting	A (dB)	C (dB)	Z (dB)	(± dB)
63 Hz	-0.3	-0.1	-0.1	0.20
125 Hz	-0.2	0.0	-0.1	
250 Hz	-0.1	-0.1	-0.1	
500 Hz	-0.1	0.0	-0.1	
1000 Hz	0.0	0.0	0.0	
2000 Hz	0.0	0.0	0.0	
4000 Hz	-0.1	-0.1	-0.1	
8000 Hz	-0.1	-0.1	-0.1	

6. Frequency and time weightings at 1kHz

UUC Setting	STD	Measured		UNCERTAINTY
FAST / 30-130	REF	UUC	ERR	
UUC Weighting	(dB)	(dB)	(dB)	(± dB)
A	114.00	114.0	0.0	0.20
C	114.00	114.0	0.0	
Z	114.00	114.0	0.0	

UUC Setting	STD	Measured		UNCERTAINTY
30-130 / A	REF	UUC	ERR	
UUC Time Respone	(dB)	(dB)	(dB)	(± dB)
Fast	114.00	114.0	0.0	0.20
Slow	114.00	114.0	0.0	
Leq	114.00	114.0	0.0	

The results related only to the item calibrated. The certificate shall not be reproduced except in full, without written approval of the Innovative Instrument Co., Ltd

INNOVATIVE INSTRUMENT CALIBRATION LAB
INNOVATIVE INSTRUMENT CO., LTD. HEAD OFFICE
7/139 MOO 13, SOI SUNTINAKORN 11 TAMBON BANG KAEO,
AMPHOE BANG PHLI SAMUT PRAKAN PROVINCE 10540 THAILAND
TEL: 66(0)-2136-5860-1 FAX: 66(0)-2116-7140

Certificate No : 25-SLM-391 Rev.1
Request No : Req-2025-2620

7. Long Term Stability

UUC Setting	Measured	UNCERTAINTY
FAST / A / 30-130	UUC	
STD Setting	(dB)	(± dB)
Initial	114.0	
Final	114.0	
Deviated	0.0	0.10

8. Level linearity on the reference level range

UUC Setting	Anticipated	Deviation		UNCERTAINTY
FAST / A / 30-130	REF	UUC	ERR	
STD dB	(dB)	(dB)	(dB)	(± dB)
138.00	138	138.0	0.0	0.30
134.00	134	134.0	0.0	
129.00	129	129.0	0.0	
124.00	124	124.0	0.0	
119.00	119	119.0	0.0	
114.00	114	114.0	0.0	
109.00	109	109.0	0.0	
104.00	104	104.0	0.0	
99.00	99	99.0	0.0	
94.00	94	94.0	0.0	
89.00	89	89.0	0.0	
84.00	84	84.0	0.0	
79.00	79	79.0	0.0	
74.00	74	74.0	0.0	
69.00	69	69.0	0.0	
64.00	64	64.0	0.0	
59.00	59	59.0	0.0	
54.00	54	54.0	0.0	
49.00	49	49.0	0.0	
44.00	44	44.0	0.0	
39.00	39	39.0	0.0	
34.00	34	34.0	0.0	
29.00	29	29.0	0.0	
24.00	24	24.1	0.1	

The results related only to the item calibrated. The certificate shall not be reproduced except in full, without written approval of the Innovative Instrument Co., Ltd

INNOVATIVE INSTRUMENT CALIBRATION LAB
INNOVATIVE INSTRUMENT CO., LTD. HEAD OFFICE
7/139 MOO 13, SOI SUNTINAKORN 11 TAMBON BANG KAEO,
AMPHOE BANG PHLI SAMUT PRAKAN PROVINCE 10540 THAILAND
TEL: 66(0)-2116-5860-1 FAX: 66(0)-2116-7140

Certificate No : 25-SLM-391 Rev.1
Request No : Req-2025-2620

12. Overload indication

UUC Setting	Measured	UNCERTAINTY
FAST / A / 30-130	UUC	
STD Setting	(dB)	(± dB)
Positive one-half cycle	139.5	
Negative one-half cycle	139.5	
Deviated	0.0	0.20

13. High Level Stability

UUC Setting	Measured	UNCERTAINTY
FAST / A / 30-130	UUC	
STD Setting	(dB)	(± dB)
Initial	129.0	
Final	129.0	
Deviated	0.0	0.10

End of Certificate

The results related only to the item calibrated. The certificate shall not be reproduced except in full, without written approval of the Innovative Instrument Co., Ltd

INNOVATIVE INSTRUMENT CALIBRATION LAB
INNOVATIVE INSTRUMENT CO., LTD. HEAD OFFICE
7/139 MOO 13, SOI SUNTINAKORN 11 TAMBON BANG KAEO,
AMPHOE BANG PHLI SAMUT PRAKAN PROVINCE 10540 THAILAND
TEL: 66(0)-2136-5860-1 FAX: 66(0)-2116-7140

Certificate No : 25-SLM-391 Rev.1
Request No : Req-2025-2620

9. Level linearity including the level range control

UUC Setting	STD	Measured		UNCERTAINTY
FAST / A	REF	UUC	ERR	
UUC Range	(dB)	(dB)	(dB)	(± dB)
30-130	29.50	29.7	0.2	0.30
	114	114.0	0.0	
30-120	32.60	33.5	0.9	
	114	113.9	-0.1	

10. Tone burst response

UUC Setting	STD	Anticipated	Measured		UNCERTAINTY
A / 30-130	Toneburst	Ref	UUC	ERR	
UUC Time Respone	(ms)	(dB)	(dB)	(dB)	(± dB)
Fast	200	126.0	126.0	0.0	0.20
	2	109.0	109.0	0.0	
	0.25	100.0	99.9	-0.1	
Slow	200	119.6	119.6	0.0	
	2	100.0	100.0	0.0	
SEL	200	120.0	120.0	0.0	
	2	100.0	100.0	0.0	
	0.25	91.0	90.9	-0.1	

11. Peak C Sound level

UUC Setting	Anticipated	Measured		UNCERTAINTY
FAST / C / 55-141	REF	UUC	ERR	
STD Setting	(dB)	(dB)	(dB)	(± dB)
Complete cycle	136.4	136.3	-0.10	0.20
Positive half cycle	135.4	135.2	-0.20	
Negative half cycle	135.4	135.2	-0.20	

The results related only to the item calibrated. The certificate shall not be reproduced except in full, without written approval of the Innovative Instrument Co., Ltd

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T. Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 0101/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/001	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 16064		Relative Humidity 60 ± 10 %RH
Condition of the Item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	Dry Cal DC-Lite BVCL-001	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.006	0.006	± 0.03	✓
1.5	1.506	0.006		✓
2	2.006	0.006		✓
2.5	2.506	0.006		✓
3	3.007	0.007		✓

Conclusion of Verification ☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ฤรยาพร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุชิต ตูขาวพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 0201/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/002	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 15944		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	Dry Cal DC Gas (DCG-MK)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.010	0.010	± 0.03	✓
1.5	1.510	0.010		✓
2	2.009	0.009		✓
2.5	2.509	0.009		✓
3	3.009	0.009		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาคร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุกูล ฐุนวรพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 0401/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/004	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 15946		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	Dry Cal DC Gas (DCG-MK)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.005	0.005	± 0.03	✓
1.5	1.507	0.007		✓
2	2.006	0.006		✓
2.5	2.507	0.007		✓
3	3.005	0.005		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาคร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุกูล ฐุนวรพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 0301/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/003	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 15945		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	Dry Cal DC Gas (DCG-MK)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.010	0.010	± 0.03	✓
1.5	1.510	0.010		✓
2	2.011	0.011		✓
2.5	2.510	0.010		✓
3	3.009	0.009		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาคร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุกูล ฐุนวรพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 0501/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/005	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 15947		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	Dry Cal DC Gas (DCG-MK)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.009	0.009	± 0.03	✓
1.5	1.506	0.006		✓
2	2.008	0.008		✓
2.5	2.507	0.007		✓
3	3.007	0.007		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาคร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุกูล ฐุนวรพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 0601/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/006	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 15948		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	Dry Cal DC-Lite (DCL-SKC)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.006	0.006	± 0.03	✓
1.5	1.507	0.007		✓
2	2.009	0.009		✓
2.5	2.507	0.007		✓
3	3.008	0.008		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ฤรยากร (Tech.) Approved by : พัชรินทร์ บุญมาวัศร์ (Asst. Section Manager)

Checked by : อนุกูล ฐุษวรพงศ์ (Supervisor) Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 0801/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/008	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 20041202016		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	Dry Cal DC-Lite (DCL-SKC)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.001	0.001	± 0.03	✓
1.5	1.502	0.002		✓
1.7	1.701	0.001		✓
2.5	2.502	0.002		✓
3	3.003	0.003		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ฤรยากร (Tech.) Approved by : พัชรินทร์ บุญมาวัศร์ (Asst. Section Manager)

Checked by : อนุกูล ฐุษวรพงศ์ (Supervisor) Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 0701/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/007	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 15950		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	Dry Cal DC-Lite (DCL-SKC)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.010	0.010	± 0.03	✓
1.5	1.508	0.008		✓
2	2.012	0.012		✓
2.5	2.509	0.009		✓
3	3.007	0.007		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ฤรยากร (Tech.) Approved by : พัชรินทร์ บุญมาวัศร์ (Asst. Section Manager)

Checked by : อนุกูล ฐุษวรพงศ์ (Supervisor) Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 0901/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/009	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 1000		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	Dry Cal DC-Lite (DCL-SKC)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.003	0.003	± 0.03	✓
1.5	1.505	0.005		✓
1.7	1.705	0.005		✓
2.5	2.505	0.005		✓
3	3.003	0.003		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ฤรยากร (Tech.) Approved by : พัชรินทร์ บุญมาวัศร์ (Asst. Section Manager)

Checked by : อนุกูล ฐุษวรพงศ์ (Supervisor) Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 1001/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/010	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 1007		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	(by Gilibrator-2 Inc.(DCL-MU))	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.004	0.004	± 0.03	✓
1.5	1.504	0.004		✓
1.7	1.706	0.006		✓
2.5	2.505	0.005		✓
3	3.005	0.005		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ฤรยาคร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุวุธ ฐานวรพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 1201/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/012	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 1009		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	(by Gilibrator-2 Inc.(DCL-MU))	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.008	0.008	± 0.03	✓
1.5	1.509	0.009		✓
1.7	1.710	0.010		✓
2.5	2.508	0.008		✓
3	3.009	0.009		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ฤรยาคร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุวุธ ฐานวรพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 1101/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/011	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 1008		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	(by Gilibrator-2 Inc.(DCL-MU))	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.008	0.008	± 0.03	✓
1.5	1.509	0.009		✓
1.7	1.710	0.010		✓
2.5	2.508	0.008		✓
3	3.010	0.010		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ฤรยาคร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุวุธ ฐานวรพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 1301/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/013	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 1010		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	(by Gilibrator-2 Inc.(DCL-MU))	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.003	0.003	± 0.03	✓
1.5	1.503	0.003		✓
1.7	1.702	0.002		✓
2.5	2.503	0.003		✓
3	3.002	0.002		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ฤรยาคร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุวุธ ฐานวรพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 1401/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/014	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 20071202001		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	(by Cal-DC-Gas (SCL-MU))	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.009	0.009	± 0.03	✓
1.5	1.510	0.010		✓
2	2.011	0.011		✓
2.5	2.509	0.009		✓
3	3.010	0.010		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาตร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : ธนกฤต ศุขวรพงศ์ (Supervisor)
Issued Date : ๐๗ / ๐๑ / ๒๐๒๖

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 1601/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/016	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 20071202003		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	(by Cal-DC-Gas (SCL-MU))	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.005	0.005	± 0.03	✓
1.5	1.505	0.005		✓
2	2.006	0.006		✓
2.5	2.507	0.007		✓
3	3.007	0.007		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาตร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : ธนกฤต ศุขวรพงศ์ (Supervisor)
Issued Date : ๐๗ / ๐๑ / ๒๐๒๖

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 1501/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/015	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 20071202002		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	(by Cal-DC-Gas (SCL-MU))	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.001	0.001	± 0.03	✓
1.5	1.502	0.002		✓
2	2.002	0.002		✓
2.5	2.501	0.001		✓
3	3.002	0.002		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาตร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : ธนกฤต ศุขวรพงศ์ (Supervisor)
Issued Date : ๐๗ / ๐๑ / ๒๐๒๖

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 1701/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/017	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 20071202004		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	(by Cal-DC-Gas (SCL-MU))	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.005	0.005	± 0.03	✓
1.5	1.504	0.004		✓
2	2.006	0.006		✓
2.5	2.505	0.005		✓
3	3.004	0.004		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาตร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : ธนกฤต ศุขวรพงศ์ (Supervisor)
Issued Date : ๐๗ / ๐๑ / ๒๐๒๖

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 1801/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/018	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 20071202005		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	Dry Cal DC Gas (DCL-M)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.008	0.008	± 0.03	✓
1.5	1.507	0.007		✓
2	2.008	0.008		✓
2.5	2.507	0.007		✓
3	3.008	0.008		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาตร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุกูล ศุขเวชพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 2001/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/020	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 20160201018		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	Dry Cal DC Gas (DCL-M)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.002	0.002	± 0.03	✓
1.5	1.502	0.002		✓
2	2.003	0.003		✓
2.5	2.503	0.003		✓
3	3.002	0.002		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาตร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุกูล ศุขเวชพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 1901/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/019	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 20160201017		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	Dry Cal DC Gas (DCL-M)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.003	0.003	± 0.03	✓
1.5	1.503	0.003		✓
2	2.003	0.003		✓
2.5	2.503	0.003		✓
3	3.002	0.002		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาตร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุกูล ศุขเวชพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 2101/26
Page 1 of 1


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/021	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 20160201019		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	Dry Cal DC Gas (DCL-M)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.003	0.003	± 0.03	✓
1.5	1.502	0.002		✓
2	2.003	0.003		✓
2.5	2.502	0.002		✓
3	3.003	0.003		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาตร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุกูล ศุขเวชพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 2201/26


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/022	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 20160201020		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	(by Cal-DC Gas EQU.-001)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.003	0.003	± 0.03	✓
1.5	1.503	0.003		✓
1.7	1.704	0.004		✓
2.5	2.502	0.002		✓
3	3.002	0.002		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาคร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุชิต สุนารพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

F52-812 (R/A)

TPI POLENE PUBLIC COMPANY LIMITED
299 Moo 5 Mitraparp Rd., T.Tubkwang, A.Kangkhoy, Saraburi 18260, Thailand.
Tel. 036-358-999, Fax. 036-358-910-12
Verification Report of Working Area Dust Air Sampler

Ver. No. : Lab 2301/26


Verification Certificate

Equipment	: Working Area Dust Air Sampler	**Verification date**	: 07 Jan 2026
Instrument Code	: Q100/01/243/023	**Next Due Date**	: 06 July 2026
Manufacturer	: Hobart Coporation	**Verification location**	: Monitoring Laboratory
Model	: GILAIR - 5RP	**Ambient condition**	: Temperature 23 ± 2 °C
Serial No.	: 20160201021		Relative Humidity 60 ± 10 %RH
Condition of the item	: Normal	**Verification Method**	: In house method based on TIS 2574-2555

Measuring Equipment :	Instrument Code	Model	Serial No.	Certificate No.	Due date
1. Primary Flow Meter	Q100/01/257/001	(by Cal-DC Gas EQU.-001)	109185	CGF-015-68	17 Sep 26
2. Digital Thermometer	Q100/01/041/020	392050	-	OS-25-267	11 Sep 26

The Standard used for the measurement is traceable to International system of Units (SI) through accredited
- JIRANATEE ASSOCIATES Co., Ltd. (Primary Flow Meter)
- INSTRUMENT SECTION TPI POLENE PUBLIC CO., Ltd. (Digital Thermometer)

Verification Result :



UUC Reading (L/min)	Actual Value (L/min)	Error (L/min)	Tolerance (± L/min)	Status
1	1.001	0.001	± 0.03	✓
1.5	1.502	0.002		✓
1.7	1.702	0.002		✓
2.5	2.501	0.001		✓
3	3.001	0.001		✓

Conclusion of Verification

☑ Can be used ☐ Can not be used

Verificated by : รัฐพล ยุรยาคร์ (Tech.)
Approved by : พัชรินทร์ บุญมาวัตร์ (Asst. Section Manager)
Checked by : อนุชิต สุนารพงศ์ (Supervisor)
Issued Date : 07 / 01 / 2026

The end of Verification Certificate

The results relate only to the items verificated/calibrated or value assigned.

Advertising the Report/Certificate and publicity of the results except in full are prohibited unless written permission is obtained from the calibration laboratory.

ภาคผนวก จ

เอกสารสำรวจสภาพเศรษฐกิจ-สังคม



สารบัญภาพถ่าย

หน้า

ภาพถ่ายที่ 1	การศึกษาสภาพเศรษฐกิจ สังคม และความคิดเห็นของโครงการฯ เมื่อวันที่ 28- 30 พฤศจิกายน พ.ศ. 2568	3

สารบัญตาราง

หน้า

ตารางที่ 1	จำนวนตัวอย่างครัวเรือนในการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นฯ	6
ตารางที่ 2	จำนวนกลุ่มหน่วยงานราชการ โรงเรียน และวัด ในการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นฯ	8
ตารางที่ 3	จำนวนตัวอย่างกลุ่มผู้นำชุมชนการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็น	10
ตารางที่ 4	ความเห็นของผู้นำชุมชนต่อผลดีด้านเศรษฐกิจ – สังคม จากการดำเนินงานของโครงการฯ	13
ตารางที่ 5	ความเห็นของผู้นำชุมชนต่อความพึงพอใจต่อการดูแลสังคมของโครงการฯ	14
ตารางที่ 6	ความเห็นของครัวเรือนรัศมี 0-3 กิโลเมตรจากที่ตั้งโครงการฯ ต่อผลกระทบทางด้านสิ่งแวดล้อมที่ได้รับในปัจจุบัน	18
ตารางที่ 7	ความเห็นของครัวเรือน 0-3 กิโลเมตรจากที่ตั้งโครงการฯ ต่อผลดีด้านเศรษฐกิจ – สังคม จากการดำเนินงานของโครงการฯ	19
ตารางที่ 8	ความเห็นของครัวเรือน 0-3 กิโลเมตรจากที่ตั้งโครงการฯ ต่อความพึงพอใจต่อการดูแลสังคมของโครงการฯ	20
ตารางที่ 9	ความเห็นของครัวเรือนรัศมี 3-5 กิโลเมตรจากที่ตั้งโครงการฯ ต่อผลกระทบทางด้านสิ่งแวดล้อมที่ได้รับในปัจจุบัน	25
ตารางที่ 10	ความเห็นของครัวเรือน 3-5 กิโลเมตรจากที่ตั้งโครงการฯ ต่อผลดีด้านเศรษฐกิจ–สังคม จากการดำเนินงานของโครงการฯ	26
ตารางที่ 11	ความเห็นของครัวเรือน 3-5 กิโลเมตรจากที่ตั้งโครงการฯ ต่อความพึงพอใจต่อการดูแลสังคมของโครงการฯ	27
ตารางที่ 12	ความเห็นของหน่วยงานต่อความพึงพอใจต่อการดูแลสังคมของโครงการฯ	30

สารบัญ

หน้า

1	หลักการและเหตุผล	1
2	วัตถุประสงค์	1
3	พื้นที่ดำเนินการศึกษา	1
4	วิธีการศึกษา	4
5	ผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็น	4
5.1	ผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มผู้นำชุมชน	9
5.2	ผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน	15
5.2.1	ผลการสำรวจสภาพเศรษฐกิจและสังคมของครัวเรือนรัศมี 0-3 กิโลเมตรจากที่ตั้งโครงการฯ	15
5.2.2	ผลการสำรวจสภาพเศรษฐกิจ และสังคม ของครัวเรือนรัศมี 3-5 กิโลเมตรจากที่ตั้งโครงการฯ	22
5.3	ผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มหน่วยงานราชการ โรงเรียน และวัด	28
	ภาคผนวก	

สารบัญรูป

หน้า

รูปที่ 1	พื้นที่ศึกษาสภาพเศรษฐกิจและสังคมโดยรอบโครงการฯ ประจำปี 2568	2

SGS

การสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็น
ต่อโครงการโรงผลิตไฟฟ้า (TG1-TG8) บริษัท ทีพีไอ โพลีน เพาเวอร์ จำกัด (มหาชน) พ.ศ. 2568
ระหว่างวันที่ 28- 30 พฤศจิกายน พ.ศ. 2568

1. หลักการและเหตุผล


การศึกษาสภาพเศรษฐกิจ สังคม ของต่อโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568 เป็นส่วนหนึ่งในมาตรการติดตามตรวจสอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม และมาตรการติดตามตรวจสอบผลกระทบสิ่งแวดล้อม ตามที่ระบุไว้ในรายงานการวิเคราะห์ผลกระทบสิ่งแวดล้อมของโครงการฯ ซึ่งโครงการฯ จะต้องดำเนินการปีละ 1 ครั้ง โดยปี พ.ศ. 2568 ได้ดำเนินการสำรวจความคิดเห็นของชุมชนบริเวณโดยรอบพื้นที่โครงการฯ ระหว่างวันที่ 28 - 30 พฤศจิกายน พ.ศ. 2568 เพื่อรับทราบความคิดเห็น ข้อเสนอแนะ และปัญหาที่อาจจะเกิดจากการดำเนินงานของโครงการฯ ในรอบปีที่ผ่านมา เพื่อให้โครงการฯ ได้รับทราบข้อมูลและนำไปพิจารณาปรับปรุงการดำเนินงานของโครงการฯ ให้สอดคล้องกับความคิดเห็นและข้อเสนอแนะของประชาชนรอบพื้นที่โครงการฯ ซึ่งจะทำให้โครงการฯ และชุมชนอยู่ร่วมกันได้อย่างปกติสุข

2. วัตถุประสงค์ของการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของประชาชน

1) เพื่อศึกษาข้อมูลทั่วไปด้านเศรษฐกิจของครัวเรือน ข้อมูลด้านสุขภาพอนามัย และสาธารณูปโภค และข้อมูลด้านสภาพแวดล้อมในปัจจุบันของชุมชน
2) เพื่อรับทราบข้อมูล/ข่าวสาร และการมีส่วนร่วมกิจกรรมของโครงการ
3) เพื่อรับทราบความคิดเห็นเกี่ยวกับการดำเนินงานโครงการ

3. พื้นที่ดำเนินการศึกษา

พื้นที่สำรวจสภาพเศรษฐกิจ สังคม ของโครงการฯ พิจารณาครอบคลุมชุมชนในพื้นที่โดยรอบรัศมี 5 กิโลเมตร **ดังรูปที่ 1**



รูปที่ 1 พื้นที่ศึกษาสภาพเศรษฐกิจและสังคมโดยรอบต่อโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) ประจำปี 2568



ภาพถ่ายที่ 1 การศึกษาสภาพเศรษฐกิจ สังคม และความคิดเห็นต่อโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) เมื่อวันที่ 28- 30 พฤศจิกายน พ.ศ. 2568

4. วิธีการศึกษาสภาพเศรษฐกิจ สังคม และความคิดเห็น

การศึกษาสภาพเศรษฐกิจ สังคม และความคิดเห็นของประชาชน ทำโดยการสุ่มตัวอย่างผู้ตอบแบบสอบถามจากชุมชนที่อยู่อาศัยโดยรอบพื้นที่โครงการฯ โดยใช้แบบสอบถาม **ดังภาพถ่ายที่ 1** โดยสามารถแยกออกเป็น 3 กลุ่ม ดังนี้

- กลุ่มผู้นำชุมชน **(แบบสอบถามดังภาคผนวก 1)**
- กลุ่มตัวแทนครัวเรือน **(แบบสอบถามดังภาคผนวก 2)**
- กลุ่มกลุ่มหน่วยงานราชการ โรงเรียน และวัด **(แบบสอบถามดังภาคผนวก 3)**

รายละเอียดวิธีการศึกษาของแต่ละกลุ่มตัวอย่างมีดังต่อไปนี้

1) วิธีการศึกษาสภาพเศรษฐกิจและสังคมของกลุ่มผู้นำชุมชน

(1) รวบรวมข้อมูลทุติยภูมิ เป็นการรวบรวมและทบทวนข้อมูลด้านเศรษฐกิจ สังคม ที่ตั้งชุมชนและสภาพแวดล้อมของชุมชนที่อยู่อาศัยโดยรอบพื้นที่โครงการฯ และจัดทำแบบสอบถาม ซึ่งมีหัวข้อดังนี้

ส่วนที่	1	ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม
ส่วนที่	2	ข้อมูลทั่วไปด้านเศรษฐกิจ-สังคม ของชุมชน
ส่วนที่	3	ข้อมูลด้านด้านสุขภาพอนามัย และสาธารณูปโภคของชุมชน
ส่วนที่	4	การรับทราบข้อมูล/ข่าวสารและการมีส่วนร่วมกิจกรรมของโครงการฯ
ส่วนที่	5	การตรวจสอบเรื่องร้องเรียน
ส่วนที่	6	ความคิดเห็นเกี่ยวกับการดำเนินโครงการฯ
ส่วนที่	7	การประชาสัมพันธ์โครงการ และการมีส่วนร่วมของประชาชน

(2) การกำหนดกลุ่มตัวอย่าง

การเก็บข้อมูลแบบสอบถามของผู้นำชุมชน ใช้วิธีการสุ่มตัวอย่างแบบเฉพาะเจาะจง (Purposive Sampling) โดยสำรวจครอบคลุมชุมชนหลักโดยรอบพื้นที่โครงการฯ รวมทั้งหมดจำนวน 14 ตัวอย่าง รายละเอียด **ดังตารางที่ 1**

(3) การประมวลผลการวิเคราะห์ข้อมูล

การวิเคราะห์ข้อมูลจะใช้โปรแกรมสำเร็จรูปทางสถิติ (Statistics Package for the Social Sciences) โดยมีขั้นตอนการประมวลผลและการวิเคราะห์ข้อมูล คือ ตรวจสอบความถูกต้องของข้อมูลแบบสอบถาม จัดเตรียมคู่มือการลงรหัสเพื่อเปลี่ยนข้อมูลจากแบบสอบถามเป็นรหัสสำหรับการบันทึกข้อมูล การแปลผลข้อมูล และจัดทำตารางแสดงข้อมูล จากนั้นทำการวิเคราะห์ข้อมูลและจัดทำรายงานต่อไป

1) กลุ่มครัวเรือนในรัศมีระยะ 0-3 กิโลเมตรจากโครงการ (70% ของจำนวนตัวอย่าง)

จำนวนตัวอย่างของกลุ่มครัวเรือนคำนวณจำนวนตัวอย่างโดยใช้สูตรของ Taro Yamane จากจำนวนครัวเรือนที่อยู่ในพื้นที่รัศมี รัศมีระยะ 0-3 กิโลเมตรจากที่ตั้งโครงการฯ ซึ่งมีทั้งหมด 2,108 ครัวเรือน จำนวน 4 ชุมชน กำหนดระดับความเชื่อมั่น ร้อยละ 95 หรือมีค่าความคลาดเคลื่อนเท่ากับ ±0.05 พบว่า ตัวอย่างครัวเรือนที่จะทำการสำรวจมีจำนวนทั้งสิ้น 267 ตัวอย่าง โดยแทนค่าในสูตรได้ดังนี้

$$\text{แทนค่าสูตร } n = \frac{2{,}108}{1+(2{,}108\ (0.05)^2)}$$

$$= 266.77 \approx 267 \text{ ตัวอย่าง}$$

2) กลุ่มครัวเรือนในรัศมีระยะ 3-5 กิโลเมตรจากโครงการ (30% ของจำนวนตัวอย่าง)

<u>ขั้นตอนที่ 1</u> คำนวณจำนวนกลุ่มตัวอย่างทั้งหมดของกลุ่มครัวเรือนในระยะ 3-5 กิโลเมตรจากที่ตั้งโครงการฯ โดยใช้สูตรของ Taro Yamane ซึ่งมีครัวเรือนทั้งหมด 5,956 ครัวเรือน จำนวน 13 ชุมชน กำหนดระดับความเชื่อมั่น ร้อยละ 95 หรือมีค่าความคลาดเคลื่อนเท่ากับ ±0.05 พบว่าตัวอย่างครัวเรือนที่จะทำการสำรวจมีจำนวนทั้งสิ้น 114 ตัวอย่าง **ดังตารางที่ 1** โดยแทนค่าในสูตรได้ดังนี้

$$\text{แทนค่าสูตร } n = \frac{5{,}956}{1+(5{,}956\ (0.05)^2)}$$

$$= 114.33 \approx 114 \text{ ตัวอย่าง}$$

<u>ขั้นตอนที่ 2</u> คำนวณประชากรแยกแต่ละชุมชน โดยคำนวณสัดส่วนกลุ่มตัวอย่างครัวเรือนในแต่ละชุมชนโดยใช้สูตรดังนี้

$$\text{จำนวนกลุ่มตัวอย่างรายชุมชน} = \frac{\text{ขนาดประชากรของชุมชน} \times \text{ขนาดกลุ่มตัวอย่างทั้งหมด}}{\text{ขนาดประชากรทั้งหมด}}$$

$$\text{ยกตัวอย่างเช่น : หมู่ที่ 5 บ้านซับบอน} = \frac{1{,}306 \times 267}{2{,}108} = 165.27 \approx 165 \text{ ตัวอย่าง}$$

ตารางที่ 1 จำนวนตัวอย่างครัวเรือนในการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นฯ

จังหวัด	อำเภอ	ตำบล	หมู่บ้าน	จำนวนตัวอย่าง			
				ครัวเรือน	การคำนวน	เก็บตัวอย่างจริง	ผู้นำชุมชน
รัศมีระยะ 0-3 กิโลเมตรจากโครงการ (70% ของจำนวนตัวอย่าง)							
สระบุรี	แก่งคอย	เทศบาลเมืองทับกวาง	หมู่ 5 บ้านซับบอน	1,306	165.27	166	1
	มวกเหล็ก	มวกเหล็ก	หมู่ 5 บ้านหินลับ	196	24.80	25	1
		มิตรภาพ	หมู่ 6 บ้านอ่างหิน	209	26.45	26	1
			หมู่ 7 บ้านไทรงาม	397	50.24	51	1
รวม				**2,108**	**266.77**	**268**	**4**
รัศมีระยะ 3-5 กิโลเมตรจากโครงการ (30% ของจำนวนตัวอย่าง)							
สระบุรี	แก่งคอย	เทศบาลเมืองทับกวาง	หมู่ 3 บ้านไทย	1,007	19.33	20	1
			หมู่ 9 ชุมชนนิคมพัฒนา	2,310	44.34	45	1
			หมู่ 9 ชุมชนบ้านเจริญพร,				
			หมู่ 9 ชุมชนบ้านจัดสรรทับกวาง				
			หมู่ 9 ชุมชนเพื่องฟ้า				
			หมู่10 บ้านถ้ำพัฒนา	304	5.84	6	1
		ท่าคล้อ	หมู่ 2 บ้านท่าสบก	169	3.24	4	1
	มวกเหล็ก	มวกเหล็ก	หมู่ 6 บ้านประดู่	271	5.20	6	1
			หมู่12 บ้านเขาแก้วียน	260	4.99	5	1
			หมู่13 บ้านท่าเสา	255	4.89	5	1
		มิตรภาพ	หมู่ 4 บ้านซับพริก	422	8.10	9	1
			หมู่ 5 บ้านเขามะกอก	467	8.96	9	1
			หมู่ 10 บ้านอมรศรี	491	9.43	10	1
รวม				**5,956**	**114.33**	**115**	**10**
รวมทั้งหมด				**8,064**	**381.10**	**383**	**14**

ที่มา : จำนวนครัวเรือนในชุมชนอ้างอิงจากสำนักบริหารการทะเบียน กรมการปกครอง ตุลาคม พ.ศ. 2568
จำนวนครัวเรือนในชุมชนกำหนดจำนวนตัวอย่างตามสูตร Taro Yamane และคำนวณหาสัดส่วนที่ต้องทำการสุ่มตัวอย่างในแต่ละชุมชน

ตารางที่ 2 จำนวนกลุ่มหน่วยงานราชการ โรงเรียน และวัด ในการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นฯ

ลำดับ	หน่วยงาน	จำนวนตัวอย่าง
1	วัดประชาวิจิตร (ซับพริก)	1
2	วัดพุทธนิมิต	1
3	วัดหินลับ	1
4	วัดซับประดู่	1
5	วัดเขาไม้แก้วียน	1
6	วัดซับบอน	1
7	วัดพระธาตุเจริญธรรม	1
8	โรงเรียนบ้านซับบอน	1
9	โรงพยาบาลส่งเสริมสุขภาพตำบลมิตรภาพ	1
10	โรงพยาบาลส่งเสริมสุขภาพตำบลทับกวาง	1
รวม		**10**

ที่มา : บริษัท เอสจีเอส (ประเทศไทย) จำกัด, 28 - 30 พฤศจิกายน พ.ศ. 2568

(3) การประมวลผลการวิเคราะห์ข้อมูล

การวิเคราะห์ข้อมูลจะใช้โปรแกรมสำเร็จรูปทางสถิติ (Statistics Package for the Social Sciences) ซึ่งมีขั้นตอน คือ ตรวจสอบความถูกต้องของข้อมูลแบบสอบถามให้ถูกต้อง จัดเตรียมคู่มือการลงรหัสเพื่อเปลี่ยนข้อมูลจากแบบสอบถามเป็นรหัสสำหรับการบันทึกข้อมูล วิเคราะห์ผลข้อมูลและจัดทำรายงานต่อไป

(3) การจัดเตรียมแบบสอบถาม

แบบสอบถามที่ใช้สอบถามครัวเรือนมีรายละเอียดครอบคลุมข้อมูลที่ต้องการดังนี้

ส่วนที่ 1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม
ส่วนที่ 2 ข้อมูลด้านเศรษฐกิจของครัวเรือน
ส่วนที่ 3 ข้อมูลด้านสุขภาพอนามัยและสาธารณูปโภค
ส่วนที่ 4 การรับทราบข้อมูล/ข่าวสารและการมีส่วนร่วมกิจกรรมของโครงการฯ
ส่วนที่ 5 ความคิดเห็นเกี่ยวกับการดำเนินโครงการฯ
ส่วนที่ 6 การประชาสัมพันธ์โครงการและการมีส่วนร่วมของประชาชน

(4) การประมวลผลการวิเคราะห์ข้อมูล

การวิเคราะห์ข้อมูลจะใช้โปรแกรมสำเร็จรูปทางสถิติ (Statistics Package for the Social Sciences) ซึ่งมีขั้นตอน คือ ตรวจสอบความถูกต้องของข้อมูลแบบสอบถามให้ถูกต้อง จัดเตรียมคู่มือการลงรหัสเพื่อเปลี่ยนข้อมูลจากแบบสอบถามเป็นรหัสสำหรับการบันทึกข้อมูล วิเคราะห์ผลข้อมูลและจัดทำรายงานต่อไป

2) วิธีการศึกษาสภาพเศรษฐกิจและสังคมของกลุ่มกลุ่มหน่วยงานราชการ โรงเรียน และวัด

(1) รวบรวมข้อมูลทุติยภูมิ เป็นการรวบรวมและทบทวนข้อมูลเกี่ยวกับข้อมูลด้านเศรษฐกิจ สังคม ที่ตั้งชุมชน และสภาพแวดล้อมของชุมชนที่อยู่อาศัยโดยรอบพื้นที่โครงการ และจัดทำแบบสอบถาม ซึ่งส่วนประกอบของแบบสอบถามมีรายละเอียดดังนี้

ส่วนที่ 1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม
ส่วนที่ 2 การตรวจสอบเรื่องร้องเรียน
ส่วนที่ 3 ความคิดเห็นเกี่ยวกับการดำเนินโครงการฯ
ส่วนที่ 4 การประชาสัมพันธ์โครงการและการมีส่วนร่วมของประชาชน

(2) การกำหนดกลุ่มตัวอย่าง

ในการเก็บข้อมูลแบบสอบถามของกลุ่มหน่วยงานราชการ โรงเรียน และวัดโดยใช้วิธีการสุ่มตัวอย่างแบบเฉพาะเจาะจง (Purposive Sampling) โดยสำรวจให้ครอบคลุมชุมชนหลักโดยรอบพื้นที่โครงการฯ ซึ่งจะต้องทำการสำรวจรวมทั้งหมด 10 ตัวอย่าง **ดังตารางที่ 2**

5. ผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็น

การศึกษาสภาพเศรษฐกิจ สังคม และความคิดเห็น ดำเนินการเมื่อวันที่ 28 - 30 พฤศจิกายน พ.ศ. 2568 โดยจำแนกกลุ่มตัวอย่างเป็น 3 กลุ่ม ได้แก่ 1) กลุ่มผู้นำชุมชน 2) กลุ่มครัวเรือน และ 3) กลุ่มกลุ่มหน่วยงานราชการ โรงเรียน และวัด ซึ่งรายละเอียดตารางประมวลผลทางสถิติแสดงดัง**ภาคผนวกที่ 4 ภาคผนวกที่ 5 และภาคผนวกที่ 6** โดยมีรายละเอียดของผลการสำรวจแต่ละกลุ่มตัวอย่างที่ทำการศึกษาดังต่อไปนี้

5.1 ผลการสำรวจสภาพเศรษฐกิจ สังคม ของกลุ่มผู้นำชุมชน

การสำรวจสภาพเศรษฐกิจ สังคม ของผู้นำชุมชน ที่อยู่โดยรอบโครงการฯ ได้ดำเนินการสำรวจความคิดเห็นจากผู้นำชุมชน จำนวน 14 ตัวอย่าง รายละเอียดของกลุ่มตัวอย่างดัง**ตารางที่ 3** ตารางแสดงผลการสำรวจสภาพเศรษฐกิจและสังคม ของกลุ่มผู้นำชุมชน โดยละเอียดนำเสนอไว้ใน**ภาคผนวกที่ 4** และสามารถสรุปรายละเอียดของผลการศึกษาได้ดังนี้

ตารางที่ 3 จำนวนตัวอย่างกลุ่มผู้นำชุมชนการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็น

จังหวัด	อำเภอ	ตำบล	หมู่บ้าน	ผู้นำชุมชน
รัศมีระยะ 0-3 กิโลเมตรจากโครงการ (70% ของจำนวนตัวอย่าง)				
สระบุรี	แก่งคอย	เทพบาลเมืองทับกวาง	หมู่ 5 บ้านซับบอน	1
	มวกเหล็ก	มวกเหล็ก	หมู่ 5 บ้านหินลับ	1
		มิตรภาพ	หมู่ 6 บ้านอ่างหิน	1
			หมู่ 7 บ้านไทรงาม	1
รวม				**4**
รัศมีระยะ 3-5 กิโลเมตรจากโครงการ (30% ของจำนวนตัวอย่าง)				
สระบุรี	แก่งคอย	เทพบาลเมืองทับกวาง	หมู่ 3 บ้านไทย	1
			หมู่ 9 ชุมชนนิคมพัฒนา	1
			หมู่ 9 ชุมชนบ้านเจริญพร,	
			หมู่ 9 ชุมชนบ้านจัดสรรทับกวาง	
			หมู่ 9 ชุมชนเฟื่องฟ้า	
			หมู่10 บ้านถ้ำพัฒนา	1
	มวกเหล็ก	ท่าคล้อ	หมู่ 2 บ้านท่าสบก	1
		มวกเหล็ก	หมู่ 6 บ้านประตู่	1
			หมู่12 บ้านเขากวิยน	1
			หมู่13 บ้านท่าเสา	1
		มิตรภาพ	หมู่ 4 บ้านซับพริก	1
			หมู่ 5 บ้านเขามะกอก	1
			หมู่ 10 บ้านอมรศรี	1
รวม				**10**
รวมทั้งหมด				**14**

ที่มา : บริษัท เอสจีเอส (ประเทศไทย) จำกัด, 28 - 30 พฤศจิกายน พ.ศ. 2568

ส่วนที่ 1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม

ผู้นำชุมชนส่วนใหญ่เป็นเพศชาย ร้อยละ 57.1 และเป็นเพศหญิง ร้อยละ 42.9 มีอายุเฉลี่ย 48 ปี สำเร็จการศึกษาระดับอนุปริญญา/ปวส. หรือเทียบเท่า ร้อยละ 50.0 รองลงมาสำเร็จการศึกษาระดับอนุปริญญา/ปวส. หรือเทียบเท่า ร้อยละ 28.6 และสำเร็จการศึกษาระดับประถมศึกษาตอนปลาย (ป.6) ร้อยละ 14.3 โดยผู้นำชุมชนทั้งหมดนับถือศาสนาพุทธ

ผู้นำชุมชนที่ตอบแบบสอบถามเป็นผู้ใหญ่บ้านมากที่สุด ร้อยละ 42.9 รองลงมาเป็นผู้ใหญ่บ้าน ร้อยละ 35.7และเป็นกรรมการชุมชน ร้อยละ 21.4 โดยระบุว่าดำรงตำแหน่งระหว่าง 6-10 ปีมากที่สุด ร้อยละ 50.0

ส่วนที่ 2 ข้อมูลทั่วไปด้านเศรษฐกิจ สังคม ของชุมชน

การสอบถามผู้นำชุมชนเกี่ยวกับลักษณะทางสังคมของชุมชน พบว่า ผู้นำชุมชนทั้งหมดให้ข้อมูลว่าคนในชุมชนประกอบอาชีพพนักงานบริษัท/โรงงานอุตสาหกรรมเป็นอาชีพหลัก โดยเห็นว่าไม่มีการประกอบอาชีพเสริม ทั้งนี้ผู้นำชุมชนทั้งหมดให้ข้อมูลว่าคนในชุมชนไม่มีปัญหาในการประกอบอาชีพแต่อย่างใด โดยผู้นำชุมชนทั้งหมดเห็นว่าประชาชนในชุมชนมีฐานะทางเศรษฐกิจปานกลาง

ส่วนที่ 3 ข้อมูลด้านสาธารณูปโภค และบริการสาธารณสุข

ผู้นำชุมชนส่วนใหญ่แจ้งว่า ในชุมชนไม่มีปัญหาด้านสุขภาพอนามัย ร้อยละ 78.6 รองลงมาแจ้งว่ามีปัญหา โรคภูมิแพ้และทางเดินหายใจ ร้อยละ 21.4 ซึ่งทั้งหมดระบุว่า มีการแก้ปัญหาโดยรักษาที่สถานพยาบาลใกล้บ้าน ในส่วนของปัญหาด้านสาธารณูปโภคผู้นำชุมชนทั้งหมดเห็นว่า ไม่มีปัญหาแต่อย่างใด

ส่วนที่ 4 ข้อมูลด้านสภาพแวดล้อมในปัจจุบันของชุมชน

ผู้นำชุมชนทั้งหมดทราบและรู้จักโครงการฯ ซึ่งทราบเจ้าหน้าที่ของโครงการฯ ร้อยละ 42.1 รองลงมาทราบจากผู้นำชุมชนด้วยกัน ร้อยละ 26.4

โดยช่วง 1 ปีที่ผ่านมา ผู้นำชุมชนทั้งหมดเคยเข้าร่วมกิจกรรมงานบุญประเพณี กิจกรรมสำคัญต่าง ๆ ที่โครงการฯ จัดขึ้น และกิจกรรมงานบุญต่างๆ

เมื่อสอบถามเกี่ยวกับความเชื่อมั่นต่อระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่าง ๆ ของโครงการฯ ผู้นำชุมชนทั้งหมดมีความเชื่อมั่นพอสมควร (หากมีอุบัติเหตุสามารถแก้ไขหรือควบคุมได้ทัน)

โดยผู้นำชุมชนทั้งหมดทราบว่า โครงการมีการดำเนินการช่วยเหลือชุมชนด้านต่าง ๆ โดยให้ความเห็นว่า โครงการฯ ให้ความช่วยเหลือสนับสนุนด้านสาธารณูปโภคและสนับสนุนด้านสุขภาพอนามัยมากที่สุด ร้อยละ 34.6 สัดส่วนเท่ากัน รวมทั้งผู้นำชุมชนทั้งหมดแจ้งว่า ทราบว่าในช่วง 1 ปี มีคนในชุมชนเข้ามาทำงานในพื้นที่โครงการฯ

ส่วนที่ 5 การตรวจสอบเรื่องร้องเรียน

เมื่อสอบถามการเรื่องร้องเรียนจากชุมชนเกี่ยวกับกิจกรรมของโครงการฯ ในช่วง 1 ปีที่ผ่านมา ผู้นำชุมชนทั้งหมดระบุว่า ไม่เคยได้รับเรื่องร้องเรียนแต่อย่างใด

ส่วนที่ 6 ความคิดเห็นเกี่ยวกับการดำเนินโครงการฯ

เมื่อสอบถามเกี่ยวกับความวิตกกังวลต่อโครงการฯ ผู้นำชุมชนทั้งหมดไม่มีความวิตกกังวลแต่อย่างใด

เมื่อสอบถามเกี่ยวกับความเชื่อมั่นต่อระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่าง ๆ ของโครงการฯ ผู้นำชุมชนทั้งหมดมีความเชื่อมั่นพอสมควร (หากมีอุบัติเหตุสามารถแก้ไขหรือควบคุมได้ทัน) และโดยภาพรวมช่วง 1 ปี ผู้นำชุมชนมีความพึงพอใจต่อการปฏิบัติตามมาตรการลดผลกระทบด้านต่าง ๆ ของโครงการฯ ในระดับปานกลาง ทั้งนี้ทั้งหมดได้ระบุว่า ไม่เคยได้รับผลกระทบเกี่ยวกับการดำเนินกิจกรรมของโครงการฯ แต่อย่างใด โดยให้ความเห็นว่าโครงการฯ ผลดีกับผลเสียพอๆกัน

สำหรับผลดีด้านเศรษฐกิจและสังคม จากการดำเนินงานโครงการฯ ผู้นำชุมชนทั้งหมดให้ความเห็นว่า โครงการฯ ส่งผลดีต่อชุมชนในทุกด้าน รายละเอียดดัง**ตารางที่ 4**

ตารางที่ 4 ความเห็นของผู้นำชุมชนต่อผลดีด้านเศรษฐกิจ – สังคม จากการดำเนินงานของโครงการฯ

ผลดีจากการดำเนินโครงการฯ	ผลดี (ร้อยละ)		ระดับผลดี (ร้อยละ)					ค่าเฉลี่ย	ค่า S.D.	แปลค่า
	ไม่มี	มี	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด			
ด้านเศรษฐกิจ - สังคม										
1. ทำให้ประชาชนในพื้นที่มีงานทำมากขึ้นจากการรับจ้างในโครงการฯ	0.0	100.0	0.0	0.0	71.4	28.6	0.0	3.29	0.469	ปานกลาง
2. ทำให้การค้าขายของร้านค้าปลีกและธุรกิจบริการต่าง ๆ ดีขึ้น	0.0	100.0	0.0	0.0	71.4	28.6	0.0	3.29	0.469	ปานกลาง
3. สภาพเศรษฐกิจของชุมชนดีขึ้น	0.0	100.0	0.0	0.0	71.4	28.6	0.0	3.29	0.469	ปานกลาง
4. ได้รับการสนับสนุนกิจกรรมชุมชนจากโครงการฯมากขึ้น	0.0	100.0	0.0	0.0	71.4	28.6	0.0	3.29	0.469	ปานกลาง
5. มีการพัฒนาระบบสาธารณูปโภคของชุมชนดีขึ้น เช่น ถนน	0.0	100.0	0.0	0.0	71.4	28.6	0.0	3.29	0.469	ปานกลาง

ที่มา : บริษัท เอสจีเอส (ประเทศไทย) จำกัด, 28- 30 พฤศจิกายน พ.ศ. 2568

ในส่วนความพึงพอใจต่อกิจกรรมชุมชนสัมพันธ์ที่ทางโครงการฯ ดำเนินการในปี 2568 ผู้นำชุมชนมีความพึงพอใจต่อการดูแลสังคมของโครงการฯ ในด้านต่าง ๆ รายละเอียด**ดังตารางที่ 5**

ตารางที่ 5 ความเห็นของผู้นำชุมชนต่อความพึงพอใจต่อการดูแลสังคมของโครงการฯ

รายละเอียด	ระดับความพึงพอใจ (จำนวนตัวอย่าง/ร้อยละ)					ค่าเฉลี่ย	ค่า S.D.	แปลค่า
	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด			
1. กิจกรรมเกี่ยวกับสุขภาพ	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
2. กิจกรรมเกี่ยวกับการอนุรักษ์สิ่งแวดล้อม	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
3. กิจกรรมเกี่ยวกับการส่งเสริมการศึกษา	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
4. กิจกรรมเกี่ยวกับการพัฒนาความสัมพันธ์ชุมชน	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
5. กิจกรรมเกี่ยวกับการส่งเสริมศาสนา วัฒนธรรม	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
6. กิจกรรมการประชาสัมพันธ์และแจ้งข่าวสารของโรงงาน	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
7. กิจกรรมเกี่ยวกับการส่งเสริม/พัฒนาอาชีพ	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
8. กิจกรรมเกี่ยวกับการพัฒนาชุมชน	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง

ที่มา : บริษัท เอสจีเอส (ประเทศไทย) จำกัด, 28 - 30 พฤศจิกายน พ.ศ. 2568

ส่วนที่ 7 การประชาสัมพันธ์โครงการและการมีส่วนร่วมของประชาชน

ผู้นำชุมชนทั้งหมดมีความคิดเห็นว่า ต้องการทราบข่าวการรับสมัครงานของโครงการฯ โดยแจ้งข้อมูลผ่านกำนัน ผู้ใหญ่บ้านหรือผู้นำชุมชน ซึ่งผู้นำชุมชนทั้งหมดระบุว่าเพิ่มเติมว่าหากทางโครงการฯ จัดกิจกรรมร่วมกับชุมชนยินดีเข้าร่วมกิจกรรม

ในด้านการช่วยเหลือ และสนับสนุนงานด้านชุมชนของทางโครงการฯ ผู้นำชุมชนต้องการให้สนับสนุนงานบุญประเพณีต่างๆ และร่วมงานบุญทางศาสนากับชุมชน ร้อยละ 64.3 รองลงมาไม่ได้ต้องการให้ทางโครงการฯ เข้ามาช่วยเหลือส่งเสริมกิจกรรมชุมชน ร้อยละ 35.7 ซึ่งได้มีข้อเสนอแนะให้โครงการฯ เข้ามาสนับสนุนชุมชนอย่างต่อเนื่อง

5.2 ผลการสำรวจสภาพเศรษฐกิจและสังคมของกลุ่มครัวเรือน

การสำรวจความคิดเห็นจากตัวแทนครัวเรือน ดำเนินการทั้งหมด 14 ชุมชน จำนวน 383 ตัวอย่าง ประกอบด้วยชุมชนในรัศมี 5 กิโลเมตร จากที่ตั้งโครงการฯ ดำเนินการสำรวจ ระหว่างวันที่ 28 - 30 พฤศจิกายน พ.ศ. 2568 และสามารถสรุปรายละเอียดของผลการศึกษาได้ดังนี้

5.2.1 ผลการสำรวจสภาพเศรษฐกิจและสังคมของครัวเรือนรัศมี 0-3 กิโลเมตรจากที่ตั้งโครงการฯ

การสำรวจสภาพเศรษฐกิจและสังคมของครัวเรือนที่อยู่รอบโครงการ รัศมี 0-3 กิโลเมตรจากที่ตั้งโครงการฯ ครอบคลุมพื้นที่ 4 ชุมชน จำนวนตัวอย่างทั้งหมด 268 ตัวอย่าง สามารถสรุปรายละเอียดได้ดังนี้

ส่วนที่ 1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม

ผู้ตอบแบบสอบถามส่วนใหญ่เป็นเพศหญิง ร้อยละ 62.7 และเป็นเพศชาย ร้อยละ 37.3 ซึ่ง 3 อันดับแรก ผู้ตอบแบบสอบถามมีอายุระหว่าง 41-50 ปี มากที่สุด ร้อยละ 56.0 รองลงมามีอายุระหว่าง 51-60 ปี ร้อยละ 37.3 และมีอายุมากกว่า 60 ปี ร้อยละ 4.9 โดย 3 อันดับแรก สำเร็จการศึกษาระดับมัธยมศึกษาตอนต้น (ม.3) มากที่สุด ร้อยละ 34.3 รองลงมาสำเร็จการศึกษาระดับอนุปริญญา/ปวส. หรือเทียบเท่า ร้อยละ 28.0 และสำเร็จการศึกษาระดับมัธยมศึกษาตอนต้น (ม.3) ร้อยละ 34.3 ผู้ตอบแบบสอบถามส่วนใหญ่มีสถานภาพเป็นหัวหน้าครัวเรือน ร้อยละ 74.6 และผู้ตอบแบบสอบถามที่มีสถานภาพเป็นสมาชิกในครัวเรือน ร้อยละ 25.4 ได้แก่ คู่สมรส บิดา/มารดา และบุตร/ธิดา ซึ่งผู้ตอบแบบสอบถามทั้งหมดนับถือศาสนาพุทธ ส่วนใหญ่ระบุว่า มีสถานภาพสมรส/อยู่ด้วยกัน ร้อยละ 73.9 รองลงมาระบุว่า มีสถานภาพโสด ร้อยละ 26.1

ด้านลักษณะการอยู่อาศัยส่วนใหญ่อยู่อาศัยแบบครอบครัวเดี่ยว (พ่อ แม่ และลูก) ร้อยละ 93.3 รองลงมาอยู่คนเดียวร้อยละ 6.7

โดยแต่ละครัวเรือนมีจำนวนสมาชิกเฉลี่ย 4 คน เป็นเพศชายเฉลี่ย 2 คน และเป็นเพศหญิงเฉลี่ย 2 คน

สำหรับการตั้งถิ่นฐานและภูมิลำเนาของผู้ตอบแบบสอบถาม พบว่า ผู้ตอบแบบสอบถามส่วนใหญ่ระบุว่า ย้ายมาจากที่อื่น ร้อยละ 59.7 โดยย้ายมาจากภาคกลางมากที่สุด และระบุว่า อยู่อาศัยในพื้นที่ระหว่าง 6-10 ปี ซึ่งย้ายมาเพื่อประกอบอาชีพและมีผู้ตอบแบบสอบถามที่ระบุว่ามีภูมิลำเนาของอยู่ในพื้นที่ตั้งแต่เกิด ร้อยละ 40.3

ส่วนที่ 2 ข้อมูลเศรษฐกิจและสังคม

ผู้ตอบแบบสอบถามส่วนใหญ่ระบุว่า การประกอบอาชีพ 3 อันดับแรก คือ ประกอบอาชีพพนักงานบริษัท/ลูกจ้าง/พนักงานโรงแรม ร้อยละ 92.9 รองลงมาประกอบอาชีพรับจ้างทั่วไป ร้อยละ 3.4 และประกอบอาชีพค้าขาย/ธุรกิจส่วนตัว ร้อยละ 2.6 โดยส่วนใหญ่ระบุว่าไม่มีการประกอบอาชีพเสริมแต่อย่างใด ร้อยละ 92.5 รองลงมาระบุว่า มีการประกอบอาชีพเสริม ร้อยละ 7.5 โดยประกอบอาชีพค้าขาย/ธุรกิจส่วนตัวมากที่สุด โดยทั้งหมดระบุว่า ไม่มีปัญหาในการประกอบอาชีพแต่อย่างใด

ด้านรายได้ รายจ่ายของครัวเรือน พบว่า ครัวเรือนมีรายได้เฉลี่ย 30,000 บาทต่อเดือน และมีรายจ่ายเฉลี่ยอยู่ที่ประมาณ 22,000 บาทต่อเดือน

เมื่อพิจารณาความเพียงพอของรายได้เปรียบเทียบกับรายจ่ายของครัวเรือน พบว่า ผู้ตอบแบบสอบถามมีรายได้เพียงพอและมีเหลือเก็บออม ร้อยละ 56.0 รองลงมามีรายได้เพียงพอ แต่ไม่มีเหลือเก็บออม ร้อยละ 44.0

ส่วนที่ 3 ข้อมูลด้านสุขภาพอนามัย และสาธารณูปโภค

การเจ็บป่วย : ผู้ตอบแบบสอบถามส่วนใหญ่ระบุว่า ในรอบ 1 ปีที่ผ่านมา สมาชิกในครัวเรือนระบุว่า สมาชิกในครัวเรือนเคยเจ็บป่วย ร้อยละ 93.3 โดย 3 อันดับแรก เคยเจ็บป่วยเป็นโรคหวัด/ทางเดินหายใจ ร้อยละ 37.5 รองลงมาเป็นโรคความดัน/โรคเกี่ยวกับระบบไหลเวียนเลือด ร้อยละ 25.0 และโรคผิวหนังและภูมิแพ้ ร้อยละ 17.5

การรักษาพยาบาล : เมื่อมีการเจ็บป่วยของสมาชิกในครัวเรือน ทั้งหมดจะเข้ารับการรักษาที่โรงพยาบาลของรัฐบาล/โรงพยาบาลส่งเสริมสุขภาพของตำบล โดยไม่ประสบปัญหาในการรับบริการด้านสาธารณสุขแต่อย่างใด

ส่วนที่ 4 ข้อมูลด้านสภาพแวดล้อม และสังคมทั่วไปในปัจจุบันของชุมชน

ผู้ตอบแบบสอบถามทั้งหมดทราบและรู้จักโครงการฯ ซึ่งแหล่งข้อมูลที่รับทราบเกี่ยวกับโครงการฯ 3 อันดับแรก ได้แก่ เจ้าหน้าที่ของโครงการฯ ร้อยละ 72.5 ทราบจากผู้นำชุมชน ร้อยละ 14.5 และเพื่อนบ้าน ร้อยละ 8.7 โดยช่วง 1 ปีที่ผ่านมา ผู้ตอบแบบสอบถามส่วนใหญ่เคยเข้าร่วมงานงานบุญประเพณี เช่น ทอดกฐิน,ผ้าป่า เป็นต้น มากที่สุด ร้อยละ 69.0 รองลงมาระบุว่าไม่เคยเข้าร่วมทำกิจกรรมกับโครงการฯ แต่อย่างใด ร้อยละ 31.0

เมื่อสอบถามถึงระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่าง ๆ ของโครงการฯ พบว่า ผู้ตอบแบบสอบถามส่วนใหญ่ทราบ/รู้จัก ร้อยละ 82.1 รองลงมาไม่ทราบ/ไม่รู้จัก ร้อยละ 17.9

สำหรับความเชื่อมั่นในดำเนินงาน และการจัดการสิ่งแวดล้อมของโครงการฯ ผู้ตอบแบบสอบถามทั้งหมดเชื่อมั่นพอสมควร (หากมีอุบัติเหตุสามารถแก้ไขหรือควบคุมได้ทัน) โดยผู้ตอบแบบสอบถามส่วนใหญ่ทราบว่า โครงการมีการดำเนินการช่วยเหลือชุมชน ร้อยละ 97.8 รองลงมาระบุว่า ไม่ทราบ ร้อยละ 2.2

โดยผู้ตอบแบบสอบถามมีความคิดเห็นว่า โครงการฯ ให้ความช่วยเหลือชุมชน 3 อันดับแรก สนับสนุนทางสนับสนุนด้านสาธารณูปโภคมากที่สุด ร้อยละ 56.2 รองลงมาสนับสนุนด้านกีฬา ร้อยละ 18.0 และสนับสนุนด้านสุขภาพอนามัย ร้อยละ 9.4 ซึ่งส่วนใหญ่ทราบว่า ในช่วง 1 ปี มีคนในชุมชนเข้ามาทำงานในพื้นที่โครงการฯ ร้อยละ 97.8 รวมทั้งทราบว่า โครงการฯ จะคัดคนเข้าทำงานโดยพิจารณาที่เหมาะสมกับตำแหน่งงาน ร้อยละ 95.9

ในช่วงปี 2568 ที่ผ่านมา ผู้ตอบแบบสอบถามให้ความเห็นว่า ไม่ทราบข้อมูลการจัดการสิ่งแวดล้อมเกี่ยวกับโครงการฯ ร้อยละ 50.7 รองลงมาระบุว่า รับทราบ ร้อยละ 49.3 โดยทราบจากเจ้าหน้าที่โครงการ มากที่สุด ร้อยละ 82.2

เมื่อสอบถามเกี่ยวกับกิจกรรมมวลชนสัมพันธ์ของโครงการและการเข้าไปมีส่วนร่วมในกิจกรรม พบว่า ผู้ตอบแบบสอบถามส่วนใหญ่รับทราบเกี่ยวกับกิจกรรม ร้อยละ 93.8 ซึ่งเมื่อสอบถามถึงการรับทราบกิจกรรมเปิดบ้านต้อนรับแขกภายนอกเพื่อเข้าเยี่ยมชมโรงงาน (เปิดบ้าน) ในช่วงปี 2568 พบว่า ผู้ตอบแบบสอบถามส่วนใหญ่ระบุว่า ทราบเกี่ยวกับกิจกรรม ร้อยละ 45.4 รองลงมาระบุว่า ไม่รับทราบ ร้อยละ 10.4

ส่วนที่ 5 ความคิดเห็นเกี่ยวกับการดำเนินโครงการฯ

<u>ผลกระทบด้านสิ่งแวดล้อม</u>

ผลการสำรวจความคิดเห็นในเรื่องของผลกระทบทางด้านสิ่งแวดล้อมผู้ตอบแบบสอบถามทั้งหมดระว่าไม่ได้รับผลกระทบแต่อย่างใด รายละเอียดดัง**ตารางที่ 6**

ตารางที่ 6 ความเห็นของครัวเรือนรัศมี 0-3 กิโลเมตรจากที่ตั้งโครงการฯ ต่อผลกระทบทางด้านสิ่งแวดล้อมที่ได้รับในปัจจุบัน

ประเภทของผลกระทบ	ผลกระทบ (ร้อยละ)		ระดับผลกระทบ (ร้อยละ)					ค่าเฉลี่ย	ค่า S.D.	แปลค่า
	ไม่มี	มี	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด			
1)ฝุ่นละออง	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
2)เสียงดัง	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
3)ความสั่นสะเทือน	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
4)น้ำเสีย	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
5)น้ำท่วมขัง	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
6)ขยะมูลฝอย	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
7) กลิ่นเหม็น	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
8) การจราจรติดขัด	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
9) อุบัติเหตุจากการจราจร	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี

ที่มา : บริษัท เอสจีเอส (ประเทศไทย) จำกัด, 28 – 30 พฤศจิกายน พ.ศ. 2568

เมื่อสอบถามถึงความรู้สึกวิตกกังวลเกี่ยวกับกิจกรรมต่อโครงการฯ ผู้ตอบแบบสอบถามทั้งหมดระบุว่า ไม่มีความวิตกกังวล ต่อโครงการฯ แต่อย่างใด ซึ่งในช่วงปี 2568 ที่ผ่านมา ผู้ตอบแบบสอบถามส่วนใหญ่มีความพึงพอใจต่อการปฏิบัติตามมาตรการลดผลกระทบด้านต่าง ๆ ของโครงการฯ ในระดับปานกลาง ร้อยละ 94.7 ซึ่งอย่างไรก็ตามผู้ตอบแบบสอบถามทั้งหมดระบุว่า ไม่เคยได้รับผลกระทบเกี่ยวกับการดำเนินโครงการฯ แต่อย่างใด

จากการสอบถามเกี่ยวกับความคิดเห็นต่อการดำเนินงานของโครงการฯ พบว่า ผู้ตอบแบบสอบถามทั้งหมดเห็นว่า มีผลดีกับผลเสียพอ ๆ กัน

<u>ผลดีด้านเศรษฐกิจ – สังคม จากการดำเนินงานของโครงการฯ</u>

ส่วนผลดีด้านเศรษฐกิจและสังคม จากการดำเนินงานโครงการฯ ได้รับผลดีในทุกด้าน รายละเอียดดัง**ตารางที่ 7**

ตารางที่ 7 ความเห็นของครัวเรือน 0-3 กิโลเมตรจากที่ตั้งโครงการฯ ต่อผลดีด้านเศรษฐกิจ – สังคม จากการดำเนินงานของโครงการฯ

ผลดีจากการดำเนินโครงการฯ	ผลดี (ร้อยละ)		ระดับผลดี (ร้อยละ)					ค่าเฉลี่ย	ค่า S.D.	แปลค่า
	ไม่มี	มี	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด			
ด้านเศรษฐกิจ - สังคม										
1. ทำให้ประชาชนในพื้นที่มีงานทำมากขึ้นจากการรับจ้างในโครงการฯ	0.0	<u>100.0</u>	0.0	0.0	98.2	0.0	1.8	3.04	0.269	ปานกลาง
2. ทำให้การค้าขายของร้านค้าปลีกและธุรกิจบริการต่างๆ ดีขึ้น	0.0	<u>100.0</u>	0.0	0.0	98.2	0.0	1.8	3.04	0.269	ปานกลาง
3. สภาพเศรษฐกิจของชุมชนดีขึ้น	0.0	<u>100.0</u>	0.0	0.0	98.2	0.0	1.8	3.04	0.269	ปานกลาง
4. ได้รับการสนับสนุนกิจกรรมชุมชนจากโครงการฯมากขึ้น	0.0	<u>100.0</u>	0.0	0.0	98.2	0.0	1.8	3.04	0.269	ปานกลาง
5. มีการพัฒนาระบบสาธารณูปโภคของชุมชนดีขึ้น เช่น ถนน	0.0	<u>100.0</u>	0.0	0.0	98.2	0.0	1.8	3.04	0.269	ปานกลาง

ที่มา : บริษัท เอสจีเอส (ประเทศไทย) จำกัด, 28 – 30 พฤศจิกายน พ.ศ. 2568

ในส่วนความพึงพอใจต่อกิจกรรมชุมชนสัมพันธ์ที่ทางโครงการฯ ดำเนินการในปี 2568 ผู้ตอบแบบสอบถามมีความพึงพอใจต่อการดูแลสังคมของโครงการฯ ในด้านต่าง ๆ รายละเอียด**ดังตารางที่ 8**

ตารางที่ 8 ความเห็นของครัวเรือน 0-3 กิโลเมตรจากที่ตั้งโครงการฯ ต่อความพึงพอใจต่อการดูแลสังคมของโครงการฯ

รายละเอียด	ระดับความพึงพอใจ (จำนวนตัวอย่าง/ร้อยละ)					ค่าเฉลี่ย	ค่า S.D.	แปลค่า
	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด			
1. กิจกรรมเกี่ยวกับสุขภาพ	0.0	0.0	93.3	6.7	0.0	3.07	0.251	ปานกลาง
2. กิจกรรมเกี่ยวกับการอนุรักษ์สิ่งแวดล้อม	0.0	0.0	90.7	9.3	0.0	3.09	0.291	ปานกลาง
3. กิจกรรมเกี่ยวกับการส่งเสริมการศึกษา	0.0	0.0	92.5	7.5	0.0	3.07	0.263	ปานกลาง
4. กิจกรรมเกี่ยวกับการพัฒนาความสัมพันธ์ชุมชน	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
5. กิจกรรมเกี่ยวกับการส่งเสริมศาสนา วัฒนธรรม	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
6. กิจกรรมการประชาสัมพันธ์และแจ้งข่าวสารของโรงงาน	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
7. กิจกรรมเกี่ยวกับการส่งเสริม/พัฒนาอาชีพ	0.0	0.0	94.8	5.2	0.0	2.05	0.223	น้อย
8. กิจกรรมเกี่ยวกับการพัฒนาชุมชน	0.0	0.0	25.4	74.6	0.0	3.75	0.436	มาก

ที่มา : บริษัท เอสจีเอส (ประเทศไทย) จำกัด, 28 – 30 พฤศจิกายน พ.ศ. 2568

ส่วนที่ 6 การประชาสัมพันธ์โครงการและการมีส่วนร่วมของประชาชน

ผู้ตอบแบบสอบถามส่วนใหญ่ไม่ต้องการรับทราบข้อมูลเพิ่มเติมเกี่ยวกับโครงการฯ ร้อยละ 96.6 รองลงมาระบุว่า ต้องการรับทราบ ร้อยละ 3.4 โดยต้องการรับทราบข้อมูลการมีส่วนร่วมกิจกรรมของบริษัทกับชุมชนมากที่สุด ร้อยละ 44.5

สำหรับรูปแบบการประชาสัมพันธ์ข้อมูลที่ผู้ตอบแบบสอบถามเห็นว่ามีความเหมาะสมและครอบคลุมกับกลุ่มเป้าหมายมากที่สุด ได้แก่ แจ้งข้อมูลผ่านวิทยุชุมชน/หอกระจายเสียชุมชน และจัดประชุมชี้แจงข้อมูลข่าวสารโดยตรงสัดส่วนเท่ากัน ร้อยละ 31.6 ทำจดหมาย/เอกสาร แจ้งต่อประชาชนโดยตรง ร้อยละ 26.3 แจ้งข้อมูลผ่านกำนัน ผู้ใหญ่บ้านหรือผู้นำชุมชน ร้อยละ 10.5 โดยผู้ตอบแบบสอบถามทั้งหมดระบุว่าหากทางโครงการฯ จัดกิจกรรมร่วมกับชุมชนท่านยินดีเข้าร่วมกิจกรรม

การช่วยเหลือและสนับสนุนด้านชุมชนของโครงการฯ ผู้ตอบแบบสอบถามส่วนใหญ่ไม่ต้องการให้ทางโครงการฯ เข้ามาช่วยเหลือส่งเสริมกิจกรรมชุมชน ร้อยละ 91.4 รองลงมาต้องการให้ทางโครงการฯ เข้ามาช่วยเหลือส่งเสริมกิจกรรมชุมชน ร้อยละ 8.6

โดยต้องการให้โครงการฯ สนับสนุนด้านสุขภาพมากที่สุด ร้อยละ 31.3 ทั้งนี้ผู้ตอบแบบสอบถามมีข้อเสนอแนะให้ทางโครงการฯ สนับสนุนกิจกรรมประเพณีในชุมชนและจัดกิจกรรมหรือประชาสัมพันธ์ข้อมูลข่าวสารให้มากขึ้น

5.2.2 ผลการสำรวจสภาพเศรษฐกิจ และสังคม ของครัวเรือนรัศมี 3-5 กิโลเมตรจากที่ตั้งโครงการฯ

การสำรวจสภาพเศรษฐกิจและสังคมของครัวเรือนที่อยู่รอบโครงการ รัศมี 3-5 กิโลเมตร ครอบคลุมพื้นที่ 13 ชุมชน จำนวนตัวอย่างทั้งหมด 115 ตัวอย่าง สามารถสรุปรายละเอียดได้ดังนี้

ส่วนที่ 1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม

ผู้ตอบแบบสอบถามส่วนใหญ่เป็นเพศหญิง ร้อยละ 73.9 และเป็นเพศชาย ร้อยละ 26.1 ซึ่ง ผู้ตอบแบบสอบถามมีอายุระหว่าง 41-50 ปี มากที่สุด ร้อยละ 56.5 รองลงมามีอายุระหว่าง 31-40 ปี ร้อยละ 43.5 โดย 3 อันดับแรก สำเร็จการศึกษาระดับอนุปริญญา/ปวส. หรือเทียบเท่า มากที่สุดร้อยละ 73.9 รองลงมา สำเร็จการศึกษาระดับมัธยมศึกษาตอนปลาย (ม.6)/ปวช. หรือเทียบเท่า ร้อยละ 20.9 และสำเร็จการศึกษาระดับปริญญาตรี ร้อยละ 5.2 ผู้ตอบแบบสอบถามส่วนใหญ่มีสถานภาพเป็นหัวหน้าครัวเรือน ร้อยละ 87.0 และผู้ตอบแบบสอบถามมีสถานภาพเป็นสมาชิกในครัวเรือน ร้อยละ 13.0 ได้แก่ คู่สมรส บุตร/ธิดา และบิดา/มารดา ซึ่ง ผู้ตอบแบบสอบถามทั้งหมดนับถือศาสนาพุทธ ส่วนใหญ่ระบุว่ามีสถานภาพสมรส/อยู่ด้วยกัน ร้อยละ 87.0 รองลงมาระบุว่ามีสถานภาพโสด ร้อยละ 13.0 ตามลำดับ

ด้านลักษณะการอยู่อาศัยทั้งหมดอยู่อาศัยแบบครอบครัวเดี่ยว (พ่อ แม่ และลูก) โดยแต่ละครัวเรือนมีจำนวนสมาชิกเฉลี่ย 4 คน เป็นเพศชายเฉลี่ย 2 คน และเป็นเพศหญิงเฉลี่ย 2 คน

สำหรับการตั้งถิ่นฐานและภูมิลำเนาของผู้ตอบแบบสอบถาม พบว่า ผู้ตอบแบบสอบถามส่วนใหญ่ย้ายมาจากที่อื่น ร้อยละ 52.2 โดยส่วนใหญ่ย้ายมาจากภาคตะวันออกเฉียงเหนือ ร้อยละ 48.3 และระบุว่าอยู่อาศัยในพื้นที่ระหว่าง 6-10 ปีไปมากที่สุด ร้อยละ 33.4 ซึ่งส่วนใหญ่ระบุว่า ย้ายมาเพื่อประกอบอาชีพ ร้อยละ 63.3 และระบุว่ามีภูมิลำเนาของอยู่ในพื้นที่ตั้งแต่เกิด ร้อยละ 47.8

ส่วนที่ 2 ข้อมูลเศรษฐกิจและสังคม

ผู้ตอบแบบสอบถามส่วนใหญ่ระบุว่า การประกอบอาชีพ 3 อันดับแรก คือ ประกอบอาชีพพนักงานบริษัท/ลูกจ้าง/พนักงานโรงแรม ร้อยละ 82.6 รองลงมาประกอบอาชีพค้าขาย/ธุรกิจส่วนตัว ร้อยละ 10.4 และประกอบอาชีพรับจ้างทั่วไป ร้อยละ 7.0 โดยทั้งหมดระบุว่า ไม่มีการประกอบอาชีพเสริมรวมทั้งระบุว่า ไม่มีปัญหาในการประกอบอาชีพแต่อย่างใด

ด้านรายได้ รายจ่ายของครัวเรือน พบว่า ครัวเรือนมีรายได้เฉลี่ย 32,000 บาทต่อเดือน และมีรายจ่ายเฉลี่ยอยู่ที่ประมาณ 25,000 บาทต่อเดือน

เมื่อพิจารณาความเพียงพอของรายได้เปรียบเทียบกับรายจ่ายของครัวเรือน พบว่า ผู้ตอบแบบสอบถามมีรายได้เพียงพอ แต่ไม่มีเก็บออม ร้อยละ 52.2 รองลงมามีรายได้เพียงพอ มีเหลือเก็บออม ร้อยละ 47.8

ส่วนที่ 3 ข้อมูลด้านสุขภาพอนามัย และสาธารณูปโภค

การเจ็บป่วย : ผู้ตอบแบบสอบถามส่วนใหญ่ระบุว่าในรอบ 1 ปีที่ผ่านมา สมาชิกในครัวเรือนระบุว่า สมาชิกในครัวเรือนเคยเจ็บป่วย ร้อยละ 58.3 โดย 3 อันดับแรก เคยเจ็บป่วยเป็นโรคหวัด/ทางเดินหายใจ ร้อยละ 35.7 รองลงมาเป็นโรคความดัน/โรคเกี่ยวกับระบบไหลเวียนเลือด ร้อยละ 23.8 และโรคผิวหนังและภูมิแพ้ ร้อยละ 11.9

การรักษาพยาบาล : เมื่อมีการเจ็บป่วยของสมาชิกในครัวเรือน ทั้งหมดจะเข้ารับการรักษาที่โรงพยาบาลของรัฐบาล/โรงพยาบาลส่งเสริมสุขภาพของตำบล โดยผู้ตอบแบบสอบถามทั้งหมดระบุว่า ไม่ประสบปัญหาในการรับบริการด้านสาธารณสุขแต่อย่างใด

ส่วนที่ 4 ข้อมูลด้านสภาพแวดล้อม และสังคมทั่วไปในปัจจุบันของชุมชน

ผู้ตอบแบบสอบถาทั้งหมดทราบและรู้จักโครงการฯ ซึ่งแหล่งข้อมูลที่รับทราบเกี่ยวกับโครงการฯ 3 อันดับแรก ได้แก่ เจ้าหน้าที่ของโครงการฯ ร้อยละ 76.3 รองลงมาทราบจากหนังสือพิมพ์ ร้อยละ 11.5 และจากหน่วยงานราชการต่างๆ ร้อยละ 4.6 โดยช่วง 1 ปีที่ผ่านมา ผู้ตอบแบบสอบถามส่วนใหญ่ไม่เคยเข้าร่วมทำกิจกรรมกับโครงการฯ แต่อย่างใด ร้อยละ 60.9 รองลงมาระบุว่า เคยเข้าร่วมงานบุญประเพณีมากที่สุด ร้อยละ 39.1

เมื่อสอบถามถึงระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่าง ๆ ของโครงการฯ พบว่า ผู้ตอบแบบสอบถามส่วนใหญ่ทราบ/รู้จัก ร้อยละ 73.9 รองลงมาไม่ทราบ/ไม่รู้จัก ร้อยละ 26.1

สำหรับความเชื่อมั่นในดำเนินงาน และการจัดการสิ่งแวดล้อมของโครงการฯ ผู้ตอบแบบสอบถามทั้งหมดเชื่อมั่นพอสมควร (หากมีอุบัติเหตุสามารถแก้ไขหรือควบคุมได้ทัน) โดยผู้ตอบแบบสอบถามส่วนใหญ่ทราบว่า โครงการมีการดำเนินการช่วยเหลือชุมชน ร้อยละ 87.0 รองลงมาระบุว่า ไม่ทราบ ร้อยละ 13.0

โดยผู้ตอบแบบสอบถามมีความคิดเห็นว่า โครงการฯ ให้ความช่วยเหลือชุมชน 3 อันดับแรก สนับสนุน สนับสนุนด้านกีฬามากที่สุด ร้อยละ 37.0 รองลงมาสนับสนุนด้านทุนการศึกษาและสนับสนุนด้านสาธารณูปโภค ร้อยละ 18.5 เท่ากัน และสนับสนุนทางด้านศาสนสถาน ร้อยละ 16.7 ซึ่งส่วนใหญ่ทราบว่า ในช่วง 1 ปี มีคนในชุมชนเข้ามาทำงานในพื้นที่โครงการฯ ร้อยละ 63.5 รวมทั้งทราบว่า โครงการฯ จะคัดคนเข้าทำงานโดยพิจารณาที่เหมาะสมกับตำแหน่งงาน ร้อยละ 61.7

ในช่วงปี 2568 ที่ผ่านมา ผู้ตอบแบบสอบถามให้ความเห็นว่า ไม่ทราบข้อมูลการจัดการสิ่งแวดล้อมเกี่ยวกับโครงการฯ ร้อยละ 69.6 รองลงมาระบุว่ารับทราบ ร้อยละ 30.4 โดยทราบจากเจ้าหน้าที่โครงการ

เมื่อสอบถามเกี่ยวกับกิจกรรมมวลชนสัมพันธ์ของโครงการและการเข้าไปมีส่วนร่วมในกิจกรรม พบว่า ผู้ตอบแบบสอบถามทั้งหมดรับทราบเกี่ยวกับกิจกรรม ซึ่งเมื่อสอบถามถึงการรับทราบ กิจกรรมเปิดบ้านต้อนรับแขกภายนอกเพื่อเข้าเยี่ยมชมโรงงาน (เปิดบ้าน) ในช่วงปี 2568 พบว่า ผู้ตอบแบบสอบถามส่วนใหญ่ระบุว่า ไม่ทราบเกี่ยวกับกิจกรรม ร้อยละ 52.2 รองลงมาระบุว่า รับทราบ ร้อยละ 47.8

ส่วนที่ 5 ความคิดเห็นเกี่ยวกับการดำเนินโครงการฯ

<u>ผลกระทบด้านสิ่งแวดล้อม</u>

ผลการสำรวจความคิดเห็นในเรื่องของผลกระทบทางด้านสิ่งแวดล้อมผู้ตอบแบบสอบถามทั้งหมดระว่าไม่ได้รับผลกระทบแต่อย่างใด รายละเอียดดัง**ตารางที่ 9**

ตารางที่ 9 ความเห็นของครัวเรือนรัศมี 3-5 กิโลเมตรจากที่ ตั้งโครงการฯ ต่อผลกระทบทางด้านสิ่งแวดล้อมที่ได้รับในปัจจุบัน

ประเภทของผลกระทบ	ผลกระทบ (ร้อยละ)		ระดับผลกระทบ (ร้อยละ)					ค่าเฉลี่ย	ค่า S.D.	แปลค่า
	ไม่มี	มี	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด			
1) ฝุ่นละออง	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
2) เสียงดัง	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
3) ความสั่นสะเทือน	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
4) น้ำเสีย	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
5) น้ำท่วมขัง	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
6) ขยะมูลฝอย	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
7) กลิ่นเหม็น	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
8) การจราจรติดขัด	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี
9) อุบัติเหตุจากการจราจร	100.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.000	ไม่มี

ที่มา : บริษัท เอสจีเอส (ประเทศไทย) จำกัด, 28 – 30 พฤศจิกายน พ.ศ. 2568

เมื่อสอบถามถึงความรู้สึกวิตกกังวลเกี่ยวกับกิจกรรมต่อโครงการฯ ผู้ตอบแบบสอบถามทั้งหมดระบุว่า ไม่มีความวิตกกังวลต่อโครงการฯ แต่อย่างใด ซึ่งในช่วงปี 2568 ที่ผ่านมา ผู้ตอบแบบสอบถามทั้งหมดมีความพึงพอใจต่อการปฏิบัติตามมาตรการลดผลกระทบด้านต่าง ๆ ของโครงการฯ ในระดับปานกลาง ซึ่งระบุว่า ไม่เคยได้รับผลกระทบเกี่ยวกับการดำเนินโครงการฯ แต่อย่างใด และจากการสอบถามเกี่ยวกับความคิดเห็นต่อการดำเนินงานของโครงการฯ พบว่า ผู้ตอบแบบสอบถามทั้งหมดเห็นว่าผลดีกับผลเสียพอๆกัน

<u>ผลดีด้านเศรษฐกิจ – สังคม จากการดำเนินงานของโครงการฯ</u>

ส่วนผลดีด้านเศรษฐกิจและสังคม จากการดำเนินงานโครงการฯ ได้รับผลดีในทุกด้าน รายละเอียดดัง**ตารางที่ 10**

ตารางที่ 10 ความเห็นของครัวเรือน 3-5 กิโลเมตรจากที่ตั้งโครงการฯ ต่อผลดีด้านเศรษฐกิจ–สังคม จากการดำเนินงานของโครงการฯ

ผลดีจากการดำเนินโครงการฯ	ผลดี (ร้อยละ)		ระดับผลดี (ร้อยละ)					ค่าเฉลี่ย	ค่า S.D.	แปลค่า
	ไม่มี	มี	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด			
ด้านเศรษฐกิจ - สังคม										
1. ทำให้ประชาชนในพื้นที่มีงานทำมากขึ้นจากการรับจ้างในโครงการฯ	0.0	100.0	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
2. ทำให้การค้าขายของร้านค้าปลีกและธุรกิจบริการต่าง ๆ ดีขึ้น	0.0	100.0	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
3. สภาพเศรษฐกิจของชุมชนดีขึ้น	0.0	100.0	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
4. ได้รับการสนับสนุนกิจกรรมชุมชนจากโครงการฯมากขึ้น	0.0	100.0	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
5. มีการพัฒนาระบบสาธารณูปโภคของชุมชนดีขึ้น เช่น ถนน	0.0	100.0	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง

ที่มา : บริษัท เอสจีเอส (ประเทศไทย) จำกัด, 28 – 30 พฤศจิกายน พ.ศ. 2568

ในส่วนความพึงพอใจต่อกิจกรรมชุมชนสัมพันธ์ที่ทางโครงการฯ ดำเนินการในปี 2568 ผู้ตอบแบบสอบถามมีความพึงพอใจต่อการดูแลสังคมของโครงการฯ ในด้านต่าง ๆ รายละเอียด**ดังตารางที่ 11**

ตารางที่ 11 ความเห็นของครัวเรือน 3-5 กิโลเมตรจากที่ตั้งโครงการฯ ต่อความพึงพอใจต่อการดูแลสังคมของโครงการฯ

รายละเอียด	ระดับความพึงพอใจ (จำนวนตัวอย่าง/ร้อยละ)					ค่าเฉลี่ย	ค่า S.D.	แปลค่า
	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด			
1. กิจกรรมเกี่ยวกับสุขภาพ	0.0	0.0	81.7	18.3	0.0	3.18	0.388	ปานกลาง
2. กิจกรรมเกี่ยวกับการอนุรักษ์สิ่งแวดล้อม	0.0	0.0	87.0	0.0	13.0	3.26	0.677	ปานกลาง
3. กิจกรรมเกี่ยวกับการส่งเสริมการศึกษา	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
4. กิจกรรมเกี่ยวกับการพัฒนาความสัมพันธ์ชุมชน	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
5. กิจกรรมเกี่ยวกับการส่งเสริมศาสนา วัฒนธรรม	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
6. กิจกรรมการประชาสัมพันธ์และแจ้งข่าวสารของโรงงาน	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
7. กิจกรรมเกี่ยวกับการส่งเสริม/พัฒนาอาชีพ	0.0	0.0	98.3	1.7	0.0	3.02	0.131	ปานกลาง
8. กิจกรรมเกี่ยวกับการพัฒนาชุมชน	0.0	0.0	80.0	20.0	0.0	3.20	0.402	ปานกลาง

ที่มา : บริษัท เอสจีเอส (ประเทศไทย) จำกัด, 28 – 30 พฤศจิกายน พ.ศ. 2568

ส่วนที่ 6 การประชาสัมพันธ์โครงการและการมีส่วนร่วมของประชาชน

ผู้ตอบแบบสอบถามส่วนใหญ่ไม่ต้องการรับทราบข้อมูลเพิ่มเติมเกี่ยวกับโครงการฯ ร้อยละ 82.6 รองลงมาระบุว่า ต้องการรับทราบ ร้อยละ 17.4 โดยต้องการรับทราบข้อมูลการมีส่วนร่วมกิจกรรมของบริษัทกับชุมชน ร้อยละ 50.0 ข้อมูลข่าวสารด้านการรับสมัครงานและข้อมูลข้อมูลโครงการและกิจกรรมต่างๆ ร้อยละ 25.0 สัดส่วนเท่ากัน

สำหรับรูปแบบการประชาสัมพันธ์ข้อมูลที่ผู้ตอบแบบสอบถามเห็นว่ามีความเหมาะสมและครอบคลุมกับกลุ่มเป้าหมายมากที่สุด ได้แก่ แจ้งข้อมูลผ่านกำนัน ผู้ใหญ่บ้าน หรือผู้นำชุมชน โดยผู้ตอบแบบสอบถามทั้งหมดระบุว่าหากทางโครงการฯ จัดกิจกรรมร่วมกับชุมชนท่านยินดีเข้าร่วมกิจกรรม

การช่วยเหลือและสนับสนุนด้านชุมชนของโครงการฯ ผู้ตอบแบบสอบถามส่วนใหญ่ไม่ต้องการให้ทางโครงการฯ เข้ามาช่วยเหลือส่งเสริมกิจกรรมชุมชน ร้อยละ 56.5 ส่วนที่เหลือต้องการให้ทางโครงการฯ เข้ามาช่วยเหลือส่งเสริมกิจกรรมชุมชน ร้อยละ 43.5 โดยต้องการให้โครงการฯ สนับสนุนด้านการศึกษามากที่สุด ร้อยละ 40.0

ทั้งนี้ผู้ตอบแบบสอบถามมีข้อเสนอแนะให้ทางโครงการฯ จัดกิจกรรมหรือประชาสัมพันธ์ข้อมูลข่าวสารให้มากขึ้นและสนับสนุนกิจกรรมประเพณีในชุมชน

5.3 ผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มหน่วยงานราชการ โรงเรียน และวัด

ส่วนที่ 1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม

ผู้ตอบแบบสอบถามส่วนใหญ่เป็นเพศหญิง ร้อยละ 60.0 และเพศหญิง ร้อยละ 40.0 มีอายุเฉลี่ย 50 ปี ผู้ตอบแบบสอบถามเป็นเจ้าอาวาสวัดมากที่สุด ร้อยละ 70.0 ซึ่งมีระยะเวลาในการดำรงตำแหน่งระหว่าง 6-10 ปี ร้อยละ 45.5 โดยมีหน้าที่ดูแลความเรียบร้อยภายในวัด

ส่วนที่ 2 การตรวจสอบเรื่องร้องเรียน

เมื่อสอบถามการเรื่องร้องเรียนจากชุมชนเกี่ยวกับกิจกรรมของโครงการฯ ในช่วง 1 ปีที่ผ่านมา ผู้ตอบแบบสอบถามทั้งหมดระบุว่า ไม่เคยได้รับเรื่องร้องเรียนแต่อย่างใด

ส่วนที่ 3 ความคิดเห็นเกี่ยวกับการดำเนินโครงการฯ

เมื่อสอบถามเกี่ยวกับความวิตกกังวลต่อโครงการฯ ผู้ตอบแบบสอบถามทั้งหมดระบุว่า ไม่มีความวิตกกังวลแต่อย่างใด

เมื่อสอบถามเกี่ยวกับความเชื่อมั่นต่อระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่าง ๆ ของโครงการฯ ผู้ตอบแบบสอบถามส่วนใหญ่มีความเชื่อมั่นพอสมควร (หากมีอุบัติเหตุสามารถแก้ไขหรือควบคุมได้ทัน) ร้อยละ 60.0 รองลงมาระบุว่า มีความเชื่อมั่นสูง ร้อยละ 40.0

โดยภาพรวมช่วง 1 ปี ผู้ตอบแบบสอบถามมีความพึงพอใจต่อการปฏิบัติตามมาตรการลดผลกระทบด้านต่าง ๆ ของโครงการฯ ในระดับปานกลาง ทั้งนี้ทั้งหมดระบุว่า ไม่เคยได้รับผลกระทบเกี่ยวกับการดำเนินกิจกรรมของโครงการฯ แต่อย่างใด

ส่วนที่ 4 การประชาสัมพันธ์โครงการและการมีส่วนร่วมของประชาชน

ผู้ตอบแบบสอบถามทั้งหมดทราบ/รู้จักโครงการฯ โดย 3 อันดับแรก ทราบจากเจ้าหน้าที่ของโครงการฯ มากที่สุด ร้อยละ 30.0 รองลงมาทราบจากผู้นำชุมชนและหน่วยงานราชการต่างๆ ร้อยละ 20.0 สัดส่วนเท่ากัน ทราบจากเพื่อนบ้านและเคยเข้าร่วมประชุมกับทางโครงการฯ ร้อยละ 15.0 สัดส่วนเท่ากัน ทั้งนี้มีความคิดเห็นว่า การประชาสัมพันธ์/ให้ข้อมูลข่าวสารของโครงการฯ เพียงพอแล้วไม่ต้องการรับทราบข้อมูลเพิ่มเติม ร้อยละ 60.0 รองลงมาระบุว่าต้องการรับทราบข้อมูลช่องทางการติดต่อเพื่อขอความช่วยเหลือด้านต่างๆ ร้อยละ 40.0

สำหรับรูปแบบการประชาสัมพันธ์ข้อมูลที่ผู้ตอบแบบสอบถามเห็นว่า มีความเหมาะสม และครอบคลุมกับกลุ่มเป้าหมายมากที่สุด ได้แก่ ทำจดหมาย/เอกสาร แจ้งต่อประชาชนโดยตรง ร้อยละ 40.0 รองลงมาแจ้งข้อมูลผ่านกำนัน ผู้ใหญ่บ้านหรือผู้นำชุมชน และจัดประชุมชี้แจงข้อมูลข่าวสารโดยตรง ร้อยละ 25.0 สัดส่วนเท่ากัน ส่วนที่เหลือแจ้งข้อมูลผ่านวิทยุชุมชน/หอกระจายเสียชุมชน ร้อยละ 10.0 ซึ่งผู้ตอบแบบสอบถามทั้งหมดระบุว่า หากทางโครงการฯ จัดกิจกรรมร่วมกับชุมชนยินดีเข้าร่วมกิจกรรม

ในด้านการช่วยเหลือ และสนับสนุนงานด้านชุมชนของทางโครงการฯ ผู้ตอบแบบสอบถามทั้งหมดต้องการให้ทางโครงการฯ เข้ามาช่วยเหลือส่งเสริมกิจกรรมชุมชน ได้แก่ สนับสนุนกิจกรรมด้านศาสนาและประเพณีต่าง ๆ อย่างต่อเนื่อง ร้อยละ 60.0 สนับสนุนด้านเศรษฐกิจและสุขภาพ ร้อยละ 30.0 และกิจกรรมส่งเสริมนักเรียนด้านต่าง ๆ ร้อยละ 10.0

ในส่วนความพึงพอใจต่อกิจกรรมชุมชนสัมพันธ์ที่ทางโครงการฯ ดำเนินการในปี 2568 ผู้ตอบแบบสอบถามมีความพึงพอใจต่อการดูแลสังคมของโครงการฯ ในด้านต่าง ๆ รายละเอียด**ดังตารางที่ 9**

ตารางที่ 12 ความเห็นของหน่วยงานต่อความพึงพอใจต่อการดูแลสังคมของโครงการฯ

รายละเอียด	ระดับความพึงพอใจ (จำนวนตัวอย่าง/ร้อยละ)					ค่าเฉลี่ย	ค่า S.D.	แปลค่า
	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด			
1. กิจกรรมเกี่ยวกับสุขภาพ	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
2. กิจกรรมเกี่ยวกับการอนุรักษ์สิ่งแวดล้อม	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
3. กิจกรรมเกี่ยวกับการส่งเสริมการศึกษา	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
4. กิจกรรมเกี่ยวกับการพัฒนาความสัมพันธ์ชุมชน	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
5. กิจกรรมเกี่ยวกับการส่งเสริมศาสนา วัฒนธรรม	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
6. กิจกรรมการประชาสัมพันธ์และแจ้งข่าวสารของโรงงาน	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
7. กิจกรรมเกี่ยวกับการส่งเสริม/พัฒนาอาชีพ	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง
8. กิจกรรมเกี่ยวกับการพัฒนาชุมชน	0.0	0.0	100.0	0.0	0.0	3.00	0.000	ปานกลาง

ที่มา : บริษัท เอสจีเอส (ประเทศไทย) จำกัด, 28 - 30 พฤศจิกายน พ.ศ. 2568

โดยผู้ตอบแบบสอบถามไม่มีมีข้อเสนอแนะเกี่ยวกับโครงการฯ แต่อย่างใด

ภาคผนวก

ภาคผนวกที่ 1
แบบสอบถามสภาพเศรษฐกิจ สังคม และความคิดเห็น ของผู้นำชุมชน

B62

ผู้สอบถาม.....

วัน/เดือน/ปี.....

แบบสอบถามสภาพเศรษฐกิจ สังคม และความคิดเห็นของผู้นำชุมชน ที่มีต่อ
โครงการโรงไฟฟ้าพลังความร้อน ขนาด 6 เมกะวัตต์ (B62)
ของบริษัท ทีพีไอ จำกัด (มหาชน)

ชื่อ-นามสกุล ผู้ตอบแบบสอบถาม.....

ที่อยู่ บ้านเลขที่.....หมู่ที่.....ชื่อชุมชน.....ตำบล.....

อำเภอ.....จังหวัด.....หมายเลขโทรศัพท์.....

ส่วนที่ 1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม

1.1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม

1. เพศ ❒ 1) ชาย ❒ 2) หญิง
2. อายุ ..... ปี
3. ศาสนา ❒ 1) พุทธ ❒ 2) คริสต์ ❒ 3) อิสลาม ❒ 4) อื่นๆ (ระบุ) .....
4. ระดับการศึกษาสูงสุด
   - ❒ 1) ไม่ได้เรียนหนังสือ
   - ❒ 2) ประถมศึกษาตอนต้น (ป.4)
   - ❒ 3) ประถมศึกษาตอนปลาย (ป.6)
   - ❒ 4) มัธยมศึกษาตอนต้น (ม.3)
   - ❒ 5) มัธยมศึกษาตอนปลาย (ม.6)/ปวช. หรือเทียบเท่า
   - ❒ 6) อนุปริญญา/ปวส. หรือเทียบเท่า
   - ❒ 7) ปริญญาตรี
   - ❒ 8) สูงกว่าปริญญาตรี
5. ตำแหน่ง/หน้าที่ในชุมชน/หน่วยงาน/องค์กร .....
6. ระยะเวลาที่ปฏิบัติหน้าที่ในชุมชน/หน่วยงาน/องค์กร
   - ❒ 1) น้อยกว่า 1 ปี
   - ❒ 2) ระหว่าง 1-5 ปี
   - ❒ 3) ระหว่าง 6-10 ปี
   - ❒ 4) ระหว่าง 11-15 ปี
   - ❒ 5) ระหว่าง 16-20 ปี
   - ❒ 6) มากกว่า 20 ปีขึ้นไป

ส่วนที่ 2 ข้อมูลทั่วไปด้านเศรษฐกิจ สังคมของชุมชน

2.1 อาชีพหลักของประชาชนในชุมชน (เลือกเพียงข้อเดียว)

- ❒ 1) รับราชการ/รัฐวิสาหกิจ
- ❒ 2) พนักงานบริษัท/โรงงานอุตสาหกรรม
- ❒ 3) ค้าขาย/ธุรกิจส่วนตัว
- ❒ 4) รับจ้างทั่วไป
- ❒ 5) เกษตรกรรม/เลี้ยงสัตว์
- ❒ 6) อื่นๆ (ระบุ).....

2.2 อาชีพเสริมของประชาชนในชุมชน (ตอบได้มากกว่า 1 อาชีพ)

- ❒ 1) ไม่มี
- ❒ 2) มี โปรดระบุ.....

2.3 ปัญหาในการประกอบอาชีพของประชาชนในชุมชนของท่าน

- ❒ 1) ไม่มี
- ❒ 2) มี ได้แก่.....

2.4 ฐานะทางเศรษฐกิจของประชาชนในชุมชน

- ❒ 1) ฐานะทางเศรษฐกิจดี
- ❒ 2) ฐานะทางเศรษฐกิจปานกลาง
- ❒ 3) ฐานะทางเศรษฐกิจไม่ดี

ส่วนที่ 3 ข้อมูลด้านสุขภาพอนามัยและสาธารณูปโภคของชุมชน

3.1 สุขภาพอนามัยและสาธารณสุข

ปัญหาสุขภาพที่เกิดขึ้นในชุมชนในรอบ 1 ปีที่ผ่านมา

❒ 1) ไม่มีปัญหา ❒ 2) มีปัญหา (ระบุ)

.....

.....

การแก้ปัญหาสุขภาพอนามัยและสาธารณสุข

❒ 1) ไม่มีการแก้ไข ❒ 2) วิธีการแก้ไขปัญหา (ระบุ)

.....

.....

3.2 ระบบสาธารณูปโภคและโครงสร้างพื้นฐานของชุมชน เช่น การไฟฟ้า การประปา ถนน

ปัญหาสาธารณูปโภคในชุมชนในรอบ 1 ปีที่ผ่านมา

❒ 1) ไม่มีปัญหา ❒ 2) มีปัญหา (ระบุ)

.....

.....

การแก้ปัญหาสาธารณูปโภคในชุมชนของท่าน

❒ 1) ไม่มีการแก้ไข ❒ 2) วิธีการแก้ไขปัญหา (ระบุ)

.....

.....

ส่วนที่ 4 การรับทราบข้อมูล/ข่าวสารและการมีส่วนร่วมกิจกรรมของโครงการฯ

4.1 ท่านทราบหรือรู้จักโครงการฯ หรือไม่

❒ 1) ไม่ทราบ/ไม่รู้จัก **(ข้ามไปตอบส่วนที่ 7)** ❒ 2) ทราบ/รู้จัก

4.2 ถ้าทราบ ท่านทราบจากแหล่งใด (ตอบได้มากกว่า 1 ข้อ)

❒ 1) เพื่อนบ้านเล่าให้ฟัง ❒ 2) ผู้นำชุมชน ❒ 3) หน่วยงานราชการต่างๆ

❒ 4) หนังสือพิมพ์ ❒ 5) เจ้าหน้าที่ของโครงการฯ ❒ 6) เคยเข้าร่วมประชุมกับทางโครงการฯ

❒ 7) ได้ร่วมกิจกรรมกับทางโครงการฯ ❒ 8) อื่นๆ (ระบุ).....

4.3 ในช่วง 1 ปีที่ผ่านมา ท่านเคยเข้าร่วมกิจกรรมกับโครงการฯ หรือไม่

❒ 1) ไม่เคย

❒ 2) เคยเข้าร่วม ระบุกิจกรรม.....

.....

4.4 ท่านมีความเชื่อมั่นต่อระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่างๆ ของโครงการฯ มากน้อยเพียงใด

❒ 1) เชื่อมั่นสูง ❒ 2) เชื่อมั่นพอสมควร (หากมีอุบัติเหตุสามารถแก้ไขหรือควบคุมได้ทัน)

❒ 3) ไม่มีความเชื่อมั่น (เมื่อมีอุบัติเหตุไม่สามารถควบคุมได้) ❒ 4) ไม่ทราบ/ไม่แน่ใจ

4.5 ท่านทราบหรือไม่ว่าโครงการมีการดำเนินการช่วยเหลือชุมชน

❒ 1) ไม่ทราบ **(ข้ามไปตอบส่วนที่ 5)** ❒ 2) ทราบ ❒ 3) ไม่แน่ใจ

4.6 โครงการฯ เคยให้ความช่วยเหลือชุมชนด้านใดบ้าง (ตอบได้มากกว่า 1 ข้อ)

❒ 1) สนับสนุนด้านทุนการศึกษา ❒ 2) สนับสนุนด้านกีฬา ❒ 3) สนับสนุนด้านสาธารณูปโภค

❒ 4) สนับสนุนทางด้านศาสนสถาน ❒ 5) สนับสนุนด้านสุขภาพอนามัย ❒ 6) อื่นๆ (ระบุ).....

4.7 ท่านทราบหรือไม่ว่ามีคนในชุมชนเข้ามาทำงานในพื้นที่โครงการฯ ในช่วง 1 ปี

❒ 1) ไม่ทราบ ❒ 2) ทราบ ❒ 3) ไม่แน่ใจ

ส่วนที่ 5 การตรวจสอบเรื่องร้องเรียน

5.1 ในช่วง 1 ปีที่ผ่านมา ท่านเคยได้รับเรื่องร้องเรียนจากชุมชนเกี่ยวกับกิจกรรมของโครงการฯ หรือไม่

❒ 1) ไม่มี **(ข้ามไปตอบส่วนที่ 6)**

❒ 2) มี เรื่อง.....

5.2 เมื่อได้รับเรื่องร้องเรียนจากลูกบ้าน ท่านได้แจ้งไปยังหน่วยงานใด

❒ 1) บริษัท ทีทีไอ โพลีน จำกัด (มหาชน) ❒ 2) หน่วยงานราชการ ❒ 3) อื่นๆ (ระบุ).....

5.3 เมื่อตรวจสอบข้อร้องเรียนแล้วเป็นเหตุจากกิจกรรมของบของโครงการฯ หรือไม่

❒ 1) ไม่ใช่ **(ข้ามไปตอบส่วนที่ 6)** ❒ 2) ใช่ ระบุ.....

5.4 ทางโครงการฯ ได้แก้ไขข้อร้องเรียนหรือไม่

❒ 1) แก้ไข ❒ 2) ไม่ได้ดำเนินการแก้ไข เนื่องจาก.....

ส่วนที่ 6 ความคิดเห็นเกี่ยวกับการดำเนินโครงการฯ

6.1 ท่านมีความรู้สึกวิตกกังวลต่อโครงการฯ หรือไม่อย่างไร

❒ 1) ไม่วิตกกังวล ❒ 2) วิตกกังวล ❒ 3) ไม่มีความเห็น

6.2 ท่านมีความเชื่อมั่นต่อระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่างๆ ของโครงการฯ มากน้อยเพียงใด

❒ 1) เชื่อมั่นสูง ❒ 2) เชื่อมั่นพอสมควร (หากมีอุบัติเหตุสามารถแก้ไขหรือควบคุมได้ทัน)

❒ 3) ไม่มีความเชื่อมั่น (เมื่อมีอุบัติเหตุไม่สามารถควบคุมได้)

❒ 4) ไม่ทราบ/ไม่แน่ใจ

6.3 โดยภาพรวมช่วง 1 ปี ท่านมีความพึงพอใจต่อการปฏิบัติตามมาตรการลดผลกระทบด้านต่างๆ ของโครงการฯ ในระดับใด

❒ 1) น้อยที่สุด ❒ 2) น้อย ❒ 3) ปานกลาง

❒ 4) มาก ❒ 5) มากที่สุด ❒ 6) ควรปรับปรุง ระบุ.....

6.4 ในช่วง 1 ปีที่ผ่านมา ชุมชนของท่านเคยได้รับผลกระทบเกี่ยวกับการดำเนินกิจกรรมของโครงการฯ หรือไม่

❒ 1) ไม่มี ❒ 2) เคย ระบุ.....

6.5 ในช่วงปี 2568 ที่ผ่านมา ท่านคิดว่าการดำเนินงานของโครงการฯ มีผลต่อชุมชนหรือชีวิตของท่านอย่างไร

❒ 1) ผลดีมากกว่าผลเสีย ❒ 2) ผลเสียมากกว่าผลดี ❒ 3) ผลดีกับผลเสียพอๆกัน

❒ 4) ไม่แน่ใจ ❒ 5) ไม่มีความเห็น

6.6 ท่านคิดว่าการโครงการฯ มีผลดีต่อชุมชนของท่านหรือไม่ และในด้านใด

ผลดีจากการดำเนินโครงการฯ	ผลดี		ระดับผลดี				
	ไม่มี	มี	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด
1. ทำให้ประชาชนในพื้นที่มีงานทำมากขึ้นจากการรับจ้างในโครงการฯ							
2. ทำให้การค้าขายของร้านค้าปลีกและธุรกิจบริการต่างๆ ดีขึ้น							
3. สภาพเศรษฐกิจของชุมชนดีขึ้น							
4. ได้รับการสนับสนุนกิจกรรมชุมชนจากโครงการฯมากขึ้น							
5. มีการพัฒนาระบบสาธารณูปโภคของชุมชนดีขึ้น เช่น ถนน							
6. อื่นๆ ระบุ.....							

6.7 ท่านมีความพึงพอใจต่อกิจกรรมชุมชนสัมพันธ์ที่ทางโครงการฯ ดำเนินการในปี 2568 ระดับใด

กิจกรรม	ระดับความพึงพอใจ				
	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด
1. กิจกรรมเกี่ยวกับสุขภาพ					
2. กิจกรรมเกี่ยวกับการอนุรักษ์สิ่งแวดล้อม					
3. กิจกรรมเกี่ยวกับการส่งเสริมการศึกษา					
4. กิจกรรมเกี่ยวกับการพัฒนาความสัมพันธ์ชุมชน					
5. กิจกรรมเกี่ยวกับการส่งเสริมศาสนา วัฒนธรรม					
6. กิจกรรมการประชาสัมพันธ์และแจ้งข่าวสารของโรงงาน					
7. กิจกรรมเกี่ยวกับการส่งเสริม/พัฒนาอาชีพ					
8. กิจกรรมเกี่ยวกับการพัฒนาชุมชน					

ส่วนที่ 7 การประชาสัมพันธ์โครงการและการมีส่วนร่วมของประชาชน

7.1 ท่านต้องการรับทราบข้อมูลเพิ่มเติมเกี่ยวกับโครงการฯ หรือไม่

❒ 1) ไม่ต้องการทราบ **(ข้ามไปตอบข้อ 7.3)**

❒ 2) ต้องการทราบ เรื่อง.....

7.2 รูปแบบ/วิธีการใดที่เหมาะสมที่ทำให้ท่านและชุมชนได้รับรู้ข้อมูลเกี่ยวกับโครงการฯ มากที่สุด (ตอบได้มากกว่า 1 ข้อ)

❒ 1) ทำจดหมาย/เอกสาร แจ้งต่อประชาชนโดยตรง ❒ 2) แจ้งข้อมูลผ่านกำนัน ผู้ใหญ่บ้าน หรือผู้นำชุมชน

❒ 3) แจ้งข้อมูลผ่านวิทยุชุมชน/หอกระจายเสียงชุมชน ❒ 4) จัดประชุมชี้แจงข้อมูลข่าวสารโดยตรง

❒ 5) อื่นๆ (ระบุ).....

7.3 หากทางโครงการฯ จัดกิจกรรมร่วมกับชุมชนท่านอินดีเข้าร่วมหรือไม่

❒ 1) ยินดีเข้าร่วม ❒ 2) ไม่ยินดี เนื่องจาก.....

7.4 ท่านต้องการให้ทางโครงการฯ ส่งเสริมกิจกรรมด้านใดให้กับชุมชนบ้าง

❒ 1) ไม่ต้องการ

❒ 2) ต้องการ ระบุ.....

7.5 ข้อเสนอแนะอื่นๆ เกี่ยวกับโครงการฯ

1) .....

2) .....

3) .....

*****ขอขอบคุณทุกท่านที่ให้ความร่วมมือในการตอบแบบสอบถาม*****

หนังสือยินยอมในการเก็บรวบรวม/ใช้/เปิดเผยข้อมูลส่วนบุคคล

บริษัท เอสจีเอส (ประเทศไทย) จำกัด ได้ให้ความสำคัญกับความเป็นส่วนตัวของท่าน ดังนั้น บริษัทฯ จึงขอความยินยอมจากท่านเพื่อการเก็บรวบรวมข้อมูล เช่น **ชื่อ – นามสกุล ที่อยู่ หมายเลขโทรศัพท์ เพศ อายุ ศาสนา สถานภาพ การศึกษา และตำแหน่ง** เป็นต้น โดยได้มีวัตถุประสงค์เพื่อใช้ประมวลผลจากการสำรวจสภาพเศรษฐกิจสังคม สิ่งแวดล้อม ตลอดจนความคิดเห็นต่อโครงการ เพื่อนำมาประกอบการจัดทำรายงานการติดตามตรวจสอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม

บริษัทฯ จะไม่เปิดเผยข้อมูลส่วนบุคคลของท่านให้แก่บุคคลอื่นเว้นแต่เป็นการเปิดเผยต่อผู้ที่บริษัทฯ มอบหมายให้เป็นผู้ประมวลผลข้อมูลส่วนบุคคลเท่านั้น ท่านมีสิทธิ์ปฏิเสธการยินยอมให้บริษัทฯ รวบรวม ใช้ และ/หรือเปิดเผยข้อมูลส่วนบุคคลของท่านเพื่อวัตถุประสงค์ตามที่ระบุไว้ข้างต้น

☐ ข้าพเจ้ายินยอม

☐ ข้าพเจ้าไม่ยินยอม

ข้าพเจ้ารับทราบว่าข้าพเจ้ามีสิทธิถอนความยินยอมที่ให้ไว้ข้างต้นได้ทุกเมื่อ

ลายมือชื่อ.....

ชื่อ – นามสกุล.....

วันที่.....

ภาคผนวกที่ 2

แบบสอบถามสภาพเศรษฐกิจ สังคม และความคิดเห็น

ของตัวแทนครัวเรือน

B62

ผู้สอบถาม.....

วันเดือนปี.....

แบบสอบถามสภาพเศรษฐกิจ สังคม และความคิดเห็นของประชาชน ที่มีต่อ
โครงการโรงไฟฟ้าพลังความร้อน ขนาด 6 เมกะวัตต์ (B62)
ของบริษัท ทีพีไอ จำกัด (มหาชน)

ชื่อ-นามสกุล ผู้ตอบแบบสอบถาม.....

ที่อยู่ บ้านเลขที่.....หมู่ที่.....ชื่อชุมชน.....ตำบล.....

อำเภอ.....จังหวัด.....หมายเลขโทรศัพท์.....

ส่วนที่ 1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม

1.1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม

1. เพศ ❒ 1) ชาย ❒ 2) หญิง
2. อายุ
   ❒ 1) 20-30 ปี ❒ 2) 31-40 ปี ❒ 3) 41-50 ปี
   ❒ 4) 51-60 ปี ❒ 5) มากกว่า 60 ปี
3. ศาสนา ❒ 1) พุทธ ❒ 2) คริสต์ ❒ 3) อิสลาม ❒ 4) อื่นๆ (ระบุ) .....
4. สถานภาพแต่งงาน ❒ 1) โสด ❒ 2) แต่งงาน/อยู่ด้วยกัน ❒ 3) หย่า/แยกทางกัน ❒ 4) หม้าย
5. ระดับการศึกษาสูงสุด
   ❒ 1) ไม่ได้เรียนหนังสือ ❒ 2) ประถมศึกษาตอนต้น (ป.4)
   ❒ 3) ประถมศึกษาตอนปลาย (ป.6) ❒ 4) มัธยมศึกษาตอนต้น (ม.3)
   ❒ 5) มัธยมศึกษาตอนปลาย (ม.6)/ปวช. หรือเทียบเท่า ❒ 6) อนุปริญญา/ปวส. หรือเทียบเท่า
   ❒ 7) ปริญญาตรี ❒ 8) สูงกว่าปริญญาตรี

1.2 โครงสร้างของครัวเรือน

1. สถานภาพในครัวเรือน ❒ 1) หัวหน้าครัวเรือน ❒ 2) สมาชิกในครัวเรือน (ระบุ) .....
2. ลักษณะการอยู่อาศัย ❒ 1) อยู่คนเดียว ❒ 2) ครอบครัวเดี่ยว (พ่อ แม่ และลูก)
   ❒ 3) ครอบครัวขยาย (อยู่รวมกันแบบญาติ)
   ❒ 4) ครัวเรือนที่อยู่รวมกันแบบไม่ใช่ญาติ ❒ 5) อื่นๆ (ระบุ) .....
3. จำนวนสมาชิกในครัวเรือน (รวมตัวท่านเอง) รวมทั้งหมด ..... คน
   แบ่งออกเป็น ชาย ..... คน หญิง ..... คน

1.3 ภูมิลำเนาเดิม (ตามทะเบียนราษฎร์)

1. ภูมิลำเนา ❒ 1) อยู่ที่นี่ตั้งแต่เกิด (ข้ามไปตอบส่วนที่ 2) ❒ 2) ย้ายมาจากที่อื่น
2. ย้ายมาจาก ❒ 1) ภาคเหนือ ❒ 2) ภาคกลาง ❒ 3) ภาคตะวันออกเฉียงเหนือ
   ❒ 4) ภาคใต้ ❒ 5) ภาคตะวันออก

3. ระยะเวลาที่ย้ายมา ❒ 1) น้อยกว่า 1 ปี ❒ 2) ระหว่าง 1-5 ปี ❒ 3) ระหว่าง 6-10 ปี
   ❒ 4) ระหว่าง 11-15 ปี ❒ 5) ระหว่าง 16-20 ปี ❒ 6) มากกว่า 20 ปีขึ้นไป
4. สาเหตุการย้ายมา ❒ 1) เพื่อประกอบอาชีพ ❒ 2) ย้ายตามญาติ/พี่น้อง ❒ 3) แต่งงานกับคนในพื้นที่
   ❒ 4) เพื่อการศึกษา ❒ 5) อื่นๆ (ระบุ).....

ส่วนที่ 2 ข้อมูลด้านเศรษฐกิจของครัวเรือน

2.1 อาชีพหลักของครัวเรือนท่าน (เลือกเพียงข้อเดียว)

❒ 1) รับราชการ/รัฐวิสาหกิจ ❒ 2) พนักงานบริษัท/พนักงานโรงแรม/โรงงานอุตสาหกรรม
❒ 3) ค้าขาย/ธุรกิจส่วนตัว ❒ 4) รับจ้างทั่วไป
❒ 5) เกษตรกรรม/เลี้ยงสัตว์ ❒ 6) อื่นๆ (ระบุ).....

หมายเหตุ : อาชีพที่สร้างรายได้มากที่สุดถือเป็นอาชีพหลัก

2.2 อาชีพรอง/อาชีพเสริมของครัวเรือนท่าน (ตอบได้มากกว่า 1 อาชีพ)

❒ 1) ไม่มี
❒ 2) มี โปรดระบุ.....

2.3 ครัวเรือนของท่านเคยมีปัญหาในการประกอบอาชีพหรือไม่

❒ 1) ไม่มี
❒ 2) มี เนื่องจาก.....

2.4 รายได้รวมของครัวเรือน โดยประมาณ .....บาท/เดือน

2.5 รายจ่ายรวมของครัวเรือน โดยประมาณ .....บาท/เดือน

2.6 ครัวเรือนของท่านมีรายได้เพียงพอกับรายจ่ายหรือไม่

❒ 1) เพียงพอ มีเหลือเก็บออม ❒ 2) เพียงพอ แต่ไม่มีเก็บออม
❒ 3) ไม่เพียงพอ แต่ไม่มีหนี้สิน ❒ 4) ไม่เพียงพอ มีหนี้สิน

ส่วนที่ 3 ข้อมูลด้านสุขภาพอนามัยและสาธารณูปโภค

3.1 ในรอบ 1 ปีที่ผ่านมาจนถึงปัจจุบันสมาชิกในครัวเรือนของท่านเคยมีการเจ็บป่วย หรือไม่

❒ 1) ไม่เคย **(ข้ามไปข้อ 3.3)** ❒ 2) เคย

3.2 ถ้าเคย โรคที่เจ็บป่วยหรืออาการที่พบบ่อย มีโรคใดบ้าง (ตอบได้มากกว่า 1 ข้อ)

❒ 1) โรคหวัด/ทางเดินหายใจ ❒ 2) โรคเกี่ยวกับระบบทางเดินอาหาร
❒ 3) โรคเกี่ยวกับระบบกล้ามเนื้อและกระดูก ❒ 4) โรคความดัน/โรคเกี่ยวกับระบบไหลเวียนเลือด
❒ 5) โรคเกี่ยวกับหู/ตา/ฟัน ❒ 6) โรคผิวหนังและภูมิแพ้
❒ 7) โรคเบาหวาน ❒ 8) โรคมะเร็ง
❒ 9) โรคระบบประสาท ❒ 10) โรคไต
❒ 11) โรคที่เกิดจากอุบัติเหตุ ❒ 12) อื่นๆ ระบุ.....

3.3 การรักษาพยาบาลเมื่อเจ็บป่วยส่วนใหญ่ไปรับการรักษาหรือใช้บริการที่

❒ 1) ไม่ได้รักษา ❒ 2) ซื้อยากินเอง
❒ 3) คลินิค ❒ 4) โรงพยาบาลของรัฐบาล/โรงพยาบาลส่งเสริมสุขภาพของตำบล
❒ 5) โรงพยาบาลของเอกชน ❒ 6) อื่นๆ (ระบุ).....

3.4 ปัญหาในการให้บริการด้านสาธารณสุข

❒ 1) ไม่มี
❒ 2) มี ได้แก่.....

ส่วนที่ 4 การรับทราบข้อมูล/ข่าวสารและการมีส่วนร่วมกิจกรรมของโครงการฯ

4.1 ท่านทราบหรือรู้จักโครงการฯ หรือไม่

❒ 1) ไม่ทราบ/ไม่รู้จัก **(ข้ามไปตอบส่วนที่ 6)** ❒ 2) ทราบ/รู้จัก

4.2 ถ้าทราบ ท่านทราบจากแหล่งใด (ตอบได้มากกว่า 1 ข้อ)

❒ 1) เพื่อนบ้านเล่าให้ฟัง ❒ 2) ผู้นำชุมชน
❒ 3) หน่วยงานราชการต่างๆ ❒ 4) หนังสือพิมพ์
❒ 5) เจ้าหน้าที่ของโครงการฯ ❒ 6) เคยเข้าร่วมประชุมกับทางโครงการฯ
❒ 7) ได้ร่วมกิจกรรมกับทางโครงการฯ ❒ 8) อื่นๆ (ระบุ).....

4.3 ในช่วง 1 ปีที่ผ่านมา ท่านเคยเข้าร่วมกิจกรรมกับโครงการฯ หรือไม่

❒ 1) ไม่เคย
❒ 2) เคยเข้าร่วม ระบุกิจกรรม.....

4.4 ท่านทราบ/รู้จักระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่างๆ ของโครงการฯ หรือไม่

❒ 1) ไม่ทราบ/ไม่รู้จัก ❒ 2) ทราบ/รู้จัก

4.5 ท่านมีความเชื่อมั่นต่อระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่างๆ ของโครงการฯ มากน้อยเพียงใด

❒ 1) เชื่อมั่นสูง ❒ 2) เชื่อมั่นพอสมควร (หากมีอุบัติเหตุสามารถแก้ไขหรือควบคุมได้ทัน)
❒ 3) ไม่มีความเชื่อมั่น (เมื่อมีอุบัติเหตุไม่สามารถควบคุมได้) ❒ 4) ไม่ทราบ/ไม่แน่ใจ

4.6 ท่านทราบหรือไม่ว่าโครงการมีการดำเนินการช่วยเหลือชุมชน

❒ 1) ไม่ทราบ **(ข้ามไปตอบส่วนที่ 6)** ❒ 2) ทราบ ❒ 3) ไม่แน่ใจ

4.7 โครงการฯ เคยให้ความช่วยเหลือชุมชนด้านใดบ้าง (ตอบได้มากกว่า 1 ข้อ)

❒ 1) สนับสนุนด้านทุนการศึกษา ❒ 2) สนับสนุนด้านกีฬา ❒ 3) สนับสนุนด้านสาธารณูปโภค
❒ 4) สนับสนุนทางด้านศาสนสถาน ❒ 5) สนับสนุนด้านสุขภาพอนามัย ❒ 6) อื่นๆ (ระบุ).....

4.8 ท่านทราบหรือไม่ว่ามีคนในชุมชนเข้ามาทำงานในพื้นที่โครงการฯ ในช่วง 1 ปี

❒ 1) ไม่ทราบ ❒ 2) ทราบ ❒ 3) ไม่แน่ใจ

4.9 ท่านเคยทราบหรือไม่ว่า โครงการฯ จะคัดคนเข้าทำงานโดยพิจารณาที่เหมาะสมกับตำแหน่งงาน

❒ 1) ไม่ทราบ ❒ 2) ทราบ ❒ 3) ไม่แน่ใจ

4.10 ในช่วงปี 2568 ที่ผ่านมา ท่านเคยได้รับข้อมูลการจัดการสิ่งแวดล้อมเกี่ยวกับโครงการฯ เพื่อให้เกิดความรู้ความเข้าใจและสร้างความมั่นใจให้กับชุมชนหรือไม่

❒ 1) ไม่ทราบ ❒ 2) ทราบจาก.....

4.11 ในช่วงปี 2568 ที่ผ่านมา ท่านรับทราบกิจกรรมมวลชนสัมพันธ์ของโครงการและการเข้าไปมีส่วนร่วมในกิจกรรมหรือไม่

❒ 1) ไม่ทราบ ❒ 2) ทราบ ❒ 3) ไม่แน่ใจ

4.12 **ในช่วงปี 2568 ที่ผ่านมา ท่านรับทราบกิจกรรม"เปิดบ้านต้อนรับแขกภายนอกเพื่อเข้าเยี่ยมชมโรงงาน (เปิดบ้าน)" หรือไม่**

❒ 1) ไม่ทราบ ❒ 2) ทราบ ❒ 3) ไม่แน่ใจ

ส่วนที่ 5 ความคิดเห็นเกี่ยวกับการดำเนินโครงการฯ

5.1 **ท่านคิดว่าช่วง 1 ปีที่ผ่านมา การดำเนินงานของโครงการฯ มีผลกระทบด้านสิ่งแวดล้อมของชุมชนหรือไม่**

ผลกระทบจากการดำเนินโครงการฯ	ผลกระทบ		ระดับผลกระทบ					ช่วงเวลา
	ไม่มี	มี	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด	
ด้านสิ่งแวดล้อม								
1. ควัน/ฝุ่นละออง								
2. เสียงดัง								
3. ความสั่นสะเทือน								
4. น้ำเสีย								
5. น้ำท่วมขัง								
6. ขยะมูลฝอย								
7. กลิ่นเหม็น								
8. การจราจรติดขัด								
9. อุบัติเหตุจากการจราจร								
10. อื่นๆ ระบุ.....								

หมายเหตุ *ช่วงเวลา 1= ฤดูหนาว 2=ฤดูร้อน 3=ฤดูฝน 4=ตลอดทั้งปี 5=ไม่แน่นอน (ระบุ) 6=อื่นๆ (ระบุ.....)

5.2 **ท่านมีความรู้สึกวิตกกังวลต่อโครงการฯ หรือไม่อย่างไร**

❒ 1) ไม่วิตกกังวล ❒ 2) วิตกกังวล ❒ 3) ไม่มีความเห็น

5.3 **โดยภาพรวมช่วง 1 ปี ท่านมีความพึงพอใจต่อการปฏิบัติตามมาตรการลดผลกระทบด้านต่างๆ ของโครงการฯ ในระดับใด**

❒ 1) น้อยที่สุด ❒ 2) น้อย ❒ 3) ปานกลาง ❒ 4) มาก

❒ 5) มากที่สุด ❒ 6) ควรปรับปรุง ระบุ.....

5.4 **ในช่วง 1 ปีที่ผ่านมา หน่วยงานของท่านเคยได้รับผลกระทบเกี่ยวกับการดำเนินกิจกรรมของโครงการฯ หรือไม่**

❒ 1) ไม่มี ❒ 2) เคย ระบุ.....

5.5 **ในช่วงปี 2568 ที่ผ่านมา ท่านคิดว่าการดำเนินงานของโครงการฯ มีผลต่อชุมชนหรือชีวิตของท่านอย่างไร**

❒ 1) ผลดีมากกว่าผลเสีย ❒ 2) ผลเสียมากกว่าผลดี ❒ 3) ผลดีกับผลเสียพอๆกัน

❒ 4) ไม่แน่ใจ ❒ 5) ไม่มีความเห็น

5.6 **ท่านคิดว่าการโครงการฯ มีผลดีต่อชุมชนของท่านหรือไม่ และในด้านใด**

ผลดีจากการดำเนินโครงการฯ	ผลดี		ระดับผลดี				
	ไม่มี	มี	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด
1. ทำให้ประชาชนในพื้นที่มีงานทำมากขึ้นจากการรับจ้างในโครงการฯ							
2. ทำให้การค้าขายของร้านค้าปลีกและธุรกิจบริการต่างๆ ดีขึ้น							
3. สภาพเศรษฐกิจของชุมชนดีขึ้น							
4. ได้รับการสนับสนุนกิจกรรมชุมชนจากโครงการฯมากขึ้น							
5. มีการพัฒนาระบบสาธารณูปโภคของชุมชนดีขึ้น เช่น ถนน							
6. อื่นๆ ระบุ.....							

5.7 **ท่านมีความพึงพอใจต่อกิจกรรมชุมชนสัมพันธ์ที่ทางโครงการฯ ดำเนินการในปี 2568 ระดับใด**

กิจกรรม	ระดับความพึงพอใจ				
	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด
1. กิจกรรมเกี่ยวกับสุขภาพ					
2. กิจกรรมเกี่ยวกับการอนุรักษ์สิ่งแวดล้อม					
3. กิจกรรมเกี่ยวกับการส่งเสริมการศึกษา					
4. กิจกรรมเกี่ยวกับการพัฒนาความสัมพันธ์ชุมชน					
5. กิจกรรมเกี่ยวกับการส่งเสริมศาสนา วัฒนธรรม					
6. กิจกรรมการประชาสัมพันธ์และแจ้งข่าวสารของโรงงาน					
7. กิจกรรมเกี่ยวกับการส่งเสริม/พัฒนาอาชีพ					
8. กิจกรรมเกี่ยวกับการพัฒนาชุมชน					

ส่วนที่ 6 การประชาสัมพันธ์โครงการและการมีส่วนร่วมของประชาชน

6.1 **ท่านต้องการรับทราบข้อมูลเพิ่มเติมเกี่ยวกับโครงการฯ หรือไม่**

❒ 1) ไม่ต้องการทราบ **(ข้ามไปตอบข้อ 6.3)**

❒ 2) ต้องการทราบ เรื่อง.....

6.2 **รูปแบบ/วิธีการใดที่เหมาะสมที่ทำให้ท่านและชุมชนได้รับรู้ข้อมูลเกี่ยวกับโครงการฯ มากที่สุด (ตอบได้มากกว่า 1 ข้อ)**

❒ 1) ทำจดหมาย/เอกสาร แจ้งต่อประชาชนโดยตรง ❒ 2) แจ้งข้อมูลผ่านกำนัน ผู้ใหญ่บ้าน หรือผู้นำชุมชน

❒ 3) แจ้งข้อมูลผ่านวิทยุชุมชน/หอกระจายเสียงชุมชน ❒ 4) จัดประชุมชี้แจงข้อมูลข่าวสารโดยตรง

❒ 5) อื่นๆ (ระบุ).....

6.3 **หากทางโครงการฯ จัดกิจกรรมร่วมกับชุมชนท่านยินดีเข้าร่วมหรือไม่**

❒ 1) ยินดีเข้าร่วม ❒ 2) ไม่ยินดี เนื่องจาก.....

6.4 **ท่านต้องการให้ทางโครงการฯ ส่งเสริมกิจกรรมด้านใดให้กับชุมชนบ้าง**

❒ 1) ไม่ต้องการ ❒ 2) ต้องการ ระบุ.....

6.5 **ข้อเสนอแนะอื่นๆ เกี่ยวกับโครงการฯ**

1) .....

2) .....

3) .....

*****ขอขอบคุณทุกท่านที่ให้ความร่วมมือในการตอบแบบสอบถาม*****

หนังสือยินยอมในการเก็บรวบรวม/ใช้/เปิดเผยข้อมูลส่วนบุคคล

บริษัท เอสจีเอส (ประเทศไทย) จำกัด ได้ให้ความสำคัญกับความเป็นส่วนตัวของท่าน ดังนั้น บริษัทฯ จึงขอความยินยอมจากท่านเพื่อการเก็บรวบรวมข้อมูล เช่น **ชื่อ – นามสกุล ที่อยู่ หมายเลขโทรศัพท์ เพศ อายุ ศาสนา สถานภาพ และการศึกษา** เป็นต้น โดยได้มีวัตถุประสงค์เพื่อใช้ประมวลผลจากการสำรวจสภาพเศรษฐกิจสังคม สิ่งแวดล้อม ตลอดจนความคิดเห็นต่อโครงการ เพื่อนำมาประกอบการจัดทำรายงานการติดตามตรวจสอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม

บริษัทฯ จะไม่เปิดเผยข้อมูลส่วนบุคคลของท่านให้แก่บุคคลอื่นเว้นแต่เป็นการเปิดเผยต่อผู้ที่บริษัทฯ มอบหมายให้เป็นผู้ประมวลผลข้อมูลส่วนบุคคลเท่านั้น ท่านมีสิทธิ์ปฏิเสธการยินยอมให้บริษัทฯ รวบรวม ใช้ และ/หรือเปิดเผยข้อมูลส่วนบุคคลของท่านเพื่อวัตถุประสงค์ตามที่ระบุไว้ข้างต้น

☐ ข้าพเจ้ายินยอม

☐ ข้าพเจ้าไม่ยินยอม

ข้าพเจ้ารับทราบว่าข้าพเจ้ามีสิทธิถอนความยินยอมที่ให้ไว้ข้างต้นได้ทุกเมื่อ

ลายมือชื่อ.....

ชื่อ – นามสกุล.....

วันที่.....

ภาคผนวกที่ 3

แบบสอบถามสภาพเศรษฐกิจ สังคม และความคิดเห็นของหน่วยงานราชการ โรงเรียน และวัด

B62

ผู้สอบถาม.....
วัน/เดือน/ปี.....

แบบสอบถามสภาพเศรษฐกิจ สังคม และความคิดเห็นของหน่วยงานราชการ โรงเรียน และวัด
โครงการโรงไฟฟ้าพลังความร้อน ขนาด 6 เมกะวัตต์ (B62)
ของบริษัท ทีพีไอ จำกัด (มหาชน)

ชื่อ-นามสกุล ผู้ตอบแบบสอบถาม.....
หน่วยงาน.....
ที่อยู่ เลขที่.....หมู่ที่.....ตำบล.....อำเภอ.....
จังหวัด.....หมายเลขโทรศัพท์.....

ส่วนที่ 1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม

1.1 เพศ ❒ 1) ชาย ❒ 2) หญิง

1.2 อายุ ..... ปี

1.3 ตำแหน่ง/หน้าที่ในชุมชน/หน่วยงาน/องค์กร .....

1.4 ระยะเวลาที่ปฏิบัติหน้าที่ในชุมชน/หน่วยงาน/องค์กร

❒ 1) น้อยกว่า 1 ปี ❒ 2) ระหว่าง 1-5 ปี ❒ 3) ระหว่าง 6-10 ปี
❒ 4) ระหว่าง 11-15 ปี ❒ 5) ระหว่าง 16-20 ปี ❒ 6) มากกว่า 20 ปีขึ้นไป

1.5 หน้าที่ความรับผิดชอบ.....

ส่วนที่ 2 การตรวจสอบเรื่องร้องเรียน

2.1 ในช่วง 1 ปีที่ผ่านมา ท่านเคยได้รับเรื่องร้องเรียนจากชุมชนเกี่ยวกับกิจกรรมของโครงการฯ หรือไม่

❒ 1) ไม่มี **(ข้ามไปตอบส่วนที่ 3)**

❒ 2) มี เรื่อง.....

2.3 เมื่อตรวจสอบข้อร้องเรียนแล้วเป็นเหตุจากกิจกรรมของบของโครงการฯ หรือไม่

❒ 1) ไม่ใช่ **(ข้ามไปตอบส่วนที่ 3)** ❒ 2) ใช่ ระบุ.....

2.4 ทางโครงการฯ ได้แก้ไขข้อร้องเรียนหรือไม่

❒ 1) แก้ไข ❒ 2) ไม่ได้ดำเนินการแก้ไขเนื่องจาก.....

ส่วนที่ 3 ความคิดเห็นเกี่ยวกับการดำเนินโครงการฯ

3.1 ท่านมีความรู้สึกวิตกกังวลต่อโครงการฯ หรือไม่อย่างไร

❒ 1) ไม่วิตกกังวล ❒ 2) วิตกกังวล ❒ 3) ไม่มีความเห็น

3.2 ท่านมีความเชื่อมั่นต่อระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่างๆ ของโครงการฯ มากน้อยเพียงใด

❒ 1) เชื่อมั่นสูง ❒ 2) เชื่อมั่นพอสมควร (หากมีอุบัติเหตุสามารถแก้ไขหรือควบคุมได้ทัน)
❒ 3) ไม่มีความเชื่อมั่น (เมื่อมีอุบัติเหตุไม่สามารถควบคุมได้)
❒ 4) ไม่ทราบ/ไม่แน่ใจ

3.3 โดยภาพรวมช่วง 1 ปี ท่านมีความพึงพอใจต่อการปฏิบัติตามมาตรการลดผลกระทบด้านต่างๆ ของโครงการฯ ในระดับใด

❒ 1) น้อยที่สุด ❒ 2) น้อย ❒ 3) ปานกลาง
❒ 4) มาก ❒ 5) มากที่สุด ❒ 6) ควรปรับปรุง ระบุ.....

3.4 ในช่วง 1 ปีที่ผ่านมา หน่วยงานของท่านเคยได้รับผลกระทบเกี่ยวกับการดำเนินกิจกรรมของโครงการฯ หรือไม่

❒ 1) ไม่มี ❒ 2) เคย ระบุ.....

ส่วนที่ 4 การประชาสัมพันธ์โครงการและการมีส่วนร่วมของประชาชน

4.1 ท่านทราบหรือรู้จักโครงการฯ หรือไม่

❒ 1) ไม่ทราบ/ไม่รู้จัก **(ข้ามไปตอบข้อ 4.8)** ❒ 2) ทราบ/รู้จัก

4.2 ถ้าทราบ ท่านทราบจากแหล่งใด (ตอบได้มากกว่า 1 ข้อ)

❒ 1) เพื่อนบ้านเล่าให้ฟัง ❒ 2) ผู้นำชุมชน
❒ 3) หน่วยงานราชการต่างๆ ❒ 4) หนังสือพิมพ์
❒ 5) เจ้าหน้าที่ของโครงการฯ ❒ 6) เคยเข้าร่วมประชุมกับทางโครงการฯ
❒ 7) ได้ร่วมกิจกรรมกับทางโครงการฯ ❒ 8) อื่นๆ (ระบุ).....

4.3 ท่านต้องการรับทราบข้อมูลเพิ่มเติมเกี่ยวกับโครงการฯ หรือไม่

❒ 1) ไม่ต้องการทราบ
❒ 2) ต้องการทราบ เรื่อง.....

4.4 รูปแบบ/วิธีการใดที่เหมาะสมที่ทำให้ท่านและชุมชนได้รับรู้ข้อมูลเกี่ยวกับโครงการฯ มากที่สุด (ตอบได้มากกว่า 1 ข้อ)

❒ 1) ทำจดหมาย/เอกสาร แจ้งต่อประชาชนโดยตรง ❒ 2) แจ้งข้อมูลผ่านกำนัน ผู้ใหญ่บ้าน หรือผู้นำชุมชน
❒ 3) แจ้งข้อมูลผ่านวิทยุชุมชน/หอกระจายเสียงชุมชน ❒ 4) จัดประชุมชี้แจงข้อมูลข่าวสารโดยตรง
❒ 5) อื่นๆ (ระบุ).....

4.5 หากทางโครงการฯ จัดกิจกรรมร่วมกับชุมชนท่านยินดีเข้าร่วมหรือไม่

❒ 1) ยินดีเข้าร่วม ❒ 2) ไม่ยินดี เนื่องจาก.....

4.6 ท่านต้องการให้ทางโครงการฯ ส่งเสริมกิจกรรมด้านใดให้กับชุมชนบ้าง

❒ 1) ไม่ต้องการ ❒ 2) ต้องการ ระบุ.....

4.7 ท่านมีความพึงพอใจต่อกิจกรรมชุมชนสัมพันธ์ที่ทางโครงการฯ ดำเนินการในปี 2568 ระดับใด

กิจกรรม	ระดับความพึงพอใจ				
	น้อยที่สุด	น้อย	ปานกลาง	มาก	มากที่สุด
1. กิจกรรมเกี่ยวกับสุขภาพ					
2. กิจกรรมเกี่ยวกับการอนุรักษ์สิ่งแวดล้อม					
3. กิจกรรมเกี่ยวกับการส่งเสริมการศึกษา					
4. กิจกรรมเกี่ยวกับการพัฒนาความสัมพันธ์ชุมชน					
5. กิจกรรมเกี่ยวกับการส่งเสริมศาสนา วัฒนธรรม					
6. กิจกรรมการประชาสัมพันธ์และแจ้งข่าวสารของโรงงาน					
7. กิจกรรมเกี่ยวกับการส่งเสริม/พัฒนาอาชีพ					
8. กิจกรรมเกี่ยวกับการพัฒนาชุมชน					

4.8 ข้อเสนอแนะอื่นๆ เกี่ยวกับโครงการฯ

1) .....
2) .....
3) .....

*****ขอขอบคุณทุกท่านที่ให้ความร่วมมือในการตอบแบบสอบถาม*****

หนังสือยินยอมในการเก็บรวบรวม/ใช้/เปิดเผยข้อมูลส่วนบุคคล

บริษัท เอสจีเอส (ประเทศไทย) จำกัด ได้ให้ความสำคัญกับความเป็นส่วนตัวของท่าน ดังนั้น บริษัทฯ จึงขอความยินยอมจากท่านเพื่อการเก็บรวบรวมข้อมูล เช่น **ชื่อ – นามสกุล ที่อยู่ หมายเลขโทรศัพท์ เพศ อายุ ศาสนา สถานภาพการศึกษา และตำแหน่ง** เป็นต้น โดยได้มีวัตถุประสงค์เพื่อใช้ประมวลผลจากการสำรวจสภาพเศรษฐกิจสังคม สิ่งแวดล้อม ตลอดจนความคิดเห็นต่อโครงการ เพื่อนำมาประกอบการจัดทำรายงานการติดตามตรวจสอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม

บริษัทฯ จะไม่เปิดเผยข้อมูลส่วนบุคคลของท่านให้แก่บุคคลอื่นเว้นแต่เป็นการเปิดเผยต่อผู้ที่บริษัทฯ มอบหมายให้เป็นผู้ประมวลผลข้อมูลส่วนบุคคลเท่านั้น ท่านมีสิทธิ์ปฏิเสธการยินยอมให้บริษัทฯ รวบรวม ใช้ และ/หรือเปิดเผยข้อมูลส่วนบุคคลของท่านเพื่อวัตถุประสงค์ตามที่ระบุไว้ข้างต้น

☐ ข้าพเจ้ายินยอม

☐ ข้าพเจ้าไม่ยินยอม

ข้าพเจ้ารับทราบว่าข้าพเจ้ามีสิทธิถอนความยินยอมที่ให้ไว้ข้างต้นได้ทุกเมื่อ

ลายมือชื่อ.....
ชื่อ – นามสกุล.....
วันที่.....

ภาคผนวกที่ 4

ผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของผู้นำชุมชน

รายการ			0 - 500 เมตร จากพื้นที่โครงการ		500 เมตร - 3 กิโลเมตร จากพื้นที่โครงการ		รวม	
			จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ส่วนที่ 1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม								
1.1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม								
1. เพศ								
	1	ชาย	2	50.0	6	60.0	8	57.1
	2	หญิง	2	50.0	4	40.0	6	42.9
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
2. อายุ								
		ค่าเฉลี่ย	**45.0**		**51.0**		**48.0**	
3. ศาสนา								
	1	พุทธ	4	100.0	10	100.0	14	100.0
	2	อิสลาม	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
4. ระดับการศึกษาสูงสุด								
	1	ไม่ได้เรียนหนังสือ	0	0.0	0	0.0	0	0.0
	2	ประถมศึกษาตอนต้น (ป.4)	0	0.0	0	0.0	0	0.0
	3	ประถมศึกษาตอนปลาย (ป.6)	0	0.0	2	20.0	2	14.3
	4	มัธยมศึกษาตอนต้น (ม.3)	0	0.0	1	10.0	1	7.1
	5	มัธยมศึกษาตอนปลาย (ม.6)/ปวช. หรือเทียบเท่า	2	50.0	5	50.0	7	50.0
	6	อนุปริญญา/ปวส. หรือเทียบเท่า	2	50.0	2	20.0	4	28.6
	7	ปริญญาตรี	0	0.0	0	0.0	0	0.0
	8	สูงกว่าปริญญาตรี	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
4. ตำแหน่ง								
	1	ผู้ใหญ่บ้าน	1	25.0	4	40.0	5	35.7
	2	ผู้ช่วยผู้ใหญ่บ้าน	2	50.0	4	40.0	6	42.9
	3	กรรมการชุมชน	1	25.0	2	20.0	3	21.4
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**

5. ระยะเวลาที่ปฏิบัติหน้าที่ในชุมชน/หน่วยงาน/องค์กร								
	1	น้อยกว่า 1 ปี	0	0.0	0	0.0	0	0.0
	2	ระหว่าง 1-5 ปี	1	25.0	2	20.0	3	21.4
	3	ระหว่าง 6-10 ปี	0	0.0	7	70.0	7	50.0
	4	ระหว่าง 11-15 ปี	3	75.0	1	10.0	4	28.6
	5	ระหว่าง 16-20 ปี	0	0.0	0	0.0	0	0.0
	6	มากกว่า 20 ปี ขึ้นไป	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ส่วนที่ 2 ข้อมูลทั่วไปด้านเศรษฐกิจ สังคมของชุมชน								
2.1 อาชีพหลักของประชาชนในชุมชน (เลือกเพียงข้อเดียว)								
	1	รับราชการ/รัฐวิสาหกิจ	0	0.0	0	0.0	0	0.0
	2	พนักงานบริษัท/ลูกจ้าง/พนักงานโรงแรม	4	100.0	10	100.0	14	100.0
	3	ค้าขาย/ธุรกิจส่วนตัว	0	0.0	0	0.0	0	0.0
	4	รับจ้างทั่วไป	0	0.0	0	0.0	0	0.0
	5	เกษตรกรรม/เลี้ยงสัตว์	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
2.2 อาชีพเสริมของประชาชนในชุมชน (ตอบได้มากกว่า 1 อาชีพ)								
	1	ไม่มี	4	100.0	10	100.0	14	100.0
	2	มี	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
2.3 ปัญหาในการประกอบอาชีพของประชาชนในชุมชนของท่าน								
	1	ไม่มี	4	100.0	10	100.0	14	100.0
	2	มีปัญหา	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
2.4 ฐานะทางเศรษฐกิจของประชาชนในชุมชน								
	1	ฐานะทางเศรษฐกิจดี	0	0.0	0	0.0	0	0.0
	2	ฐานะทางเศรษฐกิจปานกลาง	4	100.0	10	100.0	14	100.0
	3	ฐานะทางเศรษฐกิจไม่ดี	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ส่วนที่ 3 ข้อมูลด้านสุขภาพอนามัยและสาธารณูปโภคของชุมชน								
3.1 สุขภาพอนามัยและสาธารณสุข								
ปัญหาสุขภาพที่เกิดขึ้นในชุมชนในรอบ 1 ปีที่ผ่านมา								
	1	ไม่มีปัญหา	3	75.0	8	80.0	11	78.6
	2	มีปัญหา โรคภูมิแพ้และทางเดินหายใจ	1	25.0	2	20.0	3	21.4
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
การแก้ปัญหาสุขภาพอนามัยและสาธารณสุข								
	1	ไม่มีการแก้ไข	0	0.0	0	0.0	0	0.0
	2	วิธีการแก้ไขปัญหา	1	100.0	2	100.0	3	100.0
	รวม		**1**	**100.0**	**2**	**100.0**	**3**	**100.0**

วิธีการแก้ไขปัญหา (ระบุ)								
	1	รักษาที่สถานพยาบาลใกล้บ้าน	1	100.0	2	100.0	3	100.0
	รวม		**1**	**100.0**	**2**	**100.0**	**3**	**100.0**
3.2 ระบบสาธารณูปโภคและโครงสร้างพื้นฐานของชุมชน เช่น การไฟฟ้า การประปา ถนน								
ปัญหาสาธารณูปโภคในชุมชนในรอบ 1 ปีที่ผ่านมา								
	1	ไม่มีปัญหา	4	100.0	10	100.0	14	100.0
	2	มีปัญหา	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ปัญหาสาธารณูปโภค (ตอบได้มากกว่า 1 ปัญหา)								
	1	ถนนชำรุด	0	0.0	0	0.0	0	0.0
	2	น้ำประปาไม่ค่อยไหลไม่พอใช้	0	0.0	0	0.0	0	0.0
	รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
การแก้ปัญหาสาธารณูปโภคในชุมชนของท่าน								
	1	ไม่มีการแก้ไข	0	0.0	0	0.0	0	0.0
	2	วิธีการแก้ไขปัญหา	0	0.0	0	0.0	0	0.0
	รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
วิธีการแก้ไขปัญหา								
	1	แจ้งหน่วยงานที่เกี่ยวข้องให้ดำเนินการแก้ไข	0	0.0	0	0.0	0	0.0
	รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
ส่วนที่ 4 ข้อมูลด้านสภาพแวดล้อมในปัจจุบันของชุมชน								
4.1 ท่านทราบหรือรู้จักโครงการฯ หรือไม่								
	1	ไม่ทราบ/ไม่รู้จัก (ข้ามไปตอบส่วนที่ 7)	0	0.0	0	0.0	0	0.0
	2	ทราบ/รู้จัก	4	100.0	10	100.0	14	100.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
4.2 ถ้าทราบ ท่านทราบจากแหล่งใด (ตอบได้มากกว่า 1 ข้อ)								
	1	เพื่อนบ้านเล่าให้ฟัง	0	0.0	0	0.0	0	0.0
	2	ผู้นำชุมชน	2	33.3	3	23.1	5	26.4
	3	หน่วยงานราชการต่างๆ	0	0.0	0	0.0	0	0.0
	4	หนังสือพิมพ์	0	0.0	2	15.4	2	10.5
	5	เจ้าหน้าที่ของโครงการฯ	1	16.7	7	53.8	8	42.1
	6	เคยเข้าร่วมประชุมกับทางโครงการฯ	1	16.7	1	7.7	2	10.5
	7	ได้ร่วมกิจกรรมกับทางโครงการฯ	2	33.3	0	0.0	2	10.5
	รวม		**6**	**100.0**	**13**	**100.0**	**19**	**100.0**
4.3 ในช่วง 1 ปีที่ผ่านมา ท่านเคยเข้าร่วมกิจกรรมกับโครงการฯ หรือไม่								
	1	ไม่เคย	0	0.0	0	0.0	0	0.0
	2	เคยเข้าร่วม	4	100.0	10	100.0	14	100.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**

กิจกรรม (ตอบได้มากกว่า 1 กิจกรรม)								
	1	สนับสนุนกิจกรรมต่างๆของชุมชน	2	50.0	2	20.0	4	28.6
	2	กิจกรรมงานบุญต่างๆ	2	50.0	8	80.0	10	71.4
	3	กิจกรรมเกี่ยวกับสุขภาพ	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
4.4 ท่านทราบ/รู้จักกระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่างๆ ของ								
	1	เชื่อมั่นสูง	0	0.0	0	0.0	0	0.0
	2	เชื่อมั่นพอสมควร (หากมีอุปสิเหตุสามารถแก้ไขหรือควบคุม	4	100.0	10	100.0	14	100.0
	3	ไม่มีความเชื่อมั่น (เมื่อมีอุปสิเหตุไม่สามารถควบคุมได้)	0	0.0	0	0.0	0	0.0
	4	ไม่ทราบ/ไม่แน่ใจ	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
4.5 ท่านทราบหรือไม่ว่าโครงการมีการดำเนินการช่วยเหลือชุมชน								
	1	ไม่ทราบ **(ข้ามไปตอบส่วนที่ 5)**	0	0.0	0	0.0	0	0.0
	2	ทราบ	4	100.0	10	100.0	14	100.0
	3	ไม่แน่ใจ	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
4.6 โครงการฯ เคยให้ความช่วยเหลือชุมชนด้านใดบ้าง (ตอบได้มากกว่า 1 ข้อ)								
	1	สนับสนุนด้านทุนการศึกษา	0	0.0	0	0.0	0	0.0
	2	สนับสนุนด้านกีฬา	0	0.0	0	0.0	0	0.0
	3	สนับสนุนด้านสาธารณูปโภค	4	66.7	5	25.0	9	34.6
	4	สนับสนุนทางด้านศาสนสถาน	0	0.0	5	25.0	5	19.2
	5	สนับสนุนด้านสุขภาพอนามัย	2	33.3	7	35.0	9	34.6
	6	สนับสนุนกิจกรรมต่างๆของชุมชน	0	0.0	3	15.0	3	11.6
	รวม		**6**	**100.0**	**20**	**100.0**	**26**	**100.0**
4.7 ท่านทราบหรือไม่ว่ามีคนในชุมชนเข้ามาทำงานในพื้นที่โครงการฯ ในช่วง 1 ปี								
	1	ไม่ทราบ	0	0.0	0	0.0	0	0.0
	2	ทราบ	4	100.0	10	100.0	14	100.0
	3	ไม่แน่ใจ	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ส่วนที่ 5 การตรวจสอบเรื่องร้องเรียน								
5.1 ในช่วง 1 ปีที่ผ่านมา ท่านเคยได้รับเรื่องร้องเรียนจากชุมชนเกี่ยวกับกิจกรรมของโครงการฯ หรือไม่								
	1	ไม่มี (ข้ามไปตอบส่วนที่ 6)	4	100.0	10	100.0	14	100.0
	2	มี	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
เรื่อง (ตอบได้มากกว่า 1 ข้อ)								
	1	ฝุ่นละออง	0	0.0	0	0.0	0	0.0
	รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
5.2 เมื่อได้รับเรื่องร้องเรียนจากลูกบ้าน ท่านได้แจ้งไปยังหน่วยงานใด								
	1	บริษัท ทีพีไอ โพลีน จำกัด (มหาชน)	0	0.0	0	0.0	0	0.0
	รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**

5.3 เมื่อตรวจสอบข้อร้องเรียนแล้วเป็นเหตุจากกิจกรรมของของโครงการฯ หรือไม่								
	1	ไม่ใช่ (ข้ามไปตอบส่วนที่ 6)	0	0.0	0	0.0	0	0.0
	2	ใช่ ฝุ่นปูน	0	0.0	0	0.0	0	0.0
	รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
5.4 ทางโครงการฯ ได้แก้ไขข้อร้องเรียนหรือไม่								
	1	แก้ไข	0	0.0	0	0.0	0	0.0
	2	ไม่ได้ดำเนินการแก้ไขเนื่องจากยังมีผลกระทบอยู่	0	0.0	0	0.0	0	0.0
	รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
ส่วนที่ 6 ความคิดเห็นเกี่ยวกับการดำเนินโครงการฯ								
6.1 ท่านมีความมั่นใจว่าวิสกกังวลต่อโครงการฯ หรือไม่อย่างไร								
	1	ไม่วิสกกังวล	4	100.0	10	100.0	14	100.0
	2	วิสกกังวล	0	0.0	0	0.0	0	0.0
	3	ไม่มีความเห็น	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
6.2 ท่านมีความเชื่อมั่นต่อระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่างๆ								
	1	เชื่อมั่นสูง	0	0.0	0	0.0	0	0.0
	2	เชื่อมั่นพอสมควร (หากมีอุปสิเหตุสามารถแก้ไขหรือควบคุมได้ที่	4	100.0	10	100.0	14	100.0
	3	ไม่มีความเชื่อมั่น (เมื่อมีอุปสิเหตุไม่สามารถควบคุมได้)	0	0.0	0	0.0	0	0.0
	4	ไม่ทราบ/ไม่แน่ใจ	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
6.3 โดยภาพรวมช่วง 1 ปี ท่านมีความพึงพอใจต่อการปฏิบัติตามมาตรการลดผลกระทบด้านต่างๆ ของโครงการฯ ในระดับใด								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	4	100.0	10	100.0	14	100.0
	4	มาก	0	0.0	0	0.0	0	0.0
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	6	ควรปรับปรุง ระบุ	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
6.4 ในช่วง 1 ปีที่ผ่านมา ชุมชนของท่านเคยได้รับผลกระทบเกี่ยวกับการดำเนินกิจกรรมของโครงการฯ หรือไม่								
	1	ไม่มี	4	100.0	10	100.0	14	100.0
	2	เคย	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
เรื่อง (ตอบได้มากกว่า 1 ข้อ)								
	1	ฝุ่นละออง	0	0.0	0	0.0	0	0.0
	รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**

6.5 ในช่วงปี 2568 ที่ผ่านมา ท่านคิดว่าการดำเนินงานของโครงการฯ มีผลต่อชุมชนหรือชีวิตของท่านอย่างไร								
	1	ผลดีมากกว่าผลเสีย	0	0.0	0	0.0	0	0.0
	2	ผลเสียมากกว่าผลดี	0	0.0	0	0.0	0	0.0
	3	ผลดีกับผลเสียพอๆกัน	4	100.0	10	100.0	14	100.0
	4	ไม่แน่ใจ	0	0.0	0	0.0	0	0.0
	5	ไม่มีความเห็น	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
6.6 ท่านคิดว่าการโครงการฯ มีผลดีต่อชุมชนของท่านหรือไม่ และในด้านใด								
ผลดีจากการดำเนินโครงการ								
ด้านเศรษฐกิจ-สังคม								
(1) ทำให้ประชาชนในพื้นที่มีงานทำมากขึ้นจากการรับจ้างในโครงการฯ								
ผลดี								
	1	ไม่มี	0	0.0	0	0.0	0	0.0
	2	มี	4	100.0	10	100.0	14	100.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ระดับผลดี								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	0	0.0	10	100.0	10	71.4
	4	มาก	4	100.0	0	0.0	4	28.6
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ค่าเฉลี่ย			**4.00**	**มาก**	**3.00**	**ปานกลาง**	**3.29**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.000**		**0.469**	
(2) ทำให้การค้าขายของร้านค้าปลีกและธุรกิจบริการต่างๆ ดีขึ้น								
ผลดี								
	1	ไม่มี	0	0.0	0	0.0	0	0.0
	2	มี	4	100.0	10	100.0	14	100.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ระดับผลดี								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	0	0.0	10	100.0	10	71.4
	4	มาก	4	100.0	0	0.0	4	28.6
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ค่าเฉลี่ย			**4.00**	**มาก**	**3.00**	**ปานกลาง**	**3.29**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.000**		**0.469**	

(3) สภาพเศรษฐกิจของชุมชนดีขึ้น								
ผลดี								
	1	ไม่มี	0	0.0	0	0.0	0	0.0
	2	มี	4	100.0	10	100.0	14	100.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ระดับผลดี								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	0	0.0	10	100.0	10	71.4
	4	มาก	4	100.0	0	0.0	4	28.6
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ค่าเฉลี่ย			**4.00**	**มาก**	**3.00**	**ปานกลาง**	**3.29**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.000**		**0.469**	
(4) ได้รับการสนับสนุนกิจกรรมชุมชนจากโครงการฯมากขึ้น								
ผลดี								
	1	ไม่มี	0	0.0	0	0.0	0	0.0
	2	มี	4	100.0	10	100.0	14	100.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ระดับผลดี								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	0	0.0	10	100.0	10	71.4
	4	มาก	4	100.0	0	0.0	4	28.6
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ค่าเฉลี่ย			**4.00**	**มาก**	**3.00**	**ปานกลาง**	**3.29**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.000**		**0.469**	
(5) มีการพัฒนาระบบสาธารณูปโภคของชุมชนดีขึ้น เช่น ถนน								
ผลดี								
	1	ไม่มี	0	0.0	0	0.0	0	0.0
	2	มี	4	100.0	10	100.0	14	100.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**

ระดับผลดี								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	0	0.0	10	100.0	10	71.4
	4	มาก	4	100.0	0	0.0	4	28.6
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ค่าเฉลี่ย			**4.00**	**มาก**	**3.00**	**ปานกลาง**	**3.29**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.000**		**0.469**	
6.7 ท่านมีความพึงพอใจต่อกิจกรรมชุมชนสัมพันธ์ที่ทางโครงการฯ ดำเนินการในปี 2567 ระดับใด								
1. กิจกรรมเกี่ยวกับการสุขภาพ								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	0	0.0	6	60.0	6	42.9
	4	มาก	4	100.0	4	40.0	8	57.1
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ค่าเฉลี่ย			**4.00**	**มาก**	**3.40**	**ปานกลาง**	**3.57**	**มาก**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.516**		**0.514**	
2. กิจกรรมเกี่ยวกับการอนุรักษ์สิ่งแวดล้อม								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	4	100.0	10	100.0	14	100.0
	4	มาก	0	0.0	0	0.0	0	0.0
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.000**		**0.000**	
3. กิจกรรมเกี่ยวกับการส่งเสริมการศึกษา								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	4	100.0	10	100.0	14	100.0
	4	มาก	0	0.0	0	0.0	0	0.0
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.000**		**0.000**	

4. กิจกรรมเกี่ยวกับการพัฒนาความสัมพันธ์ชุมชน								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	4	100.0	10	100.0	14	100.0
	4	มาก	0	0.0	0	0.0	0	0.0
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.000**		**0.000**	
5.กิจกรรมเกี่ยวกับการส่งเสริมศาสนา วัฒนธรรม								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	4	100.0	10	100.0	14	100.0
	4	มาก	0	0.0	0	0.0	0	0.0
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.000**		**0.000**	
6.กิจกรรมการประชาสัมพันธ์และแจ้งข่าวสารของโรงงาน								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	4	100.0	10	100.0	14	100.0
	4	มาก	0	0.0	0	0.0	0	0.0
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.000**		**0.000**	
7.กิจกรรมการประชาสัมพันธ์และแจ้งข่าวสารของโรงงาน								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	4	100.0	10	100.0	14	100.0
	4	มาก	0	0.0	0	0.0	0	0.0
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.000**		**0.000**	

8. กิจกรรมเกี่ยวกับการพัฒนาชุมชน								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	4	100.0	10	100.0	14	100.0
	4	มาก	0	0.0	0	0.0	0	0.0
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.000**		**0.000**	
ส่วนที่ 7 การประชาสัมพันธ์โครงการและการมีส่วนร่วมของประชาชน								
7.1 ท่านต้องการรับทราบข้อมูลเพิ่มเติมเกี่ยวกับโครงการฯ หรือไม่								
	1	ไม่ต้องการทราบ (ข้ามไปตอบข้อ 7.3)	0	0.0	0	0.0	0	0.0
	2	ต้องการทราบ	4	100.0	10	100.0	14	100.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
7.2 รูปแบบ/วิธีการใดที่เหมาะสมที่ทำให้ท่านและชุมชนได้รับรู้ข้อมูลเกี่ยวกับโครงการฯ มากที่สุด **(ตอบได้มากกว่า 1 ข้อ)**								
	1	ทำจดหมาย/เอกสาร แจ้งต่อประชาชนโดยตรง	0	0.0	0	0.0	0	0.0
	2	แจ้งข้อมูลผ่านกำนัน ผู้ใหญ่บ้านหรือผู้นำชุมชน	4	100.0	10	100.0	14	100.0
	3	แจ้งข้อมูลผ่านวิทยุชุมชน/หอกระจายเสียงชุมชน	0	0.0	0	0.0	0	0.0
	4	จัดประชุมชี้แจงข้อมูลข่าวสารโดยตรง	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
7.3 หากทางโครงการฯ จัดกิจกรรมร่วมกับชุมชนท่านยินดีเข้าร่วมหรือไม่								
	1	ยินดีเข้าร่วม	4	100.0	10	100.0	14	100.0
	2	ไม่ยินดี	0	0.0	0	0.0	0	0.0
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
7.4 ท่านต้องการให้ทางโครงการฯ ส่งเสริมกิจกรรมด้านใดให้กับชุมชนบ้าง								
	1	ไม่ต้องการ	2	50.0	3	30.0	5	35.7
	2	ต้องการ	2	50.0	7	70.0	9	64.3
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**
ต้องการ ได้แก่								
	1	ส่งเสริมด้านอาชีพ	2	100.0	5	71.4	7	77.8
	2	ร่วมงานบุญทางศาสนากับชุมชน	0	0.0	2	28.6	2	22.2
	รวม		**2**	**100.0**	**7**	**100.0**	**9**	**100.0**

7.5 ข้อเสนอแนะอื่นๆ เกี่ยวกับโครงการฯ								
	1	ต้องการให้ทางบริษัทเข้ามาสนับสนุนชุมชนอย่างต่อเนื่อง	2	50.0	6	60.0	8	57.1
	2	ไม่มีข้อเสนอแนะ	2	50.0	4	40.0	6	42.9
	รวม		**4**	**100.0**	**10**	**100.0**	**14**	**100.0**

หมายเหตุ : 1/ ตารางวิเคราะห์ระดับของผลกระทบที่ได้รับจากค่าเฉลี่ยโดยใช้แนวคิดของ Likert (อ้างอิงจากบุญธรม กิจปรีดาบริสุทธิ์, 2553) ดังนี้

ค่าคะแนน 1.00-1.50 หมายถึง ระดับน้อยที่สุด
ค่าคะแนน 1.51-2.50 หมายถึง ระดับน้อย
ค่าคะแนน 2.51-3.50 หมายถึง ระดับปานกลาง
ค่าคะแนน 3.51-4.50 หมายถึง ระดับมาก
ค่าคะแนน 4.51-5.00 หมายถึง ระดับมากที่สุด

2/ ค่าเฉลี่ย (Mean : เป็นค่าที่ได้จากการรวมกันของข้อมูลทุกตัวในชุดข้อมูลนั้น หารด้วยจำนวนข้อมูลทั้งหมด (วรณี แกมเกตุ, 2551)

3/ ค่าส่วนเบี่ยงเบนมาตรฐาน (Standard deviation : S.D. หรือ S) ใช้สำหรับหาค่าความแตกต่างโดยเฉลี่ยของระดับเฉลี่ยของระดับผลกระทบจากค่ากึ่งกลางของข้อมูลหรือความแตกต่างของระดับผลกระทบโดยเฉลี่ย

***ผลรวมของร้อยละมีค่าไม่เท่ากับ 100.0 เนื่องจากตัวเลือกของแบบสอบถามแต่ละตัวเลือกมีความถี่เท่ากัน ทำให้เป็นทศนิยมซ้ำไม่รู้จบ จึงทำให้ไม่สามารถปัดเศษทศนิยมเท่ากับ 100.0 ได้**

ที่มา : บริษัท เอสโอล (ประเทศไทย) จำกัด, พ.ศ. 2568

ภาคผนวกที่ 5

ผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของตัวแทนครัวเรือน

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ			รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
			จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
5. ระดับการศึกษาสูงสุด								
	1	ไม่ได้เรียนหนังสือ	0	0.0	0	0.0	0	0.0
	2	ประถมศึกษาตอนต้น (ป.4)	0	0.0	0	0.0	0	0.0
	3	ประถมศึกษาตอนปลาย (ป.6)	30	11.2	0	0.0	30	7.8
	4	มัธยมศึกษาตอนต้น (ม.3)	92	34.3	0	0.0	92	24.0
	5	มัธยมศึกษาตอนปลาย (ม.6)/ปวช. หรือเทียบเท่า	65	24.3	24	20.9	89	23.2
	6	อนุปริญญา/ปวส. หรือเทียบเท่า	75	28.0	85	73.9	160	41.8
	7	ปริญญาตรี	6	2.2	6	5.2	12	3.2
	8	สูงกว่าปริญญาตรี	0	0.0	0	0.0	0	0.0
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
1.2 โครงสร้างของครัวเรือน								
1. สถานภาพในครัวเรือน								
	1	หัวหน้าครัวเรือน	200	74.6	100	87.0	300	78.3
	2	สมาชิกในครัวเรือน	68	25.4	15	13.0	83	21.7
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
		สมาชิกในครัวเรือน ได้แก่						
	1	*คู่สมรส*	*60*	*88.2*	*15*	*100.0*	*75*	*90.4*
	2	*บิดา/มารดา*	*5*	*7.4*	*0*	*0.0*	*5*	*6.0*
	3	*บุตร/ธิดา*	*3*	*4.4*	*0*	*0.0*	*3*	*3.6*
	4	*ญาติ/พี่น้อง*	*0*	*0.0*	*0*	*0.0*	*0*	*0.0*
	รวม		***68***	***100.0***	***15***	***100.0***	***83***	***100.0***
2. ลักษณะการอยู่อาศัย								
	1	อยู่คนเดียว	18	6.7	0	0.0	18	4.7
	2	ครอบครัวเดี่ยว (พ่อ แม่ และลูก)	250	93.3	115	100.0	365	95.3
	3	ครอบครัวขยาย (อยู่รวมกันแบบญาติ)	0	0.0	0	0.0	0	0.0
	4	ครัวเรือนที่อยู่รวมกันแบบไม่ใช่ญาติ	0	0.0	0	0.0	0	0.0
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
3. จำนวนสมาชิกในครัวเรือน (รวมตัวท่านเอง)								
		ค่าเฉลี่ย	**4.0**		**4.0**		**4.0**	

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ			รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
			จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ส่วนที่ 1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม								
1.1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม								
1. เพศ								
	1	ชาย	100	37.3	30	26.1	130	33.9
	2	หญิง	168	62.7	85	73.9	253	66.1
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
2. อายุ								
	1	20-30 ปี	0	0.0	0	0.0	0	0.0
	2	31-40 ปี	5	1.8	50	43.5	55	14.4
	3	41-50 ปี	150	56.0	65	56.5	215	56.1
	4	51-60 ปี	100	37.3	0	0.0	100	26.1
	5	มากกว่า 60 ปี	13	4.9	0	0.0	13	3.4
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
3. ศาสนา								
	1	พุทธ	268	100.0	115	100.0	383	100.0
	2	อิสลาม	0	0.0	0	0.0	0	0.0
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
4. สถานภาพสมรส								
	1	โสด	70	26.1	15	13.0	85	22.2
	2	แต่งงาน/อยู่ด้วยกัน	198	73.9	100	87.0	298	77.8
	3	หย่า/แยกทางกัน	0	0.0	0	0.0	0	0.0
	4	หม้าย	0	0.0	0	0.0	0	0.0
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ			รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
			จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
แบ่งออกเป็น								
ชาย (คน)								
		ค่าเฉลี่ย	**2.0**		**2.0**		**2.0**	
หญิง (คน)								
		ค่าเฉลี่ย	**2.0**		**2.0**		**2.0**	
1.3 ภูมิลำเนาเดิม (ที่อยู่ตามทะเบียนราษฎร์)								
1. ภูมิลำเนา								
	1	อยู่ที่นี่ตั้งแต่เกิด **(ข้ามไปตอบส่วนที่ 2)**	108	40.3	55	47.8	163	42.6
	2	ย้ายมาจากที่อื่น	160	59.7	60	52.2	220	57.4
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
2. ย้ายมาจาก								
	1	ภาคเหนือ	0	0.0	6	10.0	6	2.7
	2	ภาคกลาง	120	75.0	20	33.3	140	63.6
	3	ภาคตะวันออกเฉียงเหนือ	40	25.0	29	48.3	69	31.4
	4	ภาคใต้	0	0.0	0	0.0	0	0.0
	5	ภาคตะวันออก	0	0.0	5	8.4	5	2.3
	รวม		**160**	**100.0**	**60**	**100.0**	**220**	**100.0**
3. ระยะเวลาที่ย้ายมา								
	1	น้อยกว่า 1 ปี	0	0.0	0	0.0	0	0.0
	2	ระหว่าง 1-5 ปี	0	0.0	0	0.0	0	0.0
	3	ระหว่าง 6-10 ปี	120	75.0	20	33.4	140	63.6
	4	ระหว่าง 11-15 ปี	30	18.8	11	18.3	41	18.6
	5	ระหว่าง 16-20 ปี	10	6.2	12	20.0	22	10.0
	6	มากกว่า 20 ปี ขึ้นไป	0	0.0	17	28.3	17	7.8
	รวม		**160**	**100.0**	**60**	**100.0**	**220**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ		วัดมีระยะ 0-3 กิโลเมตร จากโครงการ		วัดมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
4. สาเหตุการย้ายมา							
	1 เพื่อประกอบอาชีพ	125	78.1	38	63.3	163	74.1
	2 ย้ายตามญาติ/พี่น้อง	0	0.0	0	0.0	0	0.0
	3 แต่งงานกับคนที่นี่	35	21.9	22	36.7	57	25.9
	4 เพื่อการศึกษา	0	0.0	0	0.0	0	0.0
	5 ศึกษาต่อ	0	0.0	0	0.0	0	0.0
	รวม	**160**	**100.0**	**60**	**100.0**	**220**	**100.0**
ส่วนที่ 2 ข้อมูลด้านเศรษฐกิจของครัวเรือน							
2.1 อาชีพหลักของท่าน (เลือกเพียงข้อเดียว)							
	1 รับราชการ/รัฐวิสาหกิจ	0	0.0	8	7.0	8	2.1
	2 พนักงานบริษัท/ลูกจ้าง/พนักงานโรงแรม	249	92.9	95	82.6	344	89.8
	3 ค้าขาย/ธุรกิจส่วนตัว	7	2.6	12	10.4	19	5.0
	4 รับจ้างทั่วไป	9	3.4	0	0.0	9	2.3
	5 เกษตรกรรม/เลี้ยงสัตว์	3	1.1	0	0.0	3	0.8
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
2.2 อาชีพรอง/อาชีพเสริมของท่าน (ตอบได้มากกว่า 1 อาชีพ)							
	1 ไม่มี	248	92.5	115	100.0	363	94.8
	2 มี	20	7.5	0	0.0	20	5.2
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
มี โปรดระบุ							
	1 ค้าขาย/ธุรกิจส่วนตัว	10	50.0	0	0.0	10	50.0
	2 รับจ้างทั่วไป	6	30.0	0	0.0	6	30.0
	3 เกษตรกรรม	4	20.0	0	0.0	4	20.0
	รวม	**20**	**100.0**	**0**	**0.0**	**20**	**100.0**
2.3 ท่านเคยมีใช้ยาในการประกอบอาชีพหรือไม่							
	1 ไม่มี	268	100.0	115	100.0	383	100.0
	2 มีใช้ยาหา	0	0.0	0	0.0	0	0.0
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ		วัดมีระยะ 0-3 กิโลเมตร จากโครงการ		วัดมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
3.3 การรักษาพยาบาลเมื่อเจ็บป่วยส่วนใหญ่ ไปรับการรักษาหรือใช้บริการที่ใด							
	1 ไม่ได้รักษา	0	0.0	0	0.0	0	0.0
	2 ซื้อยากินเอง	0	0.0	0	0.0	0	0.0
	3 คลินิก	0	0.0	0	0.0	0	0.0
	4 โรงพยาบาลของรัฐบาล/โรงพยาบาลส่งเสริมสุขภาพของตำบล	268	100.0	115	100.0	383	100.0
	5 โรงพยาบาลของเอกชน	0	0.0	0	0.0	0	0.0
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
3.4 ปัญหาในการให้บริการด้านสาธารณสุข							
	1 ไม่มี	268	100.0	115	100.0	383	100.0
	2 มีปัญหา	0	0.0	0	0.0	0	0.0
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ส่วนที่ 4 ข้อมูลด้านสภาพแวดล้อมในปัจจุบันของชุมชน							
4.1 การรับทราบข้อมูล/ข่าวสารและการมีส่วนร่วมกิจกรรมของโครงการฯ							
	1 ไม่ทราบ/ไม่รู้จัก (ข้ามไปตอบส่วนที่ 6)	0	0.0	0	0.0	0	0.0
	2 ทราบ/รู้จัก	268	100.0	115	100.0	383	100.0
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ถ้าทราบ ท่านทราบจากแหล่งใด (ตอบได้มากกว่า 1 ข้อ)							
	1 เพื่อนบ้านเล่าให้ฟัง	24	8.7	5	3.8	29	7.1
	2 ผู้นำชุมชน	40	14.5	5	3.8	45	7.0
	3 หนังสือพิมพ์	0	0.0	15	11.5	15	3.7
	4 หนังสือพิมพ์	0	0.0	6	4.6	6	1.5
	5 เจ้าหน้าที่ของโครงการฯ	200	72.5	100	76.3	300	73.7
	6 เคยเข้าร่วมประชุมกับทางโครงการฯ	10	3.6	0	0.0	10	2.5
	7 ได้ร่วมกิจกรรมกับทางโครงการฯ	2	0.7	0	0.0	2	0.5
	รวม	**276**	**100.0**	**131**	**100.0**	**407**	**96.0**
4.3 ในช่วง 1 ปีที่ผ่านมา ท่านเคยเข้าร่วมกิจกรรมกับโครงการฯ หรือไม่							
	1 ไม่เคย	83	31.0	70	60.9	153	39.9
	2 เคยเข้าร่วม	185	69.0	45	39.1	230	60.1
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ		วัดมีระยะ 0-3 กิโลเมตร จากโครงการ		วัดมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
2.4 รายได้รวมของครัวเรือน โดยประมาณ (บาท/เดือน)							
	ค่าเฉลี่ย	**30,000**		**32,000**		**31,000**	
2.5 รายจ่ายรวมของครัวเรือน โดยประมาณ (บาท/เดือน)							
	ค่าเฉลี่ย	**22,000**		**25,000**		**25,000**	
2.6 ครอบครัวของท่านมีรายได้เพียงพอกับรายจ่ายหรือไม่							
	1 เพียงพอ มีเหลือเก็บออม	150	56.0	55	47.8	205	53.5
	2 เพียงพอ แต่ไม่มีเก็บออม	118	44.0	60	52.2	178	46.5
	3 ไม่เพียงพอ แต่ไม่มีหนี้สิน	0	0.0	0	0.0	0	0.0
	4 ไม่เพียงพอ มีหนี้สิน	0	0.0	0	0.0	0	0.0
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ส่วนที่ 3 ข้อมูลด้านสุขภาพอนามัยและสาธารณูปโภค							
3.1 ในรอบปีที่ผ่านมา จนถึงปัจจุบันสมาชิกในครอบครัวของท่านเคยมีการเจ็บป่วย หรือไม่							
	1 ไม่เคย (**ข้ามไปตอบข้อ 3.3**)	250	93.3	48	41.7	298	77.8
	2 เคย	18	6.7	67	58.3	85	22.2
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
3.2 ถ้าเคย โรคที่เจ็บป่วย หรืออาการที่พบบ่อย มีโรคใดบ้าง (ตอบได้มากกว่า 1 ข้อ)							
	1 โรคหวัด/ทางเดินหายใจ	15	37.5	30	35.7	45	36.3
	2 โรคเกี่ยวกับระบบทางเดินอาหาร	5	12.5	4	4.7	9	7.3
	3 โรคเกี่ยวกับระบบกล้ามเนื้อและกระดูก	1	2.5	10	11.9	11	8.9
	4 โรคความดัน/โรคเกี่ยวกับระบบไหลเวียนเลือด	10	25.0	20	23.8	30	11.6
	5 โรคเกี่ยวกับหู/ตา/ฟัน	2	5.0	5	6.0	7	5.6
	6 โรคผิวหนังและภูมิแพ้	7	17.5	10	11.9	17	13.7
	7 โรคเบาหวาน	0	0.0	5	6.0	5	4.0
	8 โรคมะเร็ง	0	0.0	0	0.0	0	0.0
	9 โรคระบบประสาท	0	0.0	0	0.0	0	0.0
	10 โรคไต	0	0.0	0	0.0	0	0.0
	11 โรคที่เกิดจากอุบัติเหตุ	0	0.0	0	0.0	0	0.0
	รวม	**40**	**100.0**	**84**	**100.0**	**124**	**87.4**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ		วัดมีระยะ 0-3 กิโลเมตร จากโครงการ		วัดมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
กิจกรรม							
	1 เข้าร่วมประชุม	0	0.0	0	0.0	0	0.0
	2 งานบุญประเพณี เช่น ทอดกฐิน,ผ้าป่า เป็นต้น	80	83.3	33	38.8	113	62.4
	3 ตรวจสุขภาพ	16	16.7	25	29.4	41	22.7
	4 สนับสนุนกิจกรรมของชุมชน เช่น วันสงกรานต์ งานวันเด็ก เป็นต้น	0	0.0	7	8.2	7	6.5
	5 มอบทุนการศึกษา	0	0.0	12	14.1	12	11.0
	6 ด้านสิ่งแวดล้อม	0	0.0	8	9.5	8	4.4
	รวม	**96**	**100.0**	**85**	**100.0**	**181**	**107.0**
4.4 ท่านทราบ/รู้จักระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่างๆ ของโครงการฯ หรือไม่							
	1 ไม่ทราบ/ไม่รู้จัก	220	82.1	30	26.1	250	65.3
	2 ทราบ/รู้จัก	48	17.9	85	73.9	133	34.7
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
4.5 ท่านทราบ/รู้จักระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่างๆ ของโครงการฯ หรือไม่							
	1 เชื่อมั่นสูง	0	0.0	0	0.0	0	0.0
	2 เชื่อมั่นพอสมควร (หากมีอุบัติเหตุสามารถแก้ไขหรือควบคุมได้ทัน)	268	100.0	115	100.0	383	100.0
	3 ไม่มีความเชื่อมั่น (เมื่อมีอุบัติเหตุไม่สามารถควบคุมได้)	0	0.0	0	0.0	0	0.0
	4 ไม่ทราบ/ไม่แน่ใจ	0	0.0	0	0.0	0	0.0
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
4.6 ท่านทราบหรือไม่ว่าโครงการมีการดำเนินการช่วยเหลือชุมชน							
	1 ไม่ทราบ (ข้ามไปตอบส่วนที่ 5)	6	2.2	15	13.0	21	5.5
	2 ทราบ	262	97.8	100	87.0	362	94.5
	3 ไม่แน่ใจ	0	0.0	0	0.0	0	0.0
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
4.7 โครงการฯ เคยให้ความช่วยเหลือชุมชนด้านใดบ้าง (ตอบได้มากกว่า 1 ข้อ)							
	1 สนับสนุนด้านทุนการศึกษา	22	8.2	50	18.5	72	13.4
	2 สนับสนุนด้านกีฬา	48	18.0	100	37.0	148	27.6
	3 สนับสนุนด้านสาธารณูปโภค	150	56.2	50	18.5	200	37.2
	4 สนับสนุนทางด้านศาสนสถาน	22	8.2	45	16.7	67	12.5
	5 สนับสนุนด้านสุขภาพอนามัย	25	9.4	25	9.3	50	9.3
	รวม	**267**	**100.0**	**270**	**100.0**	**537**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ		วัดมีระยะ 0-3 กิโลเมตร จากโครงการ		วัดมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
4.8 ท่านทราบหรือไม่ว่ามีคนในชุมชนเข้ามาทำงานในพื้นที่โครงการฯ ในช่วง 1 ปี							
	1 ไม่ทราบ	4	1.5	20	17.4	24	6.3
	2 ทราบ	262	97.8	73	63.5	335	87.4
	3 ไม่แน่ใจ	2	0.7	22	19.1	24	6.3
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
4.9 ท่านเคยทราบหรือไม่ว่า โครงการฯ จะคัดคนเข้าทำงานโดยพิจารณาที่เหมาะสมกับตำแหน่งงาน							
	1 ไม่ทราบ	4	1.5	30	26.1	34	8.9
	2 ทราบ	257	95.9	71	61.7	328	85.6
	3 ไม่แน่ใจ	7	2.6	14	12.2	21	5.5
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
4.10 ในช่วงปี 2568 ที่ผ่านมา ท่านเคยได้รับข้อมูลการจัดการสิ่งแวดล้อมเกี่ยวกับโครงการฯ เพื่อให้เกิดความรู้ความเข้าใจและสร้างความมั่นใจให้กับชุมชนหรือไม่							
	1 ไม่ทราบ	136	50.7	80	69.6	216	56.4
	2 ทราบ	132	49.3	35	30.4	167	43.6
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ทราบจาก							
	1 ผู้นำชุมชน	25	17.1	0	0.0	25	13.8
	2 เจ้าหน้าที่โครงการ	120	82.2	35	100.0	155	85.6
	3 เพื่อนบ้าน	1	0.7	0	0.0	1	0.6
	4 เข้าร่วมประชุม	0	0.0	0	0.0	0	0.0
	รวม	**146**	**100.0**	**35**	**100.0**	**181**	**100.0**
4.11 ในช่วงปี 2568 ที่ผ่านมา ท่านรับทราบกิจกรรมมวลชนสัมพันธ์ของโครงการและการเข้าไปมีส่วนร่วมในกิจกรรมหรือไม่							
	1 ไม่ทราบ	16	6.2	0	0.0	16	4.3
	2 ทราบ	242	93.8	115	100.0	357	95.7
	3 ไม่แน่ใจ	0	0.0	0	0.0	0	0.0
	รวม	**258**	**100.0**	**115**	**100.0**	**373**	**100.0**
4.12 ในช่วงปี 2568 ท่านรับทราบกิจกรรม"เปิดบ้านล้อมรับแขกภายนอกเพื่อเข้าเยี่ยมชมโรงงาน (เปิดบ้าน)"หรือไม่							
	1 ไม่ทราบ	28	10.4	60	52.2	88	23.0
	2 ทราบ	240	45.4	55	47.8	295	77.0
	3 ไม่แน่ใจ	0	0.0	0	0.0	0	0.0
	รวม	**268**	**55.8**	**115**	**100.0**	**383**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ		วัดมีระยะ 0-3 กิโลเมตร จากโครงการ		วัดมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ส่วนที่ 5 ความคิดเห็นเกี่ยวกับการดำเนินโครงการฯ							
5.1 ท่านคิดว่าช่วง 1 ปีที่ผ่านมา การดำเนินงานของโครงการฯ มีผลกระทบด้านสิ่งแวดล้อมของชุมชนหรือไม่							
ลักษณะปัญหา							
1. ฝุ่นละออง							
	1 ไม่มีปัญหา	268	100.0	115	100.0	383	100.0
	2 มีปัญหา	0	0.0	0	0.0	0	0.0
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ระดับของปัญหา							
	1 น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2 น้อย	0	0.0	0	0.0	0	0.0
	3 ปานกลาง	0	0.0	0	0.0	0	0.0
	4 มาก	0	0.0	0	0.0	0	0.0
	5 มากที่สุด	0	18.7	0	0.0	0	0.0
	รวม	**0**	**18.7**	**0**	**0.0**	**0**	**0.0**
ค่าเฉลี่ย		**0.00**	**ไม่มี**	**0.00**	**ไม่มี**	**0.00**	**ไม่มีผลกระทบ**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)		**0.000**	**ผลกระทบ**	**0.000**	**ผลกระทบ**	**0.000**	
ช่วงเวลา							
	1 ฤดูหนาว	0	0.0	0	0.0	0	0.0
	2 ฤดูร้อน	0	0.0	0	0.0	0	0.0
	3 ฤดูฝน	0	0.0	0	0.0	0	0.0
	4 ตลอดทั้งปี	0	0.0	0	0.0	0	0.0
	5 ไม่แน่นอน	0	0.0	0	0.0	0	0.0
	รวม	**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
2. เสียงดัง							
	1 ไม่มีปัญหา	268	100.0	115	100.0	383	100.0
	2 มีปัญหา	0	0.0	0	0.0	0	0.0
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ		วัดมีระยะ 0-3 กิโลเมตร จากโครงการ		วัดมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ระดับของปัญหา							
	1 น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2 น้อย	0	0.0	0	0.0	0	0.0
	3 ปานกลาง	0	0.0	0	0.0	0	0.0
	4 มาก	0	0.0	0	0.0	0	0.0
	5 มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม	**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
ค่าเฉลี่ย		**0.00**	**ไม่มี**	**0.00**	**ไม่มี**	**0.00**	**ไม่มีผลกระทบ**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)		**0.000**	**ผลกระทบ**	**0.000**	**ผลกระทบ**	**0.000**	
3.ความสั่นสะเทือน							
	1 ไม่มีปัญหา	268	100.0	115	100.0	383	100.0
	2 มีปัญหา	0	0.0	0	0.0	0	0.0
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ระดับของปัญหา							
	1 น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2 น้อย	0	0.0	0	0.0	0	0.0
	3 ปานกลาง	0	0.0	0	0.0	0	0.0
	4 มาก	0	0.0	0	0.0	0	0.0
	5 มากที่สุด	0	18.7	0	0.0	0	0.0
	รวม	**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
ค่าเฉลี่ย		**0.00**	**ไม่มี**	**0.00**	**ไม่มี**	**0.00**	**ไม่มีผลกระทบ**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)		**0.000**	**ผลกระทบ**	**0.000**	**ผลกระทบ**	**0.000**	

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ		วัดมีระยะ 0-3 กิโลเมตร จากโครงการ		วัดมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ช่วงเวลา							
	1 ฤดูหนาว	0	0.0	0	0.0	0	0.0
	2 ฤดูร้อน	0	0.0	0	0.0	0	0.0
	3 ฤดูฝน	0	0.0	0	0.0	0	0.0
	4 ตลอดทั้งปี	0	0.0	0	0.0	0	0.0
	5 ไม่แน่นอน	0	0.0	0	0.0	0	0.0
	รวม	**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
4. น้ำเสีย							
	1 ไม่มีปัญหา	268	100.0	115	100.0	383	100.0
	2 มีปัญหา	0	0.0	0	0.0	0	0.0
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ระดับของปัญหา							
	1 น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2 น้อย	0	0.0	0	0.0	0	0.0
	3 ปานกลาง	0	0.0	0	0.0	0	0.0
	4 มาก	0	0.0	0	0.0	0	0.0
	5 มากที่สุด	0	18.7	0	0.0	0	0.0
	รวม	**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
ค่าเฉลี่ย		**0.00**	**ไม่มี**	**0.00**	**ไม่มี**	**0.00**	**ไม่มีผลกระทบ**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)		**0.000**	**ผลกระทบ**	**0.000**	**ผลกระทบ**	**0.000**	
ช่วงเวลา							
	1 ฤดูหนาว	0	0.0	0	0.0	0	0.0
	2 ฤดูร้อน	0	0.0	0	0.0	0	0.0
	3 ฤดูฝน	0	0.0	0	0.0	0	0.0
	4 ตลอดทั้งปี	0	0.0	0	0.0	0	0.0
	5 ไม่แน่นอน	0	0.0	0	0.0	0	0.0
	รวม	**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
5. น้ำท่วมขัง							
	1 ไม่มีปัญหา	268	100.0	115	100.0	383	100.0
	2 มีปัญหา	0	0.0	0	0.0	0	0.0
	รวม	**268**	**100.0**	**115**	**100.0**	**383**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ		รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ระดับของปัญหา							
1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
2	น้อย	0	0.0	0	0.0	0	0.0
3	ปานกลาง	0	0.0	0	0.0	0	0.0
4	มาก	0	0.0	0	0.0	0	0.0
5	มากที่สุด	0	18.7	0	0.0	0	0.0
รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
ค่าเฉลี่ย		**0.00**	**ไม่มี**	**0.00**	**ไม่มี**	**0.00**	**ไม่มีผลกระทบ**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)		**0.000**	**ผลกระทบ**	**0.000**	**ผลกระทบ**	**0.000**	
ช่วงเวลา							
1	ฤดูหนาว	0	0.0	0	0.0	0	0.0
2	ฤดูร้อน	0	0.0	0	0.0	0	0.0
3	ฤดูฝน	0	0.0	0	0.0	0	0.0
4	ตลอดทั้งปี	0	0.0	0	0.0	0	0.0
5	ไม่แน่นอน	0	0.0	0	0.0	0	0.0
รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
6. ขอรบกวนเลย							
1	ไม่มีปัญหา	268	100.0	115	100.0	383	100.0
2	มีปัญหา	0	0.0	0	0.0	0	0.0
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ระดับของปัญหา							
1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
2	น้อย	0	0.0	0	0.0	0	0.0
3	ปานกลาง	0	0.0	0	0.0	0	0.0
4	มาก	0	0.0	0	0.0	0	0.0
5	มากที่สุด	0	18.7	0	0.0	0	0.0
รวม		**0**	**18.7**	**0**	**0.0**	**0**	**0.0**
ค่าเฉลี่ย		**0.00**	**ไม่มี**	**0.00**	**ไม่มี**	**0.00**	**ไม่มีผลกระทบ**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)		**0.000**	**ผลกระทบ**	**0.000**	**ผลกระทบ**	**0.000**	

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ		รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ช่วงเวลา							
1	ฤดูหนาว	0	0.0	0	0.0	0	0.0
2	ฤดูร้อน	0	0.0	0	0.0	0	0.0
3	ฤดูฝน	0	0.0	0	0.0	0	0.0
4	ตลอดทั้งปี	0	0.0	0	0.0	0	0.0
5	ไม่แน่นอน	0	0.0	0	0.0	0	0.0
รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
7. กลิ่นเหม็น							
1	ไม่มีปัญหา	268	100.0	115	100.0	383	100.0
2	มีปัญหา	0	0.0	0	0.0	0	0.0
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ระดับของปัญหา							
1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
2	น้อย	0	0.0	0	0.0	0	0.0
3	ปานกลาง	0	0.0	0	0.0	0	0.0
4	มาก	0	0.0	0	0.0	0	0.0
5	มากที่สุด	0	0.0	0	0.0	0	0.0
รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
ค่าเฉลี่ย		**0.00**	**ไม่มี**	**0.00**	**ไม่มี**	**0.00**	**ไม่มีผลกระทบ**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)		**0.000**	**ผลกระทบ**	**0.000**	**ผลกระทบ**	**0.000**	
ช่วงเวลา							
1	ฤดูหนาว	0	0.0	0	0.0	0	0.0
2	ฤดูร้อน	0	0.0	0	0.0	0	0.0
3	ฤดูฝน	0	0.0	0	0.0	0	0.0
4	ตลอดทั้งปี	0	0.0	0	0.0	0	0.0
5	ไม่แน่นอน	0	0.0	0	0.0	0	0.0
รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
8. การจราจรติดขัด							
1	ไม่มีปัญหา	268	100.0	115	100.0	383	100.0
2	มีปัญหา	0	0.0	0	0.0	0	0.0
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ		รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
9. อุบัติเหตุจากการจราจร							
1	ไม่มีปัญหา	268	100.0	115	100.0	383	100.0
2	มีปัญหา	0	0.0	0	0.0	0	0.0
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ระดับของปัญหา							
1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
2	น้อย	0	0.0	0	0.0	0	0.0
3	ปานกลาง	0	0.0	0	0.0	0	0.0
4	มาก	0	0.0	0	0.0	0	0.0
5	มากที่สุด	0	0.0	0	0.0	0	0.0
รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
ค่าเฉลี่ย		**0.00**	**ไม่มี**	**0.00**	**ไม่มี**	**0.00**	**ไม่มีผลกระทบ**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)		**0.000**	**ผลกระทบ**	**0.000**	**ผลกระทบ**	**0.000**	

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มครัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ		รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ช่วงเวลา							
1	ฤดูหนาว	0	0.0	0	0.0	0	0.0
2	ฤดูร้อน	0	0.0	0	0.0	0	0.0
3	ฤดูฝน	0	0.0	0	0.0	0	0.0
4	ตลอดทั้งปี	0	0.0	0	0.0	0	0.0
5	ไม่แน่นอน	0	0.0	0	0.0	0	0.0
รวม		**0**	**0.0**	**0**	**0.0**	**0**	**0.0**
5.2 ท่านมีความรู้สึกวิตกกังวลต่อโครงการฯ หรือไม่อย่างไร							
1	ไม่วิตกกังวล	268	100.0	115	100.0	383	100.0
2	วิตกกังวล	0	0.0	0	0.0	0	0.0
3	ไม่มีความเห็น	0	0.0	0	0.0	0	0.0
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
5.3 โดยภาพรวมช่วง 1 ปี ท่านมีความพึงพอใจต่อการปฏิบัติตามมาตรการลดผลกระทบด้านต่างๆ ของโครงการฯ ในระดับใด							
1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
2	น้อย	0	0.0	0	0.0	0	0.0
3	ปานกลาง	268	94.7	115	100.0	383	96.2
4	มาก	15	5.3	0	0.0	15	3.8
5	มากที่สุด	0	0.0	0	0.0	0	0.0
6	ควรปรับปรุง	0	0.0	0	0.0	0	0.0
รวม		**283**	**100.0**	**115**	**100.0**	**398**	**100.0**
5.4 ในช่วง 1 ปีที่ผ่านมา ท่านเคยได้รับผลกระทบเกี่ยวกับการดำเนินกิจกรรมของโครงการฯ หรือไม่							
1	ไม่มี	268	100.0	115	100.0	383	100.0
2	เคย	0	0.0	0	0.0	0	0.0
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มตัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ			รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
			จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
5.5 ในช่วงปี 2568 ที่ผ่านมา ท่านคิดว่าการดำเนินงานของโครงการฯ มีผลต่อชุมชนหรือชีวิตของท่านอย่างไร								
	1	ผลดีมากกว่าผลเสีย	0	0.0	0	0.0	0	0.0
	2	ผลเสียมากกว่าผลดี	0	0.0	0	0.0	0	0.0
	3	ผลดีกับผลเสียพอๆกัน	268	100.0	115	100.0	383	100.0
	4	ไม่แน่ใจ	0	0.0	0	0.0	0	0.0
	5	ไม่มีความเห็น	0	0.0	0	0.0	0	0.0
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
5.6 ท่านคิดว่าการโครงการฯ มีผลดีต่อชุมชนของท่านหรือไม่ และในด้านใด								
ผลดีจากการดำเนินโครงการ ด้านสภาพเศรษฐกิจ-สังคม								
(1) ทำให้ประชาชนในพื้นที่มีงานทำมากขึ้นจากการรับจ้างในโครงการฯ								
ผลดี								
	1	ไม่มี	0	0.0	0	0.0	0	0.0
	2	มี	268	100.0	115	100.0	383	100.0
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ระดับผลดี								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	268	98.2	115	100.0	383	98.7
	4	มาก	0	0.0	0	0.0	0	0.0
	5	มากที่สุด	5	1.8	0	0.0	5	1.3
	รวม		**273**	**100.0**	**115**	**100.0**	**388**	**100.0**
ค่าเฉลี่ย			**3.04**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.03**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.269**		**0.000**		**0.226**	
(2) ทำให้การค้าขายของร้านค้าเติบโตและธุรกิจบริการต่างๆ ดีขึ้น								
ผลดี								
	1	ไม่มี	0	0.0	0	0.0	0	0.0
	2	มี	268	100.0	115	100.0	383	100.0
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มตัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ			รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
			จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ระดับผลดี								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	268	98.2	115	100.0	383	98.7
	4	มาก	0	0.0	0	0.0	0	0.0
	5	มากที่สุด	5	1.8	0	0.0	5	1.3
	รวม		**273**	**100.0**	**115**	**100.0**	**388**	**100.0**
ค่าเฉลี่ย			**3.04**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.03**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.269**		**0.000**		**0.226**	
(3) สภาพเศรษฐกิจของชุมชนดีขึ้น								
ผลดี								
	1	ไม่มี	0	0.0	0	0.0	0	0.0
	2	มี	268	100.0	115	100.0	383	100.0
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ระดับผลดี								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	268	98.2	115	100.0	383	98.7
	4	มาก	0	0.0	0	0.0	0	0.0
	5	มากที่สุด	5	1.8	0	0.0	5	1.3
	รวม		**273**	**100.0**	**115**	**100.0**	**388**	**100.0**
ค่าเฉลี่ย			**3.04**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.03**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.269**		**0.000**		**0.226**	
(4) ได้รับการสนับสนุนกิจกรรมชุมชนจากโครงการฯมากขึ้น								
ผลดี								
	1	ไม่มี	0	0.0	0	0.0	0	0.0
	2	มี	268	100.0	115	100.0	383	100.0
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มตัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ			รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
			จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ระดับผลดี								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	268	98.2	115	100.0	383	98.7
	4	มาก	0	0.0	0	0.0	0	0.0
	5	มากที่สุด	5	1.8	0	0.0	5	1.3
	รวม		**273**	**100.0**	**115**	**100.0**	**388**	**100.0**
ค่าเฉลี่ย			**3.04**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.03**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.269**		**0.000**		**0.226**	
(5) มีการพัฒนาระบบสาธารณูปโภคของชุมชนดีขึ้น เช่น ถนน								
ผลดี								
	1	ไม่มี	0	0.0	0	0.0	0	0.0
	2	มี	268	100.0	115	100.0	383	100.0
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ระดับผลดี								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	268	98.2	115	100.0	383	98.7
	4	มาก	0	0.0	0	0.0	0	0.0
	5	มากที่สุด	5	1.8	0	0.0	5	1.3
	รวม		**273**	**100.0**	**115**	**100.0**	**388**	**100.0**
ค่าเฉลี่ย			**3.04**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.03**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.269**		**0.000**		**0.226**	
5.7 ท่านมีความพึงพอใจต่อกิจกรรมชุมชนสัมพันธ์ที่ทางโครงการฯ ดำเนินการในปี 2567 ระดับใด								
1. กิจกรรมเกี่ยวกับสุขภาพ								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	250	93.3	94	81.7	344	89.8
	4	มาก	18	6.7	21	18.3	39	10.2
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ค่าเฉลี่ย			**3.07**	**ปานกลาง**	**3.18**	**ปานกลาง**	**3.10**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.251**		**0.388**		**0.303**	

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มตัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลิน จำกัด (มหาชน) พ.ศ. 2568

รายการ			รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
			จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
2. กิจกรรมเกี่ยวกับการอนุรักษ์สิ่งแวดล้อม								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	243	90.7	100	87.0	343	89.6
	4	มาก	25	9.3	0	0.0	25	6.5
	5	มากที่สุด	0	0.0	15	13.0	15	3.9
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ค่าเฉลี่ย			**3.09**	**ปานกลาง**	**3.26**	**ปานกลาง**	**3.14**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.291**		**0.677**		**0.449**	
3. กิจกรรมเกี่ยวกับการส่งเสริมการศึกษา								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	248	92.5	115	100.0	363	94.8
	4	มาก	20	7.5	0	0.0	20	5.2
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ค่าเฉลี่ย			**3.07**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.05**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.263**		**0.000**		**0.223**	
4. กิจกรรมเกี่ยวกับการพัฒนาความสัมพันธ์ชุมชน								
	1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
	2	น้อย	0	0.0	0	0.0	0	0.0
	3	ปานกลาง	268	100.0	115	100.0	383	100.0
	4	มาก	0	0.0	0	0.0	0	18.0
	5	มากที่สุด	0	0.0	0	0.0	0	0.0
	รวม		**268**	**100.0**	**115**	**100.0**	**383**	**118.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**		**0.000**		**0.000**	

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มตัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ		รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
5. กิจกรรมเกี่ยวกับการส่งเสริมศาสนา วัฒนธรรม							
1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
2	น้อย	0	0.0	0	0.0	0	0.0
3	ปานกลาง	268	100.0	115	100.0	383	100.0
4	มาก	0	0.0	0	0.0	0	0.0
5	มากที่สุด	0	0.0	0	0.0	0	0.0
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ค่าเฉลี่ย		**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)		**0.000**		**0.000**		**0.000**	
6. กิจกรรมการประชาสัมพันธ์และแจ้งข่าวสารของโรงงาน							
1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
2	น้อย	0	0.0	0	0.0	0	0.0
3	ปานกลาง	268	100.0	115	100.0	383	100.0
4	มาก	0	0.0	0	0.0	0	0.0
5	มากที่สุด	0	0.0	0	0.0	0	0.0
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ค่าเฉลี่ย		**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**	**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)		**0.000**		**0.000**		**0.000**	
7. กิจกรรมการประชาสัมพันธ์และแจ้งข่าวสารของโรงงาน							
1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
2	น้อย	254	94.8	0	0.0	254	66.3
3	ปานกลาง	14	5.2	113	98.3	127	33.2
4	มาก	0	0.0	2	1.7	2	0.5
5	มากที่สุด	0	0.0	0	0.0	0	0.0
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ค่าเฉลี่ย		**2.05**	**น้อย**	**3.02**	**ปานกลาง**	**2.34**	**น้อย**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)		**0.223**		**0.131**		**0.486**	

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มตัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ		รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ต้องการ ได้แก่							
1	ด้านการพัฒนาชุมชน	10	20.8	2	2.0	12	8.1
2	กิจกรรมด้านการกีฬา	2	4.2	5	5.0	7	4.7
3	ด้านการศึกษา	10	20.8	40	40.0	50	33.8
4	ด้านศาสนา	1	2.1	5	5.0	6	4.1
6	ด้านประเพณี	5	10.4	10	10.0	15	10.1
7	ด้านสิ่งแวดล้อม	0	0.0	13	13.0	13	8.8
8	ด้านสุขภาพ	15	31.3	15	15.0	30	20.3
9	สนับสนุนด้านอาชีพ	5	10.4	10	10.0	15	10.1
รวม		**48**	**100.0**	**100**	**100.0**	**148**	**100.0**
6.5 ข้อเสนอแนะอื่นๆ เกี่ยวกับโครงการฯ							
1	จัดกิจกรรมหรือประชาสัมพันธ์ข้อมูลข่าวสารให้มากขึ้น	1	0.4	10	8.7	11	2.9
2	สนับสนุนกิจกรรมประเพณีในชุมชน	2	0.7	7	6.1	9	2.3
3	ไม่มีข้อเสนอแนะ	265	98.9	98	85.2	363	94.8
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**

หมายเหตุ : 1/ ตารางวิเคราะห์ระดับของผลกระทบที่ได้รับจากค่าเฉลี่ยโดยใช้แนวคิดของ Likert (อ้างอิงจากบุญธรรม กิจปรีดาบริสุทธิ์, 2553) ดังนี้

ค่าคะแนน 1.00-1.50 หมายถึง ระดับน้อยที่สุด
ค่าคะแนน 1.51-2.50 หมายถึง ระดับน้อย
ค่าคะแนน 2.51-3.50 หมายถึง ระดับปานกลาง
ค่าคะแนน 3.51-4.50 หมายถึง ระดับมาก
ค่าคะแนน 4.51-5.00 หมายถึง ระดับมากที่สุด

2/ ค่าเฉลี่ย (Mean : เป็นค่าที่ได้จากการรวมกันของข้อมูลทุกตัวในชุดข้อมูลนั้น หาวิเคราะห์ด้วยข้อมูลทั้งหมด (รวมมี แกนเกตุ, 2551)

3/ ค่าส่วนเบี่ยงเบนมาตรฐาน (Standard deviation : S.D. หรือ S) ใช้สำหรับหาค่าความแตกต่างโดยเฉลี่ยของระดับผลกระทบจากค่ากึ่งกลาง ของข้อมูลหรือความแตกต่างของระดับผลกระทบโดยเฉลี่ย

ที่มา : บริษัท เอสจีเอส (ประเทศไทย) จำกัด, พ.ศ. 2568

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มตัวเรือน ต่อสำรวจสภาพเศรษฐกิจ-สังคม
และความคิดเห็นของประชาชนที่มีต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ		รัศมีระยะ 0-3 กิโลเมตร จากโครงการ		รัศมีระยะ 3-5 กิโลเมตร จากโครงการ		รวม	
		จำนวน	ร้อยละ	จำนวน	ร้อยละ	จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
8. กิจกรรมเกี่ยวกับการพัฒนาชุมชน							
1	น้อยที่สุด	0	0.0	0	0.0	0	0.0
2	น้อย	0	0.0	0	0.0	0	0.0
3	ปานกลาง	68	25.4	92	80.0	160	41.8
4	มาก	200	74.6	23	20.0	223	58.2
5	มากที่สุด	0	0.0	0	0.0	0	0.0
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ค่าเฉลี่ย		**3.75**	**มาก**	**3.20**	**ปานกลาง**	**3.58**	**มาก**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)		**0.436**		**0.402**		**0.494**	
ส่วนที่ 6 การประชาสัมพันธ์โครงการและการมีส่วนร่วมของประชาชน							
6.1 ท่านต้องการรับทราบข้อมูลเพิ่มเติมเกี่ยวกับโครงการฯ หรือไม่							
1	ไม่ต้องการทราบ (ข้ามไปตอบข้อ 6.3)	259	96.6	95	82.6	354	92.4
2	ต้องการทราบ	9	3.4	20	17.4	29	7.6
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
ต้องการทราบ เรื่อง							
1	ข่าวสารด้านการรับสมัครงาน	2	22.2	5	25.0	7	24.1
2	การมีส่วนร่วมกิจกรรมของบริษัทกับชุมชน	4	44.5	10	50.0	14	48.3
3	ข้อมูลโครงการและกิจกรรมต่างๆ	3	33.3	5	25.0	8	27.6
รวม		**9**	**100.0**	**20**	**100.0**	**29**	**100.0**
6.2 รูปแบบ/วิธีการใดที่เหมาะสมที่ทำให้ท่านและชุมชนได้รับรู้ข้อมูลเกี่ยวกับโครงการฯ มากที่สุด **(ตอบได้มากกว่า 1 ข้อ)**							
1	ทำจดหมาย/เอกสาร แจ้งห่อประชาชนโดยตรง	5	26.3	0	0.0	5	12.8
2	แจ้งข้อมูลผ่านกำนัน ผู้ใหญ่บ้านหรือผู้นำชุมชน	2	10.5	20	100.0	22	56.4
3	แจ้งข้อมูลผ่านวิทยุชุมชน/หอกระจายเสียงชุมชน	6	31.6	0	0.0	6	15.4
4	จัดประชุมชี้แจงข้อมูลข่าวสารโดยตรง	6	31.6	0	0.0	6	15.4
5	ไซเซียงฉลิเดีย	0	0.0	0	0.0	0	0.0
รวม		**19**	**100.0**	**20**	**100.0**	**39**	**100.0**
6.3 หากทางโครงการฯ จัดกิจกรรมร่วมกับชุมชนท่านยินดีเข้าร่วมหรือไม่							
1	ยินดีเข้าร่วม	268	100.0	115	100.0	383	100.0
2	ไม่ยินดี	0	0.0	0	0.0	0	0.0
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**
6.4 ท่านต้องการให้ทางโครงการฯ ส่งเสริมกิจกรรมด้านใดให้กับชุมชนบ้าง							
1	ไม่ต้องการ	245	91.4	65	56.5	310	80.9
2	ต้องการ	23	8.6	50	43.5	73	19.1
รวม		**268**	**100.0**	**115**	**100.0**	**383**	**100.0**

ภาคผนวกที่ 6

ผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของหน่วยงานราชการ โรงเรียน และวัด

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มหน่วยงานราชการ
โรงเรียน และวัด ต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8)
ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ			จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**10**	**100.0**
ส่วนที่ 1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม				
1.1 ข้อมูลทั่วไปของผู้ตอบแบบสอบถาม				
1. เพศ				
	1	ชาย	4	40.0
	2	หญิง	6	60.0
	รวม		**10**	**100.0**
2. อายุ				
		ค่าเฉลี่ย	**50.0**	
3. ตำแหน่ง				
	1	ผู้อำนวยการโรงพยาบาลส่งเสริมสุขภาพตำบล	2	20.0
	2	ครูผู้สอน	1	10.0
	3	เจ้าอาวาส	7	70.0
	รวม		**10**	**100.0**
4. ระยะเวลาที่ปฏิบัติหน้าที่ในชุมชน/หน่วยงาน/องค์กร				
	1	น้อยกว่า 1 ปี	0	0.0
	2	ระหว่าง 1-5 ปี	0	0.0
	3	ระหว่าง 6-10 ปี	5	50.0
	4	ระหว่าง 11-15 ปี	1	10.0
	5	ระหว่าง 16-20 ปี	4	40.0
	6	มากกว่า 20 ปี ขึ้นไป	0	0.0
	รวม		**10**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มหน่วยงานราชการ
โรงเรียน และวัด ต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8)
ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ			จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**10**	**100.0**
5. หน้าที่ความรับผิดชอบ				
	1	ส่งเสริม ป้องกัน ฟื้นฟูด้านสุขภาพ งานด้านสาธารณสุขในพื้นที่	2	20.0
	2	จัดการเรียนการสอน	1	10.0
	3	ดูแลความเรียบร้อยภายในวัด	7	70.0
	รวม		**10**	**100.0**
ส่วนที่ 2 การตรวจสอบเรื่องร้องเรียน				
2.1 ในช่วง 1 ปีที่ผ่านมา ท่านเคยได้รับเรื่องร้องเรียนจากชุมชนเกี่ยวกับกิจกรรมของโครงการฯ หรือไม่				
	1	ไม่มี (ข้ามไปตอบส่วนที่ 3)	10	100.0
	2	มี	0	0.0
	รวม		**10**	**100.0**
ส่วนที่ 3 ความคิดเห็นเกี่ยวกับการดำเนินโครงการฯ				
3.1 ท่านมีความรู้สึกวิตกกังวลต่อโครงการฯ หรือไม่อย่างไร				
	1	ไม่วิตกกังวล	10	100.0
	2	วิตกกังวล	0	0.0
	3	ไม่มีความเห็น	0	0.0
	รวม		**10**	**100.0**
3.2 ท่านมีความเชื่อมั่นต่อระบบการจัดการด้านสิ่งแวดล้อมและมาตรการป้องกันผลกระทบด้านต่างๆ ของโครงการฯ มากน้อยเพียงใด				
	1	เชื่อมั่นสูง	4	40.0
	2	เชื่อมั่นพอสมควร (หากมีอุบัติเหตุสามารถแก้ไขหรือควบคุมได้ทัน)	6	60.0
	3	ไม่มีความเชื่อมั่น (เมื่อมีอุบัติเหตุไม่สามารถควบคุมได้)	0	0.0
	4	ไม่ทราบ/ไม่แน่ใจ	0	0.0
	รวม		**10**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มหน่วยงานราชการ
โรงเรียน และวัด ต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8)
ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ			จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**10**	**100.0**
3.3 โดยภาพรวมช่วง 1 ปี ท่านมีความพึงพอใจต่อการปฏิบัติตามมาตรการลดผลกระทบด้านต่างๆ ของโครงการฯ ในระดับใด				
	1	น้อยที่สุด	0	0.0
	2	น้อย	0	0.0
	3	ปานกลาง	10	100.0
	4	มาก	0	0.0
	5	มากที่สุด	0	0.0
	6	ควรปรับปรุง ระบุ	0	0.0
	รวม		**10**	**100.0**
3.4 ในช่วง 1 ปีที่ผ่านมา ชุมชนของท่านเคยได้รับผลกระทบเกี่ยวกับการดำเนินกิจกรรมของโครงการฯ หรือไม่				
	1	ไม่มี	10	100.0
	2	เคย เรื่องกลิ่นเหม็นและฝุ่นละออง	0	0.0
	รวม		**10**	**100.0**
ส่วนที่ 4 การประชาสัมพันธ์โครงการและการมีส่วนร่วมของประชาชน				
4.1 ท่านทราบหรือรู้จักโครงการฯ หรือไม่				
	1	ไม่ทราบ/ไม่รู้จัก (ข้ามไปตอบส่วนที่ 4.8)	0	0.0
	2	ทราบ/รู้จัก	10	100.0
	รวม		**10**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มหน่วยงานราชการ
โรงเรียน และวัด ต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8)
ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ			จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**10**	**100.0**
4.2 ถ้าทราบ ท่านทราบจากแหล่งใด (ตอบได้มากกว่า 1 ข้อ)				
	1	เพื่อนบ้านเล่าให้ฟัง	3	15.0
	2	ผู้นำชุมชน	4	20.0
	3	หน่วยงานราชการต่างๆ	4	20.0
	4	หนังสือพิมพ์	0	0.0
	5	เจ้าหน้าที่ของโครงการฯ	6	30.0
	6	เคยเข้าร่วมประชุมกับทางโครงการฯ	3	15.0
	7	ได้ร่วมกิจกรรมกับทางโครงการฯ	0	0.0
	รวม		**20**	**100.0**
4.3 ท่านต้องการรับทราบข้อมูลเพิ่มเติมเกี่ยวกับโครงการฯ หรือไม่				
	1	ไม่ต้องการทราบ	6	60.0
	2	ต้องการทราบ	4	40.0
	รวม		**10**	**100.0**
	ต้องการทราบเรื่อง			
	1	ช่องทางการติดต่อเพื่อขอความช่วยเหลือด้านต่างๆ	4	100.0
	รวม		**4**	**100.0**
4.4 รูปแบบ/วิธีการใดที่เหมาะสมที่ทำให้ท่านและชุมชนได้รับรู้ข้อมูลเกี่ยวกับโครงการฯ มากที่สุด **(ตอบได้มากกว่า 1 ข้อ)**				
	1	ทำจดหมาย/เอกสาร แจ้งต่อประชาชนโดยตรง	8	40.0
	2	แจ้งข้อมูลผ่านกำนัน ผู้ใหญ่บ้านหรือผู้นำชุมชน	5	25.0
	3	แจ้งข้อมูลผ่านวิทยุชุมชน/หอกระจายเสียชุมชน	2	10.0
	4	จัดประชุมชี้แจงข้อมูลข่าวสารโดยตรง	5	25.0
	รวม		**20**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มหน่วยงานราชการ
โรงเรียน และวัด ต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8)
ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ			จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**10**	**100.0**
4.5 หากทางโครงการฯ จัดกิจกรรมร่วมกับชุมชนท่านยินดีเข้าร่วมหรือไม่				
	1	ยินดีเข้าร่วม	10	100.0
	2	ไม่ยินดี	0	0.0
	รวม		**10**	**100.0**
4.6 ท่านต้องการให้ทางโครงการฯ ส่งเสริมกิจกรรมด้านใดให้กับชุมชนบ้าง				
	1	ไม่ต้องการ	0	0.0
	2	ต้องการ	10	100.0
	รวม		**10**	**100.0**
	ต้องการเรื่อง (ตอบได้มากกว่า 1 ข้อ)			
	1	เศรษฐกิจและสุขภาพ	3	30.0
	2	กิจกรรมส่งเสริมนักเรียนด้านต่างๆ	1	10.0
	3	สนับสนุนกิจกรรมด้านศาสนาและประเพณีต่างๆ อย่างต่อเนื่อง	6	60.0
	รวม		**10**	**100.0**

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มหน่วยงานราชการ
โรงเรียน และวัด ต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8)
ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ			จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**10**	**100.0**
4.7 ท่านมีความพึงพอใจต่อกิจกรรมชุมชนสัมพันธ์ที่ทางโครงการฯ ดำเนินการในปี 2568 ระดับใด				
1. กิจกรรมเกี่ยวกับสุขภาพ				
	1	น้อยที่สุด	0	0.0
	2	น้อย	0	0.0
	3	ปานกลาง	10	100.0
	4	มาก	0	0.0
	5	มากที่สุด	0	0.0
	รวม		**10**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**	
2. กิจกรรมเกี่ยวกับการอนุรักษ์สิ่งแวดล้อม				
	1	น้อยที่สุด	0	0.0
	2	น้อย	0	0.0
	3	ปานกลาง	10	100.0
	4	มาก	0	0.0
	5	มากที่สุด	0	0.0
	รวม		**10**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**	

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มหน่วยงานราชการ
โรงเรียน และวัด ต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8)
ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ			จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**10**	**100.0**
3.กิจกรรมเกี่ยวกับการส่งเสริมการศึกษา				
	1	น้อยที่สุด	0	0.0
	2	น้อย	0	0.0
	3	ปานกลาง	10	100.0
	4	มาก	0	0.0
	5	มากที่สุด	0	0.0
	รวม		**10**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**	
4.กิจกรรมเกี่ยวกับการพัฒนาความสัมพันธ์ชุมชน				
	1	น้อยที่สุด	0	0.0
	2	น้อย	0	0.0
	3	ปานกลาง	10	100.0
	4	มาก	0	0.0
	5	มากที่สุด	0	0.0
	รวม		**10**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**	

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มหน่วยงานราชการ
โรงเรียน และวัด ต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8)
ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ			จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**10**	**100.0**
5.กิจกรรมเกี่ยวกับการส่งเสริมศาสนา วัฒนธรรม				
	1	น้อยที่สุด	0	0.0
	2	น้อย	0	0.0
	3	ปานกลาง	10	100.0
	4	มาก	0	0.0
	5	มากที่สุด	0	0.0
	รวม		**10**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**	
6.กิจกรรมการประชาสัมพันธ์และแจ้งข่าวสารของโรงงาน				
	1	น้อยที่สุด	0	0.0
	2	น้อย	0	0.0
	3	ปานกลาง	10	100.0
	4	มาก	0	0.0
	5	มากที่สุด	0	0.0
	รวม		**10**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**	

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มหน่วยงานราชการ โรงเรียน และวัด ต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ			จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**10**	**100.0**
7.กิจกรรมการประชาสัมพันธ์และแจ้งข่าวสารของโรงงาน				
	1	น้อยที่สุด	0	0.0
	2	น้อย	0	0.0
	3	ปานกลาง	10	100.0
	4	มาก	0	0.0
	5	มากที่สุด	0	0.0
	รวม		**10**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**	
8. กิจกรรมเกี่ยวกับการพัฒนาชุมชน				
	1	น้อยที่สุด	0	0.0
	2	น้อย	0	0.0
	3	ปานกลาง	10	100.0
	4	มาก	0	0.0
	5	มากที่สุด	0	0.0
	รวม		**10**	**100.0**
ค่าเฉลี่ย			**3.00**	**ปานกลาง**
ส่วนเบี่ยงเบนมาตรฐาน (S.D.)			**0.000**	

ตารางประมวลผลการสำรวจสภาพเศรษฐกิจ สังคม และความคิดเห็นของกลุ่มหน่วยงานราชการ โรงเรียน และวัด ต่อการดำเนินการโครงการโรงผลิตไฟฟ้า (TG1-TG8) ของบริษัท ทีพีไอ โพลีน จำกัด (มหาชน) พ.ศ. 2568

รายการ			จำนวน	ร้อยละ
จำนวนผู้ตอบแบบสอบถาม			**10**	**100.0**
4.8 ข้อเสนอแนะอื่นๆ เกี่ยวกับโครงการฯ				
	1	ไม่มีข้อเสนอแนะ	10	100.0
	รวม		**10**	**100.0**

หมายเหตุ : 1/ ตารางวิเคราะห์ระดับของผลกระทบที่ได้รับจากค่าเฉลี่ยโดยใช้แนวคิดของ Likert (อ้างอิงจากบุญธรรม กิจปรีดาบริสุทธิ์, 2553) ดังนี้

ค่าคะแนน 1.00-1.50 หมายถึง ระดับน้อยที่สุด
ค่าคะแนน 1.51-2.50 หมายถึง ระดับน้อย
ค่าคะแนน 2.51-3.50 หมายถึง ระดับปานกลาง
ค่าคะแนน 3.51-4.50 หมายถึง ระดับมาก
ค่าคะแนน 4.51-5.00 หมายถึง ระดับมากที่สุด

2/ ค่าเฉลี่ย (Mean : เป็นค่าที่ได้จากการรวมกันของข้อมูลทุกตัวในชุดข้อมูลนั้นหารด้วยจำนวนข้อมูลทั้งหมด (วรรณี แกมเกตุ, 2551)

3/ ค่าส่วนเบี่ยงเบนมาตรฐาน (Standard deviation : S.D. หรือ S) ใช้สำหรับหาค่าความแตกต่างโดยเฉลี่ยของระดับผลกระทบจากค่ากึ่งกลางของข้อมูลหรือความแตกต่างของระดับผลกระทบโดยเฉลี่ย

ที่มา : บริษัท เอสจีเอส (ประเทศไทย) จำกัด, พ.ศ. 2568

ภาคผนวก ฉ

หนังสืออนุญาตขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน

ที่ อก ๐๓๑๐(๑)/ ๓๗ ๗ ๘

กรมโรงงานอุตสาหกรรม
ถนนพระรามที่ ๖ แขวงทุ่งพญาไท
เขตราชเทวี กรุงเทพฯ ๑๐๔๐๐

๑๐ มิถุนายน ๒๕๖๙

เรื่อง เปลี่ยนแปลงบุคลากรของห้องปฏิบัติการวิเคราะห์

เรียน กรรมการผู้จัดการ บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด

อ้างถึง คำขอขึ้นทะเบียน/ต่ออายุ/เปลี่ยนแปลงบุคลากร และขนิดสารมลพิษของห้องปฏิบัติการวิเคราะห์เอกชน ลงวันที่ ๒๙ พฤษภาคม ๒๕๖๙

ตามคำขอที่อ้างถึง บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด ห้องปฏิบัติการวิเคราะห์เอกชน เลขทะเบียน ว-๑๔๕ สถานที่ตั้งเลขที่ ๓ ซอยอุดมสุข ๔๑ ถนนสุขุมวิท แขวงบางจาก เขตพระโขนง กรุงเทพมหานคร ขอเปลี่ยนแปลงบุคลากร ความละเอียดแจ้งแล้ว นั้น

กรมโรงงานอุตสาหกรรมพิจารณาแล้ว มีความเห็นดังนี้

๑. ให้ยกเลิกเจ้าหน้าที่ห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๔ ราย

๑) นายณัฐพงศ์ เมืองชัย ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๔๕
๒) นายณัฏฐชัย พรหมอารักษ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๔๖
๓) นายคุณานนท์ ฤทธาคณานนท์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๒๓
๔) นางสาวบุณยาพร บุญถนอมศรี ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๖๓

๒. ให้เพิ่มเจ้าหน้าที่ห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๒๔ ราย

๑) นายเจษฎา มาศประสิทธิ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๑๐
๒) นางสาวนฤมล ยินดี ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๑๑
๓) นายสุรชัย บุพศิริ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๑๒
๔) นางสาวปิยพร วรดี ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๑๓
๕) นางสาวสิริกันยา สุรจิต ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๑๔
๖) นางสาววทันยา วิเชียรผลา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๑๕
๗) นายธนดล แก้วประสงค์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๑๖
๘) นายวิทิต สงแสง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๑๗
๙) นางสาวดวงกมล ครีดา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๑๘
๑๐) นายภูฤทธิ์ ลีล้าน ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๑๙
๑๑) นายคณิน หนองหว้า ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๒๐
๑๒) นายต้นน้ำ สังข์นคร ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๒๑
๑๓) นายวัชรพงษ์ วราศรี ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๒๒
๑๔) นายจักรพงษ์ สัตย์สาร ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๒๓
๑๕) นายปุระชัย โพธิ์ทอง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๒๔
๑๖) นายขนะพันธ์ อภินพหิรัณย์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๒๕

UAE UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

๑๗) นายกมลไท...

๑๗) นายกมลไท ชัยสิริสมบัติ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๒๖
๑๘) นายธเนศ ทรัพย์ธำรงค์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๒๗
๑๙) นางสาวภัทรสุตา สุธรรมมา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๒๘
๒๐) นางสาวสุนันทา สมรูป ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๒๙
๒๑) นางสาวมนรดา มั่นศาสตร์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๓๐
๒๒) นางสาวรัชนีภรณ์ สาระพันธ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๓๑
๒๓) นายรณวิชย์ บุญเอก ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๓๒
๒๔) นางสาวอาทิตยา เล็กน้อย ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๓๓

อนึ่ง หนังสือฉบับนี้จะสิ้นอายุพร้อมหนังสือต่ออายุรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ในวันที่ ๒ กุมภาพันธ์ ๒๕๗๒

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ

(นายศิระ จันทร์เฉิด)
นักวิทยาศาสตร์เชี่ยวชาญ รักษาราชการแทน
ผู้อำนวยการกองวิจัยและเตือนภัยมลพิษโรงงาน
ปฏิบัติราชการแทนอธิบดีกรมโรงงานอุตสาหกรรม

กองวิจัยและเตือนภัยมลพิษโรงงาน
กลุ่มมาตรฐานวิธีการวิเคราะห์ทดสอบมลพิษและทะเบียนห้องปฏิบัติการ
โทร. ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๐๓-๕
โทรสาร ๐ ๒๔๓๐ ๖๓๓๒ ต่อ ๒๑๙๙
ไปรษณีย์อิเล็กทรอนิกส์ saraban@diw.mail.go.th

UAE UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

ที่ อก ๐๓๑๐(๑)/ ๑๗๓๘

กรมโรงงานอุตสาหกรรม
ถนนพระรามที่ ๖ แขวงทุ่งพญาไท
เขตราชเทวี กรุงเทพฯ ๑๐๔๐๐

๐๕ มีนาคม ๒๕๖๙

เรื่อง เปลี่ยนแปลงบุคลากรของห้องปฏิบัติการวิเคราะห์

เรียน กรรมการผู้จัดการ บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด

อ้างถึง คำขอขึ้นทะเบียน/ต่ออายุ/เปลี่ยนแปลงบุคลากร และขนิดสารมลพิษของห้องปฏิบัติการวิเคราะห์เอกชน ลงวันที่ ๑๐ กุมภาพันธ์ ๒๕๖๙

ตามคำขอที่อ้างถึง บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด ห้องปฏิบัติการวิเคราะห์เอกชน เลขทะเบียน ว-๑๔๕ สถานที่ตั้งเลขที่ ๓ ซอยอุดมสุข ๔๑ ถนนสุขุมวิท แขวงบางจาก เขตพระโขนง กรุงเทพมหานคร ขอเปลี่ยนแปลงบุคลากร ความละเอียดแจ้งแล้ว นั้น

กรมโรงงานอุตสาหกรรมพิจารณาแล้ว มีความเห็นดังนี้

๑. ให้ยกเลิกเจ้าหน้าที่ห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๔ ราย

๑) นายพีรณัฐ เจริญผล	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๐๓
๒) นายเจษฎา ช่วยตรึก	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๒๗
๓) นายศุภกร สวนศรี	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๓๔
๔) นางสาวณัฐกฤตา พลนิกรกิจ	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๔๐

๒. ให้เพิ่มเจ้าหน้าที่ห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๙ ราย

๑) นายเกียรติศักดิ์ ทำทอง	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๐๑
๒) นางสาวธนภร แฉะกระโทก	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๐๒
๓) นางสาวรชยา ปรีดี	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๐๓
๔) นางสาวญาณินตา แข่มเล็ก	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๐๔
๕) นางสาวมนัสพร การงานดี	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๐๕
๖) นายธนากร เชื้อมาก	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๐๖
๗) นางสาวพัชรินทร์ แพรกทอง	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๐๗
๘) นางสาวนรินทร รินทราช	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๐๘
๙) นางสาวชญานี เมินกระโทก	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๐๙

อนึ่ง หนังสือฉบับนี้จะสิ้นอายุพร้อมหนังสือต่ออายุรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ในวันที่ ๒ กุมภาพันธ์ ๒๕๗๒

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ

(นางสาวปัทมวรรณ คุณประเสริฐ)
ผู้อำนวยการกองวิจัยและเตือนภัยมลพิษโรงงาน
ปฏิบัติราชการแทนอธิบดีกรมโรงงานอุตสาหกรรม

UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED

สำเนาถูกต้อง

กองวิจัยและเตือนภัยมลพิษโรงงาน
กลุ่มมาตรฐานวิธีการวิเคราะห์ทดสอบมลพิษและทะเบียนห้องปฏิบัติการ
โทร. ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๐๓-๕
โทรสาร ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๐๙
ไปรษณีย์อิเล็กทรอนิกส์ saraban@diw.mail.go.th

ที่ อก ๐๓๑๐(๑)/ ๘๓๐๒

กรมโรงงานอุตสาหกรรม
ถนนพระรามที่ ๖ แขวงทุ่งพญาไท
เขตราชเทวี กรุงเทพฯ ๑๐๔๐๐

๐๘ ตุลาคม ๒๕๖๘

เรื่อง ยกเลิกบุคลากรของห้องปฏิบัติการวิเคราะห์

เรียน กรรมการผู้จัดการ บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด

อ้างถึง คำขอขึ้นทะเบียน/ต่ออายุ/เปลี่ยนแปลงบุคลากร และขนิดสารมลพิษของห้องปฏิบัติการวิเคราะห์เอกชน ลงวันที่ ๒๕ กันยายน ๒๕๖๘

ตามคำขอที่อ้างถึง บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด ห้องปฏิบัติการวิเคราะห์เอกชน เลขทะเบียน ว-๑๔๕ สถานที่ตั้งเลขที่ ๓ ซอยอุดมสุข ๔๑ ถนนสุขุมวิท แขวงบางจาก เขตพระโขนง กรุงเทพมหานคร ขอยกเลิกบุคลากร ความละเอียดแจ้งแล้ว นั้น

กรมโรงงานอุตสาหกรรมพิจารณาแล้ว ให้ยกเลิกเจ้าหน้าที่ห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๓ ราย ได้แก่

๑) นางสาวอารียา ทรารมย์	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๖๗
๒) นางสาวศรีเพชร ทองขาว	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๑๗
๓) นางสาวปวีณา แดนชนบ	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๖๙

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ

(นางสาวปัทมวรรณ คุณประเสริฐ)
ผู้อำนวยการกองวิจัยและเตือนภัยมลพิษโรงงาน
ปฏิบัติราชการแทนอธิบดีกรมโรงงานอุตสาหกรรม

UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED

สำเนาถูกต้อง

กองวิจัยและเตือนภัยมลพิษโรงงาน
กลุ่มมาตรฐานวิธีการวิเคราะห์ทดสอบมลพิษและทะเบียนห้องปฏิบัติการ
โทร. ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๐๓-๕
โทรสาร ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๐๙
ไปรษณีย์อิเล็กทรอนิกส์ saraban@diw.mail.go.th

ที่ อก ๐๓๑๐(๑)/ ๖๙๗๓

กรมโรงงานอุตสาหกรรม
ถนนพระรามที่ ๖ แขวงทุ่งพญาไท
เขตราชเทวี กรุงเทพฯ ๑๐๔๐๐

๒๕ สิงหาคม ๒๕๖๘

เรื่อง ยกเลิกบุคลากรของห้องปฏิบัติการวิเคราะห์

เรียน กรรมการผู้จัดการ บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด

อ้างถึง คำขอขึ้นทะเบียน/ต่ออายุ/เปลี่ยนแปลงบุคลากร และชนิดสารมลพิษของห้องปฏิบัติการวิเคราะห์เอกชน ลงวันที่ ๗ สิงหาคม ๒๕๖๘

ตามคำขอที่อ้างถึง บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด ห้องปฏิบัติการวิเคราะห์เอกชน เลขทะเบียน ว-๑๔๕ สถานที่ตั้งเลขที่ ๓ ซอยอุดมสุข ๔๑ ถนนสุขุมวิท แขวงบางจาก เขตพระโขนง กรุงเทพมหานคร ขอยกเลิกบุคลากร ความละเอียดแจ้งแล้ว นั้น

กรมโรงงานอุตสาหกรรมพิจารณาแล้ว ให้ยกเลิกเจ้าหน้าที่ห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๕ ราย ได้แก่

๑) นายคณิติน พงษ์อิศรานุพร	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๐๔
๒) นายธีรวัฒน์ ธรรมสุวรรณ	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๓๘
๓) นายอาทิตย์ ดาภา	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๖๒
๔) นางสาวกมลชนก ปุนคำ	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๗๒
๕) นายวีระพงษ์ แสงท่านั่ง	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๘๘

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ

(นายศิระ จันทร์เฉิด)
นักวิทยาศาสตร์เชี่ยวชาญ รักษาราชการแทน
ผู้อำนวยการกองวิจัยและเตือนภัยมลพิษโรงงาน
ปฏิบัติราชการแทนอธิบดีกรมโรงงานอุตสาหกรรม

กองวิจัยและเตือนภัยมลพิษโรงงาน
กลุ่มมาตรฐานวิธีการวิเคราะห์ทดสอบมลพิษและทะเบียนห้องปฏิบัติการ
โทร. ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๐๓-๕
โทรสาร ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๙๙
ไปรษณีย์อิเล็กทรอนิกส์ saraban@diw.mail.go.th

UAE UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED

สำเนาถูกต้อง

ที่ อก ๐๓๑๐(๑)/ ๕๖๙๑

กรมโรงงานอุตสาหกรรม
ถนนพระรามที่ ๖ แขวงทุ่งพญาไท
เขตราชเทวี กรุงเทพฯ ๑๐๔๐๐

๐๗ กรกฎาคม ๒๕๖๘

เรื่อง เปลี่ยนแปลงบุคลากรและสารมลพิษที่วิเคราะห์

เรียน กรรมการผู้จัดการ บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด

อ้างถึง คำขอขึ้นทะเบียน/ต่ออายุ/เปลี่ยนแปลงบุคลากร และชนิดสารมลพิษของห้องปฏิบัติการวิเคราะห์เอกชน ลงวันที่ ๙ พฤษภาคม ๒๕๖๘

สิ่งที่ส่งมาด้วย เอกสารแนบท้ายหนังสือเปลี่ยนแปลงบุคลากรและสารมลพิษที่วิเคราะห์ บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด จำนวน ๒ แผ่น

ตามหนังสือที่อ้างถึง บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด ห้องปฏิบัติการวิเคราะห์เอกชน เลขทะเบียน ว-๑๔๕ สถานที่ตั้งเลขที่ ๓ ซอยอุดมสุข ๔๑ ถนนสุขุมวิท แขวงบางจาก เขตพระโขนง กรุงเทพมหานคร ขอเปลี่ยนแปลงบุคลากรและสารมลพิษที่วิเคราะห์ ความละเอียดแจ้งแล้ว นั้น

กรมโรงงานอุตสาหกรรมพิจารณาแล้ว มีความเห็นดังนี้

๑. ให้ยกเลิกเจ้าหน้าที่ห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๓ ราย

๑) นายสุขสันต์ พันสิงห์	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๐๑
๒) นางสาวสุภัสสรา เฉี้ยนเงิน	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๔๙
๓) นางสาวชามันดา กิมาคม	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๘๖

๒. ให้เพิ่มผู้ควบคุมห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๑ ราย

นายสุขสันต์ พันสิงห์ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๔๗

๓. ให้เพิ่มขอบข่ายสารมลพิษที่วิเคราะห์ในน้ำใต้ดิน อากาศเสีย และดิน ตามสิ่งที่ส่งมาด้วย

อนึ่ง หนังสือฉบับนี้จะหมดอายุพร้อมหนังสือรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ในวันที่ ๒ กุมภาพันธ์ ๒๕๗๒

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ

(นายประสม ตำรงพงษ์)
ผู้อำนวยการกองวิจัยและเตือนภัยมลพิษโรงงาน
ปฏิบัติราชการแทนอธิบดีกรมโรงงานอุตสาหกรรม

กองวิจัยและเตือนภัยมลพิษโรงงาน
กลุ่มมาตรฐานวิธีการวิเคราะห์ทดสอบมลพิษและทะเบียนห้องปฏิบัติการ
โทร. ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๐๓-๕
โทรสาร ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๙๙
ไปรษณีย์อิเล็กทรอนิกส์ saraban@diw.mail.go.th

UAE UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED

สำเนาถูกต้อง

Green Industry
"อุตสาหกรรมก้าวไกล ประเทศไทยก้าวหน้า ร่วมกันพัฒนา อุตสาหกรรมสีเขียว"

เอกสารแนบท้ายหนังสือเปลี่ยนแปลงบุคลากรและสารมลพิษที่วิเคราะห์
บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด เลขทะเบียน ว-๑๔๕
ที่ อก ๐๓๑๐(๑)/ ๕๖๙๑ ลงวันที่ ๐๗ กรกฎาคม ๒๕๖๘

ขอบข่ายสารมลพิษที่ได้รับขึ้นทะเบียนจากกรมโรงงานอุตสาหกรรม จำนวน ๑๑ รายการ

น้ำใต้ดิน จำนวน 4 รายการ

ลำดับที่	สารมลพิษ	วิธีวิเคราะห์
1	Aluminum	Digestion, Inductively Coupled Plasma Method[1]
2	Copper	1) Digestion, Flame Atomic Absorption Spectrometric Method[1] 2) Digestion, Inductively Coupled Plasma Method[1]
3	Iron	1) Digestion, Flame Atomic Absorption Spectrometric Method[1] 2) Digestion, Inductively Coupled Plasma Method[1]
4	Molybdenum	Digestion, Inductively Coupled Plasma Method[1]

อากาศเสีย (ปล่องระบาย) จำนวน 1 รายการ

ลำดับที่	สารมลพิษ	วิธีวิเคราะห์
1	Oxides of Nitrogen	Absorption Sampling, Ion Chromatographic Method[2]

ดิน จำนวน 6 รายการ

ลำดับที่	สารมลพิษ	วิธีวิเคราะห์
1	Aluminum	Digestion, Inductively Coupled Plasma Method[3,5]
2	Copper	1) Digestion, Flame Atomic Absorption Spectrometric Method[3,6] 2) Digestion, Inductively Coupled Plasma Method[3,5]
3	Iron	1) Digestion, Flame Atomic Absorption Spectrometric Method[3,6] 2) Digestion, Inductively Coupled Plasma Method[3,5]
4	Molybdenum	Digestion, Inductively Coupled Plasma Method[3,6]
5	pH	Electrometric Method[8]
6	TPH (C_5-C_8)	Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method[4,7]

UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

เอกสารอ้างอิง

1. APHA, AWWA, WEF. **Standard Methods for the Examination of Water and Wastewater.** 24th ed. Washington, DC: APHA, 2023.

2. United States Environmental Protection Agency. **Standards of Performance for New Stationary Sources.** 40 CFR 60. Appendix A, 2023.

3. United States...

3. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Acid Digestion of Sediments, Sludges, and Soils. SW-846 Method 3050B,** 1996.

4. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Volatile Organic Compounds in Various Sample Matrices Using Equilibrium Headspace Analysis. SW-846 Method 5021A,** 2014.

5. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Inductively Coupled Plasma-Optical Emission Spectrometry. SW-846 Method 6010D,** 2018.

6. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Flame Atomic Absorption Spectrophotometry. SW-846 Method 7000B,** 2007.

7. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Volatile Organic Compounds by Gas Chromatography/ Mass Spectrometry. SW-846 Method 8260D,** 2018.

8. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Soil and Waste pH. SW-846 Method 9045D,** 2004.

UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

ที่ อก ๐๓๑๐(๓)/ ๑๔๙๑

กรมโรงงานอุตสาหกรรม
ถนนพระรามที่ ๖ แขวงทุ่งพญาไท
เขตราชเทวี กรุงเทพฯ ๑๐๔๐๐

๒๔ กุมภาพันธ์ ๒๕๖๘

เรื่อง ยกเลิกบุคลากรของห้องปฏิบัติการวิเคราะห์

เรียน กรรมการผู้จัดการ บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด

อ้างถึง คำขอขึ้นทะเบียน/ต่ออายุ/เปลี่ยนแปลงบุคลากร และชนิดสารมลพิษของห้องปฏิบัติการวิเคราะห์เอกชน ลงวันที่ ๑๘ กุมภาพันธ์ ๒๕๖๘

ตามคำขอที่อ้างถึง บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด ห้องปฏิบัติการวิเคราะห์เอกชน เลขทะเบียน ว-๑๔๕ สถานที่ตั้งเลขที่ ๓ ซอยอุดมสุข ๔๑ ถนนสุขุมวิท แขวงบางจาก เขตพระโขนง กรุงเทพมหานคร ขอยกเลิกบุคลากร ความละเอียดแจ้งแล้ว นั้น

กรมโรงงานอุตสาหกรรมพิจารณาแล้ว ให้ยกเลิกเจ้าหน้าที่ห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๓ ราย ได้แก่

๑) นายอภิสิทธิ์ ศรีคงแก้ว	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๕๘
๒) นางสาวนันธิดา พรมกวยถ้ำ	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๗๐
๓) นายภูวดล เป็งมา	ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๙๘

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ

(นายธีรทัศน์ อิศรางกูร ณ อยุธยา)
รองอธิบดี ปฏิบัติราชการแทน
อธิบดีกรมโรงงานอุตสาหกรรม

กองวิจัยและเตือนภัยมลพิษโรงงาน
กลุ่มมาตรฐานวิธีการวิเคราะห์ทดสอบมลพิษและทะเบียนห้องปฏิบัติการ
โทร. ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๐๓-๕
โทรสาร ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๙๙
ไปรษณีย์อิเล็กทรอนิกส์ saraban@diw.mail.go.th

UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED

สำเนาถูกต้อง

ที่ อก ๐๓๑๐(๓)/ ๑๐๘๙

กรมโรงงานอุตสาหกรรม
ถนนพระรามที่ ๖ แขวงทุ่งพญาไท
เขตราชเทวี กรุงเทพฯ ๑๐๔๐๐

๐๗ กุมภาพันธ์ ๒๕๖๘

เรื่อง ต่ออายุหนังสือรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน

เรียน กรรมการผู้จัดการ บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด

อ้างถึง คำขอขึ้นทะเบียน/ต่ออายุ/เปลี่ยนแปลงบุคลากร และชนิดสารมลพิษของห้องปฏิบัติการวิเคราะห์เอกชน ลงวันที่ ๓ ธันวาคม ๒๕๖๗

สิ่งที่ส่งมาด้วย ๑. รายชื่อผู้ควบคุมห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๔๐ ราย
๒. รายชื่อเจ้าหน้าที่ห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๑๔๑ ราย
๓. ขอบข่ายสารมลพิษที่ได้รับขึ้นทะเบียนจากกรมโรงงานอุตสาหกรรม

ตามคำขอที่อ้างถึง บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด ขอต่ออายุหนังสือรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน เลขทะเบียน ว-๑๔๕ สถานที่ตั้งเลขที่ ๓ ซอยอุดมสุข ๔๑ ถนนสุขุมวิท แขวงบางจาก เขตพระโขนง กรุงเทพมหานคร ต่อกรมโรงงานอุตสาหกรรม นั้น

กรมโรงงานอุตสาหกรรมพิจารณาแล้ว ให้บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด ต่ออายุหนังสือรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน โดยมีองค์ประกอบดังนี้

ก. ผู้ควบคุมห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๔๐ ราย ตามสิ่งที่ส่งมาด้วย ๑
ข. เจ้าหน้าที่ห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๑๔๑ ราย ตามสิ่งที่ส่งมาด้วย ๒
ค. ขอบข่ายสารมลพิษที่ได้รับขึ้นทะเบียนให้วิเคราะห์ในน้ำ/น้ำเสีย น้ำใต้ดิน อากาศเสีย สิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้ว และดิน ตามสิ่งที่ส่งมาด้วย ๓

หนังสือฉบับนี้จะหมดอายุในวันที่ ๒ กุมภาพันธ์ ๒๕๗๒ หากประสงค์จะต่ออายุหนังสือรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ให้ยื่นคำขอต่ออายุพร้อมเอกสารประกอบคำขอต่อกรมโรงงานอุตสาหกรรมภายใน ๖๐ วัน ก่อนวันสิ้นอายุของหนังสือรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ

(นายธีรทัศน์ อิศรางกูร ณ อยุธยา)
รองอธิบดี ปฏิบัติราชการแทน
อธิบดีกรมโรงงานอุตสาหกรรม

กองวิจัยและเตือนภัยมลพิษโรงงาน
กลุ่มมาตรฐานวิธีการวิเคราะห์ทดสอบมลพิษและทะเบียนห้องปฏิบัติการ
โทร. ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๐๓-๕
โทรสาร ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๙๙
ไปรษณีย์อิเล็กทรอนิกส์ saraban@diw.mail.go.th

UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED

สำเนาถูกต้อง

Green Industry
"อุตสาหกรรมก้าวไกล ประเทศไทยก้าวหน้า ร่วมกันพัฒนา อุตสาหกรรมสีเขียว"

เอกสารแนบท้ายหนังสือต่ออายุรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน
บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด เลขทะเบียน ว-๑๔๕
ที่ อก ๐๓๑๐(๑)/ ๑ ๐ ๘ ๙ ลงวันที่ ๐๗ กุมภาพันธ์ ๒๕๖๘

ก. ผู้ควบคุมห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๔๐ ราย

๑) นางสาวกฤชวรรณ ภัทรธีรกุล ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๐๑
๒) นายนรงค์ ฉิมพาลี ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๐๒
๓) นางสาวนันทิตา บุญไสย ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๐๓
๔) นางปิยะพัชร์ สุทธมนัสวงษ์ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๐๔
๕) นางสาวเบญจวรรณ วิริโยทัย ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๐๖
๖) นายบพรัตน์ วงค์อนุรักษ์ชัย ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๐๗
๗) นางสาวฉวีวรรณ บุญลา ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๐๘
๘) นายสุวิทย์ จอดนอก ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๐๙
๙) นางสาวโชติภา สมบรรณ์ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๑๐
๑๐) นางสาวบุษกร เลิศภาณุมาศ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๑๑
๑๑) นางสาววิไลลักษณ์ ศรีสุข ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๑๒
๑๒) นายศิลา บรรจงใจรักษ์ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๑๔
๑๓) นายปฏิกรณ์ คณะนา ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๑๕
๑๔) นายธีรวัฒน์ ขมมิ่ง ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๑๖
๑๕) นางสาวศิริพร ศรีประดิษฐ์ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๑๗
๑๖) นางสาวสาวิตรี ริรัง ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๑๘
๑๗) นางสาวนพวรรณ อุรารักษ์ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๑๙
๑๘) นายภูชงค์ พานิชย์เลิศอำไพ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๒๐
๑๙) นายณัฐวัฒน์ แดงสวัสดิ์ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๒๑
๒๐) นายเอกรัตน์ ปถะคามินทร์ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๒๒
๒๑) นางสาวนิศารัตน์ ศรีสกุลสิทธิโชค ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๒๓
๒๒) นางสาวเจตจรินทร์ ทำสะอาด ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๒๔
๒๓) นางสาวสุวรรณ คงทอง ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๒๕
๒๔) นางสาววรกร พัดสองชั้น ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๒๖
๒๕) นายวีรยุทธ โมกแก้ว ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๒๗
๒๖) นายวัชรพงษ์ เทพดนตรี ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๒๘
๒๗) นายอนุศาสน์ สวยดี ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๒๙
๒๘) นายกรวิทย์ เจี่ยศิริสกุล ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๓๐
๒๙) นายสุทธีระ อรุณจันทร์ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๓๓
๓๐) นางสาวทัศนีย์ อ่อนคำ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๓๔
๓๑) นางพริ้มพรรณ กอนสิน ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๓๕
๓๒) นายศุภณัฐฐ์ คุณธนกาญจน์ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๓๖
๓๓) นางสาวศิริภาพร เหมือนเร่ ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๓๗
๓๔) นางศิวานัส ขำนิล ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๓๘
๓๕) นางสาวพรรนิภา ธีระจินดาชล ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๓๙

UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

๓๖) นายนาเคนทร์...

๓๖) นายนาเคนทร์ พันธุ์วิชาติกุล ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๔๐
๓๗) นายกานต์พงศ์ บุญพวง ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๔๑
๓๘) นางสุธรรมา แก้วข้อนอก ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๔๒
๓๙) นางสาวรสริน ไชยเชษฐ์พิพัฒกุล ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๔๓
๔๐) นางมานิดา แย้มไย ทะเบียนเลขที่ ว-๑๔๕-ค-๐๐๔๔

UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

เอกสารแนบท้ายหนังสือต่ออายุรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน
บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด เลขทะเบียน ว-๑๔๕
ที่ อก ๐๓๑๐(๑)/ ๑๐๘๙ ลงวันที่ ๐๗ กุมภาพันธ์ ๒๕๖๘

ข. เจ้าหน้าที่ห้องปฏิบัติการวิเคราะห์เอกชน จำนวน ๑๔๑ ราย

๑) นายสุขสันต์ พันสิงห์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๐๑
๒) นายพีรณัฐ เจริญผล ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๐๓
๓) นางสาววิไลลักษณ์ เกไรสง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๐๔
๔) นายสมชาติ อุทุมรัตน์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๐๕
๕) นางสาวปรมาภรณ์ ทองแก้ว ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๐๖
๖) นางสาวกัลยา สมพงษ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๐๗
๗) นางสาววรรณี สายบุญเรือน ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๑๐
๘) นายกฤษณพงษ์ นามทิพย์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๑๑
๙) นางสาวอาภรณ์ อ่อนคง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๑๒
๑๐) นายกิตติศักดิ์ ทรงจำรัส ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๑๓
๑๑) นางสาวอักษรินทร์ บุญคง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๑๔
๑๒) นางสาวพรพิมล แว่นทอง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๑๕
๑๓) นายอภิวิชญ์ ท่วงที ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๑๗
๑๔) นายมานิตย์ ปานโชติ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๑๘
๑๕) นายทศพร ธนะพิรุหห์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๑๙
๑๖) นางสาวกัลยาณี โยธา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๒๐
๑๗) นางสาวเกวลี สุขรี ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๒๑
๑๘) นางสาวชมธนัญ อภิพัทธ์ปภา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๒๒
๑๙) นายศิรพัชร จงผดุงเกียรติ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๒๓
๒๐) นางสาวสุภาวดี อินยาศรี ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๒๔
๒๑) นายพงศ์เทพ เหล่าขจร ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๒๕
๒๒) นายขวัญชัย พันทุกข์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๒๖
๒๓) นางสาวพัชจิรา คดีพิศาล ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๒๗
๒๔) นางสาวเนวิกา เสือคำจันทร์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๒๘
๒๕) นายพีระพัฒน์ บัญญัติศิลป์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๓๒
๒๖) นายชัชวาลย์ เลื่อนล่อง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๓๔
๒๗) นายนภสินธุ์ ธนูธรรมรัตน์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๓๖
๒๘) นายกันนิกร ระโส ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๓๗
๒๙) นายปริญญา กลมเกลียว ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๓๙
๓๐) นายธีรวัจน์ มาตรโพธิ์ศรี ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๔๐
๓๑) นายบุญญฤทธิ์ ก้อนสิน ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๔๑
๓๒) นายพรรษวุฒิ โถวสกุล ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๔๓
๓๓) นายอชิตะ แสงจันทร์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๔๔
๓๔) ว่าที่ร้อยตรีณัฐพงศ์ เมืองชัย ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๔๕
๓๕) นายธนัท เลิศประเสริฐ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๔๖

UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

๓๖) นางสาวนิภาพร จันทเขตต์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๔๗
๓๗) นายรณภพ ภู่ตระกูลพัฒนา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๔๙
๓๘) นายสมพงศ์ สกุลไทย ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๕๑
๓๙) นายสุริยัน นิธิเชิดชูวงศ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๕๒
๔๐) นายอัษฎาวุธ ยนศิริ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๕๓
๔๑) นายเอกวุฒิ เสนอใจ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๕๔
๔๒) นายสุขสันต์ บุญเลี้ยง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๕๕
๔๓) นายธนเดช หวานเสนาะ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๕๖
๔๔) นายอภิสิทธิ์ ศรีคงแก้ว ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๕๘
๔๕) ว่าที่ร้อยตรีอุทัย แก้วรากมุข ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๖๐
๔๖) นางสาววนารินทร์ สานนท์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๖๑
๔๗) นายศุภกร รินวงศ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๖๒
๔๘) นางสาวจินตสุภา เปลี่ยนศรี ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๖๕
๔๙) นางสาวเนตรนภา กมลบูรณ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๖๖
๕๐) นางสาวอารียา ทรารมย์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๖๗
๕๑) นายจิรวัฒน์ สุขเกษม ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๖๘
๕๒) นายกิติพงษ์ สอนชัยภูมิ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๖๙
๕๓) นายจุมพล สวนเพชร ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๗๐
๕๔) นางสาวพัชราภรณ์ แสงฟ้า ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๗๑
๕๕) นายรัตนชัย เหล่ามา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๗๒
๕๖) นายอิทธิพงษ์ ศรวิเศษ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๗๓
๕๗) นางสาวกรรณิการ์ สำลีทา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๗๔
๕๘) นางสาวณัฐชา พรหมศิริ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๗๙
๕๙) นายนภสิทธิ์ ศรีพิมพ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๘๕
๖๐) นางสาวลักษิกา จันทรสุข ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๘๖
๖๑) นายศักดิ์ศิธนต์ นุ่มนิ่ม ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๘๙
๖๒) นายวรพงษ์ นนทจันทร์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๙๐
๖๓) นางสาวชนาภา มาคะมาตร ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๙๑
๖๔) นายณัฏฐชัย พรหมอารักษ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๙๖
๖๕) นายชนินทร์ พานแก้ว ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๙๗
๖๖) นายปรัชชาพล โสภา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๙๘
๖๗) นายวัชรินทร์ แสนงาม ทะเบียนเลขที่ ว-๑๔๕-จ-๐๐๙๙
๖๘) นายอาทิตย์ อุดมผล ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๐๑
๖๙) นายอิทธิเดช ใจบุญ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๐๒
๗๐) นายคณิติน พงษ์อิศรานุพร ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๐๔
๗๑) นายเสฏฐวุฒิ เอมกลิ่นบัว ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๐๖
๗๒) นางสาวนาตาชา แหวนในเมือง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๐๙
๗๓) นางสาวพิมลวรรณ สิมมา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๑๐

UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

๗๔) นายนันทวัฒน์ วงศ์คำ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๑๑
๗๕) นายประพันธ์ยุทธ์ เผือกนาง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๑๒
๗๖) นางสาวศมิษฐา ล่าชิต ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๑๓
๗๗) นางสาวนภาพร ชื้นนกขุ้ม ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๑๔
๗๘) นางสาวเบญญา มอมุงคุณ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๑๕
๗๙) นายอมรพล อมรลักษณ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๑๖
๘๐) นางสาวศรีเพชร ทองขาว ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๑๗
๘๑) นางสาวณิชากร ศุภชาติไกรสร ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๑๘
๘๒) นางสาววิมลวรรณ คำตัน ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๑๙
๘๓) นายคุณานนท์ ฤทธาคุณานนท์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๒๓
๘๔) นายชาญณรงค์ อำลอย ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๒๔
๘๕) นางสาวจิตรมาส ศรีวรรณ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๒๕
๘๖) นายสุจิต โปขันเงิน ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๒๖
๘๗) นายเจษฎา ช่วยตรึก ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๒๗
๘๘) นายรชต เหมะธุลิน ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๒๘
๘๙) นายสุรโชค หล่าโท ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๓๐
๙๐) นายชัย บัวสด ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๓๑
๙๑) นางสาวอรญา ประสานศรี ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๓๒
๙๒) นายนพดล เนียมนิยม ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๓๓
๙๓) นายศุภกร สวนศรี ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๓๔
๙๔) นายคณพล คิลานนท์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๓๕
๙๕) นายโชคชัย พุ่มไสว ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๓๖
๙๖) นายธีรวัฒน์ ธรรมสุวรรณ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๓๘
๙๗) นายนัทธพงศ์ ชะขุนทด ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๓๙
๙๘) นางสาวณัฐกฤตา พลนิกรกิจ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๔๐
๙๙) นางสาวชไมพร ทองบูรณ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๔๑
๑๐๐) นางสาวพรชิตา ขจรเนติยุทธ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๔๒
๑๐๑) นางสาวเพ็ญพิชชา รอดทอง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๔๕
๑๐๒) นางสาวณัชชา แสงสว่าง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๔๖
๑๐๓) นายกีรติ สีอาจ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๔๗
๑๐๔) นายตนุพร คงศรี ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๔๘
๑๐๕) นางสาวสุภัสสรา เฉื่อนเงิน ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๔๙
๑๐๖) นางสาวพรรณทิพา อะโนนาม ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๕๐
๑๐๗) นายอนันต์ มูดอ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๕๑
๑๐๘) นางสาวพรพิมล ประชาพันธุ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๕๒
๑๐๙) นายวีรภัทร บุญญาธิ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๕๓
๑๑๐) นางสาวณัฐชา แถวภาพ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๕๔
๑๑๑) นายสิทธิพล พร้อมพอชื่นบุญ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๕๖
๑๑๒) นางสาวนนท์ทิชา กลิ่นหนู ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๕๘

ตามสำเนาถูกต้อง

๑๑๓) นางสาวปิติยา ชูเชิดเชื้อ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๖๐
๑๑๔) นางสาวลัดดาวัลย์ โพธิ์พันธ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๖๑
๑๑๕) นายอาทิตย์ ดาภา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๖๒
๑๑๖) นางสาวบุณยาพร บุญถนอมศรี ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๖๓
๑๑๗) นางสาวพัชราวรรณ จันธิบุตร ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๖๔
๑๑๘) นางสาวนฤภร ไถ้บ้านกวย ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๖๕
๑๑๙) นางสาวปวีณา แดนชนบ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๖๙
๑๒๐) นางสาวนันธิดา พรมกวยถ้ำ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๗๐
๑๒๑) นางสาวกมลชนก ปุ่นคำ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๗๒
๑๒๒) นางสาวปาริฉัตร ทองใบ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๗๔
๑๒๓) นายชัยวัฒน์ จันละคร ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๗๖
๑๒๔) นางสาวกัลยา สิงห์แก้ว ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๗๘
๑๒๕) นางสาวอารีนา มะดีเย๊าะ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๘๔
๑๒๖) นายฐาปกรณ์ อนุรา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๘๕
๑๒๗) นางสาวชามันดา กิมาคม ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๘๖
๑๒๘) นายธนบดินทร์ ยาเหลี่ยม ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๘๗
๑๒๙) นายวีระพงษ์ แสงท่านั่ง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๘๘
๑๓๐) นางสาวปิยะณัฐชยา สำเภาพงษ์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๘๙
๑๓๑) นางสาวนภัสสร ศรีสถาน ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๙๐
๑๓๒) นางสาวจุรีย์รัตน์ โสแทน ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๙๑
๑๓๓) นายธีรวัฒน์ พรหมลา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๙๒
๑๓๔) นายธนวิชช์ ปลั่งกลาง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๙๓
๑๓๕) นายณภัทร เตมียบุตร ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๙๔
๑๓๖) นางสาวจิตาภา ฤาชา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๙๕
๑๓๗) นางสาวสุมณฑาทิพย์ สังข์ทอง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๙๖
๑๓๘) นางสาวชาริสา บาบุญ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๙๗
๑๓๙) นายภูวดล เป็งมา ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๙๘
๑๔๐) ว่าที่ร้อยตรีรณยุทธ ประทุมเขตต์ ทะเบียนเลขที่ ว-๑๔๕-จ-๐๑๙๙
๑๔๑) นายธนุศร พลสำโรง ทะเบียนเลขที่ ว-๑๔๕-จ-๐๒๐๐

ตามสำเนาถูกต้อง

เอกสารแนบท้ายหนังสือต่ออายุรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน
บริษัท ยูไนเต็ด แอนนาลิสต์ แอนด์ เอ็นจิเนียริ่ง คอนซัลแตนท์ จำกัด เลขทะเบียน ว-๑๔๕
ที่ อก ๐๓๑๐(๑)/ ๑ ๐ ๘ ๙ ลงวันที่ ๐๗ กุมภาพันธ์ ๒๕๖๘

ขอบข่ายสารมลพิษที่ได้รับขึ้นทะเบียนจากกรมโรงงานอุตสาหกรรม จำนวน ๓๕๗ รายการ

น้ำ/น้ำเสีย จำนวน 46 รายการ

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
1	Aldrin	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
2	Arsenic	1) Digestion, Hydride Generation/Atomic Absorption Spectrometric Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]
3	Barium	Digestion, Inductively Coupled Plasma Method[4]
4	α-BHC	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
5	β-BHC	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
6	δ-BHC	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
7	γ-BHC	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
8	Biochemical Oxygen Demand	1) 5-Day BOD Test, Azide Modification Method[4] 2) 5-Day BOD Test, Membrane Electrode Method[4]
9	Cadmium	1) Digestion, Direct Air-Acetylene Flame Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]
10	Chemical Oxygen Demand	1) Closed Reflux, Titrimetric Method[4] 2) Closed Reflux, Colorimetric Method[4] 3) Open Reflux, Titrimetric Method[4]
11	Chlordane	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
12	Chromium	1) Digestion, Direct Air-Acetylene Flame Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]
13	Color	ADMI Weighted-Ordinate Spectrophotometric Method[4]
14	Copper	1) Digestion, Direct Air-Acetylene Flame Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]
15	Cyanide	1) Distillation, Colorimetric Method[4] 2) Total Cyanide after Distillation, by Flow Injection Analysis Method[4]
16	o,p'-DDT	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
17	4,4'-DDD	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
18	4,4'-DDE	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
19	4,4'-DDT	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
20	Dieldrin	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
21	Endosulfan I	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
22	Endosulfan II	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
23	Endosulfan sulfate	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
24	Endrin	Liquid-Liquid Extraction, Gas Chromatographic Method[4]

25 Endrin aldehyde...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
25	Endrin aldehyde	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
26	Formaldehyde	Distillation, Colorimetric Method[2]
27	Free Chlorine	1) Iodometric Method[4] 2) DPD Ferrous Titrimetric Method[4]
28	Heptachlor	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
29	Heptachlor Epoxide	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
30	Hexavalent Chromium	Colorimetric Method[4]
31	Lead	1) Digestion, Direct Air-Acetylene Flame Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]
32	Manganese	1) Digestion, Direct Air-Acetylene Flame Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]
33	Mercury	Digestion, Cold-Vapor Atomic Absorption Spectrometric Method[4]
34	Methoxychlor	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
35	Nickel	1) Digestion, Direct Air-Acetylene Flame Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]
36	Oil & Grease	1) Liquid-Liquid, Partition-Gravimetric Method[4] 2) Soxhlet Extraction Method[4]
37	pH	Electrometric Method[4]
38	Phenols	1) Distillation, Chloroform Extraction Method[4] 2) Distillation, Direct Photometric Method[4]
39	Selenium	1) Digestion, Hydride Generation/Atomic Absorption Spectrometric Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]
40	Sulfide	1) Iodometric Method[4] 2) Methylene Blue Method[4]
41	Temperature	Laboratory and Field Methods[4]
42	Total Dissolved Solids	Dried at 180 °C[4]
43	Total Kjeldahl Nitrogen	Semi-Micro-Kjeldahl Method[4]
44	Total Suspended Solids	Dried from 103 to 105 °C[4]
45	Trivalent Chromium	1) Digestion, Direct Air-Acetylene Flame Method; Colorimetric Method; Calculation[4] 2) Digestion, Inductively Coupled Plasma Method; Colorimetric Method; Calculation[4]
46	Zinc	1) Digestion, Direct Air-Acetylene Flame Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]

น้ำใต้ดิน...

น้ำใต้ดิน จำนวน 126 รายการ

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
1	Acenaphthene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
2	Acetone	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
3	Aldrin	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
4	Anthracene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
5	Antimony	Digestion, Inductively Coupled Plasma Method[4]
6	Arsenic	1) Digestion, Hydride Generation/Atomic Absorption Spectrometric Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]
7	Atrazine	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
8	Barium	Digestion, Inductively Coupled Plasma Method[4]
9	Benz(a)anthracene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
10	Benzene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
11	Benzo(b)fluoranthene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
12	Benzo(k)fluoranthene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
13	Benzoic acid	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]

UAE UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

ต่อหน้า 14 Benzo(a)pyrene...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
14	Benzo(a)pyrene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
15	Benzo(g,h,i)perylene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
16	Beryllium	Digestion, Inductively Coupled Plasma Method[4]
17	Bis(2-chloroethyl)ether	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
18	Bis(2-ethylhexyl)phthalate	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
19	Bromodichloromethane	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
20	Bromoform	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
21	Butanol	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
22	Butyl benzyl phthalate	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
23	Cadmium	1) Digestion, Direct Air-Acetylene Flame Method[4] 2) Digestion, Electrothermal Atomic Absorption Spectrometric Method[4] 3) Digestion, Inductively Coupled Plasma Method[4]
24	Carbazole	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
25	Carbon disulfide	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
26	Carbon tetrachloride	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
27	Chlordane	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
28	p-Chloroaniline	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]

UAE UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

ต่อหน้า 29 Chlorobenzene...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
29	Chlorobenzene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
30	Chlorodibromomethane	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
31	Chloroform	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
32	2-Chlorophenol	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
33	Chromium	1) Digestion, Direct Air-Acetylene Flame Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]
34	Chromium (III)	1) Digestion, Direct Air-Acetylene Flame Method; Colorimetric Method; Calculation[4] 2) Digestion, Inductively Coupled Plasma Method; Colorimetric Method; Calculation[4]
35	Chromium (VI)	Colorimetric Method[4]
36	Chrysene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
37	Cyanide	Distillation, Colorimetric Method[4]
38	2,4-D	Liquid-Liquid Extraction, Gas Chromatographic Method[4]
39	DDD	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
40	DDE	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
41	DDT	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
42	Dibenz(a,h)anthracene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]

สำเนาถูกต้อง

43 Di-n-butyl phthalate...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
43	Di-n-butyl phthalate	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
44	1,2-Dichlorobenzene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
45	1,3-Dichlorobenzene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
46	1,4-Dichlorobenzene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
47	3,3′-Dichlorobenzidine	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
48	1,1-Dichloroethane	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
49	1,2-Dichloroethane	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
50	1,1-Dichloroethylene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
51	cis-1,2-Dichloroethylene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
52	trans-1,2-Dichloroethylene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
53	2,4-Dichlorophenol	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
54	1,2-Dichloropropane	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
55	1,3-Dichloropropane	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
56	1,3-Dichloropropene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
57	Dieldrin	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
58	Diethyl phthalate	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
59	2,4-Dimethylphenol	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
60	2,4-Dinitrophenol	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]

สำเนาถูกต้อง

61 2,4-Dinitrotoluene...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
61	2,4-Dinitrotoluene	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
62	2,6-Dinitrotoluene	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
63	Di-n-Octyl phthalate	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
64	Endosulfan	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
65	Endrin	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
66	Ethylbenzene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
67	Fluoranthene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
68	Fluorene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
69	Heptachlor	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
70	Heptachlor epoxide	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
71	Hexachlorobenzene	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
72	Hexachloro-1,3-butadiene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
73	n-Hexane	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]

ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
74	α-HCH	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
75	β-HCH	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
76	γ-HCH	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
77	Hexachlorocyclopentadiene	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
78	Hexachloroethane	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
79	Indeno(1,2,3-cd)pyrene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
80	Isophorone	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
81	Lead	1) Digestion, Direct Air-Acetylene Flame Method[4] 2) Digestion, Electrothermal Atomic Absorption Spectrometric Method[4] 3) Digestion, Inductively Coupled Plasma Method[4]
82	Manganese	1) Digestion, Direct Air-Acetylene Flame Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]
83	Mercury	Digestion, Cold-Vapor Atomic Absorption Spectrometric Method[4]
84	Methanol	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
85	Methoxychlor	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
86	Methyl bromide	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]

ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
87	Methylene chloride	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
88	2-Methylphenol	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
89	2-Methylnaphthalene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
90	Methyl tert-butyl ether	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
91	Naphthalene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
92	Nickel	1) Digestion, Direct Air-Acetylene Flame Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]
93	Nitrobenzene	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
94	N-Nitrosodiphenylamine	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
95	N-Nitrosodi-n-propylamine	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
96	Polychlorinated Biphenyls - PCB 1016 - PCB 1221 - PCB 1232 - PCB-1242 - PCB-1248 - PCB-1254 - PCB-1260	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
97	Pentachlorophenol	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
98	pH	Electrometric Method[4]
99	Phenanthrene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]

DAE ENVIRONMENTAL ENGINEERING CONSULTANT COMPANY LIMITED
สำเนาถูกต้อง

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
100	Phenol	1) Distillation, Chloroform Extraction Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
101	Pyrene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
102	Selenium	1) Digestion, Hydride Generation/Atomic Absorption Spectrometric Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]
103	Silver	Digestion, Inductively Coupled Plasma Method[4]
104	Styrene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
105	1,1,2,2-Tetrachloroethane	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
106	Tetrachloroethylene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
107	Toluene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
108	Toxaphene	1) Liquid-Liquid Extraction, Gas Chromatographic Method[4] 2) Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
109	TPH (C_5 - C_8)	1) Purge and Trap, Gas Chromatographic Method[12,22] 2) Purge and Trap, Gas Chromatographic/Mass spectrometric Method[12,27]
110	TPH ($C_{>8}$ – C_{16})	Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[9,22]
111	TPH ($C_{>16}$ – C_{35})	Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[9,22]
112	1,2,4-Trichlorobenzene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
113	1,1,1-Trichloroethane	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
114	1,1,2-Trichloroethane	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
115	Trichloroethylene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]

DAE ENVIRONMENTAL ENGINEERING CONSULTANT COMPANY LIMITED
สำเนาถูกต้อง

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
116	2,4,5-Trichlorophenol	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
117	2,4,6-Trichlorophenol	Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[4]
118	1,3,5-Trimethylbenzene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
119	Vanadium	Digestion, Inductively Coupled Plasma Method[4]
120	Vinyl acetate	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
121	Vinyl chloride	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
122	m-Xylene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
123	o-Xylene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
124	p-Xylene	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
125	Xylene (Total)	Purge and Trap Gas Chromatographic/Mass Spectrometric Method[4]
126	Zinc	1) Digestion, Direct Air-Acetylene Flame Method[4] 2) Digestion, Inductively Coupled Plasma Method[4]

<u>อากาศเสีย (ปล่องระบาย) จำนวน 25 รายการ</u>

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
1	Antimony	Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[5]
2	Arsenic	1) Isokinetic Sampling, Digestion, Hydride Generation/ Atomic Absorption Spectrometric Method[5] 2) Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[5]
3	Cadmium	1) Isokinetic Sampling, Digestion, Direct Air-Acetylene Flame Method[5] 2) Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[5]
4	Carbon Monoxide	Instrumental Analyzer Method[5]
5	Chlorine	Isokinetic Sampling, Ion Chromatographic Method[5]
6	Chromium	1) Isokinetic Sampling, Digestion, Direct Air-Acetylene Flame Method[5]

Chromium (ต่อ)...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
6	Chromium (ต่อ)	2) Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[5]
7	Cobalt	Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[5]
8	Copper	1) Isokinetic Sampling, Digestion, Direct Air-Acetylene Flame Method[5] 2) Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[5]
9	Cresol	Absorption Sampling, Gas Chromatographic Method[5]
10	Dioxins/Furans	Isokinetic Sampling[5]
11	Hydrogen Chloride	Isokinetic Sampling, Ion Chromatographic Method[5]
12	Hydrogen Fluoride	Isokinetic Sampling, Ion Chromatographic Method[5]
13	Hydrogen Sulfide	Absorption Sampling, Iodometric Method[5]
14	Lead	1) Isokinetic Sampling, Digestion, Direct Air-Acetylene Flame Method[5] 2) Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[5]
15	Manganese	1) Isokinetic Sampling, Digestion, Direct Air-Acetylene Flame Method[5] 2) Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[5]
16	Mercury	Isokinetic Sampling, Digestion, Cold-Vapor Atomic Absorption Spectrometric Method[5]
17	Nickel	1) Isokinetic Sampling, Digestion, Direct Air-Acetylene Flame Method[5] 2) Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[5]
18	Opacity	Ringelmann's Method[1]
19	Oxides of Nitrogen	1) Absorption Sampling, Phenoldisulfonic acid Method[5] 2) Instrumental Analyzer Method[5]
20	Selenium	1) Isokinetic Sampling, Digestion, Hydride Generation/ Atomic Absorption Spectrometric Method[5] 2) Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[5]
21	Sulfur Dioxide	1) Absorption Sampling, Barium-Thorin Titrimetric Method[5] 2) Instrumental Analyzer Method[5]
22	Sulfuric Acid	Isokinetic Sampling, Barium-Thorin Titrimetric Method[5]

23 Total Suspended Particulate...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
23	Total Suspended Particulate	Isokinetic Sampling, Gravimetric Method[5]
24	Vanadium	Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[5]
25	Xylene	1) Bag Sampling, Gas Chromatographic Method[5] 2) Adsorption Sampling, Gas Chromatographic Method[5]

<u>สิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้ว จำนวน 35 รายการ</u>

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
1	Aldrin	1) Waste Extraction, Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[3,9,23] 2) Ultrasonic Extraction, Gas Chromatographic Method[10,23]
2	Antimony	1) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 2) Digestion, Inductively Coupled Plasma Method[7,14]
3	Arsenic	1) Waste Extraction, Digestion, Hydride Generation/ Atomic Absorption Spectrometric Method[3,6,16] 2) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 3) Digestion, Hydride Generation/Atomic Absorption Spectrometric Method[7,16] 4) Digestion, Inductively Coupled Plasma Method[7,14]
4	Barium	1) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 2) Digestion, Inductively Coupled Plasma Method[7,14]
5	Beryllium	1) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 2) Digestion, Inductively Coupled Plasma Method[7,14]
6	Cadmium	1) Waste Extraction, Digestion, Flame Atomic Absorption Spectrometric Method[3,6,15] 2) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 3) Digestion, Flame Atomic Absorption Spectrometric Method[7,15] 4) Digestion, Inductively Coupled Plasma Method[7,14]
7	Chlordane	1) Waste Extraction, Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[3,9,23] 2) Ultrasonic Extraction, Gas Chromatographic Method[10,23]

8 Chromium...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
8	Chromium	1) Waste Extraction, Digestion, Flame Atomic Absorption Spectrometric Method[3,6,15] 2) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 3) Digestion, Flame Atomic Absorption Spectrometric Method[7,15] 4) Digestion, Inductively Coupled Plasma Method[7,14]
9	Chromium (III)	1) Waste Extraction, Digestion, Flame Atomic Absorption Spectrometric Method; Waste Extraction, Colorimetric Method; Calculation[3,6,15,17] 2) Waste Extraction, Digestion, Inductively Coupled Plasma Method; Waste Extraction, Colorimetric Method; Calculation[3,6,14,17] 3) Digestion, Flame Atomic Absorption Spectrometric Method; Alkaline Digestion, Colorimetric Method; Calculation[7,8,15,17] 4) Digestion, Inductively Coupled Plasma Method; Alkaline Digestion, Colorimetric Method; Calculation[7,8,14,17]
10	Chromium (VI)	1) Waste Extraction, Colorimetric Method[3,17] 2) Alkaline Digestion, Colorimetric Method[8,17]
11	Cobalt	1) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 2) Digestion, Inductively Coupled Plasma Method[7,14]
12	Copper	1) Waste Extraction, Digestion, Flame Atomic Absorption Spectrometric Method[3,6,15] 2) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 3) Digestion, Flame Atomic Absorption Spectrometric Method[7,15] 4) Digestion, Inductively Coupled Plasma Method[7,14]
13	2,4-D	1) Waste Extraction, Gas Chromatographic Method[3,26] 2) Ultrasonic Extraction, Gas Chromatographic Method[26]
14	DDD	1) Waste Extraction, Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[3,9,23] 2) Ultrasonic Extraction, Gas Chromatographic Method[10,23]

15 DDE...

UAE UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
15	DDE	1) Waste Extraction, Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[3,9,23] 2) Ultrasonic Extraction, Gas Chromatographic Method[10,23]
16	DDT	1) Waste Extraction, Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[3,9,23] 2) Ultrasonic Extraction, Gas Chromatographic Method[10,23]
17	Dieldrin	1) Waste Extraction, Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[3,9,23] 2) Ultrasonic Extraction, Gas Chromatographic Method[10,23]
18	Endrin	1) Waste Extraction, Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[3,9,23] 2) Ultrasonic Extraction, Gas Chromatographic Method[10,23]
19	Heptachlor	1) Waste Extraction, Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[3,9,23] 2) Ultrasonic Extraction, Gas Chromatographic Method[10,23]
20	Lead	1) Waste Extraction, Digestion, Flame Atomic Absorption Spectrometric Method[3,6,15] 2) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 3) Digestion, Flame Atomic Absorption Spectrometric Method[7,15] 4) Digestion, Inductively Coupled Plasma Method[7,14]
21	Lindane	1) Waste Extraction, Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[3,9,23] 2) Ultrasonic Extraction, Gas Chromatographic Method[10,23]
22	Mercury	1) Waste Extraction, Digestion, Cold-Vapor Atomic Absorption Spectrometric Method[3,19] 2) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 3) Digestion, Cold-Vapor Atomic Absorption Spectrometric Method[19] 4) Digestion, Inductively Coupled Plasma Method[7,14]

Mercury (ต่อ)...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
22	Mercury (ต่อ)	5) Thermal Decomposition Amalgamation and Atomic Absorption Spectrometric Method[20]
23	Methoxychlor	1) Waste Extraction, Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[3,9,23] 2) Ultrasonic Extraction, Gas Chromatographic Method[10,23]
24	Molybdenum	1) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 2) Digestion, Inductively Coupled Plasma Method[7,14]
25	Nickel	1) Waste Extraction, Digestion, Flame Atomic Absorption Spectrometric Method[3,6,15] 2) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 3) Digestion, Flame Atomic Absorption Spectrometric Method[7,15] 4) Digestion, Inductively Coupled Plasma Method[7,14]
26	Polychlorinated Biphenyls - Aroclor 1016 - Aroclor 1221 - Aroclor 1232 - Aroclor 1242 - Aroclor 1248 - Aroclor 1254 - Aroclor 1260 - 2-Chlorobiphenyl - 2,3-Dichlorobiphenyl - 2,2',5-Trichlorobiphenyl - 2,4',5-Trichlorobiphenyl - 2,2',3,5'-Tetrachlorobiphenyl - 2,2',5,5'-Tetrachlorobiphenyl - 2,3',4,4'-Tetrachlorobiphenyl - 2,2',3,4,5'-Pentachlorobiphenyl - 2,2',4,5,5'-Pentachlorobiphenyl - 2,3,3',4',6-Pentachlorobiphenyl	1) Waste Extraction, Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[3,9,26] 2) Ultrasonic Extraction, Gas Chromatographic Method[10,24]

Polychlorinated Biphenyls(ต่อ)...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
	Polychlorinated Biphenyls(ต่อ) - 2,2',3,4,4',5'-Hexachlorobiphenyl - 2,2',3,4,5,5'-Hexachlorobiphenyl - 2,2',3,5,5',6-Hexachlorobiphenyl - 2,2',4,4',5,5'-Hexachlorobiphenyl - 2,2',3,3',4,4',5-Heptachlorobiphenyl - 2,2',3,4,4',5,5'-Heptachlorobiphenyl - 2,2',3,4,4',5',6-Heptachlorobiphenyl - 2,2',3,4',5,5',6-Heptachlorobiphenyl - 2,2',3,3',4,4',5,5',6-Nonachlorobiphenyl	
27	Pentachlorophenol	1) Waste Extraction, Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic/Mass Spectrometric Method[3,9,28] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
28	pH	Electrometric Method[31,32]
29	Selenium	1) Waste Extraction, Digestion, Hydride Generation/Atomic Absorption Spectrometric Method[3,6,21] 2) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 3) Digestion, Hydride Generation/Atomic Absorption Spectrometric Method[7,21] 4) Digestion, Inductively Coupled Plasma Method[7,14]
30	Silver	1) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 2) Digestion, Inductively Coupled Plasma Method[7,14]
31	Thallium	1) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 2) Digestion, Inductively Coupled Plasma Method[7,14]

32 Toxaphene...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
32	Toxaphene	1) Waste Extraction, Separatory Funnel Liquid-Liquid Extraction, Gas Chromatographic Method[3,9,23] 2) Ultrasonic Extraction, Gas Chromatographic Method[10,23]
33	Trichloroethylene	1) Waste Extraction, Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[3,12,27] 2) Waste Extraction, Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method[3,11,27] 3) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 4) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method[11,27]
34	Vanadium	1) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 2) Digestion, Inductively Coupled Plasma Method[7,14]
35	Zinc	1) Waste Extraction, Digestion, Flame Atomic Absorption Spectrometric Method[3,6,15] 2) Waste Extraction, Digestion, Inductively Coupled Plasma Method[3,6,14] 3) Digestion, Flame Atomic Absorption Spectrometric Method[7,15] 4) Digestion, Inductively Coupled Plasma Method[7,14]

ดิน จำนวน 125 รายการ

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
1	Acenaphthene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
2	Acetone	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
3	Aldrin	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
4	Anthracene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25]

Anthracene (ต่อ)...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
4	Anthracene (ต่อ)	2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
5	Antimony	Digestion, Inductively Coupled Plasma Method[7,14]
6	Arsenic	1) Digestion, Hydride Generation/Atomic Absorption Spectrometric Method[7,16]
		2) Digestion, Inductively Coupled Plasma Method[7,14]
7	Atrazine	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
8	Barium	Digestion, Inductively Coupled Plasma Method[7,14]
9	Benz(a)anthracene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25]
		2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
10	Benzene	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
		2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method [11,27]
11	Benzo(b)fluoranthene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25]
		2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
12	Benzo(k)fluoranthene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25]
		2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
13	Benzoic acid	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
14	Benzo(a)pyrene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25]
		2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
15	Benzo(g,h,i)perylene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25]
		2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
16	Beryllium	Digestion, Inductively Coupled Plasma Method[7,14]

UNITED ANALYST AND ENGINEERING COMPANY LIMITED สำเนาถูกต้อง

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
17	Bis(2-chloroethyl)ether	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
18	Bis(2-ethylhexyl)phthalate	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
19	Bromodichloromethane	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
20	Bromoform	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
21	Butanol	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
22	Butyl benzyl phthalate	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
23	Cadmium	1) Digestion, Flame Atomic Absorption Spectrometric Method[7,15]
		2) Digestion, Inductively Coupled Plasma Method[7,14]
24	Carbazole	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
25	Carbon disulfide	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
26	Carbon tetrachloride	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
		2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method[11,27]
27	Chlordane	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23]
		2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
28	p-Chloroaniline	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
29	Chlorobenzene	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
30	Chlorodibromomethane	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
31	Chloroform	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
32	2-Chlorophenol	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]

UNITED ANALYST AND ENGINEERING COMPANY LIMITED สำเนาถูกต้อง

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
33	Chromium	1) Digestion, Flame Atomic Absorption Spectrometric Method[7,15] 2) Digestion, Inductively Coupled Plasma Method[7,14]
34	Chromium (III)	1) Digestion, Flame Atomic Absorption Spectrometric Method; Alkaline Digestion, Colorimetric Method; Calculation[7,8,15,17] 2) Digestion, Inductively Coupled Plasma Method; Alkaline Digestion, Colorimetric Method; Calculation[7,8,14,17]
35	Chromium (VI)	Alkaline Digestion, Colorimetric Method[8,17]
36	Chrysene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
37	Cyanide	Extraction, Distillation, Colorimetric Method[29,30]
38	2,4-D	Ultrasonic Extraction, Gas Chromatographic Method[26]
39	DDD	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
40	DDE	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
41	DDT	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
42	Dibenz(a,h)anthracene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
43	Di-n-butyl phthalate	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
44	1,2-Dichlorobenzene	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]

45 1,3-Dichlorobenzene...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
45	1,3-Dichlorobenzene	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
46	1,4-Dichlorobenzene	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
47	3,3'-Dichlorobenzidine	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
48	1,1-Dichloroethane	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method [11,27]
49	1,2-Dichloroethane	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method [11,27]
50	1,1-Dichloroethylene	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method [11,27]
51	cis-1,2-Dichloroethylene	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method [11,27]
52	trans-1,2-Dichloroethylene	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method [11,27]
53	2,4-Dichlorophenol	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
54	1,2-Dichloropropane	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
55	1,3-Dichloropropane	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
56	1,3-Dichloropropene	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
57	Dieldrin	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]

58 Diethyl phthalate...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
58	Diethyl phthalate	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
59	2,4-Dimethylphenol	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
60	2,4-Dinitrophenol	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
61	2,4-Dinitrotoluene	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
62	2,6-Dinitrotoluene	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
63	Di-n-Octyl phthalate	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
64	Endosulfan	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
65	Endrin	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
66	Ethylbenzene	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method [11,27]
67	Fluoranthene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
68	Fluorene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
69	Heptachlor	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
70	Heptachlor epoxide	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23]

Heptachlor epoxide (ต่อ)...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
70	Heptachlor epoxide (ต่อ)	2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
71	Hexachlorobenzene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
72	Hexachloro-1,3-butadiene	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
73	n-Hexane	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
74	α-HCH	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
75	β-HCH	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
76	γ-HCH	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
77	Hexachlorocyclopentadiene	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
78	Hexachloroethane	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
79	Indeno(1,2,3-cd)pyrene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
80	Isophorone	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
81	Lead	1) Digestion, Flame Atomic Absorption Spectrometric Method[7,15] 2) Digestion, Inductively Coupled Plasma Method[7,14]
82	Manganese	1) Digestion, Flame Atomic Absorption Spectrometric Method[7,15] 2) Digestion, Inductively Coupled Plasma Method[7,14]

83 Mercury...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
83	Mercury	1) Digestion, Cold-Vapor Atomic Absorption Spectrometric Method[19] 2) Thermal Decomposition Amalgamation and Atomic Absorption Spectrometric Method[20]
84	Methanol	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
85	Methoxychlor	1) Ultrasonic Extraction, Gas Chromatographic Method[10,23] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
86	Methyl bromide	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
87	Methylene chloride	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method [11,27]
88	2-Methylphenol	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
89	2-Methylnaphthalene	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
90	Methyl tert-butyl ether	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
91	Naphthalene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
92	Nickel	1) Digestion, Flame Atomic Absorption Spectrometric Method[7,15] 2) Digestion, Inductively Coupled Plasma Method[7,14]
93	Nitrobenzene	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
94	N-Nitrosodiphenylamine	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
95	N-Nitrosodi-n-propylamine	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
96	Polychlorinated Biphenyls - Aroclor 1016	1) Ultrasonic Extraction, Gas Chromatographic Method[10,24]

UAE UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

Polychlorinated Biphenyls(ต่อ)...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
96	Polychlorinated Biphenyls(ต่อ) - Aroclor 1221 - Aroclor 1232 - Aroclor 1242 - Aroclor 1248 - Aroclor 1254 - Aroclor 1260 Polychlorinated Biphenyls - 2-Chlorobiphenyl - 2,3-Dichlorobiphenyl - 2,2',5-Trichlorobiphenyl - 2,4',5-Trichlorobiphenyl - 2,2',3,5'-Tetrachlorobiphenyl - 2,2',5,5'-Tetrachlorobiphenyl - 2,3',4,4'-Tetrachlorobiphenyl - 2,2',3,4,5'-Pentachlorobiphenyl - 2,2',4,5,5'-Pentachlorobiphenyl - 2,3,3',4',6-Pentachlorobiphenyl - 2,2',3,4,4',5'-Hexachlorobiphenyl - 2,2',3,4,5,5'-Hexachlorobiphenyl - 2,2',3,5,5',6-Hexachlorobiphenyl - 2,2',4,4',5,5'-Hexachlorobiphenyl - 2,2',3,3',4,4',5-Heptachlorobiphenyl - 2,2',3,4,4',5,5'-Heptachlorobiphenyl - 2,2',3,4,4',5',6-Heptachlorobiphenyl - 2,2',3,4',5,5',6-Heptachlorobiphenyl - 2,2',3,3',4,4',5,5',6-Nonachlorobiphenyl	2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28] Ultrasonic Extraction, Gas Chromatographic Method[10,24]

UAE UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED สำเนาถูกต้อง

97 Pentachlorophenol...

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
97	Pentachlorophenol	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
98	Phenanthrene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
99	Phenol	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
100	Pyrene	1) Ultrasonic Extraction, Gas Chromatographic Method[10,25] 2) Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
101	Selenium	1) Digestion, Hydride Generation/Atomic Absorption Spectrometric Method[7,21] 2) Digestion, Inductively Coupled Plasma Method[7,14]
102	Silver	Digestion, Inductively Coupled Plasma Method[7,14]
103	Styrene	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method[11,27]
104	1,1,2,2-Tetrachloroethane	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
105	Tetrachloroethylene	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method[11,27]
106	Toluene	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method[11,27]
107	Toxaphene	Ultrasonic Extraction, Gas Chromatographic Method[10,23]
108	TPH (C_5-C_8)	1) Purge and Trap, Gas Chromatographic Method[13,22] 2) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
109	TPH ($C_{>8}$-C_{16})	Ultrasonic Extraction, Gas Chromatographic Method[10,22]
110	TPH ($C_{>16}$-C_{35})	Ultrasonic Extraction, Gas Chromatographic Method[10,22]

สำเนาถูกต้อง

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
111	1,2,4-Trichlorobenzene	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
112	1,1,1-Trichloroethane	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
113	1,1,2-Trichloroethane	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
114	Trichloroethylene	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method[11,27]
115	2,4,5-Trichlorophenol	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
116	2,4,6-Trichlorophenol	Ultrasonic Extraction, Gas Chromatographic/Mass Spectrometric Method[10,28]
117	1,3,5-Trimethylbenzene	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
118	Vanadium	Digestion, Inductively Coupled Plasma Method[7,14]
119	Vinyl acetate	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
120	Vinyl chloride	Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27]
121	m-Xylene	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method[11,27]
122	o-Xylene	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method[11,27]
123	p-Xylene	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method[11,27]
124	Xylene (Total)	1) Purge and Trap, Gas Chromatographic/Mass Spectrometric Method[13,27] 2) Equilibrium Headspace, Gas Chromatographic/Mass Spectrometric Method[11,27]

สำเนาถูกต้อง

ลำดับ	สารมลพิษ	วิธีวิเคราะห์
125	Zinc	1) Digestion, Flame Atomic Absorption Spectrometric Method[7,15] 2) Digestion, Inductively Coupled Plasma Method[7,14]

เอกสารอ้างอิง

1. กระทรวงอุตสาหกรรม. ประกาศกระทรวงอุตสาหกรรม, พ.ศ. 2549. เรื่อง กำหนดค่าปริมาณเขม่าควันที่เจือปนในอากาศที่ระบายออกจากปล่องของหม้อน้ำโรงสีข้าวที่ใช้แกลบเป็นเชื้อเพลิง. **ราชกิจจานุเบกษา.** 4 ธันวาคม 2549. เล่มที่ 123 ตอนพิเศษ 125ง.

2. สมาคมวิศวกรรมสิ่งแวดล้อมแห่งประเทศไทย. **คู่มือวิเคราะห์น้ำเสีย.** พิมพ์ครั้งที่ 4. กรุงเทพฯ: เรือนแก้วการพิมพ์, 2547.

3. กระทรวงอุตสาหกรรม. ประกาศกระทรวงอุตสาหกรรม, พ.ศ. 2566. เรื่อง การจัดการสิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้ว.**ราชกิจจานุเบกษา.** 31 พฤษภาคม 2566. เล่มที่ 140 ตอนพิเศษ 126 ง.

4. APHA, AWWA, WEF. **Standard Methods for the Examination of Water and Wastewater.** 24th ed. Washington, DC: APHA, 2023.

5. United States Environmental Protection Agency. **Standards of Performance for New Stationary Sources.** 40 CFR 60. Appendix A, 2020.

6. United States Environmental Protection Agency. **Test Methods for Evaluation Solid Waste Physical/Chemical Methods. SW-846,** 2014.

7. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Acid Digestion of Sediments, Sludges, and Soils. SW-846 Method 3050B,** 1996.

8. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Alkaline Digestion for Hexavalent Chromium. SW-846 Method 3060A,** 1996.

9. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste 3. Physical/Chemical Methods. **Separatory Funnel Liquid-Liquid Extraction. SW-846 Method 3510C,** 1996.

10. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Ultrasonic Extraction. SW-846 Method 3550C,** 2007.

11. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Volatile Organic Compounds in Various Sample Matrices Using Equilibrium Headspace Analysis. SW-846 Method 5021A,** 2014.

12. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Purge and Trap for Aqueous Samples. SW-846 Method 5030C,** 2003.

13. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Closed System Purge and Trap and Extraction for Volatile Organics in Soil and Waste Sample. SW-846 Method 5035A,** 2000.

14. United States...

14. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Inductively Coupled Plasma-Optical Emission Spectrometry. SW-846 Method 6010D,** 2014.

15. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Flame Atomic Absorption Spectrophotometry. SW-846 Method 7000B,** 2007.

16. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Arsenic (Atomic Absorption, Gaseous Hydride). SW-846 Method 7061A,** 1992.

17. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Chromium, Hexavalent (Colorimetric). SW-846 Method 7196A,** 1992.

18. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Mercury in Liquid Waste (Manual Cold Vapor Technique). SW-846 Method 7470A,** 1994.

19. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Mercury in Solid or Semisolid Waste (Manual Cold-Vapor Technique). SW-846 Method 7471B,** 1998.

20. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Mercury in Solids and Solutions by Thermal Decomposition, Amalgamation, and Atomic Absorption Spectrophotometry. SW-846 Method 7473,** 2007.

21. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Selenium (Atomic Absorption, Borohydride Reduction). SW-846 Method 7742,** 1994.

22. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Nonhalogenated Organics Using GC/FID. SW-846 Method 8015D,** 2003.

23. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Organochlorine Pesticides by Gas Chromatography. SW-846 Method 8081B,** 2007.

24. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Polychlorinated Biphenyls (PCBs) by Gas Chromatography. SW-846 Method 8082A,** 2007.

25. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Organochlorine Pesticides by Gas Chromatography. SW-846 Method 8081B,** 2007.

26. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Chlorinated Herbicides by GC Using Methylation or Pentafluorobenzylation Derivertization. SW-846 Method 8151A,** 1996.

27. United States...

27. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Volatile Organic Compounds by Gas Chromatography/ Mass Spectrometry. SW-846 Method 8260D**, 2018.

28. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Semivolatile Organic Compounds by Gas Chromatography/Mass Spectrometry. SW-846 Method 8270E**, 2018.

29. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Cyanide Extraction Procedure for Solids and Oils. SW-846 Method 9013A**, 2014.

30. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Cyanide in Waters and Extracts using Titrimetric and Manual Spectrophotometric Procedures. SW-846 Method 9014**, 2014.

31. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **pH Electrometric Measurement. SW-846 Method 9040C**, 2004.

32. United States Environmental Protection Agency. Test Methods for Evaluation Solid Waste Physical/Chemical Methods. **Soil and Waste pH. SW-846 Method 9045D**, 2004.

UAE
UNITED ANALYST AND ENGINEERING CONSULTANT COMPANY LIMITED

สำเนาถูกต้อง

ที่ อก ๐๓๑๐(๑)/ ๑๕๓๗๘

กรมโรงงานอุตสาหกรรม
ถนนพระรามที่ ๖ แขวงทุ่งพญาไท
เขตราชเทวี กรุงเทพฯ ๑๐๔๐๐

๐๓ พฤศจิกายน ๒๕๖๖

เรื่อง ต่ออายุหนังสือรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน

เรียน กรรมการผู้จัดการ บริษัท ทีพีไอ โพลีน จำกัด (มหาชน)

อ้างถึง คำขอขึ้นทะเบียน/ต่ออายุ/เปลี่ยนแปลงบุคลากร และชนิดสารมลพิษของห้องปฏิบัติการวิเคราะห์เอกชน ลงวันที่ ๑๓ กรกฎาคม ๒๕๖๖

สิ่งที่ส่งมาด้วย เอกสารแนบท้ายหนังสือรับต่ออายุขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน บริษัท ทีพีไอ โพลีน จำกัด (มหาชน) จำนวน ๓ แผ่น

ตามหนังสือที่อ้างถึง บริษัท ทีพีไอ โพลีน จำกัด (มหาชน) ขอต่ออายุหนังสือรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน เลขทะเบียน ร-๐๙๗ สถานที่ตั้งเลขที่ ๒๙๙ หมู่ที่ ๕ ถนนมิตรภาพ ตำบลทับกวาง อำเภอแก่งคอย จังหวัดสระบุรี ต่อกรมโรงงานอุตสาหกรรม นั้น

กรมโรงงานอุตสาหกรรมพิจารณาแล้ว ให้บริษัท ทีพีไอ โพลีน จำกัด (มหาชน) ต่ออายุหนังสือรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน โดยมีองค์ประกอบดังนี้

ก. ผู้ควบคุมดูแลห้องปฏิบัติการวิเคราะห์

๑) นางสาวอาทยา ศรีงาม	ทะเบียนเลขที่ ร-๐๙๗-ค-๐๐๐๑
๒) นางสาวสุวรรณี มิสสิตะ	ทะเบียนเลขที่ ร-๐๙๗-ค-๐๐๐๒
๓) นายอนุกูล สุขเวสพงษ์	ทะเบียนเลขที่ ร-๐๙๗-ค-๐๐๐๓
๔) นางสาวพัชรินทร์ บุญมาวัตร์	ทะเบียนเลขที่ ร-๐๙๗-ค-๐๐๐๔
๕) นางสาวอภิญญา ภูนิคม	ทะเบียนเลขที่ ร-๐๙๗-ค-๐๐๐๕
๖) นายวุฒิชัย จันมูลตรี	ทะเบียนเลขที่ ร-๐๙๗-ค-๐๐๐๖
๗) นางสาวสุธาสินี สุขวินิช	ทะเบียนเลขที่ ร-๐๙๗-ค-๐๐๐๗
๘) Mr. Thu Yein Win	ทะเบียนเลขที่ ร-๐๙๗-ค-๐๐๐๘

ข. เจ้าหน้าที่ประจำห้องปฏิบัติการวิเคราะห์

๑) นายบุญชู คลังสุภา	ทะเบียนเลขที่ ร-๐๙๗-จ-๐๐๐๑
๒) นายชด พัดมุกข์	ทะเบียนเลขที่ ร-๐๙๗-จ-๐๐๐๒
๓) นายมงคล คุณกิจชัยเจริญ	ทะเบียนเลขที่ ร-๐๙๗-จ-๐๐๐๓
๔) นายชวัญชัย โพธิ์แก้ว	ทะเบียนเลขที่ ร-๐๙๗-จ-๐๐๐๔
๕) นางดวงกมล อินทร์อนันต์	ทะเบียนเลขที่ ร-๐๙๗-จ-๐๐๐๕
๖) นายสมชาย มะลิทอง	ทะเบียนเลขที่ ร-๐๙๗-จ-๐๐๐๖
๗) นายกำจร เณรตาก้อง	ทะเบียนเลขที่ ร-๐๙๗-จ-๐๐๐๗
๘) นายยุทธนา มณฑา	ทะเบียนเลขที่ ร-๐๙๗-จ-๐๐๐๘
๙) นางสาวศิริลักษณ์ สงวนศักดิ์	ทะเบียนเลขที่ ร-๐๙๗-จ-๐๐๐๙
๑๐) นายวัชรพงศ์ อำพรพงษ์	ทะเบียนเลขที่ ร-๐๙๗-จ-๐๐๑๐

ค. ขอบข่ายสารมลพิษ...

ค. ขอบข่ายสารมลพิษที่ได้รับขึ้นทะเบียนให้วิเคราะห์ในน้ำเสีย อากาศเสีย และสิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้ว ตามสิ่งที่ส่งมาด้วย

หนังสือฉบับนี้จะหมดอายุในวันที่ ๑๙ กรกฎาคม ๒๕๖๙ หากประสงค์จะต่ออายุหนังสือรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ให้ยื่นคำขอต่ออายุพร้อมเอกสารประกอบคำขอต่อกรมโรงงานอุตสาหกรรมภายใน ๓๐ วัน ก่อนวันสิ้นอายุของหนังสือรับขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน ทั้งนี้ สามารถยื่นคำขอผ่านระบบอิเล็กทรอนิกส์ได้ที่หน้าเว็บไซต์กรมโรงงานอุตสาหกรรม

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ

(นายศิระ จันทร์เฉิด)
นักวิทยาศาสตร์เชี่ยวชาญ รักษาราชการแทน
ผู้อำนวยการกองวิจัยและเตือนภัยมลพิษโรงงาน
ปฏิบัติราชการแทนอธิบดีกรมโรงงานอุตสาหกรรม

กองวิจัยและเตือนภัยมลพิษโรงงาน
กลุ่มมาตรฐานวิธีการวิเคราะห์ทดสอบมลพิษและทะเบียนห้องปฏิบัติการ
โทร. ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๐๓-๕
โทรสาร ๐ ๒๔๓๐ ๖๓๑๒ ต่อ ๒๑๐๙
ไปรษณีย์อิเล็กทรอนิกส์ saraban@diw.mail.go.th

เอกสารแนบท้ายหนังสือรับต่ออายุขึ้นทะเบียนห้องปฏิบัติการวิเคราะห์เอกชน
บริษัท ทีพีไอ โพลีน จำกัด (มหาชน) เลขทะเบียน ร-๐๙๗
ที่ อก ๐๓๑๐(๑)/ ๑๕๓๗๘ ลงวันที่ ๐๓ พฤศจิกายน ๒๕๖๖

ขอบข่ายสารมลพิษที่ได้รับขึ้นทะเบียนจากกรมโรงงานอุตสาหกรรม จำนวน ๔๓ รายการ

น้ำเสีย จำนวน 19 รายการ

ลำดับที่	สารมลพิษ	วิธีวิเคราะห์
1	Arsenic	Digestion, Inductively Coupled Plasma Method[3]
2	Barium	Digestion, Inductively Coupled Plasma Method[3]
3	Biochemical Oxygen Demand	5-Day BOD Test, Membrane Electrode Method[3]
4	Cadmium	Digestion, Inductively Coupled Plasma Method[3]
5	Chemical Oxygen Demand	Open Reflux, Titrimetric Method[3]
6	Chromium	Digestion, Inductively Coupled Plasma Method[3]
7	Copper	Digestion, Inductively Coupled Plasma Method[3]
8	Free Chlorine	DPD Colorimetric Method[3]
9	Lead	Digestion, Inductively Coupled Plasma Method[3]
10	Manganese	Digestion, Inductively Coupled Plasma Method[3]
11	Nickel	Digestion, Inductively Coupled Plasma Method[3]
12	Oil & Grease	Liquid-Liquid, Partition-Gravimetric Method[3]
13	pH	Electrometric Method[3]
14	Selenium	Digestion, Inductively Coupled Plasma Method[3]
15	Sulfide	Methylene Blue Method[3]
16	Temperature	Laboratory and Field Methods[3]
17	Total Dissolved Solids	Dried at 180 ^{0}C[3]
18	Total Suspended Solids	Dried at 103-105^{0}C[3]
19	Zinc	Digestion, Inductively Coupled Plasma Method[3]

อากาศเสีย (ปล่องระบาย) จำนวน 8 รายการ

ลำดับที่	สารมลพิษ	วิธีวิเคราะห์
1	Antimony	Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[4]
2	Arsenic	Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[4]
3	Carbon Monoxide	Instrumental Analyzer[4]
4	Copper	Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[4]
5	Lead	Isokinetic Sampling, Digestion, Inductively Coupled Plasma Method[4]
6	Oxides of Nitrogen	Instrumental Analyzer[4]
7	Sulfur Dioxide	Instrumental Analyzer[4]
8	Total Suspended Particulate	Isokinetic Sampling, Gravimetric Method[4]

สิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้ว...

สิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้ว จำนวน 16 รายการ

ลำดับที่	สารมลพิษ	วิธีวิเคราะห์
1	Antimony	1) Waste Extraction, Inductively Coupled Plasma Method[1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]
2	Arsenic	1) Waste Extraction, Inductively Coupled Plasma Method [1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]
3	Barium	1) Waste Extraction, Inductively Coupled Plasma Method [1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]
4	Cadmium	1) Waste Extraction, Inductively Coupled Plasma Method [1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]
5	Chromium	1) Waste Extraction, Inductively Coupled Plasma Method [1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]
6	Copper	1) Waste Extraction, Inductively Coupled Plasma Method [1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]
7	Heating Value (Gross Calorific Value)	Bomb Calorimetry[2]
8	Heating Value (Net Calorific Value)	Bomb Calorimetry[2]
9	Lead	1) Waste Extraction, Inductively Coupled Plasma Method [1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]
10	Mercury	1) Waste Extraction, Inductively Coupled Plasma Method [1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]
11	Nickel	1) Waste Extraction, Inductively Coupled Plasma Method [1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]
12	Selenium	1) Waste Extraction, Inductively Coupled Plasma Method [1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]
13	Silver	1) Waste Extraction, Inductively Coupled Plasma Method [1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]
14	Thallium	1) Waste Extraction, Inductively Coupled Plasma Method [1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]
15	Vanadium	1) Waste Extraction, Inductively Coupled Plasma Method [1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]
16	Zinc	1) Waste Extraction, Inductively Coupled Plasma Method [1,5,6,7] 2) Digestion, Inductively Coupled Plasma Method[5,6,7]

เอกสารอ้างอิง...

เอกสารอ้างอิง

1. กระทรวงอุตสาหกรรม. **ประกาศกระทรวงอุตสาหกรรม, พ.ศ. 2566.** เรื่องการจัดการสิ่งปฏิกูลหรือวัสดุที่ไม่ใช้แล้ว. **ราชกิจจานุเบกษา.** 31 พฤษภาคม 2566. เล่ม 140 ตอนพิเศษ 126 ง.

2. American Society for Testing and Materials. **D 240-19, Standard Test Method for Heat of Combustion of Liquid Hydrocarbon Fuels by Bomb Calorimeter**

3. APHA, AWWA, WEF. **Standard Methods for the Examination of Water and Wastewater.** 23rd ed. Washington, DC: APHA, 2017.

4. United States Environmental Protection Agency. **Standard of Performance for New Stationary Sources.** 40 CFR Part 60, Appendix A, 2022.

5. United States Environmental Protection Agency. **Acid Digestion of Aqueous Sample and Extracts for Total Metals for Analysis by FLAA or ICP Spectroscopy. SW-846 Method 3010A,** 1992.

6. United States Environmental Protection Agency. **Acid Digestion for Sediments, Sludges, and Soils. SW-846 Method 3050B,** 1996.

7. United States Environmental Protection Agency. **Inductively Coupled Plasma-Atomic Emission Spectrometry. SW-846 Method 6010D,** 2018.