

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF January 2026

Location	Emergency light			Central Batt	Remark	Check By
	Guest's lift Zone	Staff's lift Zone	Link Zone			
14 th floor	/	/			ปกติ	ธวัชชัย
12 th floor	/	/		/	ปกติ	ธวัชชัย
11 th floor	/	/		/	ปกติ	ธวัชชัย
10 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
9 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
8 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
7 th floor	/	/		/	ปกติ	ธวัชชัย
6 th floor	/	/		/	ปกติ	ธวัชชัย
5 th floor	/	/	/	/	ปกติ	ธวัชชัย
4 th floor	/	/	/	Xแบตเตอรี่	เสีย	ธวัชชัย
3 rd floor	/	/	/	Xเครื่องเก่า	เสีย	ธวัชชัย
2 nd floor	/	/		/	ปกติ	ธวัชชัย
Ground floor	/	/		/	ปกติ	ธวัชชัย
Basement floor	/	/			ปกติ	ธวัชชัย
Carpark	/	/			ปกติ	ธวัชชัย

Public Area

Location	Emergency light		Central Batt	Remark	Check By
Administration office			Xแบตเตอรี่	เสีย	ธวัชชัย
Housekeeping office			Xแบตเตอรี่	เสีย	ธวัชชัย
Engineering office			Xแบตเตอรี่	เสีย	ธวัชชัย
Laundry room	/			ปกติ	ธวัชชัย
Canteen	/			ปกติ	ธวัชชัย
Male locker room	/			ปกติ	ธวัชชัย
Female locker room	/			ปกติ	ธวัชชัย
Fitness Center				ไม่มี	ธวัชชัย
In front of guest's lift 14 th floor				ไม่มี	ธวัชชัย

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF February 2026

Location	Emergency light			Central Batt	Remark	Check By
	Guest's lift Zone	Staff's lift Zone	Link Zone			
14 th floor	/	/			ปกติ	ธวัชชัย
12 th floor	/	/		/	ปกติ	ธวัชชัย
11 th floor	/	/		/	ปกติ	ธวัชชัย
10 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
9 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
8 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
7 th floor	/	/		/	ปกติ	ธวัชชัย
6 th floor	/	/		/	ปกติ	ธวัชชัย
5 th floor	/	/	/	/	ปกติ	ธวัชชัย
4 th floor	/	/	/	Xแบตเตอรี่	เสีย	ธวัชชัย
3 rd floor	/	/	/	Xเครื่องเก่า	เสีย	ธวัชชัย
2 nd floor	/	/		/	ปกติ	ธวัชชัย
Ground floor	/	/		/	ปกติ	ธวัชชัย
Basement floor	/	/			ปกติ	ธวัชชัย
Carpark	/	/			ปกติ	ธวัชชัย

Public Area

Location	Emergency light	Central Batt	Remark	Check By
Administration office		Xแบตเตอรี่	เสีย	ธวัชชัย
Housekeeping office		Xแบตเตอรี่	เสีย	ธวัชชัย
Engineering office		Xแบตเตอรี่	เสีย	ธวัชชัย
Laundry room	/		ปกติ	ธวัชชัย
Canteen	/		ปกติ	ธวัชชัย
Male locker room	/		ปกติ	ธวัชชัย
Female locker room	/		ปกติ	ธวัชชัย
Fitness Center			ไม่มี	ธวัชชัย
In front of guest's lift 14 th floor			ไม่มี	ธวัชชัย

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF March2026

Location	Emergency light			Central Batt	Remark	Check By
	Guest's lift Zone	Staff's lift Zone	Link Zone			
14 th floor	/	/			ปกติ	ธวัชชัย
12 th floor	/	/		/	ปกติ	ธวัชชัย
11 th floor	/	/		/	ปกติ	ธวัชชัย
10 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
9 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
8 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
7 th floor	/	/		/	ปกติ	ธวัชชัย
6 th floor	/	/		/	ปกติ	ธวัชชัย
5 th floor	/	/	/	/	ปกติ	ธวัชชัย
4 th floor	/	/	/	Xแบตเตอรี่	เสีย	ธวัชชัย
3 rd floor	/	/	/	Xเครื่องเก่า	เสีย	ธวัชชัย
2 nd floor	/	/		/	ปกติ	ธวัชชัย
Ground floor	/	/		/	ปกติ	ธวัชชัย
Basement floor	/	/			ปกติ	ธวัชชัย
Carpark	/	/			ปกติ	ธวัชชัย

Plublic Area

Location	Emergency light	Central Batt	Remark	Check By
Administration office		Xแบตเตอรี่	เสีย	ธวัชชัย
Housekeeping office		Xแบตเตอรี่	เสีย	ธวัชชัย
Engineering office		Xแบตเตอรี่	เสีย	ธวัชชัย
Laundry room	/		ปกติ	ธวัชชัย
Canteen	/		ปกติ	ธวัชชัย
Male locker room	/		ปกติ	ธวัชชัย
Female locker room	/		ปกติ	ธวัชชัย
Fitness Center			ไม่มี	ธวัชชัย
In front of guest's lift 14 th floor			ไม่มี	ธวัชชัย

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF April2026

Location	Emergency light			Central Batt	Remark	Check By
	Guest's lift Zone	Staff's lift Zone	Link Zone			
14 th floor	/	/			ปกติ	ธวัชชัย
12 th floor	/	/		/	ปกติ	ธวัชชัย
11 th floor	/	/		/	ปกติ	ธวัชชัย
10 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
9 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
8 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
7 th floor	/	/		/	ปกติ	ธวัชชัย
6 th floor	/	/		/	ปกติ	ธวัชชัย
5 th floor	/	/	/	/	ปกติ	ธวัชชัย
4 th floor	/	/	/	Xแบตเตอรี่	เสีย	ธวัชชัย
3 rd floor	/	/	/	Xเครื่องเก่า	เสีย	ธวัชชัย
2 nd floor	/	/		/	ปกติ	ธวัชชัย
Ground floor	/	/		/	ปกติ	ธวัชชัย
Basement floor	/	/			ปกติ	ธวัชชัย
Carpark	/	/			ปกติ	ธวัชชัย

Public Area

Location	Emergency light	Central Batt	Remark	Check By
Administration office		Xแบตเตอรี่	เสีย	ธวัชชัย
Housekeeping office		Xแบตเตอรี่	เสีย	ธวัชชัย
Engineering office		Xแบตเตอรี่	เสีย	ธวัชชัย
Laundry room	/		ปกติ	ธวัชชัย
Canteen	/		ปกติ	ธวัชชัย
Male locker room	/		ปกติ	ธวัชชัย
Female locker room	/		ปกติ	ธวัชชัย
Fitness Center			ไม่มี	ธวัชชัย
In front of guest's lift 14 th floor			ไม่มี	ธวัชชัย

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF May 2026

Location	Emergency light			Central Batt	Remark	Check By
	Guest's lift Zone	Staff's lift Zone	Link Zone			
14 th floor	/	/			ปกติ	ธวัชชัย
12 th floor	/	/		/	ปกติ	ธวัชชัย
11 th floor	/	/		/	ปกติ	ธวัชชัย
10 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
9 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
8 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
7 th floor	/	/		/	ปกติ	ธวัชชัย
6 th floor	/	/		/	ปกติ	ธวัชชัย
5 th floor	/	/	/	/	ปกติ	ธวัชชัย
4 th floor	/	/	/	Xแบตเตอรี่	เสีย	ธวัชชัย
3 rd floor	/	/	/	Xเครื่องเก่า	เสีย	ธวัชชัย
2 nd floor	/	/		/	ปกติ	ธวัชชัย
Ground floor	/	/		/	ปกติ	ธวัชชัย
Basement floor	/	/			ปกติ	ธวัชชัย
Carpark	/	/			ปกติ	ธวัชชัย

Public Area

Location	Emergency light	Central Batt	Remark	Check By
Administration office		Xแบตเตอรี่	เสีย	ธวัชชัย
Housekeeping office		Xแบตเตอรี่	เสีย	ธวัชชัย
Engineering office		Xแบตเตอรี่	เสีย	ธวัชชัย
Laundry room	/		ปกติ	ธวัชชัย
Canteen	/		ปกติ	ธวัชชัย
Male locker room	/		ปกติ	ธวัชชัย
Female locker room	/		ปกติ	ธวัชชัย
Fitness Center			ไม่มี	ธวัชชัย
In front of guest's lift 14 th floor			ไม่มี	ธวัชชัย

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

MONTHLY EMERGENCY LIGHT TEST FOR DETAIL OF June 2026

Location	Emergency light			Central Batt	Remark	Check By
	Guest's lift Zone	Staff's lift Zone	Link Zone			
14 th floor	/	/			ปกติ	ธวัชชัย
12 th floor	/	/		/	ปกติ	ธวัชชัย
11 th floor	/	/		/	ปกติ	ธวัชชัย
10 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
9 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
8 th floor	/	/		Xแบตเตอรี่	เสีย	ธวัชชัย
7 th floor	/	/		/	ปกติ	ธวัชชัย
6 th floor	/	/		/	ปกติ	ธวัชชัย
5 th floor	/	/	/	/	ปกติ	ธวัชชัย
4 th floor	/	/	/	Xแบตเตอรี่	เสีย	ธวัชชัย
3 rd floor	/	/	/	Xเครื่องเก่า	เสีย	ธวัชชัย
2 nd floor	/	/		/	ปกติ	ธวัชชัย
Ground floor	/	/		/	ปกติ	ธวัชชัย
Basement floor	/	/			ปกติ	ธวัชชัย
Carpark	/	/			ปกติ	ธวัชชัย

Plublic Area

Location	Emergency light	Central Batt	Remark	Check By
Administration office		Xแบตเตอรี่	เสีย	ธวัชชัย
Housekeeping office		Xแบตเตอรี่	เสีย	ธวัชชัย
Engineering office		Xแบตเตอรี่	เสีย	ธวัชชัย
Laundry room	/		ปกติ	ธวัชชัย
Canteen	/		ปกติ	ธวัชชัย
Male locker room	/		ปกติ	ธวัชชัย
Female locker room	/		ปกติ	ธวัชชัย
Fitness Center			ไม่มี	ธวัชชัย
In front of guest's lift 14 th floor			ไม่มี	ธวัชชัย

LOG TEST FIRE ALAM CONTROL SYSTEM 2026

SYSTEM:FIRE PROTECTION

FREQUENCY :WEEKLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 7/1/69

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR1201.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Tast Alarm Smoke Detector Bed Room 1201 PL.12 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....7...../.....1...../.....69.....

DATE:.....7...../.....1...../.....69.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2026

SYSTEM:FIRE PROTECTION

FREQUENCY :WEEKLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 7/2/69

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR1202.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Tast Alarm Smoke Detector Bed Room 1202 PL.12 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....7...../.....2...../.....69.....

DATE:.....7...../.....2...../.....69.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2026

SYSTEM:FIRE PROTECTION

FREQUENCY :WEEKLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 7/3/69

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR1203.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Tast Alarm Smoke Detector Bed Room 1203 PL.12 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....7...../.....3...../.....69.....

DATE:.....7...../.....3...../.....69.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2026

SYSTEM:FIRE PROTECTION

FREQUENCY :WEEKLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 7/4/69

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR1204.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Tast Alarm Smoke Detector Bed Room 1204 PL.12 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....7...../.....4...../.....69.....

DATE:.....7...../.....4...../.....69.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2026

SYSTEM:FIRE PROTECTION

FREQUENCY :WEEKLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 7/5/69

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR1205.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Tast Alarm Smoke Detector Bed Room 1205 PL.12 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....7....../.....5...../.....69.....

DATE:.....7....../.....5...../.....69.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2026

SYSTEM:FIRE PROTECTION

FREQUENCY :WEEKLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 7/6/69

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR1206.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Tast Alarm Smoke Detector Bed Room 1206 PL.12 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....7...../.....6...../.....69.....

DATE:.....7...../.....6...../.....69.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF January 2026						
LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 7/1/69	Remark
	Guest's lift Zone		Staff's lift Zone			
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE	CHECK BY ๕๖๗๘๙	
14 th floor		/	/			
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/					
Laundry room	/					
Administration office	/					
Room control lift		/				
Server room	/					

Remark.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OFFebruary2026						
LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 7/2/69	Remark
	Guest's lift Zone		Staff's lift Zone			
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE	CHECK BY ๕๖๗๘๙	
14 th floor		/	/			
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/					
Laundry room	/					
Administration office	/					
Room control lift		/				
Server room	/					

Remark.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2026

SYSTEM:FIRE PROTECTION

FREQUENCY :WEEKLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 7/3/69

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR1203.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Tast Alarm Smoke Detector Bed Room 1203 PL.12 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....7...../.....3...../.....69.....

DATE:.....7...../.....3...../.....69.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2026

SYSTEM:FIRE PROTECTION

FREQUENCY :WEEKLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 7/4/69

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR1204.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Tast Alarm Smoke Detector Bed Room 1204 PL.12 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....7...../.....4...../.....69.....

DATE:.....7...../.....4...../.....69.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2026

SYSTEM:FIRE PROTECTION

FREQUENCY :WEEKLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 7/5/69

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR1205.....		HEAT DETECTOR		PULL STATION		INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Tast Alarm Smoke Detector Bed Room 1205 PL.12 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....7....../.....5...../.....69.....

DATE:.....7....../.....5...../.....69.....

LOG SHEET FIRE EXTINGUISHERS FOR DETAIL OF June 2026

LOCATION	CHECKING THE FIRE EXTINGUISHERS				DATE: 7/6/69	Remark
	Guest's lift Zone		Staff's lift Zone			
	DRY CHEMICAL	CARBON DIOXIDE	DRY CHEMICAL	CARBON DIOXIDE	CHECK BY ๓๖๖๖๖๖๖๖	
14 th floor		/	/			
12 th floor		/	/			
11 th floor		/	/			
10 th floor		/	/			
9 th floor		/	/			
8 th floor		/	/			
7 th floor		/	/			
6 th floor		/	/			
5 th floor		/	/			
4 th floor		/	/			
3 rd floor		/	/			
2 nd floor		/	/			
Ground floor		/	/			
Basement floor	/					
Laundry room	/					
Administration office	/					
Room control lift		/				
Server room	/					

Remark.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT :Asoke Residence Bangkok Grand Mercure	DATE :7.../...1.../...69.....
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

1	RECORDED LEVEL OF DIESEL OIL :.....458.....LITE	
2	EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M [/] H
3	EXAMINE LEVEL OF WATER IN BOILER:	[] L [] M [/] H
4	EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY:	[] L [] M [/] H
5	RECORDED VOLTAGE OF BATTERY : B1.....14.7.....V B2.....12.5.....V	
6	RECORDED ENGINE WATER TEMPERATURE :.....80.....C'	
7	RECORDED PRESSURE OF LUBRICATING OIL :.....60..... PSI	
8	RECORDED SPEED OF FIRE PUMP :.....1700.....RPM	
9	RECORDED WORK HOUR OF FIRE PUMP :.....000330.....HOUR	
10	EXAMINE AIR FILTER OF FIREPUMP :	[/] NORMAL [] CLEAN [] C
11	EXAMINE LEAKAGE OF OIL PIPE :	[/] NORMAL [] CLEAN [] C
12	TEST THE OPERATION OF CONTROL CABINET:	[/] NORMAL [] ABNORMAL [] CO
13	TEST THE OPERATION OF RELASE VALVE:	[/] NORMAL [] ABNORMAL [] CO
14	TEST THE OPERATION OF CHECK VALVE :	[/] NORMAL [] ABNORMAL [] C
15	EXAMINE CHECK THE TREMBLER OF FIRE PUMP:	[/] NORMAL [] ABNORMAL [] C
16	CLEAN ,FIRE PUMP ,BATTERY AND FUEL TANK :	[/] CLEAN [] NO CLEAN
17	RECORDED PRESSURE OF WATER PIPE :	
17.1	OUTPUT FIRE PUMP PRESSURE :.....250.....PSI	
17.2	OUTPUT JOCKEY PUMP PRESSURE :.....240.....PSI	
18	RELEASE WATER FOR AUTOMATIC TESTED:	
18.1	FIRE PUMP:	START :.....220.....PSI
18.2	JOCKEY PUMP:	START :.....210.....PSI STOP :.....
19		TIME :START.....15.00..... TIME
20		

SUGGESTION / REMARKS.....Manual test Running.....

.....

.....

.....

CHECKED BY :.....

(.....)

DATE :.....7.../...1.../...69.....

APPROVED BY :.....

(.....)

DATE :.....7.../...1.../...69.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT :Asoke Residence Bangkok Grand Mercure	DATE :7.../...2...../...69.....
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

1	RECORDED LEVEL OF DIESEL OIL :.....458.....LITE	
2	EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M [/] H
3	EXAMINE LEVEL OF WATER IN BOILER:	[] L [] M [/] H
4	EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY:	[] L [] M [/] H
5	RECORDED VOLTAGE OF BATTERY : B1.....14.7.....V B2.....12.5.....V	
6	RECORDED ENGINE WATER TEMPERATURE :.....80.....C'	
7	RECORDED PRESSURE OF LUBRICATING OIL :.....60..... PSI	
8	RECORDED SPEED OF FIRE PUMP :.....1700.....RPM	
9	RECORDED WORK HOUR OF FIRE PUMP :.....000330.....HOUR	
10	EXAMINE AIR FILTER OF FIREPUMP :	[/] NORMAL [] CLEAN [] C
11	EXAMINE LEAKAGE OF OIL PIPE :	[/] NORMAL [] CLEAN [] C
12	TEST THE OPERATION OF CONTROL CABINET:	[/] NORMAL [] ABNORMAL [] CO
13	TEST THE OPERATION OF RELASE VALVE:	[/] NORMAL [] ABNORMAL [] CO
14	TEST THE OPERATION OF CHECK VALVE :	[/] NORMAL [] ABNORMAL [] C
15	EXAMINE CHECK THE TREMBLER OF FIRE PUMP:	[/] NORMAL [] ABNORMAL [] C
16	CLEAN ,FIRE PUMP ,BATTERY AND FUEL TANK :	[/] CLEAN [] NO CLEAN
17	RECORDED PRESSURE OF WATER PIPE :	
17.1	OUTPUT FIRE PUMP PRESSURE :.....250.....PSI	
17.2	OUTPUT JOCKEY PUMP PRESSURE :.....240.....PSI	
18	RELEASE WATER FOR AUTOMATIC TESTED:	
18.1	FIRE PUMP:	START :.....220.....PSI
18.2	JOCKEY PUMP:	START :.....210.....PSI STOP :.....
19		TIME :START.....15.00..... TIME
20		

SUGGESTION / REMARKS.....Manual test Running.....

.....

.....

.....

CHECKED BY :.....

(.....)

DATE :.....7.../...2...../...69.....

APPROVED BY :.....

(.....)

DATE :.....7.../...2...../...69.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT :Asoke Residence Bangkok Grand Mercure	DATE :7.../...3...../...69.....
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

1	RECORDED LEVEL OF DIESEL OIL :.....458.....LITE	
2	EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M [/] H
3	EXAMINE LEVEL OF WATER IN BOILER:	[] L [] M [/] H
4	EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY:	[] L [] M [/] H
5	RECORDED VOLTAGE OF BATTERY : B1.....14.7.....V B2.....12.5.....V	
6	RECORDED ENGINE WATER TEMPERATURE :.....80.....C'	
7	RECORDED PRESSURE OF LUBRICATING OIL :.....60..... PSI	
8	RECORDED SPEED OF FIRE PUMP :.....1700.....RPM	
9	RECORDED WORK HOUR OF FIRE PUMP :.....000331.....HOUR	
10	EXAMINE AIR FILTER OF FIREPUMP :	[/] NORMAL [] CLEAN [] C
11	EXAMINE LEAKAGE OF OIL PIPE :	[/] NORMAL [] CLEAN [] C
12	TEST THE OPERATION OF CONTROL CABINET:	[/] NORMAL [] ABNORMAL [] CO
13	TEST THE OPERATION OF RELASE VALVE:	[/] NORMAL [] ABNORMAL [] CO
14	TEST THE OPERATION OF CHECK VALVE :	[/] NORMAL [] ABNORMAL [] C
15	EXAMINE CHECK THE TREMBLER OF FIRE PUMP:	[/] NORMAL [] ABNORMAL [] C
16	CLEAN ,FIRE PUMP ,BATTERY AND FUEL TANK :	[/] CLEAN [] NO CLEAN
17	RECORDED PRESSURE OF WATER PIPE :	
17.1	OUTPUT FIRE PUMP PRESSURE :.....250.....PSI	
17.2	OUTPUT JOCKEY PUMP PRESSURE :.....240.....PSI	
18	RELEASE WATER FOR AUTOMATIC TESTED:	
18.1	FIRE PUMP:	START :.....220.....PSI
18.2	JOCKEY PUMP:	START :.....210.....PSI STOP :.....
19		TIME :START.....15.00..... TIME
20		

SUGGESTION / REMARKS.....Manual test Running.....

.....

.....

.....

CHECKED BY :.....

(.....)

DATE :.....7.../...3...../...69.....

APPROVED BY :.....

(.....)

DATE :.....7.../...3...../...69.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT :Asoke Residence Bangkok Grand Mercure	DATE :7.../...4...../...69.....
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

1	RECORDED LEVEL OF DIESEL OIL :.....458.....LITE	
2	EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M [/] H
3	EXAMINE LEVEL OF WATER IN BOILER:	[] L [] M [/] H
4	EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY:	[] L [] M [/] H
5	RECORDED VOLTAGE OF BATTERY : B1.....14.7.....V B2.....12.5.....V	
6	RECORDED ENGINE WATER TEMPERATURE :.....80.....C'	
7	RECORDED PRESSURE OF LUBRICATING OIL :.....60..... PSI	
8	RECORDED SPEED OF FIRE PUMP :.....1700.....RPM	
9	RECORDED WORK HOUR OF FIRE PUMP :.....000331.....HOUR	
10	EXAMINE AIR FILTER OF FIREPUMP :	[/] NORMAL [] CLEAN [] C
11	EXAMINE LEAKAGE OF OIL PIPE :	[/] NORMAL [] CLEAN [] C
12	TEST THE OPERATION OF CONTROL CABINET:	[/] NORMAL [] ABNORMAL [] C
13	TEST THE OPERATION OF RELASE VALVE:	[/] NORMAL [] ABNORMAL [] C
14	TEST THE OPERATION OF CHECK VALVE :	[/] NORMAL [] ABNORMAL [] C
15	EXAMINE CHECK THE TREMBLER OF FIRE PUMP:	[/] NORMAL [] ABNORMAL [] C
16	CLEAN ,FIRE PUMP ,BATTERY AND FUEL TANK :	[/] CLEAN [] NO CLEAN
17	RECORDED PRESSURE OF WATER PIPE :	
17.1	OUTPUT FIRE PUMP PRESSURE :.....250.....PSI	
17.2	OUTPUT JOCKEY PUMP PRESSURE :.....240.....PSI	
18	RELEASE WATER FOR AUTOMATIC TESTED:	
18.1	FIRE PUMP:	START :.....220.....PSI
18.2	JOCKEY PUMP:	START :.....210.....PSI STOP :.....
19		TIME :START.....15.00..... TIME
20		

SUGGESTION / REMARKS.....Manual test Running.....

.....

.....

.....

CHECKED BY :.....

(.....)

DATE :.....7.../...4...../...69.....

APPROVED BY :.....

(.....)

DATE :.....7.../...4...../...69.....

GRAND MERCURE

BANGKOK ASOKE RESIDENCE

FIRE PROTECTION SYSTEM / LOG SHEET

PROJECT :Asoke Residence Bangkok Grand Mercure	DATE :7.../...5...../...69.....
SYSTEM : FIRE PROTECTION	FREQUENCY : WEEKLY
EQUIPMENT : FIRE PUMP	LOCATION : PUMP ROOM TOWER B.

1	RECORDED LEVEL OF DIESEL OIL :.....458.....LITE	
2	EXAMINE LEVEL OF LUBRICANT OIL :	[] L [] M [/] H
3	EXAMINE LEVEL OF WATER IN BOILER:	[] L [] M [/] H
4	EXAMINE THE WATER LEVEL DISTILLS OF THE BATTERY:	[] L [] M [/] H
5	RECORDED VOLTAGE OF BATTERY : B1.....14.7.....V B2.....12.5.....V	
6	RECORDED ENGINE WATER TEMPERATURE :.....80.....C'	
7	RECORDED PRESSURE OF LUBRICATING OIL :.....60..... PSI	
8	RECORDED SPEED OF FIRE PUMP :.....1700.....RPM	
9	RECORDED WORK HOUR OF FIRE PUMP :.....000331.....HOUR	
10	EXAMINE AIR FILTER OF FIREPUMP :	[/] NORMAL [] CLEAN [] C
11	EXAMINE LEAKAGE OF OIL PIPE :	[/] NORMAL [] CLEAN [] C
12	TEST THE OPERATION OF CONTROL CABINET:	[/] NORMAL [] ABNORMAL [] CO
13	TEST THE OPERATION OF RELASE VALVE:	[/] NORMAL [] ABNORMAL [] CO
14	TEST THE OPERATION OF CHECK VALVE :	[/] NORMAL [] ABNORMAL [] C
15	EXAMINE CHECK THE TREMBLER OF FIRE PUMP:	[/] NORMAL [] ABNORMAL [] C
16	CLEAN ,FIRE PUMP ,BATTERY AND FUEL TANK :	[/] CLEAN [] NO CLEAN
17	RECORDED PRESSURE OF WATER PIPE :	
17.1	OUTPUT FIRE PUMP PRESSURE :.....250.....PSI	
17.2	OUTPUT JOCKEY PUMP PRESSURE :.....240.....PSI	
18	RELEASE WATER FOR AUTOMATIC TESTED:	
18.1	FIRE PUMP:	START :.....220.....PSI
18.2	JOCKEY PUMP:	START :.....210.....PSI STOP :.....
19		TIME :START.....15.00..... TIME
20		

SUGGESTION / REMARKS.....Manual test Running.....

.....

.....

.....

CHECKED BY :.....

(.....)

DATE :.....7.../...5...../...69.....

APPROVED BY :.....

(.....)

DATE :.....7.../...5...../...69.....

LOG TEST FIRE ALAM CONTROL SYSTEM 2026

SYSTEM:FIRE PROTECTION

FREQUENCY :WEEKLY

PROJECT: Grand Mercure Bangkok Asoke Residence

Date: 7/6/69

LOCATION TEST FIRE ALARM CONTROL PANAL SYSTEM

SMOKE DETECTOR1206.....	☐	HEAT DETECTOR	☐	PULL STATION	☐	INSPECTER	REMARK
NORMAL	ABNORMAL	NORMAL	ABNORMAL	NORMAL	ABNORMAL		

Suggestion / Remark.Tast Alarm Smoke Detector Bed Room 1206 PL.12 Bell working Normal

Checked By:.....

Approve By:

(.....)

(.....)

DATE:.....7...../.....6...../.....69.....

DATE:.....7...../.....6...../.....69.....