

ภาคผนวก ค
ใบรายงานผลการวิเคราะห์คุณภาพน้ำสระว่ายนํ้า

- ค 1 ใบรายงานผลวิเคราะห์คุณภาพน้ำสระว่ายนํ้า เดือนมกราคม พ.ศ. 2569
- ค 2 ใบรายงานผลวิเคราะห์คุณภาพน้ำสระว่ายนํ้า เดือนกุมภาพันธ์ พ.ศ. 2569
- ค 3 ใบรายงานผลวิเคราะห์คุณภาพน้ำสระว่ายนํ้า เดือนมีนาคม พ.ศ. 2569
- ค 4 ใบรายงานผลวิเคราะห์คุณภาพน้ำสระว่ายนํ้า เดือนเมษายน พ.ศ. 2569
- ค 5 ใบรายงานผลวิเคราะห์คุณภาพน้ำสระว่ายนํ้า เดือนพฤษภาคม พ.ศ. 2569
- ค 6 ใบรายงานผลวิเคราะห์คุณภาพน้ำสระว่ายนํ้า เดือนมิถุนายน พ.ศ. 2569

ภาคผนวก ค 1
ใบรายงานผลวิเคราะห์คุณภาพน้ำสระว่ายนํ้า
เดือนมกราคม พ.ศ. 2569

ANALYSIS REPORT

PROJECT NAME : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม
โครงการ GRANDE CENTRE POINT PRESTIGE BANGKOK ประจำปี 2569

CUSTOMER NAME : LH MALL & HOTEL COMPANY LIMITED

ADDRESS : 153 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330

CONTACT INFORMATION : TEL : 06 1241 5598 e-mail : Samart.t@gcphotels.com

SAMPLING SOURCE : GRANDE CENTRE POINT PRESTIGE BANGKOK

SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL

SAMPLING DATE : JANUARY 13, 2026

SAMPLING TIME : 13:05 HOUR

SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE

SAMPLING BY ^c : MR SUKSAN BOONLEANG

ANALYZED BY : MISS CHATTRAPORN RATCHANET

RECEIVED DATE : JANUARY 13, 2026

ANALYTICAL DATE : JANUARY 13-18, 2026

ISSUE DATE : JANUARY 20, 2026

REPORT NO. : 2026-U004179

WORK NO. : 2025-007920

ANALYSIS NO. : T26AA546-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			น้ำสระว่ายน้ำส่วนต้น T26AA546-0001			
MICROBIOLOGY						
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1	-
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NOT DETECTED	1.1	-
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR			
SEDIMENT			-			

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.

[REDACTED]

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

PROJECT NAME : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม
โครงการ GRANDE CENTRE POINT PRESTIGE BANGKOK ประจำปี 2569

CUSTOMER NAME : LH MALL & HOTEL COMPANY LIMITED

ADDRESS : 153 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330

CONTACT INFORMATION : TEL : 06 1241 5598 e-mail : Samart.t@gcphotels.com

SAMPLING SOURCE : GRANDE CENTRE POINT PRESTIGE BANGKOK

SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL

SAMPLING DATE : JANUARY 13, 2026

SAMPLING TIME : 13:00 HOUR

SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE

SAMPLING BY ^c : MR SUKSAN BOONLEANG

ANALYZED BY : MISS CHATTRAPORN RATCHANET

RECEIVED DATE : JANUARY 13, 2026

ANALYTICAL DATE : JANUARY 13-18, 2026

ISSUE DATE : JANUARY 20, 2026

REPORT NO. : 2026-U004180

WORK NO. : 2025-007920

ANALYSIS NO. : T26AA546-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			น้ำสรวายน้ำส่วนลึก T26AA546-0002			
MICROBIOLOGY						
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1	-
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NOT DETECTED	1.1	-
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR			
SEDIMENT			-			

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ภาคผนวก ค 2
ใบรายงานผลวิเคราะห์คุณภาพน้ำสระว่ายนํ้า
เดือนกุมภาพันธ์ พ.ศ. 2569

ANALYSIS REPORT

PROJECT NAME : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรฐานการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม
โครงการ GRANDE CENTRE POINT PRESTIGE BANGKOK ประจำปี 2569

CUSTOMER NAME : LH MALL & HOTEL COMPANY LIMITED

ADDRESS : 153 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330

CONTACT INFORMATION : TEL : 06 1241 5598 e-mail : Samart.t@gcphotels.com

SAMPLING SOURCE : GRANDE CENTRE POINT PRESTIGE BANGKOK

SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL

SAMPLING DATE : FEBRUARY 3, 2026

SAMPLING TIME : 13:25 HOUR

SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE

SAMPLING BY ^c : MR SUKSAN BOONLEANG

ANALYZED BY : MR RATCHATA THONGPIYAPOOM

RECEIVED DATE : FEBRUARY 3, 2026

ANALYTICAL DATE : FEBRUARY 3-9, 2026

ISSUE DATE : FEBRUARY 12, 2026

REPORT NO. : 2026-U010718

WORK NO. : 2025-007920

ANALYSIS NO. : T26AC077-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			น้ำสรวายน้ำส่วนต้น T26AC077-0001			
MICROBIOLOGY						
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1	-
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NOT DETECTED	1.1	-
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR			
SEDIMENT			-			

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

PROJECT NAME : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม
โครงการ GRANDE CENTRE POINT PRESTIGE BANGKOK ประจำปี 2569

CUSTOMER NAME : LH MALL & HOTEL COMPANY LIMITED

ADDRESS : 153 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330

CONTACT INFORMATION : TEL : 06 1241 5598 e-mail : Samart.t@gcphotels.com

SAMPLING SOURCE : GRANDE CENTRE POINT PRESTIGE BANGKOK

SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL

SAMPLING DATE : FEBRUARY 3, 2026

SAMPLING TIME : 13:20 HOUR

SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE

SAMPLING BY ^c : MR SUKSAN BOONLEANG

ANALYZED BY : MISS CHATRAPORN RATCHANET

RECEIVED DATE : FEBRUARY 3, 2026

ANALYTICAL DATE : FEBRUARY 3-8, 2026

ISSUE DATE : FEBRUARY 12, 2026

REPORT NO. : 2026-U010720

WORK NO. : 2025-007920

ANALYSIS NO. : T26AC077-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			น้ำสระว้ายน้ำส่วนลึก T26AC077-0002			
MICROBIOLOGY						
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1	-
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NOT DETECTED	1.1	-
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR			
SEDIMENT			-			

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ภาคผนวก ค 3
ใบรายงานผลวิเคราะห์คุณภาพน้ำสระว่ายนํ้า
เดือนมีนาคม พ.ศ. 2569

ANALYSIS REPORT

PROJECT NAME : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม
โครงการ GRANDE CENTRE POINT PRESTIGE BANGKOK ประจำปี 2569
CUSTOMER NAME : LH MALL & HOTEL COMPANY LIMITED
ADDRESS : 153 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330
CONTACT INFORMATION : TEL : 06 1241 5598 e-mail : Samart.t@gcphotels.com
SAMPLING SOURCE : GRANDE CENTRE POINT PRESTIGE BANGKOK
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MARCH 6, 2026
SAMPLING TIME : 14:05 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : MR SUKSAN BOONLEANG
ANALYZED BY : MISS BUSSAKORN MAJAI

RECEIVED DATE : MARCH 6, 2026
ANALYTICAL DATE : MARCH 6-12, 2026
ISSUE DATE : MARCH 17, 2026
REPORT NO. : 2026-U019392
WORK NO. : 2025-007920
ANALYSIS NO. : T26AE645-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรวายน้ำส่วนต้น T26AE645-0001		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NOT DETECTED	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		
			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

PROJECT NAME : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม
โครงการ GRANDE CENTRE POINT PRESTIGE BANGKOK ประจำปี 2569
CUSTOMER NAME : LH MALL & HOTEL COMPANY LIMITED
ADDRESS : 153 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330
CONTACT INFORMATION : TEL : 06 1241 5598 e-mail : Samart.t@gcphotels.com
SAMPLING SOURCE : GRANDE CENTRE POINT PRESTIGE BANGKOK
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MARCH 6, 2026
SAMPLING TIME : 14:00 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : MR SUKSAN BOONLEANG
ANALYZED BY : MISS BUSSAKORN MAJAI
RECEIVED DATE : MARCH 6, 2026
ANALYTICAL DATE : MARCH 6-12, 2026
ISSUE DATE : MARCH 17, 2026
REPORT NO. : 2026-U019393
WORK NO. : 2025-007920
ANALYSIS NO. : T26AE645-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สระบัวน้ำสวนลิก T26AE645-0002		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NOT DETECTED	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR		
SEDIMENT			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ภาคผนวก ค 4
ใบรายงานผลวิเคราะห์คุณภาพน้ำสระว่ายนํ้า
เดือนเมษายน พ.ศ. 2569

ANALYSIS REPORT

PROJECT NAME : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม
โครงการ GRANDE CENTRE POINT PRESTIGE BANGKOK ประจำปี 2569
CUSTOMER NAME : LH MALL & HOTEL COMPANY LIMITED
ADDRESS : 153 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330
CONTACT INFORMATION : TEL : 06 1241 5598 e-mail : Samart.t@gcphotels.com
SAMPLING SOURCE : GRANDE CENTRE POINT PRESTIGE BANGKOK
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : APRIL 3, 2026
SAMPLING TIME : 13:20 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SUKSAN BOONLEANG
ANALYZED BY : MISS JITSAMON NGAMKANA
RECEIVED DATE : APRIL 3, 2026
ANALYTICAL DATE : APRIL 3-10, 2026
ISSUE DATE : APRIL 17, 2026
REPORT NO. : 2026-U029517
WORK NO. : 2025-007920
ANALYSIS NO. : T26AH202-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรุบน้ำส่วนต้น T26AH202-0001		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NOT DETECTED	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

PROJECT NAME : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม
โครงการ GRANDE CENTRE POINT PRESTIGE BANGKOK ประจำปี 2569
CUSTOMER NAME : LH MALL & HOTEL COMPANY LIMITED
ADDRESS : 153 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330
CONTACT INFORMATION : TEL : 06 1241 5598 e-mail : Samart.t@gcphotels.com
SAMPLING SOURCE : GRANDE CENTRE POINT PRESTIGE BANGKOK
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : APRIL 3, 2026
SAMPLING TIME : 13:15 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SUKSAN BOONLEANG
ANALYZED BY : MISS JITSAMON NGAMKANA
RECEIVED DATE : APRIL 3, 2026
ANALYTICAL DATE : APRIL 3-10, 2026
ISSUE DATE : APRIL 17, 2026
REPORT NO. : 2026-U029518
WORK NO. : 2025-007920
ANALYSIS NO. : T26AH202-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรุบน้ำส่วนลึก T26AH202-0002		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NOT DETECTED	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR		
SEDIMENT			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.

[Redacted Signature]

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ภาคผนวก ค 5
ใบรายงานผลวิเคราะห์คุณภาพน้ำสระว่ายนํ้า
เดือนพฤษภาคม พ.ศ. 2569

ANALYSIS REPORT

PROJECT NAME : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม
โครงการ GRANDE CENTRE POINT PRESTIGE BANGKOK ประจำปี 2569

CUSTOMER NAME : LH MALL & HOTEL COMPANY LIMITED

ADDRESS : 153 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330

CONTACT INFORMATION : TEL : 06 1241 5598 e-mail : Samart.t@gcphotels.com

SAMPLING SOURCE : GRANDE CENTRE POINT PRESTIGE BANGKOK

SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL

SAMPLING DATE : MAY 5, 2026

SAMPLING TIME : 13:20 HOUR

SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE

SAMPLING BY ^c : MR SUKSAN BOONLEANG

ANALYZED BY : MISS CHATTRAPORN RATCHANET

RECEIVED DATE : MAY 5, 2026

ANALYTICAL DATE : MAY 5-10, 2026

ISSUE DATE : MAY 15, 2026

REPORT NO. : 2026-U039057

WORK NO. : 2025-007920

ANALYSIS NO. : T26AJ460-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรวายน้ำส่วนต้น T26AJ460-0001		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NOT DETECTED	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR		
SEDIMENT			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.

[Redacted Signature]

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

PROJECT NAME : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรฐานการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม
โครงการ GRANDE CENTRE POINT PRESTIGE BANGKOK ประจำปี 2569
CUSTOMER NAME : LH MALL & HOTEL COMPANY LIMITED
ADDRESS : 153 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330
CONTACT INFORMATION : TEL : 06 1241 5598 e-mail : Samart.t@gcphotels.com
SAMPLING SOURCE : GRANDE CENTRE POINT PRESTIGE BANGKOK
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 5, 2026
SAMPLING TIME : 13:15 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SUKSAN BOONLEANG
ANALYZED BY : MISS CHATTRAPORN RATCHANET

RECEIVED DATE : MAY 5, 2026
ANALYTICAL DATE : MAY 5-10, 2026
ISSUE DATE : MAY 15, 2026
REPORT NO. : 2026-U039058
WORK NO. : 2025-007920
ANALYSIS NO. : T26AJ460-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรุบน้ำส่วนลึก T26AJ460-0002		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NOT DETECTED	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR		
SEDIMENT			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ภาคผนวก ค 6
ใบรายงานผลวิเคราะห์คุณภาพน้ำสระว่ายนํ้า
เดือนมิถุนายน พ.ศ. 2569

ANALYSIS REPORT

PROJECT NAME : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรฐานการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม
โครงการ GRANDE CENTRE POINT PRESTIGE BANGKOK ประจำปี 2569
CUSTOMER NAME : LH MALL & HOTEL COMPANY LIMITED
ADDRESS : 153 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330
CONTACT INFORMATION : TEL : 06 1241 5598 e-mail : Samart.t@gcphotels.com
SAMPLING SOURCE : GRANDE CENTRE POINT PRESTIGE BANGKOK
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JUNE 9, 2026
SAMPLING TIME : 14:35 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SUKSAN BOONLEANG
ANALYZED BY : MISS SUJIRA PRASERTSUKHO

RECEIVED DATE : JUNE 9, 2026
ANALYTICAL DATE : JUNE 9-16, 2026
ISSUE DATE : JUNE 18, 2026
REPORT NO. : 2026-U052787
WORK NO. : 2025-007920
ANALYSIS NO. : T26AM661-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรุบน้ำส่วนต้น T26AM661-0001		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NOT DETECTED	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR		
SEDIMENT			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.

[Redacted Signature]

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

PROJECT NAME : การตรวจวัดคุณภาพสิ่งแวดล้อม และการตรวจสอบการปฏิบัติตามมาตรการป้องกันและแก้ไขผลกระทบสิ่งแวดล้อม
โครงการ GRANDE CENTRE POINT PRESTIGE BANGKOK ประจำปี 2569
CUSTOMER NAME : LH MALL & HOTEL COMPANY LIMITED
ADDRESS : 153 RATCHADAMRI ROAD LUMPHINI PATHUM WAN BANGKOK 10330
CONTACT INFORMATION : TEL : 06 1241 5598 e-mail : Samart.t@gcphotels.com
SAMPLING SOURCE : GRANDE CENTRE POINT PRESTIGE BANGKOK
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JUNE 9, 2026
SAMPLING TIME : 14:30 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : MR SUKSAN BOONLEANG
ANALYZED BY : MISS CHATTRAPORN RATCHANET
RECEIVED DATE : JUNE 9, 2026
ANALYTICAL DATE : JUNE 9-16, 2026
ISSUE DATE : JUNE 18, 2026
REPORT NO. : 2026-U052789
WORK NO. : 2025-007920
ANALYSIS NO. : T26AM661-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรุบน้ำส่วนลึก T26AM661-0002		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	NOT DETECTED	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR		
SEDIMENT			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RECOMMENDATIONS OF PUBLIC HEALTH COMMITTEE NO. 1/2550; CONTROL OF SWIMMING POOLS BUSINESSES OR OTHER SIMILAR BUSINESSES.

< 1.1 : LESS THAN 1.1 MPN/100 mL MEANS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

