

ภาคผนวก ค

สำเนาใบรายงานผลวิเคราะห์ (Analysis Report)

ภาคผนวก ค-1

คุณภาพอากาศ

ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE

CUSTOMER NAME : PTT LNG COMPANY LIMITED

ADDRESS :

CONTACT INFORMATION :

SAMPLING SOURCE : วัดดาวนกคงคาราม

SAMPLE TYPE : AMBIENT

SAMPLING DATE : *, **, ***

SAMPLING TIME : *, **, ***

SAMPLING BY :

ANALYZED BY :

RECEIVED DATE : MARCH 31, 2026

ANALYTICAL DATE : MARCH 31 - APRIL 3, 2026

ISSUE DATE : APRIL 9, 2026

REPORT NO. : 2026-U027810

WORK NO. : 2025-010629

ANALYSIS NO. : T26AG824-0001 - T26AG824-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		
			วัดดาวนกคงคาราม		
			* T26AG824-0001	** T26AG824-0002	*** T26AG824-0003
TOTAL SUSPENDED PARTICULATE MATTER ^a	µg/m ³	US EPA, CODE OF FEDERAL REGULATIONS, 40 CFR CHAPTER I-PART 50 APPENDIX B, REFERENCE METHOD FOR THE DETERMINATION OF SUSPENDED PARTICULATE MATTER IN THE ATMOSPHERE (HIGH-VOLUME METHOD) REVISED AS OF JULY 1, 2021.	31.4	32.9	34.7
PARTICULATE MATTER as PM10 (≤ 10 µm) ^a	µg/m ³	US EPA, CODE OF FEDERAL REGULATIONS, 40 CFR CHAPTER I-PART 50 APPENDIX J, REFERENCE METHOD FOR THE DETERMINATION OF PARTICULATE MATTER AS PM10 IN THE ATMOSPHERE (HIGH-VOLUME METHOD) REVISED AS OF JULY 1, 2021.	20.9	20.3	22.9
SAMPLE CONDITION			COMPLETE	COMPLETE	COMPLETE

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)


REMARK

TSP, PM10 : REFERENCE CONDITION IS 25 DEGREE CELSIUS AT 1 ATMOSPHERE.

* : SAMPLING FROM 09:00 HOUR ON MARCH 21, 2026 TO 09:00 HOUR ON MARCH 22, 2026.

** : SAMPLING FROM 09:00 HOUR ON MARCH 22, 2026 TO 09:00 HOUR ON MARCH 23, 2026.

*** : SAMPLING FROM 09:00 HOUR ON MARCH 23, 2026 TO 09:00 HOUR ON MARCH 24, 2026.



ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE

CUSTOMER NAME : PTT LNG COMPANY LIMITED

ADDRESS :

CONTACT INFORMATION :

SAMPLING SOURCE : วัดดาวนคดคาราม

SAMPLE TYPE : AMBIENT

SAMPLING DATE : * ** *** ****

SAMPLING TIME : * ** *** ****

SAMPLING BY :

ANALYZED BY :

RECEIVED DATE : MARCH 31, 2026

ANALYTICAL DATE : MARCH 31 - APRIL 3, 2026

ISSUE DATE : APRIL 9, 2026

REPORT NO. : 2026-U027815

WORK NO. : 2025-010629

ANALYSIS NO. : T26AG824-0004 - T26AG824-0007

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT			
			วัดดาวนคดคาราม			
			* T26AG824-0004	** T26AG824-0005	*** T26AG824-0006	**** T26AG824-0007
TOTAL SUSPENDED PARTICULATE MATTER ^a	µg/m ³	US EPA, CODE OF FEDERAL REGULATIONS, 40 CFR CHAPTER I-PART 50 APPENDIX B, REFERENCE METHOD FOR THE DETERMINATION OF SUSPENDED PARTICULATE MATTER IN THE ATMOSPHERE (HIGH-VOLUME METHOD) REVISED AS OF JULY 1, 2021.	36.0	34.1	38.9	35.7
PARTICULATE MATTER as PM10 (≤ 10 µm) ^a	µg/m ³	US EPA, CODE OF FEDERAL REGULATIONS, 40 CFR CHAPTER I-PART 50 APPENDIX J, REFERENCE METHOD FOR THE DETERMINATION OF PARTICULATE MATTER AS PM10 IN THE ATMOSPHERE (HIGH-VOLUME METHOD) REVISED AS OF JULY 1, 2021.	23.2	21.1	26.0	24.2
SAMPLE CONDITION			COMPLETE	COMPLETE	COMPLETE	COMPLETE

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

REMARK

TSP, PM10 : REFERENCE CONDITION IS 25 DEGREE CELSIUS AT 1 ATMOSPHERE.

* : SAMPLING FROM 09:00 HOUR ON MARCH 24, 2026 TO 09:00 HOUR ON MARCH 25, 2026.

** : SAMPLING FROM 09:00 HOUR ON MARCH 25, 2026 TO 09:00 HOUR ON MARCH 26, 2026.

*** : SAMPLING FROM 09:00 HOUR ON MARCH 26, 2026 TO 09:00 HOUR ON MARCH 27, 2026.

**** : SAMPLING FROM 09:00 HOUR ON MARCH 27, 2026 TO 09:00 HOUR ON MARCH 28, 2026.

ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE

CUSTOMER NAME : PTT LNG COMPANY LIMITED

ADDRESS :

CONTACT INFORMATION :

MEASURING PLACE : วัดตากวนคงคาราม

MEASURING TYPE : AMBIENT (AIR)

MEASURING DATE : MARCH 21-28, 2026

MEASURING TIME : *

MEASURING METHOD :

MEASURED BY :

RECEIVED DATE : MARCH 21-28, 2026

ANALYTICAL DATE : MARCH 21-28, 2026

ISSUE DATE : APRIL 10, 2026

REPORT NO. : 2026-U028006

WORK NO. : 2025-010629

ANALYSIS NO. : T26AG824-0001 - T26AG824-0007

TIME *	RESULT (ppb)		
	NITROGEN DIOXIDE		
	วัดตากวนคงคาราม		
	MARCH 21 - 22, 2026 T26AG824-0001	MARCH 22 - 23, 2026 T26AG824-0002	MARCH 23 - 24, 2026 T26AG824-0003
07:00-08:00 HOUR	21.7	21.9	24.6
08:00-09:00 HOUR	21.9	20.7	21.9
09:00-10:00 HOUR	17.9	18.0	18.1
10:00-11:00 HOUR	17.2	16.2	16.1
11:00-12:00 HOUR	16.0	14.9	16.7
12:00-13:00 HOUR	15.4	13.8	18.0
13:00-14:00 HOUR	17.1	13.7	19.2
14:00-15:00 HOUR	17.6	15.6	19.8
15:00-16:00 HOUR	21.1	18.2	21.0
16:00-17:00 HOUR	22.0	20.6	23.0
17:00-18:00 HOUR	24.4	20.8	24.2
18:00-19:00 HOUR	24.3	21.7	25.3
19:00-20:00 HOUR	25.3	21.8	24.6
20:00-21:00 HOUR	24.8	22.0	23.0
21:00-22:00 HOUR	23.4	20.9	22.1
22:00-23:00 HOUR	22.2	20.8	21.7
23:00-00:00 HOUR	20.8	20.1	21.2
00:00-01:00 HOUR	19.4	20.7	20.7
01:00-02:00 HOUR	19.0	20.2	21.0
02:00-03:00 HOUR	19.0	20.9	21.2
03:00-04:00 HOUR	19.7	22.2	20.4
04:00-05:00 HOUR	21.2	23.0	20.6
05:00-06:00 HOUR	21.8	24.9	23.6
06:00-07:00 HOUR	23.4	24.9	24.6



TIME *	RESULT (ppb)			
	NITROGEN DIOXIDE			
	วัดดาวมงคลาราม			
	MARCH 24 - 25, 2026 T26AG824-0004	MARCH 25 - 26, 2026 T26AG824-0005	MARCH 26 - 27, 2026 T26AG824-0006	MARCH 27 - 28, 2026 T26AG824-0007
07:00-08:00 HOUR	24.8	21.5	22.3	22.7
08:00-09:00 HOUR	21.8	18.8	21.0	20.5
09:00-10:00 HOUR	20.1	15.3	16.8	17.8
10:00-11:00 HOUR	17.9	14.9	15.3	16.5
11:00-12:00 HOUR	18.1	15.7	14.8	16.6
12:00-13:00 HOUR	17.3	17.3	15.4	17.2
13:00-14:00 HOUR	18.3	19.3	18.0	19.2
14:00-15:00 HOUR	19.2	20.2	19.5	20.1
15:00-16:00 HOUR	22.6	22.1	22.1	21.3
16:00-17:00 HOUR	23.0	23.0	24.1	21.0
17:00-18:00 HOUR	22.2	24.0	24.1	20.8
18:00-19:00 HOUR	20.9	23.4	23.2	20.7
19:00-20:00 HOUR	21.0	22.0	21.3	22.1
20:00-21:00 HOUR	20.0	20.9	22.4	20.7
21:00-22:00 HOUR	19.4	20.4	22.8	19.8
22:00-23:00 HOUR	18.2	21.6	21.7	18.8
23:00-00:00 HOUR	18.9	22.6	19.9	18.9
00:00-01:00 HOUR	17.8	23.1	18.5	18.6
01:00-02:00 HOUR	17.0	23.1	18.8	18.6
02:00-03:00 HOUR	16.1	21.9	18.6	19.1
03:00-04:00 HOUR	17.0	21.7	17.3	19.9
04:00-05:00 HOUR	19.6	21.7	18.7	21.0
05:00-06:00 HOUR	21.9	22.3	21.0	21.9
06:00-07:00 HOUR	23.6	24.5	24.1	24.2

ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE
CUSTOMER NAME : PTT LNG COMPANY LIMITED
ADDRESS :
CONTACT INFORMATION :
MEASURING PLACE : วัดตากวนคงคาราม
MEASURING TYPE : AMBIENT (AIR)
MEASURING DATE : MARCH 21-28, 2026
MEASURING TIME : *
MEASURING METHOD :
MEASURED BY :
RECEIVED DATE : MARCH 21-28, 2026
ANALYTICAL DATE : MARCH 21-28, 2026
ISSUE DATE : APRIL 10, 2026
REPORT NO. : 2026-U028008
WORK NO. : 2025-010629
ANALYSIS NO. : T26AG824-0001 - T26AG824-0007

TIME *	RESULT (ppb)		
	SULPHUR DIOXIDE		
	วัดตากวนคงคาราม		
	MARCH 21 - 22, 2026 T26AG824-0001	MARCH 22 - 23, 2026 T26AG824-0002	MARCH 23 - 24, 2026 T26AG824-0003
07:00-08:00 HOUR	4.9	4.8	5.2
08:00-09:00 HOUR	4.5	4.0	5.3
09:00-10:00 HOUR	4.2	3.6	4.9
10:00-11:00 HOUR	4.5	3.5	4.6
11:00-12:00 HOUR	4.7	3.5	5.1
12:00-13:00 HOUR	5.4	3.6	5.5
13:00-14:00 HOUR	6.4	4.4	5.8
14:00-15:00 HOUR	7.1	5.4	5.4
15:00-16:00 HOUR	7.3	5.9	5.7
16:00-17:00 HOUR	7.4	5.7	6.0
17:00-18:00 HOUR	7.2	5.6	6.0
18:00-19:00 HOUR	7.9	6.0	6.2
19:00-20:00 HOUR	7.6	5.9	5.7
20:00-21:00 HOUR	7.8	5.3	6.0
21:00-22:00 HOUR	7.1	4.5	5.9
22:00-23:00 HOUR	6.1	3.9	5.7
23:00-00:00 HOUR	5.0	3.6	4.9
00:00-01:00 HOUR	4.2	3.5	4.3
01:00-02:00 HOUR	4.5	3.9	4.8
02:00-03:00 HOUR	5.0	4.7	5.9
03:00-04:00 HOUR	6.1	5.4	6.8
04:00-05:00 HOUR	6.4	6.2	6.8
05:00-06:00 HOUR	6.4	5.9	6.9
06:00-07:00 HOUR	5.5	5.6	6.1
AVERAGE 24 HOUR	6.0	4.8	5.6



TIME *	RESULT (ppb)			
	SULPHUR DIOXIDE			
	วัดถาวรคงคาราม			
	MARCH 24 - 25, 2026 T26AG824-0004	MARCH 25 - 26, 2026 T26AG824-0005	MARCH 26 - 27, 2026 T26AG824-0006	MARCH 27 - 28, 2026 T26AG824-0007
07:00-08:00 HOUR	5.6	5.3	4.9	5.6
08:00-09:00 HOUR	4.8	4.7	3.8	4.5
09:00-10:00 HOUR	4.8	3.7	3.3	3.9
10:00-11:00 HOUR	4.6	3.6	3.1	4.2
11:00-12:00 HOUR	4.4	3.3	3.4	4.6
12:00-13:00 HOUR	4.0	3.6	4.0	4.7
13:00-14:00 HOUR	4.6	4.0	5.0	4.8
14:00-15:00 HOUR	5.5	4.9	5.1	5.2
15:00-16:00 HOUR	6.3	5.6	6.0	5.5
16:00-17:00 HOUR	6.4	6.2	6.3	5.6
17:00-18:00 HOUR	6.2	6.2	7.2	5.5
18:00-19:00 HOUR	5.8	5.9	6.7	5.7
19:00-20:00 HOUR	5.4	4.9	6.1	6.0
20:00-21:00 HOUR	5.1	4.8	5.4	5.9
21:00-22:00 HOUR	4.5	4.9	5.0	6.1
22:00-23:00 HOUR	4.8	5.1	5.3	6.3
23:00-00:00 HOUR	4.3	4.7	5.0	6.8
00:00-01:00 HOUR	4.6	4.8	5.2	7.0
01:00-02:00 HOUR	4.6	4.6	4.8	7.0
02:00-03:00 HOUR	5.5	5.1	5.3	6.5
03:00-04:00 HOUR	6.0	5.0	5.4	6.3
04:00-05:00 HOUR	6.0	5.3	5.8	5.7
05:00-06:00 HOUR	5.7	5.6	6.1	5.9
06:00-07:00 HOUR	5.6	5.5	6.2	4.9
AVERAGE 24 HOUR	5.2	4.9	5.2	5.6

ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE

CUSTOMER NAME : PTT LNG COMPANY LIMITED

ADDRESS :

CONTACT INFORMATION :

MEASURING PLACE :

MEASURING TYPE : AMBIENT (AIR)

MEASURING DATE : MARCH 21-28, 2026

MEASURING TIME : *

MEASURING METHOD : WIND SPEED & WIND DIRECTION EQUIPMENT

MEASURED BY :

RECEIVED DATE : MARCH 21-28, 2026

ANALYTICAL DATE : MARCH 21-28, 2026

ISSUE DATE : APRIL 10, 2026

REPORT NO. : 2026-U028009

WORK NO. : 2025-010629

ANALYSIS NO. : T26AG824-0001 - T26AG824-0007

TIME *	RESULT (m/s)					
	วัดดาวกวนคงคาราม					
	MARCH 21 - 22, 2026 T26AG824-0001		MARCH 22 - 23, 2026 T26AG824-0002		MARCH 23 - 24, 2026 T26AG824-0003	
	WIND SPEED	WIND DIRECTION	WIND SPEED	WIND DIRECTION	WIND SPEED	WIND DIRECTION
07:00-08:00 HOUR	1.9	S	2.4	SSW	0.8	SSE
08:00-09:00 HOUR	1.4	SSW	2.5	SW	1.0	S
09:00-10:00 HOUR	1.1	S	1.7	SSE	1.1	SSW
10:00-11:00 HOUR	1.2	S	1.5	SSE	1.1	SW
11:00-12:00 HOUR	0.8	SE	2.1	S	1.1	SSW
12:00-13:00 HOUR	0.7	SE	2.5	SE	0.9	SSW
13:00-14:00 HOUR	1.1	ESE	2.8	ESE	1.2	SE
14:00-15:00 HOUR	1.3	SE	3.3	ESE	0.9	SSE
15:00-16:00 HOUR	1.4	SE	3.4	ESE	1.2	SE
16:00-17:00 HOUR	1.5	SE	3.4	SE	0.9	SSE
17:00-18:00 HOUR	1.9	SE	2.0	SE	0.8	SSE
18:00-19:00 HOUR	2.1	SE	2.5	ESE	1.1	SE
19:00-20:00 HOUR	1.8	SE	2.1	SE	1.4	SE
20:00-21:00 HOUR	2.0	ESE	1.7	SE	1.5	SE
21:00-22:00 HOUR	2.9	SE	1.8	SSE	1.7	S
22:00-23:00 HOUR	2.3	ESE	1.1	ESE	2.5	SSW
23:00-00:00 HOUR	2.9	SSE	1.1	SSE	2.3	SSW
00:00-01:00 HOUR	2.2	SW	1.2	SSE	3.5	SSW
01:00-02:00 HOUR	3.1	SW	1.2	SE	2.4	SSW
02:00-03:00 HOUR	3.0	SW	1.1	SE	2.5	S
03:00-04:00 HOUR	2.7	SSW	1.2	SSE	2.0	S
04:00-05:00 HOUR	3.7	SW	1.2	S	2.4	S
05:00-06:00 HOUR	3.4	SSW	1.1	S	1.5	S
06:00-07:00 HOUR	2.4	SSW	1.0	SSW	1.7	SSW



TIME *	RESULT (m/s)							
	วัดดาวมงคลคาราม							
	MARCH 24 - 25, 2026		MARCH 25 - 26, 2026		MARCH 26 - 27, 2026		MARCH 27 - 28, 2026	
	T26AG824-0004		T26AG824-0005		T26AG824-0006		T26AG824-0007	
	WIND SPEED	WIND DIRECTION	WIND SPEED	WIND DIRECTION	WIND SPEED	WIND DIRECTION	WIND SPEED	WIND DIRECTION
07:00-08:00 HOUR	2.3	SSW	1.7	ESE	2.1	S	3.4	SE
08:00-09:00 HOUR	1.7	SSW	2.5	E	1.6	SE	2.7	S
09:00-10:00 HOUR	1.8	S	2.4	ESE	1.6	SSE	2.4	SSW
10:00-11:00 HOUR	2.5	SSW	2.9	SE	1.5	SSE	1.8	SSW
11:00-12:00 HOUR	3.2	S	2.1	SE	1.2	SSE	1.8	SSW
12:00-13:00 HOUR	3.1	SSW	2.3	SSE	0.7	S	2.1	S
13:00-14:00 HOUR	2.9	S	1.3	SSE	1.1	SE	2.3	SW
14:00-15:00 HOUR	3.7	SSE	1.4	S	1.3	SSE	2.1	SSW
15:00-16:00 HOUR	3.6	SW	0.8	S	1.3	SSW	2.1	S
16:00-17:00 HOUR	3.7	S	0.8	SSW	2.0	SSE	1.4	S
17:00-18:00 HOUR	3.6	S	0.9	S	1.4	SSE	1.7	S
18:00-19:00 HOUR	2.9	SSW	1.2	S	1.7	S	1.0	SSE
19:00-20:00 HOUR	3.0	S	1.3	SSE	1.3	SSE	0.7	SSE
20:00-21:00 HOUR	2.5	S	1.0	SSE	1.9	SW	0.9	SE
21:00-22:00 HOUR	2.4	SSW	1.0	SSE	2.2	S	1.3	SE
22:00-23:00 HOUR	2.3	SSW	0.8	S	1.9	SSW	0.9	SE
23:00-00:00 HOUR	1.5	SW	1.2	SSE	1.8	SSW	0.7	ESE
00:00-01:00 HOUR	1.0	S	0.9	S	2.8	SSW	0.8	SSE
01:00-02:00 HOUR	0.9	SSW	1.1	SSW	2.8	SSW	1.0	ESE
02:00-03:00 HOUR	1.0	SE	1.0	S	2.8	S	1.0	ESE
03:00-04:00 HOUR	1.0	SSW	1.2	SSW	3.1	S	1.1	E
04:00-05:00 HOUR	0.7	SSE	1.4	S	3.0	SW	1.2	ESE
05:00-06:00 HOUR	0.9	ESE	2.7	SSE	2.9	SE	0.7	E
06:00-07:00 HOUR	1.7	ESE	2.4	SSE	2.2	SSE	0.8	E



ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE

CUSTOMER NAME : PTT LNG COMPANY LIMITED

ADDRESS :

CONTACT INFORMATION :

SAMPLING SOURCE : PTT LNG COMPANY LIMITED

SAMPLE TYPE : STACK

SAMPLING DATE : MARCH 23, 2026

SAMPLING TIME : 12:15-12:57 HOUR

SAMPLING BY :

ANALYZED BY :

RECEIVED DATE : MARCH 24, 2026

ANALYTICAL DATE : MARCH 24-30, 2026

ISSUE DATE : MARCH 31, 2026

REPORT NO. : 2026-U025150

WORK NO. : 2025-010629

ANALYSIS NO. : T26AG219-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	
			COMMON STACK UNIT B T26AG219-0001	
			ACTUAL OXYGEN	7% OXYGEN
TOTAL SUSPENDED PARTICULATE	mg/m ³	ISOKINETIC, GRAVIMETRIC METHOD (US EPA METHOD 5)	2.23	6.31
SAMPLE CONDITION			COMPLETE	

REMARK

RESULT : REFERENCE CONDITION IS 25 DEGREE CELSIUS AT 1 ATMOSPHERE AND DRY BASIS.



ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE

CUSTOMER NAME : PTT LNG COMPANY LIMITED

ADDRESS :

CONTACT INFORMATION :

MEASURING SOURCE : PTT LNG COMPANY LIMITED

MEASURING TYPE : STACK

MEASURING DATE : MARCH 23, 2026

MEASURING TIME : 12:18-12:28 HOUR

MEASURING METHOD : U.S. EPA METHOD 6C, 7E

MEASURED BY :

RECEIVED DATE : MARCH 23, 2026

ANALYTICAL DATE : MARCH 23, 2026

ISSUE DATE : MARCH 31, 2026

REPORT NO. : 2026-U025152

WORK NO. : 2025-010629

ANALYSIS NO. : T26AG219-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	
			COMMON STACK UNIT B T26AG219-0001	
			ACTUAL OXYGEN	7% OXYGEN
SULPHUR DIOXIDE	ppm	U.S. EPA, CODE OF FEDERAL REGULATIONS, 40 CFR PART 60 APPENDIX A, METHOD 6C, JULY 2021	< 1	< 1
OXIDES OF NITROGEN AS NITROGEN DIOXIDE	ppm	U.S. EPA, CODE OF FEDERAL REGULATIONS, 40 CFR PART 60 APPENDIX A, METHOD 7E, JULY 2021	6	17
SAMPLE CONDITION			COMPLETE	

REMARK

RESULT : REFERENCE CONDITION IS 25 DEGREE CELSIUS AT 1 ATMOSPHERE AND DRY BASIS.



ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE

CUSTOMER NAME : PTT LNG COMPANY LIMITED

ADDRESS :

CONTACT INFORMATION :

SAMPLING SOURCE : PTT LNG COMPANY LIMITED

SAMPLE TYPE : STACK

SAMPLING DATE : MARCH 23, 2026

SAMPLING TIME : 12:30-12:50 HOUR

SAMPLING BY : MR KANNIKORN RASO ๖-145-๖-0037

ANALYZED BY : MISS SUWAN KONGTHONG ๖-145-๘-0025

RECEIVED DATE : MARCH 23, 2026

ANALYTICAL DATE : MARCH 23, 2026

ISSUE DATE : MARCH 31, 2026

REPORT NO. : 2026-U025151

WORK NO. : 2025-010629

ANALYSIS NO. : T26AG219-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	
			COMMON STACK UNIT B T26AG219-0001	
			ACTUAL OXYGEN	7% OXYGEN
SULPHUR DIOXIDE	ppm	ABSORPTION, BARIUM-THORIN TITRIMETRIC METHOD AT SITE (US EPA METHOD 6)	< 1.30	< 1.30
SAMPLE CONDITION			COMPLETE	

REMARK

RESULT : REFERENCE CONDITION IS 25 DEGREE CELSIUS AT 1 ATMOSPHERE AND DRY BASIS.



ISO 9001
Quality
Management
Systems
CERTIFIED

ISO 14001
Environmental
Management
CERTIFIED

ISO 45001
Occupational
Health and Safety
Management
CERTIFIED

- PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
- THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.



ภาคผนวก ค-2

ระดับเสียง

ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE
CUSTOMER NAME : PTT LNG COMPANY LIMITED
ADDRESS :
CONTACT INFORMATION :
MEASURING SOURCE : บริเวณเครื่องกังหันก๊าซ
MEASURING TYPE : AMBIENT (NOISE)
MEASURING DATE : MARCH 27-28, 2026
MEASURING TIME : *
MEASURING METHOD : INTEGRATED SOUND LEVEL METER **
MEASURED BY :
RECEIVED DATE : MARCH 27-28, 2026
ANALYTICAL DATE : MARCH 27-28, 2026
ISSUE DATE : APRIL 10, 2026
REPORT NO. : 2026-U028010
WORK NO. : 2025-010629
ANALYSIS NO. : T26AG825-0001

TIME*	RESULT dB(A)		
	บริเวณเครื่องกังหันก๊าซ		
	MARCH 27 - 28, 2026		
	T26AG825-0001		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{Aeq} 8 hours
07:00-08:00 HOUR	65.9	74.0	-
08:00-09:00 HOUR	66.4	71.6	-
09:00-10:00 HOUR	67.3	71.5	-
10:00-11:00 HOUR	65.9	70.4	-
11:00-12:00 HOUR	69.3	80.0	-
12:00-13:00 HOUR	69.5	77.3	-
13:00-14:00 HOUR	65.6	70.7	-
14:00-15:00 HOUR	65.6	72.1	67.2
15:00-16:00 HOUR	65.4	69.6	-
16:00-17:00 HOUR	65.4	68.9	-
17:00-18:00 HOUR	65.5	68.8	-
18:00-19:00 HOUR	65.6	68.8	-
19:00-20:00 HOUR	65.6	69.3	-
20:00-21:00 HOUR	65.7	68.9	-
21:00-22:00 HOUR	65.7	68.6	-
22:00-23:00 HOUR	65.7	67.9	65.6
23:00-00:00 HOUR	65.8	68.5	-
00:00-01:00 HOUR	65.9	68.1	-
01:00-02:00 HOUR	65.0	69.1	-
02:00-03:00 HOUR	68.1	72.7	-
03:00-04:00 HOUR	67.5	71.8	-
04:00-05:00 HOUR	66.5	70.5	-
05:00-06:00 HOUR	67.1	71.1	-
06:00-07:00 HOUR	64.1	68.4	66.4
L _{Aeq} 24 hours		66.5	



REMARK :

** ISO 1996-2: 2017


** NOTIFICATION OF THE NATIONAL ENVIRONMENT BOARD NO. 15 (B.E. 2540) ON ENVIRONMENTAL NOISE STANDARDS, DATED 12 MARCH 1997

** NOTIFICATION OF THE POLLUTION CONTROL DEPARTMENT (B.E. 2540) ON METHODS FOR NOISE LEVEL CALCULATION,
DATED 11 AUGUST 1997

** NOTIFICATION OF THE MINISTRY OF NATURAL RESOURCES AND ENVIRONMENT ON STANDARDS FOR CONTROL OF NOISE AND VIBRATION,
DATED 7 NOVEMBER 2005

** NOTIFICATION OF THE DEPARTMENT OF INDUSTRIAL WORKS ON METHODS FOR MEASUREMENT OF ANNOYANCE NOISE LEVEL, 24-HOUR
EQUIVALENT CONTINUOUS SOUND LEVEL, AND MAXIMUM SOUND LEVEL FROM INDUSTRIAL OPERATIONS, B.E. 2553,
DATED 20 DECEMBER 2010

** NOTIFICATION OF THE MINISTRY OF INDUSTRY ON STANDARDS FOR CONTROL OF NOISE FROM MINING, MINERAL DRESSING,
AND METALLURGICAL ACTIVITIES, AND VIBRATION FROM THE USE OF EXPLOSIVES IN MINING ACTIVITIES, B.E. 2567 (2024)



ISO 9001
Quality
Management
Systems
CERTIFIED

ISO 14001
Environmental
Management
CERTIFIED

ISO 45001
Occupational
Health and Safety
Management
CERTIFIED

- PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
- THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE
CUSTOMER NAME : PTT LNG COMPANY LIMITED
ADDRESS : [REDACTED]
CONTACT INFORMATION : [REDACTED]
MEASURING SOURCE : ริมรั้วด้านเหนือของพื้นที่โครงการ
MEASURING TYPE : AMBIENT (NOISE)
MEASURING DATE : MARCH 21-28, 2026
MEASURING TIME : *
MEASURING METHOD : INTEGRATED SOUND LEVEL METER **
MEASURED BY : [REDACTED]

RECEIVED DATE : MARCH 21-28, 2026
ANALYTICAL DATE : MARCH 21-28, 2026
ISSUE DATE : APRIL 10, 2026
REPORT NO. : 2026-U028011
WORK NO. : 2025-010629
ANALYSIS NO. : T26AG825-0002 - T26AG825-0008

TIME*	RESULT dB(A)		
	ริมรั้วด้านเหนือของพื้นที่โครงการ		
	MARCH 21 - 22, 2026		
	T26AG825-0002		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{A90} 1 hour
07:00-08:00 HOUR	58.3	77.1	51.7
08:00-09:00 HOUR	54.9	78.8	49.9
09:00-10:00 HOUR	55.1	81.0	47.2
10:00-11:00 HOUR	54.4	71.5	48.2
11:00-12:00 HOUR	54.9	77.7	50.5
12:00-13:00 HOUR	52.5	75.3	50.2
13:00-14:00 HOUR	53.5	79.2	50.4
14:00-15:00 HOUR	52.7	66.1	50.6
15:00-16:00 HOUR	52.5	69.5	50.8
16:00-17:00 HOUR	55.0	74.7	51.7
17:00-18:00 HOUR	55.7	73.7	51.6
18:00-19:00 HOUR	54.4	71.8	50.7
19:00-20:00 HOUR	52.7	73.9	50.5
20:00-21:00 HOUR	53.0	75.3	50.7
21:00-22:00 HOUR	51.9	62.8	50.8
22:00-23:00 HOUR	51.7	62.7	50.8
23:00-00:00 HOUR	51.8	69.3	50.9
00:00-01:00 HOUR	51.4	63.6	50.7
01:00-02:00 HOUR	51.3	65.3	50.5
02:00-03:00 HOUR	51.3	64.1	50.5
03:00-04:00 HOUR	51.2	63.5	50.5
04:00-05:00 HOUR	51.3	66.4	50.4
05:00-06:00 HOUR	51.7	69.4	50.5
06:00-07:00 HOUR	54.1	69.8	51.0
L _{Aeq} 24 hours		53.6	
L _{Adn}		58.7	



TIME*	RESULT dB(A)		
	ริมรั้วด้านเหนือของพื้นที่โครงการ		
	MARCH 22 - 23, 2026		
	T26AG825-0003		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{A90} 1 hour
07:00-08:00 HOUR	55.9	78.8	51.4
08:00-09:00 HOUR	53.4	75.5	50.5
09:00-10:00 HOUR	52.4	67.1	50.6
10:00-11:00 HOUR	52.6	74.7	50.9
11:00-12:00 HOUR	52.8	70.7	51.1
12:00-13:00 HOUR	52.9	68.7	51.1
13:00-14:00 HOUR	52.2	66.8	51.0
14:00-15:00 HOUR	52.1	64.0	51.0
15:00-16:00 HOUR	52.6	70.5	51.1
16:00-17:00 HOUR	52.5	70.4	50.7
17:00-18:00 HOUR	54.0	76.4	50.7
18:00-19:00 HOUR	52.3	70.3	50.7
19:00-20:00 HOUR	53.1	71.3	51.4
20:00-21:00 HOUR	53.0	75.3	51.3
21:00-22:00 HOUR	52.4	68.5	51.2
22:00-23:00 HOUR	52.0	68.0	51.1
23:00-00:00 HOUR	51.8	64.6	51.0
00:00-01:00 HOUR	51.9	60.2	51.1
01:00-02:00 HOUR	52.0	64.1	51.1
02:00-03:00 HOUR	51.6	60.7	50.7
03:00-04:00 HOUR	51.5	66.0	50.7
04:00-05:00 HOUR	52.2	66.7	51.0
05:00-06:00 HOUR	52.1	67.5	50.8
06:00-07:00 HOUR	55.2	71.4	51.9
L _{Aeq} 24 hours		52.8	
L _{Adn}		58.9	

TIME*	RESULT dB(A)		
	ริมรั้วด้านเหนือของพื้นที่โครงการ		
	MARCH 23 - 24, 2026		
	T26AG825-0004		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{A90} 1 hour
07:00-08:00 HOUR	59.4	79.5	53.2
08:00-09:00 HOUR	56.8	76.7	52.5
09:00-10:00 HOUR	55.4	75.6	52.2
10:00-11:00 HOUR	54.8	85.4	51.1
11:00-12:00 HOUR	55.2	79.3	51.4
12:00-13:00 HOUR	53.0	70.6	51.0
13:00-14:00 HOUR	53.0	68.4	51.1
14:00-15:00 HOUR	54.6	75.9	51.3
15:00-16:00 HOUR	53.0	70.9	51.1
16:00-17:00 HOUR	54.8	72.6	51.5
17:00-18:00 HOUR	56.2	77.1	51.9
18:00-19:00 HOUR	54.7	73.7	51.4
19:00-20:00 HOUR	53.1	73.0	51.1
20:00-21:00 HOUR	53.7	78.1	51.0
21:00-22:00 HOUR	52.1	63.1	51.0
22:00-23:00 HOUR	52.1	64.2	51.1
23:00-00:00 HOUR	52.0	63.7	51.2
00:00-01:00 HOUR	52.2	68.3	51.2
01:00-02:00 HOUR	52.3	73.6	51.1
02:00-03:00 HOUR	51.9	66.0	51.1
03:00-04:00 HOUR	51.8	63.3	51.1
04:00-05:00 HOUR	52.2	65.9	51.0
05:00-06:00 HOUR	52.5	66.1	51.1
06:00-07:00 HOUR	55.6	76.8	52.1
L _{Aeq} 24 hours	54.3		
L _{Adn}	59.5		

TIME*	RESULT dB(A)		
	ริมรั้วด้านเหนือของพื้นที่โครงการ		
	MARCH 24 - 25, 2026		
	T26AG825-0005		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{A90} 1 hour
07:00-08:00 HOUR	60.2	84.5	53.2
08:00-09:00 HOUR	57.8	81.6	52.7
09:00-10:00 HOUR	58.7	83.1	54.5
10:00-11:00 HOUR	52.6	73.0	47.8
11:00-12:00 HOUR	54.4	76.7	51.0
12:00-13:00 HOUR	53.1	70.5	51.1
13:00-14:00 HOUR	54.6	76.0	50.9
14:00-15:00 HOUR	53.2	69.2	51.0
15:00-16:00 HOUR	53.3	79.4	51.0
16:00-17:00 HOUR	53.5	69.6	50.9
17:00-18:00 HOUR	55.9	74.7	51.3
18:00-19:00 HOUR	56.0	90.2	50.5
19:00-20:00 HOUR	54.1	84.5	50.1
20:00-21:00 HOUR	52.3	75.8	49.7
21:00-22:00 HOUR	51.1	62.3	49.7
22:00-23:00 HOUR	50.9	62.8	49.8
23:00-00:00 HOUR	51.0	63.7	50.0
00:00-01:00 HOUR	50.8	63.1	50.0
01:00-02:00 HOUR	50.3	60.3	49.6
02:00-03:00 HOUR	50.1	60.3	49.6
03:00-04:00 HOUR	50.6	65.2	49.4
04:00-05:00 HOUR	50.7	64.4	49.5
05:00-06:00 HOUR	51.9	70.2	49.5
06:00-07:00 HOUR	54.7	70.7	50.8
L _{Aeq} 24 hours		54.4	
L _{Adn}		58.7	

TIME*	RESULT dB(A)		
	ริมรั้วด้านเหนือของพื้นที่โครงการ		
	MARCH 25 - 26, 2026		
	T26AG825-0006		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{A90} 1 hour
07:00-08:00 HOUR	58.4	79.4	52.4
08:00-09:00 HOUR	55.8	78.7	50.3
09:00-10:00 HOUR	53.1	76.0	50.0
10:00-11:00 HOUR	52.1	71.5	49.8
11:00-12:00 HOUR	54.4	75.0	51.1
12:00-13:00 HOUR	52.9	70.1	50.9
13:00-14:00 HOUR	53.9	71.6	51.3
14:00-15:00 HOUR	53.0	71.0	50.9
15:00-16:00 HOUR	52.7	66.8	51.7
16:00-17:00 HOUR	53.6	68.9	51.3
17:00-18:00 HOUR	55.8	73.9	51.4
18:00-19:00 HOUR	54.6	72.8	50.7
19:00-20:00 HOUR	55.8	86.6	50.4
20:00-21:00 HOUR	52.1	70.0	50.2
21:00-22:00 HOUR	52.0	75.8	50.2
22:00-23:00 HOUR	51.5	63.7	50.3
23:00-00:00 HOUR	51.1	62.0	50.2
00:00-01:00 HOUR	51.4	70.8	50.2
01:00-02:00 HOUR	51.5	62.8	50.3
02:00-03:00 HOUR	51.3	63.0	50.3
03:00-04:00 HOUR	51.0	63.0	50.3
04:00-05:00 HOUR	51.7	64.8	50.4
05:00-06:00 HOUR	51.6	61.5	50.3
06:00-07:00 HOUR	55.5	72.9	51.6
L _{Aeq} 24 hours		53.7	
L _{Adn}		58.9	

TIME*	RESULT dB(A)		
	ริมรั้วด้านเหนือของพื้นที่โครงการ		
	MARCH 26 - 27, 2026		
	T26AG825-0007		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{A90} 1 hour
07:00-08:00 HOUR	59.0	77.3	52.8
08:00-09:00 HOUR	56.7	75.9	51.8
09:00-10:00 HOUR	53.5	70.1	51.2
10:00-11:00 HOUR	55.0	79.8	51.5
11:00-12:00 HOUR	54.5	78.1	51.6
12:00-13:00 HOUR	53.4	67.8	51.3
13:00-14:00 HOUR	54.9	76.7	51.6
14:00-15:00 HOUR	52.9	67.2	51.7
15:00-16:00 HOUR	54.2	75.0	51.7
16:00-17:00 HOUR	56.3	75.6	51.6
17:00-18:00 HOUR	56.8	78.9	52.1
18:00-19:00 HOUR	55.3	70.8	51.5
19:00-20:00 HOUR	54.5	80.8	51.1
20:00-21:00 HOUR	52.9	67.4	51.1
21:00-22:00 HOUR	52.9	75.6	51.2
22:00-23:00 HOUR	52.2	66.8	51.2
23:00-00:00 HOUR	52.1	61.5	51.2
00:00-01:00 HOUR	52.0	65.8	51.3
01:00-02:00 HOUR	52.1	60.1	51.3
02:00-03:00 HOUR	51.9	62.7	51.2
03:00-04:00 HOUR	52.1	62.7	51.3
04:00-05:00 HOUR	52.4	63.9	51.4
05:00-06:00 HOUR	53.1	74.5	51.8
06:00-07:00 HOUR	55.6	74.4	52.4
L _{Aeq} 24 hours		54.5	
L _{Adn}		59.6	

TIME*	RESULT dB(A)		
	ริมรั้วด้านเหนือของพื้นที่โครงการ		
	MARCH 27 - 28, 2026		
	T26AG825-0008		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{A90} 1 hour
07:00-08:00 HOUR	59.0	79.8	53.7
08:00-09:00 HOUR	57.7	79.7	52.7
09:00-10:00 HOUR	58.6	76.8	53.2
10:00-11:00 HOUR	53.9	70.9	51.7
11:00-12:00 HOUR	54.2	76.1	51.9
12:00-13:00 HOUR	54.3	70.2	51.8
13:00-14:00 HOUR	55.2	76.8	52.1
14:00-15:00 HOUR	54.5	76.2	52.4
15:00-16:00 HOUR	53.9	72.5	52.3
16:00-17:00 HOUR	56.3	78.7	52.9
17:00-18:00 HOUR	56.3	73.9	52.8
18:00-19:00 HOUR	54.9	71.4	52.2
19:00-20:00 HOUR	55.5	76.8	51.9
20:00-21:00 HOUR	53.5	71.4	52.0
21:00-22:00 HOUR	52.9	63.0	52.1
22:00-23:00 HOUR	53.0	62.7	52.1
23:00-00:00 HOUR	52.8	60.1	52.1
00:00-01:00 HOUR	53.0	60.9	52.2
01:00-02:00 HOUR	53.2	67.4	52.2
02:00-03:00 HOUR	53.1	69.4	52.2
03:00-04:00 HOUR	53.0	66.7	52.2
04:00-05:00 HOUR	53.1	61.1	52.2
05:00-06:00 HOUR	53.2	63.3	52.2
06:00-07:00 HOUR	55.2	71.5	51.7
L _{Aeq} 24 hours		55.0	
L _{Adn}		60.2	

REMARK :

- ** ISO 1996-2: 2017
- ** NOTIFICATION OF THE NATIONAL ENVIRONMENT BOARD NO. 15 (B.E. 2540) ON ENVIRONMENTAL NOISE STANDARDS, DATED 12 MARCH 1997
- ** NOTIFICATION OF THE POLLUTION CONTROL DEPARTMENT (B.E. 2540) ON METHODS FOR NOISE LEVEL CALCULATION, DATED 11 AUGUST 1997
- ** NOTIFICATION OF THE MINISTRY OF NATURAL RESOURCES AND ENVIRONMENT ON STANDARDS FOR CONTROL OF NOISE AND VIBRATION, DATED 7 NOVEMBER 2005
- ** NOTIFICATION OF THE DEPARTMENT OF INDUSTRIAL WORKS ON METHODS FOR MEASUREMENT OF ANNOYANCE NOISE LEVEL, 24-HOUR EQUIVALENT CONTINUOUS SOUND LEVEL, AND MAXIMUM SOUND LEVEL FROM INDUSTRIAL OPERATIONS, B.E. 2553, DATED 20 DECEMBER 2010
- ** NOTIFICATION OF THE MINISTRY OF INDUSTRY ON STANDARDS FOR CONTROL OF NOISE FROM MINING, MINERAL DRESSING, AND METALLURGICAL ACTIVITIES, AND VIBRATION FROM THE USE OF EXPLOSIVES IN MINING ACTIVITIES, B.E. 2567 (2024)



ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE
CUSTOMER NAME : PTT LNG COMPANY LIMITED
ADDRESS : [REDACTED]
CONTACT INFORMATION : [REDACTED]
MEASURING SOURCE : วัดตากวนคองคาราม
MEASURING TYPE : AMBIENT (NOISE)
MEASURING DATE : MARCH 21-28, 2026
MEASURING TIME : *
MEASURING METHOD : INTEGRATED SOUND LEVEL METER **
MEASURED BY : [REDACTED]

RECEIVED DATE : MARCH 21-28, 2026
ANALYTICAL DATE : MARCH 21-28, 2026
ISSUE DATE : APRIL 10, 2026
REPORT NO. : 2026-U028012
WORK NO. : 2025-010629
ANALYSIS NO. : T26AG825-0009 - T26AG825-0015

TIME*	RESULT dB(A)		
	วัดตากวนคองคาราม		
	MARCH 21 - 22, 2026		
	T26AG825-0009		
	LAeq 1 hour	LAmx 1 hour	LA90 1 hour
07:00-08:00 HOUR	59.8	75.4	52.8
08:00-09:00 HOUR	56.0	74.4	48.6
09:00-10:00 HOUR	53.9	75.0	47.5
10:00-11:00 HOUR	53.6	76.2	45.0
11:00-12:00 HOUR	60.3	80.6	54.1
12:00-13:00 HOUR	55.9	77.6	47.0
13:00-14:00 HOUR	55.5	75.9	47.0
14:00-15:00 HOUR	58.0	82.4	46.0
15:00-16:00 HOUR	60.5	79.4	49.5
16:00-17:00 HOUR	60.7	80.2	49.6
17:00-18:00 HOUR	47.9	69.2	41.7
18:00-19:00 HOUR	48.5	71.4	41.6
19:00-20:00 HOUR	60.0	72.6	46.2
20:00-21:00 HOUR	51.7	72.4	45.9
21:00-22:00 HOUR	55.2	74.3	45.6
22:00-23:00 HOUR	47.5	65.4	44.0
23:00-00:00 HOUR	48.2	65.7	42.4
00:00-01:00 HOUR	48.0	62.0	45.1
01:00-02:00 HOUR	52.7	81.3	43.4
02:00-03:00 HOUR	56.0	66.1	52.5
03:00-04:00 HOUR	55.5	64.3	52.7
04:00-05:00 HOUR	58.6	77.7	50.0
05:00-06:00 HOUR	50.1	78.3	40.0
06:00-07:00 HOUR	53.5	70.9	42.9
LAeq 24 hours		56.4	
LAdn		61.0	



TIME*	RESULT dB(A)		
	วัดตากวนคลองคาราม		
	MARCH 22 - 23, 2026		
	T26AG825-0010		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{A90} 1 hour
07:00-08:00 HOUR	55.9	86.2	42.0
08:00-09:00 HOUR	51.6	77.2	43.3
09:00-10:00 HOUR	52.0	79.7	43.3
10:00-11:00 HOUR	50.8	75.8	44.0
11:00-12:00 HOUR	54.0	80.1	46.2
12:00-13:00 HOUR	51.2	67.5	47.1
13:00-14:00 HOUR	51.8	75.8	45.9
14:00-15:00 HOUR	55.2	75.3	48.7
15:00-16:00 HOUR	59.5	75.4	49.1
16:00-17:00 HOUR	51.2	82.3	43.9
17:00-18:00 HOUR	48.4	67.6	42.2
18:00-19:00 HOUR	52.0	69.7	43.3
19:00-20:00 HOUR	59.3	79.9	50.9
20:00-21:00 HOUR	49.8	67.0	46.0
21:00-22:00 HOUR	50.3	63.6	44.4
22:00-23:00 HOUR	53.7	66.6	48.5
23:00-00:00 HOUR	50.4	64.6	45.0
00:00-01:00 HOUR	48.5	61.0	43.8
01:00-02:00 HOUR	45.3	61.5	42.3
02:00-03:00 HOUR	44.0	60.0	41.1
03:00-04:00 HOUR	51.8	68.1	44.4
04:00-05:00 HOUR	50.8	75.2	42.3
05:00-06:00 HOUR	53.0	74.3	39.4
06:00-07:00 HOUR	51.2	88.4	42.7
L _{Aeq} 24 hours		53.2	
L _{Adn}		57.9	

TIME*	RESULT dB(A)		
	วัดตากวนคลองคาราม		
	MARCH 23 - 24, 2026		
	T26AG825-0011		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{A90} 1 hour
07:00-08:00 HOUR	53.6	85.5	44.7
08:00-09:00 HOUR	55.5	83.5	44.4
09:00-10:00 HOUR	57.3	77.1	44.3
10:00-11:00 HOUR	62.2	82.0	47.2
11:00-12:00 HOUR	56.6	72.9	46.7
12:00-13:00 HOUR	52.3	78.9	45.1
13:00-14:00 HOUR	55.9	75.7	47.1
14:00-15:00 HOUR	57.6	80.1	45.9
15:00-16:00 HOUR	59.0	79.7	44.0
16:00-17:00 HOUR	51.4	76.1	44.3
17:00-18:00 HOUR	52.4	80.5	45.2
18:00-19:00 HOUR	53.4	80.9	47.0
19:00-20:00 HOUR	58.1	78.3	48.6
20:00-21:00 HOUR	55.5	67.4	46.0
21:00-22:00 HOUR	60.3	70.8	55.5
22:00-23:00 HOUR	57.2	80.1	49.9
23:00-00:00 HOUR	49.8	66.9	43.6
00:00-01:00 HOUR	44.9	64.7	41.6
01:00-02:00 HOUR	57.0	77.0	49.7
02:00-03:00 HOUR	47.6	67.4	43.0
03:00-04:00 HOUR	47.1	68.8	40.7
04:00-05:00 HOUR	46.4	69.1	39.3
05:00-06:00 HOUR	50.0	74.1	43.1
06:00-07:00 HOUR	50.6	69.7	43.2
L _{Aeq} 24 hours		55.9	
L _{Adn}		59.8	

TIME*	RESULT dB(A)		
	วัดถาวรณดงคาราม		
	MARCH 24 - 25, 2026		
	T26AG825-0012		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{A90} 1 hour
07:00-08:00 HOUR	55.6	80.9	44.0
08:00-09:00 HOUR	55.4	81.7	44.2
09:00-10:00 HOUR	57.6	87.3	45.8
10:00-11:00 HOUR	60.2	79.7	44.5
11:00-12:00 HOUR	57.0	78.5	44.8
12:00-13:00 HOUR	51.4	74.1	44.8
13:00-14:00 HOUR	57.9	76.5	47.0
14:00-15:00 HOUR	57.8	80.5	43.3
15:00-16:00 HOUR	56.6	82.8	44.8
16:00-17:00 HOUR	54.0	75.1	43.1
17:00-18:00 HOUR	47.5	65.4	42.4
18:00-19:00 HOUR	54.0	70.5	42.9
19:00-20:00 HOUR	44.7	62.7	40.4
20:00-21:00 HOUR	52.4	81.2	41.5
21:00-22:00 HOUR	51.0	74.2	42.0
22:00-23:00 HOUR	51.2	97.3	42.1
23:00-00:00 HOUR	48.0	88.4	42.9
00:00-01:00 HOUR	51.5	66.5	43.1
01:00-02:00 HOUR	40.9	63.2	38.9
02:00-03:00 HOUR	48.9	61.0	41.2
03:00-04:00 HOUR	44.9	77.1	38.7
04:00-05:00 HOUR	43.6	67.1	36.2
05:00-06:00 HOUR	49.8	77.5	38.3
06:00-07:00 HOUR	53.3	79.3	42.8
L _{Aeq} 24 hours		54.2	
L _{Adn}		57.5	

TIME*	RESULT dB(A)		
	วัดตามโครงการ		
	MARCH 25 - 26, 2026		
	T26AG825-0013		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{A90} 1 hour
07:00-08:00 HOUR	54.7	76.4	42.9
08:00-09:00 HOUR	54.8	80.8	45.0
09:00-10:00 HOUR	59.7	82.3	43.9
10:00-11:00 HOUR	52.0	73.8	44.0
11:00-12:00 HOUR	58.7	72.9	43.7
12:00-13:00 HOUR	50.0	73.2	44.8
13:00-14:00 HOUR	58.2	75.5	44.5
14:00-15:00 HOUR	61.2	75.3	47.8
15:00-16:00 HOUR	53.2	73.5	44.6
16:00-17:00 HOUR	49.5	73.3	44.0
17:00-18:00 HOUR	49.8	76.5	43.1
18:00-19:00 HOUR	53.2	76.6	42.7
19:00-20:00 HOUR	49.0	87.4	41.5
20:00-21:00 HOUR	48.6	66.6	42.8
21:00-22:00 HOUR	49.2	78.6	42.5
22:00-23:00 HOUR	52.2	83.5	42.4
23:00-00:00 HOUR	48.1	67.5	42.9
00:00-01:00 HOUR	47.6	88.4	40.9
01:00-02:00 HOUR	53.6	69.6	48.7
02:00-03:00 HOUR	42.3	83.5	38.6
03:00-04:00 HOUR	45.6	79.2	40.6
04:00-05:00 HOUR	54.6	90.8	40.0
05:00-06:00 HOUR	50.4	82.1	40.9
06:00-07:00 HOUR	51.5	74.7	43.5
L _{Aeq} 24 hours	54.3		
L _{Adn}	58.4		

TIME*	RESULT dB(A)		
	วัดตากวนคลองคาราม		
	MARCH 26 - 27, 2026		
	T26AG825-0014		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{A90} 1 hour
07:00-08:00 HOUR	52.0	79.4	43.5
08:00-09:00 HOUR	55.6	82.7	44.1
09:00-10:00 HOUR	60.0	81.7	44.3
10:00-11:00 HOUR	52.2	69.3	44.5
11:00-12:00 HOUR	55.9	77.9	44.5
12:00-13:00 HOUR	57.3	73.9	46.4
13:00-14:00 HOUR	54.3	76.8	45.9
14:00-15:00 HOUR	56.0	81.3	45.5
15:00-16:00 HOUR	61.0	82.5	47.3
16:00-17:00 HOUR	57.9	76.4	47.5
17:00-18:00 HOUR	47.0	68.2	40.7
18:00-19:00 HOUR	49.5	69.2	40.2
19:00-20:00 HOUR	59.2	73.1	47.3
20:00-21:00 HOUR	58.0	70.6	46.5
21:00-22:00 HOUR	52.8	63.9	46.4
22:00-23:00 HOUR	48.2	67.1	43.1
23:00-00:00 HOUR	50.2	65.8	42.8
00:00-01:00 HOUR	48.9	67.2	46.3
01:00-02:00 HOUR	52.0	78.9	41.2
02:00-03:00 HOUR	52.5	63.7	46.6
03:00-04:00 HOUR	55.2	63.6	46.8
04:00-05:00 HOUR	58.5	74.4	51.2
05:00-06:00 HOUR	47.0	76.6	39.0
06:00-07:00 HOUR	52.1	72.5	42.2
L _{Aeq} 24 hours		55.6	
L _{Adn}		60.2	

TIME*	RESULT dB(A)		
	วัดตามวงศคาราม		
	MARCH 27 - 28, 2026		
	T26AG825-0015		
	L _{Aeq} 1 hour	L _{Amax} 1 hour	L _{A90} 1 hour
07:00-08:00 HOUR	53.3	88.5	41.3
08:00-09:00 HOUR	51.1	79.9	42.2
09:00-10:00 HOUR	50.0	71.7	42.6
10:00-11:00 HOUR	49.7	75.0	42.5
11:00-12:00 HOUR	53.0	77.4	45.2
12:00-13:00 HOUR	50.2	64.9	45.8
13:00-14:00 HOUR	51.2	76.7	45.2
14:00-15:00 HOUR	56.8	71.5	47.0
15:00-16:00 HOUR	56.5	78.9	47.9
16:00-17:00 HOUR	51.3	80.2	43.1
17:00-18:00 HOUR	48.1	69.2	41.4
18:00-19:00 HOUR	52.3	72.3	42.4
19:00-20:00 HOUR	57.7	85.9	49.5
20:00-21:00 HOUR	50.3	72.8	45.1
21:00-22:00 HOUR	50.9	71.3	43.4
22:00-23:00 HOUR	49.7	70.4	45.6
23:00-00:00 HOUR	57.6	73.5	43.9
00:00-01:00 HOUR	47.8	61.7	42.8
01:00-02:00 HOUR	44.6	62.3	41.4
02:00-03:00 HOUR	42.6	59.6	39.7
03:00-04:00 HOUR	49.1	70.8	40.8
04:00-05:00 HOUR	51.3	63.9	46.4
05:00-06:00 HOUR	50.1	63.2	46.5
06:00-07:00 HOUR	53.1	67.7	48.8
L _{Aeq} 24 hours		52.6	
L _{Adn}		58.3	

REMARK :

** ISO 1996-2: 2017


** NOTIFICATION OF THE NATIONAL ENVIRONMENT BOARD NO. 15 (B.E. 2540) ON ENVIRONMENTAL NOISE STANDARDS, DATED 12 MARCH 1997

** NOTIFICATION OF THE POLLUTION CONTROL DEPARTMENT (B.E. 2540) ON METHODS FOR NOISE LEVEL CALCULATION, DATED 11 AUGUST 1997

** NOTIFICATION OF THE MINISTRY OF NATURAL RESOURCES AND ENVIRONMENT ON STANDARDS FOR CONTROL OF NOISE AND VIBRATION, DATED 7 NOVEMBER 2005

** NOTIFICATION OF THE DEPARTMENT OF INDUSTRIAL WORKS ON METHODS FOR MEASUREMENT OF ANNOYANCE NOISE LEVEL, 24-HOUR EQUIVALENT CONTINUOUS SOUND LEVEL, AND MAXIMUM SOUND LEVEL FROM INDUSTRIAL OPERATIONS, B.E. 2553, DATED 20 DECEMBER 2010

** NOTIFICATION OF THE MINISTRY OF INDUSTRY ON STANDARDS FOR CONTROL OF NOISE FROM MINING, MINERAL DRESSING, AND METALLURGICAL ACTIVITIES, AND VIBRATION FROM THE USE OF EXPLOSIVES IN MINING ACTIVITIES, B.E. 2567 (2024)



ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE

CUSTOMER NAME : PTT LNG COMPANY LIMITED

ADDRESS :

CONTACT INFORMATION :

MEASURING PLACE : ริมรั้วด้านเหนือของพื้นที่โครงการ

MEASURING TYPE : AMBIENT (ANNOYANCE NOISE)

MEASURING DATE : MARCH 21-28, 2026

MEASURING TIME : *

MEASURING METHOD : INTEGRATED SOUND LEVEL METER
AND CALCULATION ****

MEASURED BY :

RECEIVED DATE : MARCH 21-28, 2026

ANALYTICAL DATE : MARCH 21-28, 2026

ISSUE DATE : APRIL 10, 2026

REPORT NO. : 2026-U028013

WORK NO. : 2025-010629

ANALYSIS NO. : T26AG825-0002 - T26AG825-0008

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 21, 2026 T26AG825-0002	DAY TIME ^{1/}					
	07:00-08:00 HOUR	58.3 ^{1/}	55.5 **	55.1 ^{1/}	49.1 **	6.0
	08:00-09:00 HOUR	54.9 ^{1/}	52.6 **	51.0 ^{1/}	49.1 **	1.9
	09:00-10:00 HOUR	55.1 ^{1/}	50.9 **	53.0 ^{1/}	46.6 **	6.4
	10:00-11:00 HOUR	54.4 ^{1/}	52.7 **	49.5 ^{1/}	46.8 **	2.7
	11:00-12:00 HOUR	54.9 ^{1/}	50.5 **	52.9 ^{1/}	47.9 **	5.0
	12:00-13:00 HOUR	52.5 ^{1/}	50.4 **	48.3 ^{1/}	48.7 **	<0.8 ^{3/}
	13:00-14:00 HOUR	53.5 ^{1/}	50.3 **	50.7 ^{1/}	48.5 **	2.2
	14:00-15:00 HOUR	52.7 ^{1/}	51.4 **	46.8 ^{1/}	48.9 **	<0.8 ^{3/}
	15:00-16:00 HOUR	52.5 ^{1/}	51.4 **	46.0 ^{1/}	50.1 **	<0.8 ^{3/}
	16:00-17:00 HOUR	55.0 ^{1/}	52.5 **	51.4 ^{1/}	50.6 **	0.8
	17:00-18:00 HOUR	55.7 ^{1/}	52.1 **	53.2 ^{1/}	50.1 **	3.1
	18:00-19:00 HOUR	54.4 ^{1/}	51.3 **	51.5 ^{1/}	50.1 **	1.4
	19:00-20:00 HOUR	52.7 ^{1/}	49.9 **	49.5 ^{1/}	48.5 **	1.0
	20:00-21:00 HOUR	53.0 ^{1/}	50.4 **	49.5 ^{1/}	49.2 **	<0.8 ^{3/}
	21:00-22:00 HOUR	51.9 ^{1/}	49.8 **	47.7 ^{1/}	48.8 **	<0.8 ^{3/}
	NIGHT TIME ^{2/}					
	22:00-22:05 HOUR	51.5 ^{2/}	49.4 ***	50.3 ^{2/}	48.7 ***	1.6
	22:05-22:10 HOUR	51.2 ^{2/}	49.4 ***	49.5 ^{2/}	48.7 ***	0.8
	22:10-22:15 HOUR	51.7 ^{2/}	49.4 ***	50.8 ^{2/}	48.7 ***	2.1
	22:15-22:20 HOUR	51.6 ^{2/}	51.0 ***	45.7 ^{2/}	50.3 ***	<0.8 ^{3/}
	22:20-22:25 HOUR	51.4 ^{2/}	51.0 ***	43.8 ^{2/}	50.3 ***	<0.8 ^{3/}
	22:25-22:30 HOUR	51.5 ^{2/}	51.0 ***	44.9 ^{2/}	50.3 ***	<0.8 ^{3/}
	22:30-22:35 HOUR	52.8 ^{2/}	50.0 ***	52.6 ^{2/}	48.9 ***	3.7
	22:35-22:40 HOUR	52.1 ^{2/}	50.0 ***	50.9 ^{2/}	48.9 ***	2.0
	22:40-22:45 HOUR	51.2 ^{2/}	50.0 ***	48.0 ^{2/}	48.9 ***	<0.8 ^{3/}
	22:45-22:50 HOUR	51.6 ^{2/}	49.6 ***	50.3 ^{2/}	48.8 ***	1.5
	22:50-22:55 HOUR	51.1 ^{2/}	49.6 ***	48.8 ^{2/}	48.8 ***	<0.8 ^{3/}
	22:55-23:00 HOUR	52.1 ^{2/}	49.6 ***	51.5 ^{2/}	48.8 ***	2.7
	23:00-23:05 HOUR	51.8 ^{2/}	48.8 ***	51.8 ^{2/}	48.3 ***	3.5
	23:05-23:10 HOUR	51.8 ^{2/}	48.8 ***	51.8 ^{2/}	48.3 ***	3.5
	23:10-23:15 HOUR	51.1 ^{2/}	48.8 ***	50.2 ^{2/}	48.3 ***	1.9



DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 21, 2026 T26AG825-0002	NIGHT TIME ^{2/}					
	23:15-23:20 HOUR	51.2 ^{2/}	49.0 ***	50.2 ^{2/}	48.4 ***	1.8
	23:20-23:25 HOUR	51.1 ^{2/}	49.0 ***	49.9 ^{2/}	48.4 ***	1.5
	23:25-23:30 HOUR	52.4 ^{2/}	49.0 ***	52.7 ^{2/}	48.4 ***	4.3
	23:30-23:35 HOUR	53.3 ^{2/}	51.2 ***	52.1 ^{2/}	49.8 ***	2.3
	23:35-23:40 HOUR	51.5 ^{2/}	51.2 ***	42.7 ^{2/}	49.8 ***	<0.8 ^{3/}
	23:40-23:45 HOUR	51.8 ^{2/}	51.2 ***	45.9 ^{2/}	49.8 ***	<0.8 ^{3/}
	23:45-23:50 HOUR	51.3 ^{2/}	49.5 ***	49.6 ^{2/}	48.8 ***	0.8
	23:50-23:55 HOUR	51.5 ^{2/}	49.5 ***	50.2 ^{2/}	48.8 ***	1.4
	23:55-00:00 HOUR	51.8 ^{2/}	49.5 ***	50.9 ^{2/}	48.8 ***	2.1
MARCH 22, 2026 T26AG825-0002	NIGHT TIME ^{2/}					
	00:00-00:05 HOUR	51.3 ^{2/}	50.2 ***	47.8 ^{2/}	49.8 ***	<0.8 ^{3/}
	00:05-00:10 HOUR	51.9 ^{2/}	50.2 ***	50.0 ^{2/}	49.8 ***	<0.8 ^{3/}
	00:10-00:15 HOUR	51.4 ^{2/}	50.2 ***	48.2 ^{2/}	49.8 ***	<0.8 ^{3/}
	00:15-00:20 HOUR	51.3 ^{2/}	49.1 ***	50.3 ^{2/}	48.6 ***	1.7
	00:20-00:25 HOUR	51.0 ^{2/}	49.1 ***	49.5 ^{2/}	48.6 ***	0.9
	00:25-00:30 HOUR	51.2 ^{2/}	49.1 ***	50.0 ^{2/}	48.6 ***	1.4
	00:30-00:35 HOUR	51.1 ^{2/}	48.4 ***	50.8 ^{2/}	48.1 ***	2.7
	00:35-00:40 HOUR	50.9 ^{2/}	48.4 ***	50.3 ^{2/}	48.1 ***	2.2
	00:40-00:45 HOUR	50.8 ^{2/}	48.4 ***	50.1 ^{2/}	48.1 ***	2.0
	00:45-00:50 HOUR	51.7 ^{2/}	50.5 ***	48.5 ^{2/}	49.5 ***	<0.8 ^{3/}
	00:50-00:55 HOUR	52.1 ^{2/}	50.5 ***	50.0 ^{2/}	49.5 ***	<0.8 ^{3/}
	00:55-01:00 HOUR	51.7 ^{2/}	50.5 ***	48.5 ^{2/}	49.5 ***	<0.8 ^{3/}
	01:00-01:05 HOUR	50.9 ^{2/}	49.7 ***	47.7 ^{2/}	49.0 ***	<0.8 ^{3/}
	01:05-01:10 HOUR	52.0 ^{2/}	49.7 ***	51.1 ^{2/}	49.0 ***	2.1
	01:10-01:15 HOUR	50.9 ^{2/}	49.7 ***	47.7 ^{2/}	49.0 ***	<0.8 ^{3/}
	01:15-01:20 HOUR	51.8 ^{2/}	48.9 ***	51.7 ^{2/}	48.4 ***	3.3
	01:20-01:25 HOUR	51.1 ^{2/}	48.9 ***	50.1 ^{2/}	48.4 ***	1.7
	01:25-01:30 HOUR	50.8 ^{2/}	48.9 ***	49.3 ^{2/}	48.4 ***	0.9
	01:30-01:35 HOUR	50.8 ^{2/}	49.2 ***	48.7 ^{2/}	48.9 ***	<0.8 ^{3/}
	01:35-01:40 HOUR	50.8 ^{2/}	49.2 ***	48.7 ^{2/}	48.9 ***	<0.8 ^{3/}
	01:40-01:45 HOUR	50.7 ^{2/}	49.2 ***	48.4 ^{2/}	48.9 ***	<0.8 ^{3/}
	01:45-01:50 HOUR	51.9 ^{2/}	51.2 ***	46.6 ^{2/}	50.0 ***	<0.8 ^{3/}
	01:50-01:55 HOUR	52.6 ^{2/}	51.2 ***	50.0 ^{2/}	50.0 ***	<0.8 ^{3/}
	01:55-02:00 HOUR	51.1 ^{2/}	51.2 ***	<0.8 ^{3/}	50.0 ***	<0.8 ^{3/}
	02:00-02:05 HOUR	51.6 ^{2/}	50.1 ***	49.3 ^{2/}	49.4 ***	<0.8 ^{3/}
	02:05-02:10 HOUR	51.0 ^{2/}	50.1 ***	46.7 ^{2/}	49.4 ***	<0.8 ^{3/}
	02:10-02:15 HOUR	51.1 ^{2/}	50.1 ***	47.2 ^{2/}	49.4 ***	<0.8 ^{3/}
	02:15-02:20 HOUR	50.8 ^{2/}	49.3 ***	48.5 ^{2/}	48.4 ***	<0.8 ^{3/}
	02:20-02:25 HOUR	51.5 ^{2/}	49.3 ***	50.5 ^{2/}	48.4 ***	2.1
	02:25-02:30 HOUR	50.7 ^{2/}	49.3 ***	48.1 ^{2/}	48.4 ***	<0.8 ^{3/}
	02:30-02:35 HOUR	51.8 ^{2/}	49.6 ***	50.8 ^{2/}	48.5 ***	2.3
	02:35-02:40 HOUR	51.6 ^{2/}	49.6 ***	50.3 ^{2/}	48.5 ***	1.8
	02:40-02:45 HOUR	52.1 ^{2/}	49.6 ***	51.5 ^{2/}	48.5 ***	3.0
	02:45-02:50 HOUR	51.3 ^{2/}	49.0 ***	50.4 ^{2/}	48.1 ***	2.3

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 22, 2026	NIGHT TIME ^{2/}					
T26AG825-0002	02:50-02:55 HOUR	51.2 ^{2/}	49.0 ***	50.2 ^{2/}	48.1 ***	2.1
	02:55-03:00 HOUR	50.9 ^{2/}	49.0 ***	49.4 ^{2/}	48.1 ***	1.3
	03:00-03:05 HOUR	52.6 ^{2/}	49.4 ***	52.8 ^{2/}	48.5 ***	4.3
	03:05-03:10 HOUR	51.0 ^{2/}	49.4 ***	48.9 ^{2/}	48.5 ***	<0.8 ^{3/}
	03:10-03:15 HOUR	50.9 ^{2/}	49.4 ***	48.6 ^{2/}	48.5 ***	<0.8 ^{3/}
	03:15-03:20 HOUR	50.7 ^{2/}	50.2 ***	44.1 ^{2/}	49.5 ***	<0.8 ^{3/}
	03:20-03:25 HOUR	50.6 ^{2/}	50.2 ***	43.0 ^{2/}	49.5 ***	<0.8 ^{3/}
	03:25-03:30 HOUR	51.4 ^{2/}	50.2 ***	48.2 ^{2/}	49.5 ***	<0.8 ^{3/}
	03:30-03:35 HOUR	51.4 ^{2/}	50.1 ***	48.5 ^{2/}	49.5 ***	<0.8 ^{3/}
	03:35-03:40 HOUR	50.9 ^{2/}	50.1 ***	46.2 ^{2/}	49.5 ***	<0.8 ^{3/}
	03:40-03:45 HOUR	51.2 ^{2/}	50.1 ***	47.7 ^{2/}	49.5 ***	<0.8 ^{3/}
	03:45-03:50 HOUR	51.0 ^{2/}	49.5 ***	48.7 ^{2/}	48.9 ***	<0.8 ^{3/}
	03:50-03:55 HOUR	51.3 ^{2/}	49.5 ***	49.6 ^{2/}	48.9 ***	<0.8 ^{3/}
	03:55-04:00 HOUR	51.1 ^{2/}	49.5 ***	49.0 ^{2/}	48.9 ***	<0.8 ^{3/}
	04:00-04:05 HOUR	50.6 ^{2/}	49.4 ***	47.4 ^{2/}	49.0 ***	<0.8 ^{3/}
	04:05-04:10 HOUR	51.3 ^{2/}	49.4 ***	49.8 ^{2/}	49.0 ***	0.8
	04:10-04:15 HOUR	50.9 ^{2/}	49.4 ***	48.6 ^{2/}	49.0 ***	<0.8 ^{3/}
	04:15-04:20 HOUR	51.6 ^{2/}	49.9 ***	49.7 ^{2/}	49.4 ***	<0.8 ^{3/}
	04:20-04:25 HOUR	50.7 ^{2/}	49.9 ***	46.0 ^{2/}	49.4 ***	<0.8 ^{3/}
	04:25-04:30 HOUR	50.8 ^{2/}	49.9 ***	46.5 ^{2/}	49.4 ***	<0.8 ^{3/}
	04:30-04:35 HOUR	51.3 ^{2/}	50.4 ***	47.0 ^{2/}	49.4 ***	<0.8 ^{3/}
	04:35-04:40 HOUR	51.7 ^{2/}	50.4 ***	48.8 ^{2/}	49.4 ***	<0.8 ^{3/}
	04:40-04:45 HOUR	51.4 ^{2/}	50.4 ***	47.5 ^{2/}	49.4 ***	<0.8 ^{3/}
	04:45-04:50 HOUR	52.1 ^{2/}	51.1 ***	48.2 ^{2/}	50.0 ***	<0.8 ^{3/}
	04:50-04:55 HOUR	50.7 ^{2/}	51.1 ***	<0.8 ^{3/}	50.0 ***	<0.8 ^{3/}
	04:55-05:00 HOUR	52.4 ^{2/}	51.1 ***	49.5 ^{2/}	50.0 ***	<0.8 ^{3/}
	05:00-05:05 HOUR	51.7 ^{2/}	50.0 ***	49.8 ^{2/}	49.0 ***	0.8
	05:05-05:10 HOUR	51.3 ^{2/}	50.0 ***	48.4 ^{2/}	49.0 ***	<0.8 ^{3/}
	05:10-05:15 HOUR	51.0 ^{2/}	50.0 ***	47.1 ^{2/}	49.0 ***	<0.8 ^{3/}
	05:15-05:20 HOUR	51.3 ^{2/}	50.5 ***	46.6 ^{2/}	49.4 ***	<0.8 ^{3/}
	05:20-05:25 HOUR	52.2 ^{2/}	50.5 ***	50.3 ^{2/}	49.4 ***	0.9
	05:25-05:30 HOUR	51.0 ^{2/}	50.5 ***	44.4 ^{2/}	49.4 ***	<0.8 ^{3/}
	05:30-05:35 HOUR	51.7 ^{2/}	50.5 ***	48.5 ^{2/}	49.0 ***	<0.8 ^{3/}
	05:35-05:40 HOUR	50.7 ^{2/}	50.5 ***	40.2 ^{2/}	49.0 ***	<0.8 ^{3/}
	05:40-05:45 HOUR	53.9 ^{2/}	50.5 ***	54.2 ^{2/}	49.0 ***	5.2
	05:45-05:50 HOUR	51.4 ^{2/}	51.3 ***	38.0 ^{2/}	49.3 ***	<0.8 ^{3/}
	05:50-05:55 HOUR	50.9 ^{2/}	51.3 ***	<0.8 ^{3/}	49.3 ***	<0.8 ^{3/}
	05:55-06:00 HOUR	52.5 ^{2/}	51.3 ***	49.3 ^{2/}	49.3 ***	<0.8 ^{3/}
	DAY TIME ^{1/}					
	06:00-07:00 HOUR	54.1 ^{1/}	52.3 **	49.4 ^{1/}	49.9 **	<0.8 ^{3/}
MARCH 22, 2026	DAY TIME ^{1/}					
T26AG825-0003	07:00-08:00 HOUR	55.9 ^{1/}	53.5 **	52.2 ^{1/}	50.0 **	2.2
	08:00-09:00 HOUR	53.4 ^{1/}	50.3 **	50.5 ^{1/}	49.0 **	1.5
	09:00-10:00 HOUR	52.4 ^{1/}	50.4 **	48.1 ^{1/}	48.6 **	<0.8 ^{3/}
	10:00-11:00 HOUR	52.6 ^{1/}	51.1 **	47.3 ^{1/}	49.4 **	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 22, 2026 T26AG825-0003	DAY TIME ^{1/}					
	11:00-12:00 HOUR	52.8 ^{1/}	50.6 **	48.8 ^{1/}	49.0 **	<0.8 ^{3/}
	12:00-13:00 HOUR	52.9 ^{1/}	51.4 **	47.6 ^{1/}	49.6 **	<0.8 ^{3/}
	13:00-14:00 HOUR	52.2 ^{1/}	50.3 **	47.7 ^{1/}	49.1 **	<0.8 ^{3/}
	14:00-15:00 HOUR	52.1 ^{1/}	50.4 **	47.2 ^{1/}	49.4 **	<0.8 ^{3/}
	15:00-16:00 HOUR	52.6 ^{1/}	50.4 **	48.6 ^{1/}	49.0 **	<0.8 ^{3/}
	16:00-17:00 HOUR	52.5 ^{1/}	51.7 **	44.8 ^{1/}	49.6 **	<0.8 ^{3/}
	17:00-18:00 HOUR	54.0 ^{1/}	52.0 **	49.7 ^{1/}	48.9 **	0.8
	18:00-19:00 HOUR	52.3 ^{1/}	50.8 **	47.0 ^{1/}	49.7 **	<0.8 ^{3/}
	19:00-20:00 HOUR	53.1 ^{1/}	51.1 **	48.8 ^{1/}	49.5 **	<0.8 ^{3/}
	20:00-21:00 HOUR	53.0 ^{1/}	50.3 **	49.7 ^{1/}	49.7 **	<0.8 ^{3/}
	21:00-22:00 HOUR	52.4 ^{1/}	51.8 **	43.5 ^{1/}	50.1 **	<0.8 ^{3/}
	NIGHT TIME ^{2/}					
	22:00-22:05 HOUR	51.7 ^{2/}	50.8 ***	47.4 ^{2/}	50.1 ***	<0.8 ^{3/}
	22:05-22:10 HOUR	52.2 ^{2/}	50.8 ***	49.6 ^{2/}	50.1 ***	<0.8 ^{3/}
	22:10-22:15 HOUR	52.1 ^{2/}	50.8 ***	49.2 ^{2/}	50.1 ***	<0.8 ^{3/}
	22:15-22:20 HOUR	51.4 ^{2/}	52.0 ***	<0.8 ^{3/}	50.5 ***	<0.8 ^{3/}
	22:20-22:25 HOUR	51.9 ^{2/}	52.0 ***	<0.8 ^{3/}	50.5 ***	<0.8 ^{3/}
	22:25-22:30 HOUR	53.3 ^{2/}	52.0 ***	50.4 ^{2/}	50.5 ***	<0.8 ^{3/}
	22:30-22:35 HOUR	52.7 ^{2/}	50.8 ***	51.2 ^{2/}	50.0 ***	1.2
	22:35-22:40 HOUR	51.6 ^{2/}	50.8 ***	46.9 ^{2/}	50.0 ***	<0.8 ^{3/}
	22:40-22:45 HOUR	52.2 ^{2/}	50.8 ***	49.6 ^{2/}	50.0 ***	<0.8 ^{3/}
	22:45-22:50 HOUR	51.9 ^{2/}	50.1 ***	50.2 ^{2/}	49.4 ***	0.8
	22:50-22:55 HOUR	51.5 ^{2/}	50.1 ***	48.9 ^{2/}	49.4 ***	<0.8 ^{3/}
	22:55-23:00 HOUR	51.7 ^{2/}	50.1 ***	49.6 ^{2/}	49.4 ***	<0.8 ^{3/}
	23:00-23:05 HOUR	51.5 ^{2/}	50.7 ***	46.8 ^{2/}	50.0 ***	<0.8 ^{3/}
	23:05-23:10 HOUR	51.9 ^{2/}	50.7 ***	48.7 ^{2/}	50.0 ***	<0.8 ^{3/}
	23:10-23:15 HOUR	51.5 ^{2/}	50.7 ***	46.8 ^{2/}	50.0 ***	<0.8 ^{3/}
	23:15-23:20 HOUR	51.7 ^{2/}	50.7 ***	47.8 ^{2/}	49.9 ***	<0.8 ^{3/}
	23:20-23:25 HOUR	52.5 ^{2/}	50.7 ***	50.8 ^{2/}	49.9 ***	0.9
	23:25-23:30 HOUR	51.6 ^{2/}	50.7 ***	47.3 ^{2/}	49.9 ***	<0.8 ^{3/}
	23:30-23:35 HOUR	51.6 ^{2/}	49.6 ***	50.3 ^{2/}	48.9 ***	1.4
	23:35-23:40 HOUR	52.0 ^{2/}	49.6 ***	51.3 ^{2/}	48.9 ***	2.4
	23:40-23:45 HOUR	51.5 ^{2/}	49.6 ***	50.0 ^{2/}	48.9 ***	1.1
	23:45-23:50 HOUR	52.3 ^{2/}	49.7 ***	51.8 ^{2/}	48.9 ***	2.9
	23:50-23:55 HOUR	51.5 ^{2/}	49.7 ***	49.8 ^{2/}	48.9 ***	0.9
	23:55-00:00 HOUR	52.3 ^{2/}	49.7 ***	51.8 ^{2/}	48.9 ***	2.9
MARCH 23, 2026 T26AG825-0003	NIGHT TIME ^{2/}					
	00:00-00:05 HOUR	51.7 ^{2/}	51.0 ***	46.4 ^{2/}	50.4 ***	<0.8 ^{3/}
	00:05-00:10 HOUR	51.4 ^{2/}	51.0 ***	43.8 ^{2/}	50.4 ***	<0.8 ^{3/}
	00:10-00:15 HOUR	51.6 ^{2/}	51.0 ***	45.7 ^{2/}	50.4 ***	<0.8 ^{3/}
	00:15-00:20 HOUR	51.4 ^{2/}	50.4 ***	47.5 ^{2/}	49.6 ***	<0.8 ^{3/}
	00:20-00:25 HOUR	51.5 ^{2/}	50.4 ***	48.0 ^{2/}	49.6 ***	<0.8 ^{3/}
	00:25-00:30 HOUR	52.0 ^{2/}	50.4 ***	49.9 ^{2/}	49.6 ***	<0.8 ^{3/}
	00:30-00:35 HOUR	52.1 ^{2/}	50.0 ***	50.9 ^{2/}	49.2 ***	1.7
	00:35-00:40 HOUR	51.9 ^{2/}	50.0 ***	50.4 ^{2/}	49.2 ***	1.2

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 23, 2026 T26AG825-0003	NIGHT TIME ^{2/}					
	00:40-00:45 HOUR	52.4 ^{2/}	50.0 ***	51.7 ^{2/}	49.2 ***	2.5
	00:45-00:50 HOUR	52.2 ^{2/}	49.9 ***	51.3 ^{2/}	49.1 ***	2.2
	00:50-00:55 HOUR	52.1 ^{2/}	49.9 ***	51.1 ^{2/}	49.1 ***	2.0
	00:55-01:00 HOUR	52.0 ^{2/}	49.9 ***	50.8 ^{2/}	49.1 ***	1.7
	01:00-01:05 HOUR	51.8 ^{2/}	50.1 ***	49.9 ^{2/}	49.1 ***	0.8
	01:05-01:10 HOUR	51.7 ^{2/}	50.1 ***	49.6 ^{2/}	49.1 ***	<0.8 ^{3/}
	01:10-01:15 HOUR	52.9 ^{2/}	50.1 ***	52.7 ^{2/}	49.1 ***	3.6
	01:15-01:20 HOUR	52.1 ^{2/}	49.5 ***	51.6 ^{2/}	48.5 ***	3.1
	01:20-01:25 HOUR	52.3 ^{2/}	49.5 ***	52.1 ^{2/}	48.5 ***	3.6
	01:25-01:30 HOUR	51.9 ^{2/}	49.5 ***	51.2 ^{2/}	48.5 ***	2.7
	01:30-01:35 HOUR	51.5 ^{2/}	50.1 ***	48.9 ^{2/}	49.5 ***	<0.8 ^{3/}
	01:35-01:40 HOUR	51.6 ^{2/}	50.1 ***	49.3 ^{2/}	49.5 ***	<0.8 ^{3/}
	01:40-01:45 HOUR	51.7 ^{2/}	50.1 ***	49.6 ^{2/}	49.5 ***	<0.8 ^{3/}
	01:45-01:50 HOUR	51.7 ^{2/}	50.9 ***	47.0 ^{2/}	50.0 ***	<0.8 ^{3/}
	01:50-01:55 HOUR	52.2 ^{2/}	50.9 ***	49.3 ^{2/}	50.0 ***	<0.8 ^{3/}
	01:55-02:00 HOUR	52.0 ^{2/}	50.9 ***	48.5 ^{2/}	50.0 ***	<0.8 ^{3/}
	02:00-02:05 HOUR	51.8 ^{2/}	50.5 ***	48.9 ^{2/}	49.6 ***	<0.8 ^{3/}
	02:05-02:10 HOUR	51.3 ^{2/}	50.5 ***	46.6 ^{2/}	49.6 ***	<0.8 ^{3/}
	02:10-02:15 HOUR	51.9 ^{2/}	50.5 ***	49.3 ^{2/}	49.6 ***	<0.8 ^{3/}
	02:15-02:20 HOUR	51.0 ^{2/}	49.2 ***	49.3 ^{2/}	48.3 ***	1.0
	02:20-02:25 HOUR	51.6 ^{2/}	49.2 ***	50.9 ^{2/}	48.3 ***	2.6
	02:25-02:30 HOUR	51.8 ^{2/}	49.2 ***	51.3 ^{2/}	48.3 ***	3.0
	02:30-02:35 HOUR	51.7 ^{2/}	49.9 ***	50.0 ^{2/}	49.2 ***	0.8
	02:35-02:40 HOUR	51.8 ^{2/}	49.9 ***	50.3 ^{2/}	49.2 ***	1.1
	02:40-02:45 HOUR	51.5 ^{2/}	49.9 ***	49.4 ^{2/}	49.2 ***	<0.8 ^{3/}
	02:45-02:50 HOUR	51.2 ^{2/}	50.4 ***	46.5 ^{2/}	49.7 ***	<0.8 ^{3/}
	02:50-02:55 HOUR	51.5 ^{2/}	50.4 ***	48.0 ^{2/}	49.7 ***	<0.8 ^{3/}
	02:55-03:00 HOUR	51.7 ^{2/}	50.4 ***	48.8 ^{2/}	49.7 ***	<0.8 ^{3/}
	03:00-03:05 HOUR	51.1 ^{2/}	50.3 ***	46.4 ^{2/}	49.7 ***	<0.8 ^{3/}
	03:05-03:10 HOUR	51.2 ^{2/}	50.3 ***	46.9 ^{2/}	49.7 ***	<0.8 ^{3/}
	03:10-03:15 HOUR	51.7 ^{2/}	50.3 ***	49.1 ^{2/}	49.7 ***	<0.8 ^{3/}
	03:15-03:20 HOUR	51.2 ^{2/}	50.5 ***	45.9 ^{2/}	49.6 ***	<0.8 ^{3/}
	03:20-03:25 HOUR	51.8 ^{2/}	50.5 ***	48.9 ^{2/}	49.6 ***	<0.8 ^{3/}
	03:25-03:30 HOUR	51.0 ^{2/}	50.5 ***	44.4 ^{2/}	49.6 ***	<0.8 ^{3/}
	03:30-03:35 HOUR	52.4 ^{2/}	49.6 ***	52.2 ^{2/}	48.8 ***	3.4
	03:35-03:40 HOUR	51.1 ^{2/}	49.6 ***	48.8 ^{2/}	48.8 ***	<0.8 ^{3/}
	03:40-03:45 HOUR	51.4 ^{2/}	49.6 ***	49.7 ^{2/}	48.8 ***	0.9
	03:45-03:50 HOUR	51.3 ^{2/}	50.8 ***	44.7 ^{2/}	49.8 ***	<0.8 ^{3/}
	03:50-03:55 HOUR	52.3 ^{2/}	50.8 ***	50.0 ^{2/}	49.8 ***	<0.8 ^{3/}
	03:55-04:00 HOUR	51.1 ^{2/}	50.8 ***	42.3 ^{2/}	49.8 ***	<0.8 ^{3/}
	04:00-04:05 HOUR	52.0 ^{2/}	50.8 ***	48.8 ^{2/}	49.4 ***	<0.8 ^{3/}
	04:05-04:10 HOUR	51.9 ^{2/}	50.8 ***	48.4 ^{2/}	49.4 ***	<0.8 ^{3/}
	04:10-04:15 HOUR	53.1 ^{2/}	50.8 ***	52.2 ^{2/}	49.4 ***	2.8
	04:15-04:20 HOUR	52.4 ^{2/}	50.7 ***	50.5 ^{2/}	50.0 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 23, 2026 T26AG825-0003	NIGHT TIME ^{2/}					
	04:20-04:25 HOUR	52.3 ^{2/}	50.7 ***	50.2 ^{2/}	50.0 ***	<0.8 ^{3/}
	04:25-04:30 HOUR	51.5 ^{2/}	50.7 ***	46.8 ^{2/}	50.0 ***	<0.8 ^{3/}
	04:30-04:35 HOUR	52.3 ^{2/}	51.1 ***	49.1 ^{2/}	50.0 ***	<0.8 ^{3/}
	04:35-04:40 HOUR	51.4 ^{2/}	51.1 ***	42.6 ^{2/}	50.0 ***	<0.8 ^{3/}
	04:40-04:45 HOUR	52.9 ^{2/}	51.1 ***	51.2 ^{2/}	50.0 ***	1.2
	04:45-04:50 HOUR	52.1 ^{2/}	50.1 ***	50.8 ^{2/}	49.4 ***	1.4
	04:50-04:55 HOUR	52.2 ^{2/}	50.1 ***	51.0 ^{2/}	49.4 ***	1.6
	04:55-05:00 HOUR	51.6 ^{2/}	50.1 ***	49.3 ^{2/}	49.4 ***	<0.8 ^{3/}
	05:00-05:05 HOUR	51.3 ^{2/}	49.5 ***	49.6 ^{2/}	48.8 ***	0.8
	05:05-05:10 HOUR	51.7 ^{2/}	49.5 ***	50.7 ^{2/}	48.8 ***	1.9
	05:10-05:15 HOUR	51.7 ^{2/}	49.5 ***	50.7 ^{2/}	48.8 ***	1.9
	05:15-05:20 HOUR	51.3 ^{2/}	50.1 ***	48.1 ^{2/}	49.3 ***	<0.8 ^{3/}
	05:20-05:25 HOUR	52.3 ^{2/}	50.1 ***	51.3 ^{2/}	49.3 ***	2.0
	05:25-05:30 HOUR	51.4 ^{2/}	50.1 ***	48.5 ^{2/}	49.3 ***	<0.8 ^{3/}
	05:30-05:35 HOUR	53.4 ^{2/}	49.8 ***	53.9 ^{2/}	48.8 ***	5.1
	05:35-05:40 HOUR	51.8 ^{2/}	49.8 ***	50.5 ^{2/}	48.8 ***	1.7
	05:40-05:45 HOUR	51.6 ^{2/}	49.8 ***	49.9 ^{2/}	48.8 ***	1.1
	05:45-05:50 HOUR	52.1 ^{2/}	52.4 ***	<0.8 ^{3/}	50.2 ***	<0.8 ^{3/}
	05:50-05:55 HOUR	53.4 ^{2/}	52.4 ***	49.5 ^{2/}	50.2 ***	<0.8 ^{3/}
	05:55-06:00 HOUR	53.0 ^{2/}	52.4 ***	47.1 ^{2/}	50.2 ***	<0.8 ^{3/}
	DAY TIME ^{1/}					
	06:00-07:00 HOUR	55.2 ^{1/}	52.1 **	52.3 ^{1/}	49.7 **	2.6
MARCH 23, 2026 T26AG825-0004	DAY TIME ^{1/}					
	07:00-08:00 HOUR	59.4 ^{1/}	56.6 **	56.2 ^{1/}	51.9 **	4.3
	08:00-09:00 HOUR	56.8 ^{1/}	52.4 **	54.8 ^{1/}	50.8 **	4.0
	09:00-10:00 HOUR	55.4 ^{1/}	51.7 **	53.0 ^{1/}	50.5 **	2.5
	10:00-11:00 HOUR	54.8 ^{1/}	53.7 **	48.3 ^{1/}	50.1 **	<0.8 ^{3/}
	11:00-12:00 HOUR	55.2 ^{1/}	50.8 **	53.2 ^{1/}	49.6 **	3.6
	12:00-13:00 HOUR	53.0 ^{1/}	51.2 **	48.3 ^{1/}	49.5 **	<0.8 ^{3/}
	13:00-14:00 HOUR	53.0 ^{1/}	50.4 **	49.5 ^{1/}	49.2 **	<0.8 ^{3/}
	14:00-15:00 HOUR	54.6 ^{1/}	54.2 **	44.0 ^{1/}	49.4 **	<0.8 ^{3/}
	15:00-16:00 HOUR	53.0 ^{1/}	51.9 **	46.5 ^{1/}	50.2 **	<0.8 ^{3/}
	16:00-17:00 HOUR	54.8 ^{1/}	53.5 **	48.9 ^{1/}	50.1 **	<0.8 ^{3/}
	17:00-18:00 HOUR	56.2 ^{1/}	53.5 **	52.9 ^{1/}	50.9 **	2.0
	18:00-19:00 HOUR	54.7 ^{1/}	51.6 **	51.8 ^{1/}	49.7 **	2.1
	19:00-20:00 HOUR	53.1 ^{1/}	51.7 **	47.5 ^{1/}	49.6 **	<0.8 ^{3/}
	20:00-21:00 HOUR	53.7 ^{1/}	50.9 **	50.5 ^{1/}	49.9 **	<0.8 ^{3/}
	21:00-22:00 HOUR	52.1 ^{1/}	50.6 **	46.8 ^{1/}	50.0 **	<0.8 ^{3/}
	NIGHT TIME ^{2/}					
	22:00-22:05 HOUR	52.1 ^{2/}	51.2 ***	47.8 ^{2/}	50.1 ***	<0.8 ^{3/}
	22:05-22:10 HOUR	51.3 ^{2/}	51.2 ***	37.9 ^{2/}	50.1 ***	<0.8 ^{3/}
	22:10-22:15 HOUR	51.6 ^{2/}	51.2 ***	44.0 ^{2/}	50.1 ***	<0.8 ^{3/}
	22:15-22:20 HOUR	52.5 ^{2/}	51.9 ***	46.6 ^{2/}	50.7 ***	<0.8 ^{3/}
	22:20-22:25 HOUR	52.6 ^{2/}	51.9 ***	47.3 ^{2/}	50.7 ***	<0.8 ^{3/}
	22:25-22:30 HOUR	52.3 ^{2/}	51.9 ***	44.7 ^{2/}	50.7 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 23, 2026 T26AG825-0004	NIGHT TIME ^{2/}					
	22:30-22:35 HOUR	52.1 ^{2/}	49.7 ***	51.4 ^{2/}	49.1 ***	2.3
	22:35-22:40 HOUR	52.8 ^{2/}	49.7 ***	52.9 ^{2/}	49.1 ***	3.8
	22:40-22:45 HOUR	52.1 ^{2/}	49.7 ***	51.4 ^{2/}	49.1 ***	2.3
	22:45-22:50 HOUR	51.6 ^{2/}	50.4 ***	48.4 ^{2/}	49.7 ***	<0.8 ^{3/}
	22:50-22:55 HOUR	51.5 ^{2/}	50.4 ***	48.0 ^{2/}	49.7 ***	<0.8 ^{3/}
	22:55-23:00 HOUR	52.5 ^{2/}	50.4 ***	51.3 ^{2/}	49.7 ***	1.6
	23:00-23:05 HOUR	51.8 ^{2/}	50.9 ***	47.5 ^{2/}	50.0 ***	<0.8 ^{3/}
	23:05-23:10 HOUR	51.7 ^{2/}	50.9 ***	47.0 ^{2/}	50.0 ***	<0.8 ^{3/}
	23:10-23:15 HOUR	51.8 ^{2/}	50.9 ***	47.5 ^{2/}	50.0 ***	<0.8 ^{3/}
	23:15-23:20 HOUR	52.3 ^{2/}	49.3 ***	52.3 ^{2/}	48.6 ***	3.7
	23:20-23:25 HOUR	52.4 ^{2/}	49.3 ***	52.5 ^{2/}	48.6 ***	3.9
	23:25-23:30 HOUR	51.5 ^{2/}	49.3 ***	50.5 ^{2/}	48.6 ***	1.9
	23:30-23:35 HOUR	51.8 ^{2/}	49.9 ***	50.3 ^{2/}	49.2 ***	1.1
	23:35-23:40 HOUR	52.1 ^{2/}	49.9 ***	51.1 ^{2/}	49.2 ***	1.9
	23:40-23:45 HOUR	52.0 ^{2/}	49.9 ***	50.8 ^{2/}	49.2 ***	1.6
	23:45-23:50 HOUR	52.0 ^{2/}	49.3 ***	51.7 ^{2/}	48.6 ***	3.1
	23:50-23:55 HOUR	51.8 ^{2/}	49.3 ***	51.2 ^{2/}	48.6 ***	2.6
	23:55-00:00 HOUR	52.4 ^{2/}	49.3 ***	52.5 ^{2/}	48.6 ***	3.9
MARCH 24, 2026 T26AG825-0004	NIGHT TIME ^{2/}					
	00:00-00:05 HOUR	51.6 ^{2/}	50.2 ***	49.0 ^{2/}	49.6 ***	<0.8 ^{3/}
	00:05-00:10 HOUR	52.1 ^{2/}	50.2 ***	50.6 ^{2/}	49.6 ***	1.0
	00:10-00:15 HOUR	51.7 ^{2/}	50.2 ***	49.4 ^{2/}	49.6 ***	<0.8 ^{3/}
	00:15-00:20 HOUR	51.9 ^{2/}	51.4 ***	45.3 ^{2/}	50.2 ***	<0.8 ^{3/}
	00:20-00:25 HOUR	51.9 ^{2/}	51.4 ***	45.3 ^{2/}	50.2 ***	<0.8 ^{3/}
	00:25-00:30 HOUR	51.7 ^{2/}	51.4 ***	42.9 ^{2/}	50.2 ***	<0.8 ^{3/}
	00:30-00:35 HOUR	52.6 ^{2/}	51.3 ***	49.7 ^{2/}	50.2 ***	<0.8 ^{3/}
	00:35-00:40 HOUR	53.0 ^{2/}	51.3 ***	51.1 ^{2/}	50.2 ***	0.9
	00:40-00:45 HOUR	52.0 ^{2/}	51.3 ***	46.7 ^{2/}	50.2 ***	<0.8 ^{3/}
	00:45-00:50 HOUR	51.8 ^{2/}	51.8 ***	<0.8 ^{3/}	50.7 ***	<0.8 ^{3/}
	00:50-00:55 HOUR	53.1 ^{2/}	51.8 ***	50.2 ^{2/}	50.7 ***	<0.8 ^{3/}
	00:55-01:00 HOUR	52.1 ^{2/}	51.8 ***	43.3 ^{2/}	50.7 ***	<0.8 ^{3/}
	01:00-01:05 HOUR	52.6 ^{2/}	50.2 ***	51.9 ^{2/}	49.6 ***	2.3
	01:05-01:10 HOUR	51.7 ^{2/}	50.2 ***	49.4 ^{2/}	49.6 ***	<0.8 ^{3/}
	01:10-01:15 HOUR	51.6 ^{2/}	50.2 ***	49.0 ^{2/}	49.6 ***	<0.8 ^{3/}
	01:15-01:20 HOUR	52.1 ^{2/}	50.4 ***	50.2 ^{2/}	49.6 ***	<0.8 ^{3/}
	01:20-01:25 HOUR	51.6 ^{2/}	50.4 ***	48.4 ^{2/}	49.6 ***	<0.8 ^{3/}
	01:25-01:30 HOUR	52.2 ^{2/}	50.4 ***	50.5 ^{2/}	49.6 ***	0.9
	01:30-01:35 HOUR	54.8 ^{2/}	50.6 ***	55.7 ^{2/}	50.1 ***	5.6
	01:35-01:40 HOUR	52.4 ^{2/}	50.6 ***	50.7 ^{2/}	50.1 ***	<0.8 ^{3/}
	01:40-01:45 HOUR	51.6 ^{2/}	50.6 ***	47.7 ^{2/}	50.1 ***	<0.8 ^{3/}
	01:45-01:50 HOUR	51.6 ^{2/}	49.1 ***	51.0 ^{2/}	48.6 ***	2.4
	01:50-01:55 HOUR	51.6 ^{2/}	49.1 ***	51.0 ^{2/}	48.6 ***	2.4
	01:55-02:00 HOUR	52.0 ^{2/}	49.1 ***	51.9 ^{2/}	48.6 ***	3.3
	02:00-02:05 HOUR	52.3 ^{2/}	49.9 ***	51.6 ^{2/}	49.0 ***	2.6

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 24, 2026 T26AG825-0004	NIGHT TIME ^{2/}					
	02:05-02:10 HOUR	52.1 ^{2/}	49.9 ***	51.1 ^{2/}	49.0 ***	2.1
	02:10-02:15 HOUR	51.6 ^{2/}	49.9 ***	49.7 ^{2/}	49.0 ***	<0.8 ^{3/}
	02:15-02:20 HOUR	51.6 ^{2/}	50.6 ***	47.7 ^{2/}	50.0 ***	<0.8 ^{3/}
	02:20-02:25 HOUR	51.9 ^{2/}	50.6 ***	49.0 ^{2/}	50.0 ***	<0.8 ^{3/}
	02:25-02:30 HOUR	51.5 ^{2/}	50.6 ***	47.2 ^{2/}	50.0 ***	<0.8 ^{3/}
	02:30-02:35 HOUR	52.5 ^{2/}	51.4 ***	49.0 ^{2/}	50.6 ***	<0.8 ^{3/}
	02:35-02:40 HOUR	52.2 ^{2/}	51.4 ***	47.5 ^{2/}	50.6 ***	<0.8 ^{3/}
	02:40-02:45 HOUR	52.0 ^{2/}	51.4 ***	46.1 ^{2/}	50.6 ***	<0.8 ^{3/}
	02:45-02:50 HOUR	51.7 ^{2/}	51.1 ***	45.8 ^{2/}	50.5 ***	<0.8 ^{3/}
	02:50-02:55 HOUR	51.7 ^{2/}	51.1 ***	45.8 ^{2/}	50.5 ***	<0.8 ^{3/}
	02:55-03:00 HOUR	51.5 ^{2/}	51.1 ***	43.9 ^{2/}	50.5 ***	<0.8 ^{3/}
	03:00-03:05 HOUR	51.4 ^{2/}	49.8 ***	49.3 ^{2/}	49.0 ***	<0.8 ^{3/}
	03:05-03:10 HOUR	52.1 ^{2/}	49.8 ***	51.2 ^{2/}	49.0 ***	2.2
	03:10-03:15 HOUR	52.2 ^{2/}	49.8 ***	51.5 ^{2/}	49.0 ***	2.5
	03:15-03:20 HOUR	51.9 ^{2/}	49.3 ***	51.4 ^{2/}	48.5 ***	2.9
	03:20-03:25 HOUR	51.8 ^{2/}	49.3 ***	51.2 ^{2/}	48.5 ***	2.7
	03:25-03:30 HOUR	52.0 ^{2/}	49.3 ***	51.7 ^{2/}	48.5 ***	3.2
	03:30-03:35 HOUR	52.0 ^{2/}	50.6 ***	49.4 ^{2/}	49.9 ***	<0.8 ^{3/}
	03:35-03:40 HOUR	51.9 ^{2/}	50.6 ***	49.0 ^{2/}	49.9 ***	<0.8 ^{3/}
	03:40-03:45 HOUR	51.9 ^{2/}	50.6 ***	49.0 ^{2/}	49.9 ***	<0.8 ^{3/}
	03:45-03:50 HOUR	51.5 ^{2/}	50.0 ***	49.2 ^{2/}	49.4 ***	<0.8 ^{3/}
	03:50-03:55 HOUR	51.4 ^{2/}	50.0 ***	48.8 ^{2/}	49.4 ***	<0.8 ^{3/}
	03:55-04:00 HOUR	51.8 ^{2/}	50.0 ***	50.1 ^{2/}	49.4 ***	<0.8 ^{3/}
	04:00-04:05 HOUR	52.7 ^{2/}	51.1 ***	50.6 ^{2/}	49.6 ***	1.0
	04:05-04:10 HOUR	52.4 ^{2/}	51.1 ***	49.5 ^{2/}	49.6 ***	<0.8 ^{3/}
	04:10-04:15 HOUR	52.4 ^{2/}	51.1 ***	49.5 ^{2/}	49.6 ***	<0.8 ^{3/}
	04:15-04:20 HOUR	53.2 ^{2/}	51.4 ***	51.5 ^{2/}	50.0 ***	1.5
	04:20-04:25 HOUR	52.3 ^{2/}	51.4 ***	48.0 ^{2/}	50.0 ***	<0.8 ^{3/}
	04:25-04:30 HOUR	51.8 ^{2/}	51.4 ***	44.2 ^{2/}	50.0 ***	<0.8 ^{3/}
	04:30-04:35 HOUR	51.8 ^{2/}	50.2 ***	49.7 ^{2/}	49.5 ***	<0.8 ^{3/}
	04:35-04:40 HOUR	51.7 ^{2/}	50.2 ***	49.4 ^{2/}	49.5 ***	<0.8 ^{3/}
	04:40-04:45 HOUR	51.9 ^{2/}	50.2 ***	50.0 ^{2/}	49.5 ***	<0.8 ^{3/}
	04:45-04:50 HOUR	52.2 ^{2/}	50.1 ***	51.0 ^{2/}	49.5 ***	1.5
	04:50-04:55 HOUR	51.4 ^{2/}	50.1 ***	48.5 ^{2/}	49.5 ***	<0.8 ^{3/}
	04:55-05:00 HOUR	51.7 ^{2/}	50.1 ***	49.6 ^{2/}	49.5 ***	<0.8 ^{3/}
	05:00-05:05 HOUR	51.8 ^{2/}	50.3 ***	49.5 ^{2/}	49.0 ***	<0.8 ^{3/}
	05:05-05:10 HOUR	51.6 ^{2/}	50.3 ***	48.7 ^{2/}	49.0 ***	<0.8 ^{3/}
	05:10-05:15 HOUR	52.1 ^{2/}	50.3 ***	50.4 ^{2/}	49.0 ***	1.4
	05:15-05:20 HOUR	53.4 ^{2/}	50.7 ***	53.1 ^{2/}	50.0 ***	3.1
	05:20-05:25 HOUR	52.1 ^{2/}	50.7 ***	49.5 ^{2/}	50.0 ***	<0.8 ^{3/}
	05:25-05:30 HOUR	51.6 ^{2/}	50.7 ***	47.3 ^{2/}	50.0 ***	<0.8 ^{3/}
	05:30-05:35 HOUR	51.5 ^{2/}	51.3 ***	41.0 ^{2/}	49.9 ***	<0.8 ^{3/}
	05:35-05:40 HOUR	52.1 ^{2/}	51.3 ***	47.4 ^{2/}	49.9 ***	<0.8 ^{3/}
	05:40-05:45 HOUR	52.7 ^{2/}	51.3 ***	50.1 ^{2/}	49.9 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 24, 2026 T26AG825-0004	NIGHT TIME ^{2/} 05:45-05:50 HOUR	52.4 ^{2/}	51.3 ***	48.9 ^{2/}	49.2 ***	<0.8 ^{3/}
	05:50-05:55 HOUR	53.7 ^{2/}	51.3 ***	53.0 ^{2/}	49.2 ***	3.8
	05:55-06:00 HOUR	53.7 ^{2/}	51.3 ***	53.0 ^{2/}	49.2 ***	3.8
	DAY TIME ^{1/} 06:00-07:00 HOUR	55.6 ^{1/}	54.3 **	49.7 ^{1/}	51.1 **	<0.8 ^{3/}
MARCH 24, 2026 T26AG825-0005	DAY TIME ^{1/} 07:00-08:00 HOUR	60.2 ^{1/}	55.6 **	58.4 ^{1/}	51.4 **	7.0
	08:00-09:00 HOUR	57.8 ^{1/}	56.0 **	53.1 ^{1/}	51.5 **	1.6
	09:00-10:00 HOUR	58.7 ^{1/}	56.1 **	55.2 ^{1/}	52.7 **	2.5
	10:00-11:00 HOUR	52.6 ^{1/}	51.0 **	47.5 ^{1/}	46.7 **	0.8
	11:00-12:00 HOUR	54.4 ^{1/}	53.6 **	46.7 ^{1/}	49.8 **	<0.8 ^{3/}
	12:00-13:00 HOUR	53.1 ^{1/}	50.5 **	49.6 ^{1/}	49.4 **	<0.8 ^{3/}
	13:00-14:00 HOUR	54.6 ^{1/}	52.5 **	50.4 ^{1/}	49.4 **	1.0
	14:00-15:00 HOUR	53.2 ^{1/}	51.4 **	48.5 ^{1/}	49.8 **	<0.8 ^{3/}
	15:00-16:00 HOUR	53.3 ^{1/}	51.0 **	49.4 ^{1/}	49.8 **	<0.8 ^{3/}
	16:00-17:00 HOUR	53.5 ^{1/}	51.1 **	49.8 ^{1/}	49.4 **	<0.8 ^{3/}
	17:00-18:00 HOUR	55.9 ^{1/}	53.4 **	52.3 ^{1/}	49.8 **	2.5
	18:00-19:00 HOUR	56.0 ^{1/}	54.5 **	50.7 ^{1/}	49.5 **	1.2
	19:00-20:00 HOUR	54.1 ^{1/}	50.9 **	51.3 ^{1/}	49.0 **	2.3
	20:00-21:00 HOUR	52.3 ^{1/}	51.5 **	44.6 ^{1/}	48.2 **	<0.8 ^{3/}
	21:00-22:00 HOUR	51.1 ^{1/}	49.6 **	45.8 ^{1/}	48.7 **	<0.8 ^{3/}
	NIGHT TIME ^{2/} 22:00-22:05 HOUR	51.1 ^{2/}	48.6 ***	50.5 ^{2/}	47.7 ***	2.8
	22:05-22:10 HOUR	50.8 ^{2/}	48.6 ***	49.8 ^{2/}	47.7 ***	2.1
	22:10-22:15 HOUR	50.8 ^{2/}	48.6 ***	49.8 ^{2/}	47.7 ***	2.1
	22:15-22:20 HOUR	50.3 ^{2/}	49.3 ***	46.4 ^{2/}	48.3 ***	<0.8 ^{3/}
	22:20-22:25 HOUR	51.0 ^{2/}	49.3 ***	49.1 ^{2/}	48.3 ***	0.8
	22:25-22:30 HOUR	50.9 ^{2/}	49.3 ***	48.8 ^{2/}	48.3 ***	<0.8 ^{3/}
	22:30-22:35 HOUR	50.6 ^{2/}	49.8 ***	45.9 ^{2/}	48.5 ***	<0.8 ^{3/}
	22:35-22:40 HOUR	50.9 ^{2/}	49.8 ***	47.4 ^{2/}	48.5 ***	<0.8 ^{3/}
	22:40-22:45 HOUR	51.1 ^{2/}	49.8 ***	48.2 ^{2/}	48.5 ***	<0.8 ^{3/}
	22:45-22:50 HOUR	52.0 ^{2/}	49.8 ***	51.0 ^{2/}	49.2 ***	1.8
	22:50-22:55 HOUR	50.7 ^{2/}	49.8 ***	46.4 ^{2/}	49.2 ***	<0.8 ^{3/}
	22:55-23:00 HOUR	50.3 ^{2/}	49.8 ***	43.7 ^{2/}	49.2 ***	<0.8 ^{3/}
	23:00-23:05 HOUR	50.4 ^{2/}	49.4 ***	46.5 ^{2/}	48.8 ***	<0.8 ^{3/}
	23:05-23:10 HOUR	50.1 ^{2/}	49.4 ***	44.8 ^{2/}	48.8 ***	<0.8 ^{3/}
	23:10-23:15 HOUR	50.3 ^{2/}	49.4 ***	46.0 ^{2/}	48.8 ***	<0.8 ^{3/}
	23:15-23:20 HOUR	50.9 ^{2/}	49.5 ***	48.3 ^{2/}	48.4 ***	<0.8 ^{3/}
	23:20-23:25 HOUR	51.7 ^{2/}	49.5 ***	50.7 ^{2/}	48.4 ***	2.3
	23:25-23:30 HOUR	50.6 ^{2/}	49.5 ***	47.1 ^{2/}	48.4 ***	<0.8 ^{3/}
	23:30-23:35 HOUR	52.5 ^{2/}	49.6 ***	52.4 ^{2/}	48.6 ***	3.8
	23:35-23:40 HOUR	51.3 ^{2/}	49.6 ***	49.4 ^{2/}	48.6 ***	0.8
	23:40-23:45 HOUR	51.1 ^{2/}	49.6 ***	48.8 ^{2/}	48.6 ***	<0.8 ^{3/}
	23:45-23:50 HOUR	51.0 ^{2/}	50.3 ***	45.7 ^{2/}	49.5 ***	<0.8 ^{3/}
	23:50-23:55 HOUR	51.1 ^{2/}	50.3 ***	46.4 ^{2/}	49.5 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 24, 2026 T26AG825-0005	NIGHT TIME ^{2/} 23:55-00:00 HOUR	50.3 ^{2/}	50.3 ***	<0.8 ^{3/}	49.5 ***	<0.8 ^{3/}
MARCH 25, 2026 T26AG825-0005	NIGHT TIME ^{2/} 00:00-00:05 HOUR	50.9 ^{2/}	50.2 ***	45.6 ^{2/}	49.5 ***	<0.8 ^{3/}
	00:05-00:10 HOUR	51.2 ^{2/}	50.2 ***	47.3 ^{2/}	49.5 ***	<0.8 ^{3/}
	00:10-00:15 HOUR	50.9 ^{2/}	50.2 ***	45.6 ^{2/}	49.5 ***	<0.8 ^{3/}
	00:15-00:20 HOUR	50.5 ^{2/}	49.6 ***	46.2 ^{2/}	49.0 ***	<0.8 ^{3/}
	00:20-00:25 HOUR	50.7 ^{2/}	49.6 ***	47.2 ^{2/}	49.0 ***	<0.8 ^{3/}
	00:25-00:30 HOUR	50.6 ^{2/}	49.6 ***	46.7 ^{2/}	49.0 ***	<0.8 ^{3/}
	00:30-00:35 HOUR	50.9 ^{2/}	49.7 ***	47.7 ^{2/}	48.7 ***	<0.8 ^{3/}
	00:35-00:40 HOUR	50.6 ^{2/}	49.7 ***	46.3 ^{2/}	48.7 ***	<0.8 ^{3/}
	00:40-00:45 HOUR	50.3 ^{2/}	49.7 ***	44.4 ^{2/}	48.7 ***	<0.8 ^{3/}
	00:45-00:50 HOUR	51.9 ^{2/}	47.8 ***	52.8 ^{2/}	47.2 ***	5.6
	00:50-00:55 HOUR	49.9 ^{2/}	47.8 ***	48.7 ^{2/}	47.2 ***	1.5
	00:55-01:00 HOUR	50.5 ^{2/}	47.8 ***	50.2 ^{2/}	47.2 ***	3.0
	01:00-01:05 HOUR	50.5 ^{2/}	49.5 ***	46.6 ^{2/}	48.5 ***	<0.8 ^{3/}
	01:05-01:10 HOUR	50.5 ^{2/}	49.5 ***	46.6 ^{2/}	48.5 ***	<0.8 ^{3/}
	01:10-01:15 HOUR	50.2 ^{2/}	49.5 ***	44.9 ^{2/}	48.5 ***	<0.8 ^{3/}
	01:15-01:20 HOUR	50.7 ^{2/}	49.3 ***	48.1 ^{2/}	48.6 ***	<0.8 ^{3/}
	01:20-01:25 HOUR	50.7 ^{2/}	49.3 ***	48.1 ^{2/}	48.6 ***	<0.8 ^{3/}
	01:25-01:30 HOUR	50.5 ^{2/}	49.3 ***	47.3 ^{2/}	48.6 ***	<0.8 ^{3/}
	01:30-01:35 HOUR	50.3 ^{2/}	49.1 ***	47.1 ^{2/}	48.6 ***	<0.8 ^{3/}
	01:35-01:40 HOUR	50.1 ^{2/}	49.1 ***	46.2 ^{2/}	48.6 ***	<0.8 ^{3/}
	01:40-01:45 HOUR	49.9 ^{2/}	49.1 ***	45.2 ^{2/}	48.6 ***	<0.8 ^{3/}
	01:45-01:50 HOUR	50.0 ^{2/}	48.2 ***	48.3 ^{2/}	47.6 ***	<0.8 ^{3/}
	01:50-01:55 HOUR	50.1 ^{2/}	48.2 ***	48.6 ^{2/}	47.6 ***	1.0
	01:55-02:00 HOUR	50.6 ^{2/}	48.2 ***	49.9 ^{2/}	47.6 ***	2.3
	02:00-02:05 HOUR	50.0 ^{2/}	49.6 ***	42.4 ^{2/}	48.6 ***	<0.8 ^{3/}
	02:05-02:10 HOUR	51.0 ^{2/}	49.6 ***	48.4 ^{2/}	48.6 ***	<0.8 ^{3/}
	02:10-02:15 HOUR	50.7 ^{2/}	49.6 ***	47.2 ^{2/}	48.6 ***	<0.8 ^{3/}
	02:15-02:20 HOUR	50.1 ^{2/}	49.5 ***	44.2 ^{2/}	49.0 ***	<0.8 ^{3/}
	02:20-02:25 HOUR	50.0 ^{2/}	49.5 ***	43.4 ^{2/}	49.0 ***	<0.8 ^{3/}
	02:25-02:30 HOUR	50.0 ^{2/}	49.5 ***	43.4 ^{2/}	49.0 ***	<0.8 ^{3/}
	02:30-02:35 HOUR	49.9 ^{2/}	48.9 ***	46.0 ^{2/}	48.5 ***	<0.8 ^{3/}
	02:35-02:40 HOUR	49.9 ^{2/}	48.9 ***	46.0 ^{2/}	48.5 ***	<0.8 ^{3/}
	02:40-02:45 HOUR	49.9 ^{2/}	48.9 ***	46.0 ^{2/}	48.5 ***	<0.8 ^{3/}
	02:45-02:50 HOUR	50.0 ^{2/}	48.5 ***	47.7 ^{2/}	47.5 ***	<0.8 ^{3/}
	02:50-02:55 HOUR	50.0 ^{2/}	48.5 ***	47.7 ^{2/}	47.5 ***	<0.8 ^{3/}
	02:55-03:00 HOUR	50.1 ^{2/}	48.5 ***	48.0 ^{2/}	47.5 ***	<0.8 ^{3/}
	03:00-03:05 HOUR	51.6 ^{2/}	48.8 ***	51.4 ^{2/}	48.4 ***	3.0
	03:05-03:10 HOUR	50.1 ^{2/}	48.8 ***	47.2 ^{2/}	48.4 ***	<0.8 ^{3/}
	03:10-03:15 HOUR	49.8 ^{2/}	48.8 ***	45.9 ^{2/}	48.4 ***	<0.8 ^{3/}
	03:15-03:20 HOUR	49.8 ^{2/}	48.0 ***	48.1 ^{2/}	47.5 ***	<0.8 ^{3/}
	03:20-03:25 HOUR	49.9 ^{2/}	48.0 ***	48.4 ^{2/}	47.5 ***	0.9
	03:25-03:30 HOUR	49.8 ^{2/}	48.0 ***	48.1 ^{2/}	47.5 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 25, 2026 T26AG825-0005	NIGHT TIME ^{2/}					
	03:30-03:35 HOUR	50.3 ^{2/}	47.9 ***	49.6 ^{2/}	47.4 ***	2.2
	03:35-03:40 HOUR	49.8 ^{2/}	47.9 ***	48.3 ^{2/}	47.4 ***	0.9
	03:40-03:45 HOUR	49.7 ^{2/}	47.9 ***	48.0 ^{2/}	47.4 ***	<0.8 ^{3/}
	03:45-03:50 HOUR	53.1 ^{2/}	49.0 ***	54.0 ^{2/}	47.5 ***	6.5
	03:50-03:55 HOUR	51.6 ^{2/}	49.0 ***	51.1 ^{2/}	47.5 ***	3.6
	03:55-04:00 HOUR	49.8 ^{2/}	49.0 ***	45.1 ^{2/}	47.5 ***	<0.8 ^{3/}
	04:00-04:05 HOUR	52.3 ^{2/}	47.9 ***	53.3 ^{2/}	47.1 ***	6.2
	04:05-04:10 HOUR	51.1 ^{2/}	47.9 ***	51.3 ^{2/}	47.1 ***	4.2
	04:10-04:15 HOUR	50.2 ^{2/}	47.9 ***	49.3 ^{2/}	47.1 ***	2.2
	04:15-04:20 HOUR	50.0 ^{2/}	49.8 ***	39.5 ^{2/}	49.0 ***	<0.8 ^{3/}
	04:20-04:25 HOUR	52.1 ^{2/}	49.8 ***	51.2 ^{2/}	49.0 ***	2.2
	04:25-04:30 HOUR	50.1 ^{2/}	49.8 ***	41.3 ^{2/}	49.0 ***	<0.8 ^{3/}
	04:30-04:35 HOUR	49.9 ^{2/}	49.7 ***	39.4 ^{2/}	49.0 ***	<0.8 ^{3/}
	04:35-04:40 HOUR	50.8 ^{2/}	49.7 ***	47.3 ^{2/}	49.0 ***	<0.8 ^{3/}
	04:40-04:45 HOUR	50.0 ^{2/}	49.7 ***	41.2 ^{2/}	49.0 ***	<0.8 ^{3/}
	04:45-04:50 HOUR	50.6 ^{2/}	48.3 ***	49.7 ^{2/}	47.5 ***	2.2
	04:50-04:55 HOUR	49.9 ^{2/}	48.3 ***	47.8 ^{2/}	47.5 ***	<0.8 ^{3/}
	04:55-05:00 HOUR	50.8 ^{2/}	48.3 ***	50.2 ^{2/}	47.5 ***	2.7
	05:00-05:05 HOUR	50.3 ^{2/}	50.6 ***	<0.8 ^{3/}	48.6 ***	<0.8 ^{3/}
	05:05-05:10 HOUR	50.2 ^{2/}	50.6 ***	<0.8 ^{3/}	48.6 ***	<0.8 ^{3/}
	05:10-05:15 HOUR	53.8 ^{2/}	50.6 ***	54.0 ^{2/}	48.6 ***	5.4
	05:15-05:20 HOUR	51.0 ^{2/}	48.9 ***	49.8 ^{2/}	48.0 ***	1.8
	05:20-05:25 HOUR	51.2 ^{2/}	48.9 ***	50.3 ^{2/}	48.0 ***	2.3
	05:25-05:30 HOUR	50.3 ^{2/}	48.9 ***	47.7 ^{2/}	48.0 ***	<0.8 ^{3/}
	05:30-05:35 HOUR	50.1 ^{2/}	51.0 ***	<0.8 ^{3/}	48.9 ***	<0.8 ^{3/}
	05:35-05:40 HOUR	50.8 ^{2/}	51.0 ***	<0.8 ^{3/}	48.9 ***	<0.8 ^{3/}
	05:40-05:45 HOUR	51.4 ^{2/}	51.0 ***	43.8 ^{2/}	48.9 ***	<0.8 ^{3/}
	05:45-05:50 HOUR	53.1 ^{2/}	50.7 ***	52.4 ^{2/}	47.8 ***	4.6
	05:50-05:55 HOUR	51.7 ^{2/}	50.7 ***	47.8 ^{2/}	47.8 ***	<0.8 ^{3/}
	05:55-06:00 HOUR	55.2 ^{2/}	50.7 ***	56.3 ^{2/}	47.8 ***	8.5
	DAY TIME ^{1/}					
	06:00-07:00 HOUR	54.7 ^{1/}	54.2 **	45.1 ^{1/}	50.0 **	<0.8 ^{3/}
MARCH 25, 2026 T26AG825-0006	DAY TIME ^{1/}					
	07:00-08:00 HOUR	58.4 ^{1/}	55.2 **	55.6 ^{1/}	51.1 **	4.5
	08:00-09:00 HOUR	55.8 ^{1/}	53.1 **	52.5 ^{1/}	48.5 **	4.0
	09:00-10:00 HOUR	53.1 ^{1/}	52.1 **	46.2 ^{1/}	48.5 **	<0.8 ^{3/}
	10:00-11:00 HOUR	52.1 ^{1/}	49.6 **	48.5 ^{1/}	47.7 **	0.8
	11:00-12:00 HOUR	54.4 ^{1/}	51.5 **	51.3 ^{1/}	49.4 **	1.9
	12:00-13:00 HOUR	52.9 ^{1/}	50.7 **	48.9 ^{1/}	49.3 **	<0.8 ^{3/}
	13:00-14:00 HOUR	53.9 ^{1/}	51.5 **	50.2 ^{1/}	49.6 **	<0.8 ^{3/}
	14:00-15:00 HOUR	53.0 ^{1/}	51.7 **	47.1 ^{1/}	50.2 **	<0.8 ^{3/}
	15:00-16:00 HOUR	52.7 ^{1/}	50.9 **	48.0 ^{1/}	50.1 **	<0.8 ^{3/}
	16:00-17:00 HOUR	53.6 ^{1/}	52.4 **	47.4 ^{1/}	50.3 **	<0.8 ^{3/}
	17:00-18:00 HOUR	55.8 ^{1/}	53.5 **	51.9 ^{1/}	50.0 **	1.9
	18:00-19:00 HOUR	54.6 ^{1/}	52.8 **	49.9 ^{1/}	49.6 **	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 25, 2026 T26AG825-0006	DAY TIME ^{1/}					
	19:00-20:00 HOUR	55.8 ^{1/}	53.7 **	51.6 ^{1/}	48.7 **	2.9
	20:00-21:00 HOUR	52.1 ^{1/}	50.6 **	46.8 ^{1/}	49.7 **	<0.8 ^{3/}
	21:00-22:00 HOUR	52.0 ^{1/}	50.0 **	47.7 ^{1/}	49.2 **	<0.8 ^{3/}
	NIGHT TIME ^{2/}					
	22:00-22:05 HOUR	50.6 ^{2/}	49.2 ***	48.0 ^{2/}	48.8 ***	<0.8 ^{3/}
	22:05-22:10 HOUR	51.0 ^{2/}	49.2 ***	49.3 ^{2/}	48.8 ***	<0.8 ^{3/}
	22:10-22:15 HOUR	50.6 ^{2/}	49.2 ***	48.0 ^{2/}	48.8 ***	<0.8 ^{3/}
	22:15-22:20 HOUR	51.0 ^{2/}	49.9 ***	47.5 ^{2/}	48.4 ***	<0.8 ^{3/}
	22:20-22:25 HOUR	51.4 ^{2/}	49.9 ***	49.1 ^{2/}	48.4 ***	<0.8 ^{3/}
	22:25-22:30 HOUR	51.0 ^{2/}	49.9 ***	47.5 ^{2/}	48.4 ***	<0.8 ^{3/}
	22:30-22:35 HOUR	52.7 ^{2/}	50.1 ***	52.2 ^{2/}	48.8 ***	3.4
	22:35-22:40 HOUR	52.2 ^{2/}	50.1 ***	51.0 ^{2/}	48.8 ***	2.2
	22:40-22:45 HOUR	51.6 ^{2/}	50.1 ***	49.3 ^{2/}	48.8 ***	<0.8 ^{3/}
	22:45-22:50 HOUR	51.6 ^{2/}	49.0 ***	51.1 ^{2/}	48.2 ***	2.9
	22:50-22:55 HOUR	51.8 ^{2/}	49.0 ***	51.6 ^{2/}	48.2 ***	3.4
	22:55-23:00 HOUR	51.4 ^{2/}	49.0 ***	50.7 ^{2/}	48.2 ***	2.5
	23:00-23:05 HOUR	51.1 ^{2/}	49.8 ***	48.2 ^{2/}	49.2 ***	<0.8 ^{3/}
	23:05-23:10 HOUR	50.6 ^{2/}	49.8 ***	45.9 ^{2/}	49.2 ***	<0.8 ^{3/}
	23:10-23:15 HOUR	50.7 ^{2/}	49.8 ***	46.4 ^{2/}	49.2 ***	<0.8 ^{3/}
	23:15-23:20 HOUR	51.5 ^{2/}	49.3 ***	50.5 ^{2/}	48.6 ***	1.9
	23:20-23:25 HOUR	51.0 ^{2/}	49.3 ***	49.1 ^{2/}	48.6 ***	<0.8 ^{3/}
	23:25-23:30 HOUR	50.5 ^{2/}	49.3 ***	47.3 ^{2/}	48.6 ***	<0.8 ^{3/}
	23:30-23:35 HOUR	51.1 ^{2/}	50.8 ***	42.3 ^{2/}	49.7 ***	<0.8 ^{3/}
	23:35-23:40 HOUR	50.6 ^{2/}	50.8 ***	<0.8 ^{3/}	49.7 ***	<0.8 ^{3/}
	23:40-23:45 HOUR	50.7 ^{2/}	50.8 ***	<0.8 ^{3/}	49.7 ***	<0.8 ^{3/}
	23:45-23:50 HOUR	52.5 ^{2/}	49.9 ***	52.0 ^{2/}	48.7 ***	3.3
	23:50-23:55 HOUR	51.4 ^{2/}	49.9 ***	49.1 ^{2/}	48.7 ***	<0.8 ^{3/}
	23:55-00:00 HOUR	50.5 ^{2/}	49.9 ***	44.6 ^{2/}	48.7 ***	<0.8 ^{3/}
MARCH 26, 2026 T26AG825-0006	NIGHT TIME ^{2/}					
	00:00-00:05 HOUR	51.7 ^{2/}	50.0 ***	49.8 ^{2/}	49.2 ***	<0.8 ^{3/}
	00:05-00:10 HOUR	50.8 ^{2/}	50.0 ***	46.1 ^{2/}	49.2 ***	<0.8 ^{3/}
	00:10-00:15 HOUR	50.5 ^{2/}	50.0 ***	43.9 ^{2/}	49.2 ***	<0.8 ^{3/}
	00:15-00:20 HOUR	54.7 ^{2/}	50.3 ***	55.7 ^{2/}	49.7 ***	6.0
	00:20-00:25 HOUR	50.6 ^{2/}	50.3 ***	41.8 ^{2/}	49.7 ***	<0.8 ^{3/}
	00:25-00:30 HOUR	50.7 ^{2/}	50.3 ***	43.1 ^{2/}	49.7 ***	<0.8 ^{3/}
	00:30-00:35 HOUR	50.5 ^{2/}	49.2 ***	47.6 ^{2/}	48.6 ***	<0.8 ^{3/}
	00:35-00:40 HOUR	51.2 ^{2/}	49.2 ***	49.9 ^{2/}	48.6 ***	1.3
	00:40-00:45 HOUR	50.6 ^{2/}	49.2 ***	48.0 ^{2/}	48.6 ***	<0.8 ^{3/}
	00:45-00:50 HOUR	51.0 ^{2/}	49.5 ***	48.7 ^{2/}	48.8 ***	<0.8 ^{3/}
	00:50-00:55 HOUR	50.7 ^{2/}	49.5 ***	47.5 ^{2/}	48.8 ***	<0.8 ^{3/}
	00:55-01:00 HOUR	51.1 ^{2/}	49.5 ***	49.0 ^{2/}	48.8 ***	<0.8 ^{3/}
	01:00-01:05 HOUR	51.4 ^{2/}	51.0 ***	43.8 ^{2/}	49.9 ***	<0.8 ^{3/}
	01:05-01:10 HOUR	51.6 ^{2/}	51.0 ***	45.7 ^{2/}	49.9 ***	<0.8 ^{3/}
	01:10-01:15 HOUR	52.4 ^{2/}	51.0 ***	49.8 ^{2/}	49.9 ***	<0.8 ^{3/}
	01:15-01:20 HOUR	50.8 ^{2/}	48.6 ***	49.8 ^{2/}	47.7 ***	2.1

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 26, 2026 T26AG825-0006	NIGHT TIME ^{2/}					
	01:20-01:25 HOUR	51.3 ^{2/}	48.6 ***	51.0 ^{2/}	47.7 ***	3.3
	01:25-01:30 HOUR	50.7 ^{2/}	48.6 ***	49.5 ^{2/}	47.7 ***	1.8
	01:30-01:35 HOUR	51.4 ^{2/}	50.4 ***	47.5 ^{2/}	49.3 ***	<0.8 ^{3/}
	01:35-01:40 HOUR	51.8 ^{2/}	50.4 ***	49.2 ^{2/}	49.3 ***	<0.8 ^{3/}
	01:40-01:45 HOUR	51.9 ^{2/}	50.4 ***	49.6 ^{2/}	49.3 ***	<0.8 ^{3/}
	01:45-01:50 HOUR	50.7 ^{2/}	49.4 ***	47.8 ^{2/}	48.3 ***	<0.8 ^{3/}
	01:50-01:55 HOUR	51.7 ^{2/}	49.4 ***	50.8 ^{2/}	48.3 ***	2.5
	01:55-02:00 HOUR	51.6 ^{2/}	49.4 ***	50.6 ^{2/}	48.3 ***	2.3
	02:00-02:05 HOUR	51.8 ^{2/}	49.4 ***	51.1 ^{2/}	48.7 ***	2.4
	02:05-02:10 HOUR	50.9 ^{2/}	49.4 ***	48.6 ^{2/}	48.7 ***	<0.8 ^{3/}
	02:10-02:15 HOUR	50.8 ^{2/}	49.4 ***	48.2 ^{2/}	48.7 ***	<0.8 ^{3/}
	02:15-02:20 HOUR	50.7 ^{2/}	50.4 ***	41.9 ^{2/}	49.3 ***	<0.8 ^{3/}
	02:20-02:25 HOUR	51.4 ^{2/}	50.4 ***	47.5 ^{2/}	49.3 ***	<0.8 ^{3/}
	02:25-02:30 HOUR	52.2 ^{2/}	50.4 ***	50.5 ^{2/}	49.3 ***	1.2
	02:30-02:35 HOUR	51.5 ^{2/}	50.8 ***	46.2 ^{2/}	49.8 ***	<0.8 ^{3/}
	02:35-02:40 HOUR	50.7 ^{2/}	50.8 ***	<0.8 ^{3/}	49.8 ***	<0.8 ^{3/}
	02:40-02:45 HOUR	52.1 ^{2/}	50.8 ***	49.2 ^{2/}	49.8 ***	<0.8 ^{3/}
	02:45-02:50 HOUR	51.0 ^{2/}	49.7 ***	48.1 ^{2/}	48.8 ***	<0.8 ^{3/}
	02:50-02:55 HOUR	51.3 ^{2/}	49.7 ***	49.2 ^{2/}	48.8 ***	<0.8 ^{3/}
	02:55-03:00 HOUR	51.4 ^{2/}	49.7 ***	49.5 ^{2/}	48.8 ***	<0.8 ^{3/}
	03:00-03:05 HOUR	50.8 ^{2/}	49.8 ***	46.9 ^{2/}	49.2 ***	<0.8 ^{3/}
	03:05-03:10 HOUR	51.3 ^{2/}	49.8 ***	49.0 ^{2/}	49.2 ***	<0.8 ^{3/}
	03:10-03:15 HOUR	50.6 ^{2/}	49.8 ***	45.9 ^{2/}	49.2 ***	<0.8 ^{3/}
	03:15-03:20 HOUR	50.7 ^{2/}	49.7 ***	46.8 ^{2/}	49.3 ***	<0.8 ^{3/}
	03:20-03:25 HOUR	50.7 ^{2/}	49.7 ***	46.8 ^{2/}	49.3 ***	<0.8 ^{3/}
	03:25-03:30 HOUR	50.7 ^{2/}	49.7 ***	46.8 ^{2/}	49.3 ***	<0.8 ^{3/}
	03:30-03:35 HOUR	50.7 ^{2/}	49.8 ***	46.4 ^{2/}	48.8 ***	<0.8 ^{3/}
	03:35-03:40 HOUR	50.7 ^{2/}	49.8 ***	46.4 ^{2/}	48.8 ***	<0.8 ^{3/}
	03:40-03:45 HOUR	50.7 ^{2/}	49.8 ***	46.4 ^{2/}	48.8 ***	<0.8 ^{3/}
	03:45-03:50 HOUR	52.5 ^{2/}	48.8 ***	53.1 ^{2/}	47.9 ***	5.2
	03:50-03:55 HOUR	51.4 ^{2/}	48.8 ***	50.9 ^{2/}	47.9 ***	3.0
	03:55-04:00 HOUR	51.3 ^{2/}	48.8 ***	50.7 ^{2/}	47.9 ***	2.8
	04:00-04:05 HOUR	51.3 ^{2/}	50.9 ***	43.7 ^{2/}	49.5 ***	<0.8 ^{3/}
	04:05-04:10 HOUR	51.5 ^{2/}	50.9 ***	45.6 ^{2/}	49.5 ***	<0.8 ^{3/}
	04:10-04:15 HOUR	51.7 ^{2/}	50.9 ***	47.0 ^{2/}	49.5 ***	<0.8 ^{3/}
	04:15-04:20 HOUR	53.0 ^{2/}	50.2 ***	52.8 ^{2/}	49.0 ***	3.8
	04:20-04:25 HOUR	51.0 ^{2/}	50.2 ***	46.3 ^{2/}	49.0 ***	<0.8 ^{3/}
	04:25-04:30 HOUR	53.0 ^{2/}	50.2 ***	52.8 ^{2/}	49.0 ***	3.8
	04:30-04:35 HOUR	51.3 ^{2/}	50.3 ***	47.4 ^{2/}	49.2 ***	<0.8 ^{3/}
	04:35-04:40 HOUR	50.9 ^{2/}	50.3 ***	45.0 ^{2/}	49.2 ***	<0.8 ^{3/}
	04:40-04:45 HOUR	52.6 ^{2/}	50.3 ***	51.7 ^{2/}	49.2 ***	2.5
	04:45-04:50 HOUR	50.6 ^{2/}	50.5 ***	37.2 ^{2/}	49.7 ***	<0.8 ^{3/}
	04:50-04:55 HOUR	51.5 ^{2/}	50.5 ***	47.6 ^{2/}	49.7 ***	<0.8 ^{3/}
	04:55-05:00 HOUR	50.8 ^{2/}	50.5 ***	42.0 ^{2/}	49.7 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 26, 2026 T26AG825-0006	NIGHT TIME ^{2/}					
	05:00-05:05 HOUR	51.1 ^{2/}	50.5 ***	45.2 ^{2/}	49.2 ***	<0.8 ^{3/}
	05:05-05:10 HOUR	51.8 ^{2/}	50.5 ***	48.9 ^{2/}	49.2 ***	<0.8 ^{3/}
	05:10-05:15 HOUR	51.8 ^{2/}	50.5 ***	48.9 ^{2/}	49.2 ***	<0.8 ^{3/}
	05:15-05:20 HOUR	51.3 ^{2/}	50.5 ***	46.6 ^{2/}	49.3 ***	<0.8 ^{3/}
	05:20-05:25 HOUR	51.5 ^{2/}	50.5 ***	47.6 ^{2/}	49.3 ***	<0.8 ^{3/}
	05:25-05:30 HOUR	51.9 ^{2/}	50.5 ***	49.3 ^{2/}	49.3 ***	<0.8 ^{3/}
	05:30-05:35 HOUR	51.6 ^{2/}	50.2 ***	49.0 ^{2/}	49.0 ***	<0.8 ^{3/}
	05:35-05:40 HOUR	50.8 ^{2/}	50.2 ***	44.9 ^{2/}	49.0 ***	<0.8 ^{3/}
	05:40-05:45 HOUR	51.9 ^{2/}	50.2 ***	50.0 ^{2/}	49.0 ***	1.0
	05:45-05:50 HOUR	51.9 ^{2/}	50.3 ***	49.8 ^{2/}	49.2 ***	<0.8 ^{3/}
	05:50-05:55 HOUR	51.5 ^{2/}	50.3 ***	48.3 ^{2/}	49.2 ***	<0.8 ^{3/}
	05:55-06:00 HOUR	52.1 ^{2/}	50.3 ***	50.4 ^{2/}	49.2 ***	1.2
	DAY TIME ^{1/}					
	06:00-07:00 HOUR	55.5 ^{1/}	53.8 **	50.6 ^{1/}	50.5 **	<0.8 ^{3/}
MARCH 26, 2026 T26AG825-0007	DAY TIME ^{1/}					
	07:00-08:00 HOUR	59.0 ^{1/}	55.9 **	56.1 ^{1/}	51.9 **	4.2
	08:00-09:00 HOUR	56.7 ^{1/}	52.8 **	54.4 ^{1/}	50.1 **	4.3
	09:00-10:00 HOUR	53.5 ^{1/}	50.9 **	50.0 ^{1/}	49.6 **	<0.8 ^{3/}
	10:00-11:00 HOUR	55.0 ^{1/}	52.3 **	51.7 ^{1/}	49.9 **	1.8
	11:00-12:00 HOUR	54.5 ^{1/}	52.9 **	49.4 ^{1/}	50.0 **	<0.8 ^{3/}
	12:00-13:00 HOUR	53.4 ^{1/}	51.7 **	48.5 ^{1/}	49.3 **	<0.8 ^{3/}
	13:00-14:00 HOUR	54.9 ^{1/}	53.6 **	49.0 ^{1/}	50.1 **	<0.8 ^{3/}
	14:00-15:00 HOUR	52.9 ^{1/}	51.4 **	47.6 ^{1/}	50.1 **	<0.8 ^{3/}
	15:00-16:00 HOUR	54.2 ^{1/}	51.8 **	50.5 ^{1/}	50.5 **	<0.8 ^{3/}
	16:00-17:00 HOUR	56.3 ^{1/}	51.4 **	54.6 ^{1/}	49.8 **	4.8
	17:00-18:00 HOUR	56.8 ^{1/}	52.9 **	54.5 ^{1/}	50.8 **	3.7
	18:00-19:00 HOUR	55.3 ^{1/}	51.8 **	52.7 ^{1/}	50.0 **	2.7
	19:00-20:00 HOUR	54.5 ^{1/}	50.8 **	52.1 ^{1/}	49.1 **	3.0
	20:00-21:00 HOUR	52.9 ^{1/}	51.2 **	48.0 ^{1/}	49.9 **	<0.8 ^{3/}
	21:00-22:00 HOUR	52.9 ^{1/}	51.0 **	48.4 ^{1/}	49.7 **	<0.8 ^{3/}
	NIGHT TIME ^{2/}					
	22:00-22:05 HOUR	53.0 ^{2/}	50.5 ***	52.4 ^{2/}	49.7 ***	2.7
	22:05-22:10 HOUR	51.7 ^{2/}	50.5 ***	48.5 ^{2/}	49.7 ***	<0.8 ^{3/}
	22:10-22:15 HOUR	52.3 ^{2/}	50.5 ***	50.6 ^{2/}	49.7 ***	0.9
	22:15-22:20 HOUR	51.8 ^{2/}	51.0 ***	47.1 ^{2/}	50.2 ***	<0.8 ^{3/}
	22:20-22:25 HOUR	52.0 ^{2/}	51.0 ***	48.1 ^{2/}	50.2 ***	<0.8 ^{3/}
	22:25-22:30 HOUR	51.8 ^{2/}	51.0 ***	47.1 ^{2/}	50.2 ***	<0.8 ^{3/}
	22:30-22:35 HOUR	52.4 ^{2/}	50.8 ***	50.3 ^{2/}	49.7 ***	<0.8 ^{3/}
	22:35-22:40 HOUR	52.7 ^{2/}	50.8 ***	51.2 ^{2/}	49.7 ***	1.5
	22:40-22:45 HOUR	52.4 ^{2/}	50.8 ***	50.3 ^{2/}	49.7 ***	<0.8 ^{3/}
	22:45-22:50 HOUR	52.1 ^{2/}	49.9 ***	51.1 ^{2/}	49.1 ***	2.0
	22:50-22:55 HOUR	52.0 ^{2/}	49.9 ***	50.8 ^{2/}	49.1 ***	1.7
	22:55-23:00 HOUR	51.9 ^{2/}	49.9 ***	50.6 ^{2/}	49.1 ***	1.5
	23:00-23:05 HOUR	52.4 ^{2/}	49.9 ***	51.8 ^{2/}	49.1 ***	2.7
	23:05-23:10 HOUR	52.0 ^{2/}	49.9 ***	50.8 ^{2/}	49.1 ***	1.7

DATE	TIME*	RESULT (dB(A))				
		รวมวัดด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 26, 2026 T26AG825-0007	NIGHT TIME ^{2/}					
	23:10-23:15 HOUR	52.1 ^{2/}	49.9 ***	51.1 ^{2/}	49.1 ***	2.0
	23:15-23:20 HOUR	52.1 ^{2/}	49.4 ***	51.8 ^{2/}	48.6 ***	3.2
	23:20-23:25 HOUR	51.7 ^{2/}	49.4 ***	50.8 ^{2/}	48.6 ***	2.2
	23:25-23:30 HOUR	52.2 ^{2/}	49.4 ***	52.0 ^{2/}	48.6 ***	3.4
	23:30-23:35 HOUR	52.2 ^{2/}	50.4 ***	50.5 ^{2/}	49.7 ***	0.8
	23:35-23:40 HOUR	52.0 ^{2/}	50.4 ***	49.9 ^{2/}	49.7 ***	<0.8 ^{3/}
	23:40-23:45 HOUR	51.8 ^{2/}	50.4 ***	49.2 ^{2/}	49.7 ***	<0.8 ^{3/}
	23:45-23:50 HOUR	51.8 ^{2/}	49.6 ***	50.8 ^{2/}	48.7 ***	2.1
	23:50-23:55 HOUR	51.6 ^{2/}	49.6 ***	50.3 ^{2/}	48.7 ***	1.6
	23:55-00:00 HOUR	52.8 ^{2/}	49.6 ***	53.0 ^{2/}	48.7 ***	4.3
MARCH 27, 2026 T26AG825-0007	NIGHT TIME ^{2/}					
	00:00-00:05 HOUR	51.6 ^{2/}	50.2 ***	49.0 ^{2/}	49.7 ***	<0.8 ^{3/}
	00:05-00:10 HOUR	52.1 ^{2/}	50.2 ***	50.6 ^{2/}	49.7 ***	0.9
	00:10-00:15 HOUR	51.7 ^{2/}	50.2 ***	49.4 ^{2/}	49.7 ***	<0.8 ^{3/}
	00:15-00:20 HOUR	51.9 ^{2/}	51.7 ***	41.4 ^{2/}	50.8 ***	<0.8 ^{3/}
	00:20-00:25 HOUR	53.1 ^{2/}	51.7 ***	50.5 ^{2/}	50.8 ***	<0.8 ^{3/}
	00:25-00:30 HOUR	51.8 ^{2/}	51.7 ***	38.4 ^{2/}	50.8 ***	<0.8 ^{3/}
	00:30-00:35 HOUR	51.9 ^{2/}	49.4 ***	51.3 ^{2/}	48.8 ***	2.5
	00:35-00:40 HOUR	52.1 ^{2/}	49.4 ***	51.8 ^{2/}	48.8 ***	3.0
	00:40-00:45 HOUR	51.9 ^{2/}	49.4 ***	51.3 ^{2/}	48.8 ***	2.5
	00:45-00:50 HOUR	51.9 ^{2/}	51.4 ***	45.3 ^{2/}	50.7 ***	<0.8 ^{3/}
	00:50-00:55 HOUR	51.8 ^{2/}	51.4 ***	44.2 ^{2/}	50.7 ***	<0.8 ^{3/}
	00:55-01:00 HOUR	52.2 ^{2/}	51.4 ***	47.5 ^{2/}	50.7 ***	<0.8 ^{3/}
	01:00-01:05 HOUR	52.2 ^{2/}	50.4 ***	50.5 ^{2/}	49.7 ***	0.8
	01:05-01:10 HOUR	51.8 ^{2/}	50.4 ***	49.2 ^{2/}	49.7 ***	<0.8 ^{3/}
	01:10-01:15 HOUR	51.9 ^{2/}	50.4 ***	49.6 ^{2/}	49.7 ***	<0.8 ^{3/}
	01:15-01:20 HOUR	52.3 ^{2/}	50.8 ***	50.0 ^{2/}	50.2 ***	<0.8 ^{3/}
	01:20-01:25 HOUR	51.7 ^{2/}	50.8 ***	47.4 ^{2/}	50.2 ***	<0.8 ^{3/}
	01:25-01:30 HOUR	51.8 ^{2/}	50.8 ***	47.9 ^{2/}	50.2 ***	<0.8 ^{3/}
	01:30-01:35 HOUR	52.1 ^{2/}	50.5 ***	50.0 ^{2/}	49.7 ***	<0.8 ^{3/}
	01:35-01:40 HOUR	52.5 ^{2/}	50.5 ***	51.2 ^{2/}	49.7 ***	1.5
	01:40-01:45 HOUR	51.7 ^{2/}	50.5 ***	48.5 ^{2/}	49.7 ***	<0.8 ^{3/}
	01:45-01:50 HOUR	52.1 ^{2/}	50.1 ***	50.8 ^{2/}	49.2 ***	1.6
	01:50-01:55 HOUR	52.3 ^{2/}	50.1 ***	51.3 ^{2/}	49.2 ***	2.1
	01:55-02:00 HOUR	52.4 ^{2/}	50.1 ***	51.5 ^{2/}	49.2 ***	2.3
	02:00-02:05 HOUR	51.8 ^{2/}	51.0 ***	47.1 ^{2/}	50.1 ***	<0.8 ^{3/}
	02:05-02:10 HOUR	52.8 ^{2/}	51.0 ***	51.1 ^{2/}	50.1 ***	1.0
	02:10-02:15 HOUR	51.6 ^{2/}	51.0 ***	45.7 ^{2/}	50.1 ***	<0.8 ^{3/}
	02:15-02:20 HOUR	51.6 ^{2/}	50.6 ***	47.7 ^{2/}	50.1 ***	<0.8 ^{3/}
	02:20-02:25 HOUR	52.1 ^{2/}	50.6 ***	49.8 ^{2/}	50.1 ***	<0.8 ^{3/}
	02:25-02:30 HOUR	51.6 ^{2/}	50.6 ***	47.7 ^{2/}	50.1 ***	<0.8 ^{3/}
	02:30-02:35 HOUR	51.6 ^{2/}	50.3 ***	48.7 ^{2/}	49.6 ***	<0.8 ^{3/}
	02:35-02:40 HOUR	51.8 ^{2/}	50.3 ***	49.5 ^{2/}	49.6 ***	<0.8 ^{3/}
	02:40-02:45 HOUR	52.1 ^{2/}	50.3 ***	50.4 ^{2/}	49.6 ***	0.8

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 27, 2026	NIGHT TIME ^{2/}					
T26AG825-0007	02:45-02:50 HOUR	51.6 ^{2/}	51.0 ***	45.7 ^{2/}	50.2 ***	<0.8 ^{3/}
	02:50-02:55 HOUR	52.3 ^{2/}	51.0 ***	49.4 ^{2/}	50.2 ***	<0.8 ^{3/}
	02:55-03:00 HOUR	52.2 ^{2/}	51.0 ***	49.0 ^{2/}	50.2 ***	<0.8 ^{3/}
	03:00-03:05 HOUR	51.7 ^{2/}	50.6 ***	48.2 ^{2/}	49.8 ***	<0.8 ^{3/}
	03:05-03:10 HOUR	52.1 ^{2/}	50.6 ***	49.8 ^{2/}	49.8 ***	<0.8 ^{3/}
	03:10-03:15 HOUR	52.4 ^{2/}	50.6 ***	50.7 ^{2/}	49.8 ***	0.9
	03:15-03:20 HOUR	52.2 ^{2/}	51.1 ***	48.7 ^{2/}	50.3 ***	<0.8 ^{3/}
	03:20-03:25 HOUR	51.8 ^{2/}	51.1 ***	46.5 ^{2/}	50.3 ***	<0.8 ^{3/}
	03:25-03:30 HOUR	52.2 ^{2/}	51.1 ***	48.7 ^{2/}	50.3 ***	<0.8 ^{3/}
	03:30-03:35 HOUR	51.7 ^{2/}	50.4 ***	48.8 ^{2/}	49.7 ***	<0.8 ^{3/}
	03:35-03:40 HOUR	52.4 ^{2/}	50.4 ***	51.1 ^{2/}	49.7 ***	1.4
	03:40-03:45 HOUR	51.7 ^{2/}	50.4 ***	48.8 ^{2/}	49.7 ***	<0.8 ^{3/}
	03:45-03:50 HOUR	51.9 ^{2/}	51.2 ***	46.6 ^{2/}	50.3 ***	<0.8 ^{3/}
	03:50-03:55 HOUR	52.5 ^{2/}	51.2 ***	49.6 ^{2/}	50.3 ***	<0.8 ^{3/}
	03:55-04:00 HOUR	52.2 ^{2/}	51.2 ***	48.3 ^{2/}	50.3 ***	<0.8 ^{3/}
	04:00-04:05 HOUR	53.3 ^{2/}	50.0 ***	53.6 ^{2/}	48.8 ***	4.8
	04:05-04:10 HOUR	52.3 ^{2/}	50.0 ***	51.4 ^{2/}	48.8 ***	2.6
	04:10-04:15 HOUR	52.3 ^{2/}	50.0 ***	51.4 ^{2/}	48.8 ***	2.6
	04:15-04:20 HOUR	53.2 ^{2/}	50.8 ***	52.5 ^{2/}	49.9 ***	2.6
	04:20-04:25 HOUR	51.8 ^{2/}	50.8 ***	47.9 ^{2/}	49.9 ***	<0.8 ^{3/}
	04:25-04:30 HOUR	52.1 ^{2/}	50.8 ***	49.2 ^{2/}	49.9 ***	<0.8 ^{3/}
	04:30-04:35 HOUR	52.3 ^{2/}	50.5 ***	50.6 ^{2/}	49.9 ***	<0.8 ^{3/}
	04:35-04:40 HOUR	52.7 ^{2/}	50.5 ***	51.7 ^{2/}	49.9 ***	1.8
	04:40-04:45 HOUR	51.9 ^{2/}	50.5 ***	49.3 ^{2/}	49.9 ***	<0.8 ^{3/}
	04:45-04:50 HOUR	51.9 ^{2/}	50.9 ***	48.0 ^{2/}	50.1 ***	<0.8 ^{3/}
	04:50-04:55 HOUR	52.3 ^{2/}	50.9 ***	49.7 ^{2/}	50.1 ***	<0.8 ^{3/}
	04:55-05:00 HOUR	52.2 ^{2/}	50.9 ***	49.3 ^{2/}	50.1 ***	<0.8 ^{3/}
	05:00-05:05 HOUR	52.5 ^{2/}	51.9 ***	46.6 ^{2/}	50.8 ***	<0.8 ^{3/}
	05:05-05:10 HOUR	52.6 ^{2/}	51.9 ***	47.3 ^{2/}	50.8 ***	<0.8 ^{3/}
	05:10-05:15 HOUR	52.9 ^{2/}	51.9 ***	49.0 ^{2/}	50.8 ***	<0.8 ^{3/}
	05:15-05:20 HOUR	53.4 ^{2/}	50.6 ***	53.2 ^{2/}	49.4 ***	3.8
	05:20-05:25 HOUR	52.9 ^{2/}	50.6 ***	52.0 ^{2/}	49.4 ***	2.6
	05:25-05:30 HOUR	52.4 ^{2/}	50.6 ***	50.7 ^{2/}	49.4 ***	1.3
	05:30-05:35 HOUR	52.5 ^{2/}	51.3 ***	49.3 ^{2/}	50.0 ***	<0.8 ^{3/}
	05:35-05:40 HOUR	53.1 ^{2/}	51.3 ***	51.4 ^{2/}	50.0 ***	1.4
	05:40-05:45 HOUR	53.0 ^{2/}	51.3 ***	51.1 ^{2/}	50.0 ***	1.1
	05:45-05:50 HOUR	54.1 ^{2/}	52.4 ***	52.2 ^{2/}	50.7 ***	1.5
	05:50-05:55 HOUR	52.9 ^{2/}	52.4 ***	46.3 ^{2/}	50.7 ***	<0.8 ^{3/}
	05:55-06:00 HOUR	54.8 ^{2/}	52.4 ***	54.1 ^{2/}	50.7 ***	3.4
	DAY TIME ^{1/}					
	06:00-07:00 HOUR	55.6 ^{1/}	54.0 **	50.5 ^{1/}	50.8 **	<0.8 ^{3/}
MARCH 27, 2026	DAY TIME ^{1/}					
T26AG825-0008	07:00-08:00 HOUR	59.0 ^{1/}	55.8 **	56.2 ^{1/}	51.5 **	4.7
	08:00-09:00 HOUR	57.7 ^{1/}	56.8 **	50.4 ^{1/}	51.9 **	<0.8 ^{3/}
	09:00-10:00 HOUR	58.6 ^{1/}	55.8 **	55.4 ^{1/}	52.3 **	3.1

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 27, 2026	DAY TIME ^{1/}					
T26AG825-0008	10:00-11:00 HOUR	53.9 ^{1/}	52.1 **	49.2 ^{1/}	49.9 **	<0.8 ^{3/}
	11:00-12:00 HOUR	54.2 ^{1/}	52.5 **	49.3 ^{1/}	50.4 **	<0.8 ^{3/}
	12:00-13:00 HOUR	54.3 ^{1/}	52.6 **	49.4 ^{1/}	50.3 **	<0.8 ^{3/}
	13:00-14:00 HOUR	55.2 ^{1/}	52.0 **	52.4 ^{1/}	50.6 **	1.8
	14:00-15:00 HOUR	54.5 ^{1/}	52.9 **	49.4 ^{1/}	51.3 **	<0.8 ^{3/}
	15:00-16:00 HOUR	53.9 ^{1/}	51.9 **	49.6 ^{1/}	50.7 **	<0.8 ^{3/}
	16:00-17:00 HOUR	56.3 ^{1/}	53.0 **	53.6 ^{1/}	51.0 **	2.6
	17:00-18:00 HOUR	56.3 ^{1/}	55.5 **	48.6 ^{1/}	51.2 **	<0.8 ^{3/}
	18:00-19:00 HOUR	54.9 ^{1/}	53.0 **	50.4 ^{1/}	51.1 **	<0.8 ^{3/}
	19:00-20:00 HOUR	55.5 ^{1/}	53.6 **	51.0 ^{1/}	50.3 **	<0.8 ^{3/}
	20:00-21:00 HOUR	53.5 ^{1/}	51.4 **	49.3 ^{1/}	50.3 **	<0.8 ^{3/}
	21:00-22:00 HOUR	52.9 ^{1/}	50.8 **	48.7 ^{1/}	50.0 **	<0.8 ^{3/}
	NIGHT TIME ^{2/}					
	22:00-22:05 HOUR	52.9 ^{2/}	50.3 ***	52.4 ^{2/}	49.5 ***	2.9
	22:05-22:10 HOUR	52.7 ^{2/}	50.3 ***	52.0 ^{2/}	49.5 ***	2.5
	22:10-22:15 HOUR	53.4 ^{2/}	50.3 ***	53.5 ^{2/}	49.5 ***	4.0
	22:15-22:20 HOUR	52.7 ^{2/}	51.8 ***	48.4 ^{2/}	51.0 ***	<0.8 ^{3/}
	22:20-22:25 HOUR	53.2 ^{2/}	51.8 ***	50.6 ^{2/}	51.0 ***	<0.8 ^{3/}
	22:25-22:30 HOUR	52.6 ^{2/}	51.8 ***	47.9 ^{2/}	51.0 ***	<0.8 ^{3/}
	22:30-22:35 HOUR	53.2 ^{2/}	52.1 ***	49.7 ^{2/}	51.1 ***	<0.8 ^{3/}
	22:35-22:40 HOUR	53.3 ^{2/}	52.1 ***	50.1 ^{2/}	51.1 ***	<0.8 ^{3/}
	22:40-22:45 HOUR	53.1 ^{2/}	52.1 ***	49.2 ^{2/}	51.1 ***	<0.8 ^{3/}
	22:45-22:50 HOUR	53.3 ^{2/}	51.8 ***	51.0 ^{2/}	51.0 ***	<0.8 ^{3/}
	22:50-22:55 HOUR	52.6 ^{2/}	51.8 ***	47.9 ^{2/}	51.0 ***	<0.8 ^{3/}
	22:55-23:00 HOUR	52.8 ^{2/}	51.8 ***	48.9 ^{2/}	51.0 ***	<0.8 ^{3/}
	23:00-23:05 HOUR	53.1 ^{2/}	52.3 ***	48.4 ^{2/}	51.4 ***	<0.8 ^{3/}
	23:05-23:10 HOUR	52.9 ^{2/}	52.3 ***	47.0 ^{2/}	51.4 ***	<0.8 ^{3/}
	23:10-23:15 HOUR	53.0 ^{2/}	52.3 ***	47.7 ^{2/}	51.4 ***	<0.8 ^{3/}
	23:15-23:20 HOUR	52.5 ^{2/}	50.0 ***	51.9 ^{2/}	49.4 ***	2.5
	23:20-23:25 HOUR	52.8 ^{2/}	50.0 ***	52.6 ^{2/}	49.4 ***	3.2
	23:25-23:30 HOUR	52.6 ^{2/}	50.0 ***	52.1 ^{2/}	49.4 ***	2.7
	23:30-23:35 HOUR	52.6 ^{2/}	51.2 ***	50.0 ^{2/}	50.5 ***	<0.8 ^{3/}
	23:35-23:40 HOUR	52.9 ^{2/}	51.2 ***	51.0 ^{2/}	50.5 ***	<0.8 ^{3/}
	23:40-23:45 HOUR	52.7 ^{2/}	51.2 ***	50.4 ^{2/}	50.5 ***	<0.8 ^{3/}
	23:45-23:50 HOUR	52.7 ^{2/}	50.1 ***	52.2 ^{2/}	49.5 ***	2.7
	23:50-23:55 HOUR	52.7 ^{2/}	50.1 ***	52.2 ^{2/}	49.5 ***	2.7
	23:55-00:00 HOUR	53.0 ^{2/}	50.1 ***	52.9 ^{2/}	49.5 ***	3.4
MARCH 28, 2026	NIGHT TIME ^{2/}					
T26AG825-0008	00:00-00:05 HOUR	52.6 ^{2/}	52.4 ***	42.1 ^{2/}	51.6 ***	<0.8 ^{3/}
	00:05-00:10 HOUR	52.9 ^{2/}	52.4 ***	46.3 ^{2/}	51.6 ***	<0.8 ^{3/}
	00:10-00:15 HOUR	53.2 ^{2/}	52.4 ***	48.5 ^{2/}	51.6 ***	<0.8 ^{3/}
	00:15-00:20 HOUR	52.7 ^{2/}	50.3 ***	52.0 ^{2/}	49.6 ***	2.4
	00:20-00:25 HOUR	52.8 ^{2/}	50.3 ***	52.2 ^{2/}	49.6 ***	2.6
	00:25-00:30 HOUR	53.3 ^{2/}	50.3 ***	53.3 ^{2/}	49.6 ***	3.7
	00:30-00:35 HOUR	53.2 ^{2/}	52.0 ***	50.0 ^{2/}	51.2 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 28, 2026 T26AG825-0008	NIGHT TIME ^{2/}					
	00:35-00:40 HOUR	53.4 ^{2/}	52.0 ***	50.8 ^{2/}	51.2 ***	<0.8 ^{3/}
	00:40-00:45 HOUR	52.9 ^{2/}	52.0 ***	48.6 ^{2/}	51.2 ***	<0.8 ^{3/}
	00:45-00:50 HOUR	52.8 ^{2/}	51.4 ***	50.2 ^{2/}	50.6 ***	<0.8 ^{3/}
	00:50-00:55 HOUR	53.0 ^{2/}	51.4 ***	50.9 ^{2/}	50.6 ***	<0.8 ^{3/}
	00:55-01:00 HOUR	53.1 ^{2/}	51.4 ***	51.2 ^{2/}	50.6 ***	<0.8 ^{3/}
	01:00-01:05 HOUR	53.6 ^{2/}	51.1 ***	53.0 ^{2/}	50.1 ***	2.9
	01:05-01:10 HOUR	53.0 ^{2/}	51.1 ***	51.5 ^{2/}	50.1 ***	1.4
	01:10-01:15 HOUR	53.1 ^{2/}	51.1 ***	51.8 ^{2/}	50.1 ***	1.7
	01:15-01:20 HOUR	53.7 ^{2/}	52.1 ***	51.6 ^{2/}	51.2 ***	<0.8 ^{3/}
	01:20-01:25 HOUR	52.9 ^{2/}	52.1 ***	48.2 ^{2/}	51.2 ***	<0.8 ^{3/}
	01:25-01:30 HOUR	53.3 ^{2/}	52.1 ***	50.1 ^{2/}	51.2 ***	<0.8 ^{3/}
	01:30-01:35 HOUR	53.0 ^{2/}	51.6 ***	50.4 ^{2/}	50.6 ***	<0.8 ^{3/}
	01:35-01:40 HOUR	53.3 ^{2/}	51.6 ***	51.4 ^{2/}	50.6 ***	0.8
	01:40-01:45 HOUR	53.3 ^{2/}	51.6 ***	51.4 ^{2/}	50.6 ***	0.8
	01:45-01:50 HOUR	53.3 ^{2/}	51.2 ***	52.1 ^{2/}	50.6 ***	1.5
	01:50-01:55 HOUR	52.9 ^{2/}	51.2 ***	51.0 ^{2/}	50.6 ***	<0.8 ^{3/}
	01:55-02:00 HOUR	52.7 ^{2/}	51.2 ***	50.4 ^{2/}	50.6 ***	<0.8 ^{3/}
	02:00-02:05 HOUR	52.8 ^{2/}	51.7 ***	49.3 ^{2/}	51.1 ***	<0.8 ^{3/}
	02:05-02:10 HOUR	52.7 ^{2/}	51.7 ***	48.8 ^{2/}	51.1 ***	<0.8 ^{3/}
	02:10-02:15 HOUR	52.7 ^{2/}	51.7 ***	48.8 ^{2/}	51.1 ***	<0.8 ^{3/}
	02:15-02:20 HOUR	52.8 ^{2/}	51.5 ***	49.9 ^{2/}	50.2 ***	<0.8 ^{3/}
	02:20-02:25 HOUR	53.0 ^{2/}	51.5 ***	50.7 ^{2/}	50.2 ***	<0.8 ^{3/}
	02:25-02:30 HOUR	55.2 ^{2/}	51.5 ***	55.8 ^{2/}	50.2 ***	5.6
	02:30-02:35 HOUR	52.9 ^{2/}	50.7 ***	51.9 ^{2/}	50.2 ***	1.7
	02:35-02:40 HOUR	52.8 ^{2/}	50.7 ***	51.6 ^{2/}	50.2 ***	1.4
	02:40-02:45 HOUR	52.8 ^{2/}	50.7 ***	51.6 ^{2/}	50.2 ***	1.4
	02:45-02:50 HOUR	52.9 ^{2/}	50.8 ***	51.7 ^{2/}	50.1 ***	1.6
	02:50-02:55 HOUR	53.1 ^{2/}	50.8 ***	52.2 ^{2/}	50.1 ***	2.1
	02:55-03:00 HOUR	52.7 ^{2/}	50.8 ***	51.2 ^{2/}	50.1 ***	1.1
	03:00-03:05 HOUR	52.6 ^{2/}	51.2 ***	50.0 ^{2/}	50.6 ***	<0.8 ^{3/}
	03:05-03:10 HOUR	52.9 ^{2/}	51.2 ***	51.0 ^{2/}	50.6 ***	<0.8 ^{3/}
	03:10-03:15 HOUR	52.7 ^{2/}	51.2 ***	50.4 ^{2/}	50.6 ***	<0.8 ^{3/}
	03:15-03:20 HOUR	52.8 ^{2/}	50.6 ***	51.8 ^{2/}	50.1 ***	1.7
	03:20-03:25 HOUR	52.7 ^{2/}	50.6 ***	51.5 ^{2/}	50.1 ***	1.4
	03:25-03:30 HOUR	52.7 ^{2/}	50.6 ***	51.5 ^{2/}	50.1 ***	1.4
	03:30-03:35 HOUR	52.7 ^{2/}	50.8 ***	51.2 ^{2/}	50.1 ***	1.1
	03:35-03:40 HOUR	52.8 ^{2/}	50.8 ***	51.5 ^{2/}	50.1 ***	1.4
	03:40-03:45 HOUR	53.4 ^{2/}	50.8 ***	52.9 ^{2/}	50.1 ***	2.8
	03:45-03:50 HOUR	52.7 ^{2/}	51.8 ***	48.4 ^{2/}	50.7 ***	<0.8 ^{3/}
	03:50-03:55 HOUR	54.3 ^{2/}	51.8 ***	53.7 ^{2/}	50.7 ***	3.0
	03:55-04:00 HOUR	53.1 ^{2/}	51.8 ***	50.2 ^{2/}	50.7 ***	<0.8 ^{3/}
	04:00-04:05 HOUR	53.3 ^{2/}	50.9 ***	52.6 ^{2/}	50.0 ***	2.6
	04:05-04:10 HOUR	52.9 ^{2/}	50.9 ***	51.6 ^{2/}	50.0 ***	1.6
	04:10-04:15 HOUR	53.0 ^{2/}	50.9 ***	51.8 ^{2/}	50.0 ***	1.8

DATE	TIME*	RESULT (dB(A))				
		ริมรั้วด้านเหนือของพื้นที่โครงการ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 28, 2026 T26AG825-0008	NIGHT TIME ^{2/}					
	04:15-04:20 HOUR	52.9 ^{2/}	50.8 ***	51.7 ^{2/}	50.0 ***	1.7
	04:20-04:25 HOUR	53.1 ^{2/}	50.8 ***	52.2 ^{2/}	50.0 ***	2.2
	04:25-04:30 HOUR	53.0 ^{2/}	50.8 ***	52.0 ^{2/}	50.0 ***	2.0
	04:30-04:35 HOUR	52.6 ^{2/}	52.4 ***	42.1 ^{2/}	51.5 ***	<0.8 ^{3/}
	04:35-04:40 HOUR	53.0 ^{2/}	52.4 ***	47.1 ^{2/}	51.5 ***	<0.8 ^{3/}
	04:40-04:45 HOUR	53.3 ^{2/}	52.4 ***	49.0 ^{2/}	51.5 ***	<0.8 ^{3/}
	04:45-04:50 HOUR	53.2 ^{2/}	52.7 ***	46.6 ^{2/}	51.7 ***	<0.8 ^{3/}
	04:50-04:55 HOUR	53.5 ^{2/}	52.7 ***	48.8 ^{2/}	51.7 ***	<0.8 ^{3/}
	04:55-05:00 HOUR	53.0 ^{2/}	52.7 ***	44.2 ^{2/}	51.7 ***	<0.8 ^{3/}
	05:00-05:05 HOUR	53.1 ^{2/}	52.3 ***	48.4 ^{2/}	51.6 ***	<0.8 ^{3/}
	05:05-05:10 HOUR	53.3 ^{2/}	52.3 ***	49.4 ^{2/}	51.6 ***	<0.8 ^{3/}
	05:10-05:15 HOUR	53.0 ^{2/}	52.3 ***	47.7 ^{2/}	51.6 ***	<0.8 ^{3/}
	05:15-05:20 HOUR	52.6 ^{2/}	50.0 ***	52.1 ^{2/}	49.5 ***	2.6
	05:20-05:25 HOUR	52.8 ^{2/}	50.0 ***	52.6 ^{2/}	49.5 ***	3.1
	05:25-05:30 HOUR	52.6 ^{2/}	50.0 ***	52.1 ^{2/}	49.5 ***	2.6
	05:30-05:35 HOUR	53.0 ^{2/}	50.5 ***	52.4 ^{2/}	49.6 ***	2.8
	05:35-05:40 HOUR	52.7 ^{2/}	50.5 ***	51.7 ^{2/}	49.6 ***	2.1
	05:40-05:45 HOUR	53.8 ^{2/}	50.5 ***	54.1 ^{2/}	49.6 ***	4.5
	05:45-05:50 HOUR	54.1 ^{2/}	52.7 ***	51.5 ^{2/}	51.5 ***	<0.8 ^{3/}
	05:50-05:55 HOUR	53.7 ^{2/}	52.7 ***	49.8 ^{2/}	51.5 ***	<0.8 ^{3/}
	05:55-06:00 HOUR	53.2 ^{2/}	52.7 ***	46.6 ^{2/}	51.5 ***	<0.8 ^{3/}
	DAY TIME ^{1/}					
	06:00-07:00 HOUR	55.2 ^{1/}	52.6 **	51.7 ^{1/}	50.2 **	1.5

REMARK :

- 1/ CASE 1 CALCULATION (DURING 06:00 TO 22:00 HOUR) : SPECIFIC SOUND LEVEL CONTINUOUSLY OCCUR AT LEAST 1 HOUR, MEASURING AS $L_{Aeq} 1 \text{ hour}$.
- 2/ CASE 4 CALCULATION (DURING 22:00 TO 06:00 HOUR) : SPECIFIC SOUND LEVEL OCCUR IN RESTFUL AREA OR NIGHT TIME, MEASURING AS $L_{Aeq} 5 \text{ minutes}$.
- 3/ THERE IS NO IMPACT CAUSE ANNOYANCE SOUND LEVEL
- ** PERCENTILE LEVEL 90 (L_{A90}) IS THE MIDDLE VALUE OF 11 TIMES MEASURING.
(55 MINUTES MEASURING DURING 06:00 TO 22:00 HOUR)
AND RESIDUAL SOUND LEVEL ($L_{Aeq} 5 \text{ minutes}$) IS CHOSEN AT THE SAME TIME AS PERCENTILE LEVEL 90 ABOVE.
- *** PERCENTILE LEVEL 90 (L_{A90}) IS THE MIDDLE VALUE OF 3 TIMES MEASURING.
(15 MINUTES MEASURING DURING 22:00 TO 06:00 HOUR)
AND RESIDUAL SOUND LEVEL ($L_{Aeq} 5 \text{ minutes}$) IS CHOSEN AT THE SAME TIME AS PERCENTILE LEVEL 90 ABOVE.
- **** ISO 1996-1: 2016
- **** NOTIFICATION OF THE NATIONAL ENVIRONMENT BOARD NO. 29 (B.E. 2550) ON ANNOYANCE NOISE LEVELS, DATED 29 JUNE B.E. 2550 (2007)
- **** NOTIFICATION OF THE POLLUTION CONTROL COMMITTEE ON METHODS FOR MEASUREMENT OF BACKGROUND SOUND LEVEL, RESIDUAL SOUND LEVEL, MEASUREMENT AND CALCULATION OF RATING LEVEL, CALCULATION OF ANNOYANCE NOISE LEVEL, AND MEASUREMENT RECORD FORMS, DATED 21 SEPTEMBER B.E. 2565 (2022)
- **** NOTIFICATION OF THE MINISTRY OF INDUSTRY (B.E. 2548) ON ANNOYANCE NOISE LEVELS AND NOISE LEVELS FROM FACTORY OPERATIONS, DATED 27 DECEMBER B.E. 2548 (2005)
- **** NOTIFICATION OF THE DEPARTMENT OF INDUSTRIAL WORKS ON METHODS FOR MEASUREMENT OF ANNOYANCE NOISE LEVEL, 24-HOUR EQUIVALENT CONTINUOUS SOUND LEVEL, AND MAXIMUM SOUND LEVEL FROM FACTORY OPERATIONS, B.E. 2553 (2010), DATED 20 DECEMBER B.E. 2553 (2010)

ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE

CUSTOMER NAME : PTT LNG COMPANY LIMITED

ADDRESS :

CONTACT INFORMATION :

MEASURING PLACE : วัดดาวมงคลคาราม

MEASURING TYPE : AMBIENT (ANNOYANCE NOISE)

MEASURING DATE : MARCH 21-28, 2026

MEASURING TIME : *

MEASURING METHOD : INTEGRATED SOUND LEVEL METER
AND CALCULATION ****

MEASURED BY :

RECEIVED DATE : MARCH 21-28, 2026

ANALYTICAL DATE : MARCH 21-28, 2026

ISSUE DATE : APRIL 10, 2026

REPORT NO. : 2026-U028015

WORK NO. : 2025-010629

ANALYSIS NO. : T26AG825-0009 - T26AG825-0015

DATE	TIME*	RESULT (dB(A))				
		วัดดาวมงคลคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 21, 2026	DAY TIME ^{1/}					
T26AG825-0009	07:00-08:00 HOUR	59.8 ^{1/}	57.6 **	55.8 ^{1/}	52.0 **	3.8
	08:00-09:00 HOUR	56.0 ^{1/}	53.3 **	52.7 ^{1/}	47.1 **	5.6
	09:00-10:00 HOUR	53.9 ^{1/}	50.4 **	51.3 ^{1/}	45.8 **	5.5
	10:00-11:00 HOUR	53.6 ^{1/}	50.3 **	50.9 ^{1/}	44.3 **	6.6
	11:00-12:00 HOUR	60.3 ^{1/}	56.6 **	57.9 ^{1/}	51.7 **	6.2
	12:00-13:00 HOUR	55.9 ^{1/}	51.6 **	53.9 ^{1/}	46.3 **	7.6
	13:00-14:00 HOUR	55.5 ^{1/}	54.8 **	47.2 ^{1/}	45.0 **	2.2
	14:00-15:00 HOUR	58.0 ^{1/}	56.6 **	52.4 ^{1/}	44.7 **	7.7
	15:00-16:00 HOUR	60.5 ^{1/}	57.1 **	57.8 ^{1/}	51.1 **	6.7
	16:00-17:00 HOUR	60.7 ^{1/}	56.8 **	58.4 ^{1/}	51.2 **	7.2
	17:00-18:00 HOUR	47.9 ^{1/}	45.5 **	44.2 ^{1/}	40.4 **	3.8
	18:00-19:00 HOUR	48.5 ^{1/}	47.3 **	42.3 ^{1/}	40.3 **	2.0
	19:00-20:00 HOUR	60.0 ^{1/}	53.5 **	58.9 ^{1/}	51.2 **	7.7
	20:00-21:00 HOUR	51.7 ^{1/}	50.1 **	46.6 ^{1/}	47.6 **	<0.8 ^{3/}
	21:00-22:00 HOUR	55.2 ^{1/}	49.2 **	53.9 ^{1/}	47.1 **	6.8
	NIGHT TIME ^{2/}					
	22:00-22:05 HOUR	48.0 ^{2/}	46.4 ***	45.9 ^{2/}	42.7 ***	3.2
	22:05-22:10 HOUR	47.0 ^{2/}	46.4 ***	41.1 ^{2/}	42.7 ***	<0.8 ^{3/}
	22:10-22:15 HOUR	47.8 ^{2/}	46.4 ***	45.2 ^{2/}	42.7 ***	2.5
	22:15-22:20 HOUR	47.6 ^{2/}	45.6 ***	46.3 ^{2/}	42.2 ***	4.1
	22:20-22:25 HOUR	47.2 ^{2/}	45.6 ***	45.1 ^{2/}	42.2 ***	2.9
	22:25-22:30 HOUR	47.6 ^{2/}	45.6 ***	46.3 ^{2/}	42.2 ***	4.1
	22:30-22:35 HOUR	45.2 ^{2/}	46.0 ***	<0.8 ^{3/}	42.7 ***	<0.8 ^{3/}
	22:35-22:40 HOUR	46.4 ^{2/}	46.0 ***	38.8 ^{2/}	42.7 ***	<0.8 ^{3/}
	22:40-22:45 HOUR	46.8 ^{2/}	46.0 ***	42.1 ^{2/}	42.7 ***	<0.8 ^{3/}
	22:45-22:50 HOUR	47.7 ^{2/}	45.9 ***	46.0 ^{2/}	43.4 ***	2.6
	22:50-22:55 HOUR	49.3 ^{2/}	45.9 ***	49.6 ^{2/}	43.4 ***	6.2
	22:55-23:00 HOUR	47.6 ^{2/}	45.9 ***	45.7 ^{2/}	43.4 ***	2.3
	23:00-23:05 HOUR	48.2 ^{2/}	53.4 ***	<0.8 ^{3/}	50.3 ***	<0.8 ^{3/}
	23:05-23:10 HOUR	47.9 ^{2/}	53.4 ***	<0.8 ^{3/}	50.3 ***	<0.8 ^{3/}
	23:10-23:15 HOUR	49.3 ^{2/}	53.4 ***	<0.8 ^{3/}	50.3 ***	<0.8 ^{3/}



DATE	TIME*	RESULT (dB(A))				
		วัดตามวงศการาม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 21, 2026 T26AG825-0009	NIGHT TIME ^{2/}					
	23:15-23:20 HOUR	52.0 ^{2/}	48.7 ***	52.3 ^{2/}	46.0 ***	6.3
	23:20-23:25 HOUR	52.5 ^{2/}	48.7 ***	53.2 ^{2/}	46.0 ***	7.2
	23:25-23:30 HOUR	44.5 ^{2/}	48.7 ***	<0.8 ^{3/}	46.0 ***	<0.8 ^{3/}
	23:30-23:35 HOUR	45.3 ^{2/}	42.4 ***	45.2 ^{2/}	40.0 ***	5.2
	23:35-23:40 HOUR	45.1 ^{2/}	42.4 ***	44.8 ^{2/}	40.0 ***	4.8
	23:40-23:45 HOUR	43.4 ^{2/}	42.4 ***	39.5 ^{2/}	40.0 ***	<0.8 ^{3/}
	23:45-23:50 HOUR	43.9 ^{2/}	48.7 ***	<0.8 ^{3/}	41.6 ***	<0.8 ^{3/}
	23:50-23:55 HOUR	44.1 ^{2/}	48.7 ***	<0.8 ^{3/}	41.6 ***	<0.8 ^{3/}
	23:55-00:00 HOUR	49.2 ^{2/}	48.7 ***	42.6 ^{2/}	41.6 ***	1.0
MARCH 22, 2026 T26AG825-0009	NIGHT TIME ^{2/}					
	00:00-00:05 HOUR	49.2 ^{2/}	45.8 ***	49.5 ^{2/}	42.3 ***	7.2
	00:05-00:10 HOUR	47.1 ^{2/}	45.8 ***	44.2 ^{2/}	42.3 ***	1.9
	00:10-00:15 HOUR	47.3 ^{2/}	45.8 ***	45.0 ^{2/}	42.3 ***	2.7
	00:15-00:20 HOUR	48.8 ^{2/}	47.9 ***	44.5 ^{2/}	43.4 ***	1.1
	00:20-00:25 HOUR	49.2 ^{2/}	47.9 ***	46.3 ^{2/}	43.4 ***	2.9
	00:25-00:30 HOUR	47.1 ^{2/}	47.9 ***	<0.8 ^{3/}	43.4 ***	<0.8 ^{3/}
	00:30-00:35 HOUR	47.5 ^{2/}	46.3 ***	44.3 ^{2/}	44.3 ***	<0.8 ^{3/}
	00:35-00:40 HOUR	46.9 ^{2/}	46.3 ***	41.0 ^{2/}	44.3 ***	<0.8 ^{3/}
	00:40-00:45 HOUR	47.7 ^{2/}	46.3 ***	45.1 ^{2/}	44.3 ***	0.8
	00:45-00:50 HOUR	48.5 ^{2/}	45.5 ***	48.5 ^{2/}	43.3 ***	5.2
	00:50-00:55 HOUR	47.3 ^{2/}	45.5 ***	45.6 ^{2/}	43.3 ***	2.3
	00:55-01:00 HOUR	48.0 ^{2/}	45.5 ***	47.4 ^{2/}	43.3 ***	4.1
	01:00-01:05 HOUR	54.3 ^{2/}	58.6 ***	<0.8 ^{3/}	50.7 ***	<0.8 ^{3/}
	01:05-01:10 HOUR	58.9 ^{2/}	58.6 ***	50.1 ^{2/}	50.7 ***	<0.8 ^{3/}
	01:10-01:15 HOUR	59.4 ^{2/}	58.6 ***	54.7 ^{2/}	50.7 ***	4.0
	01:15-01:20 HOUR	47.5 ^{2/}	47.8 ***	<0.8 ^{3/}	39.9 ***	<0.8 ^{3/}
	01:20-01:25 HOUR	44.5 ^{2/}	47.8 ***	<0.8 ^{3/}	39.9 ***	<0.8 ^{3/}
	01:25-01:30 HOUR	45.4 ^{2/}	47.8 ***	<0.8 ^{3/}	39.9 ***	<0.8 ^{3/}
	01:30-01:35 HOUR	45.9 ^{2/}	42.3 ***	46.4 ^{2/}	40.2 ***	6.2
	01:35-01:40 HOUR	44.8 ^{2/}	42.3 ***	44.2 ^{2/}	40.2 ***	4.0
	01:40-01:45 HOUR	44.2 ^{2/}	42.3 ***	42.7 ^{2/}	40.2 ***	2.5
	01:45-01:50 HOUR	44.5 ^{2/}	45.9 ***	<0.8 ^{3/}	43.7 ***	<0.8 ^{3/}
	01:50-01:55 HOUR	44.9 ^{2/}	45.9 ***	<0.8 ^{3/}	43.7 ***	<0.8 ^{3/}
	01:55-02:00 HOUR	45.4 ^{2/}	45.9 ***	<0.8 ^{3/}	43.7 ***	<0.8 ^{3/}
	02:00-02:05 HOUR	51.6 ^{2/}	51.2 ***	44.0 ^{2/}	49.2 ***	<0.8 ^{3/}
	02:05-02:10 HOUR	54.4 ^{2/}	51.2 ***	54.6 ^{2/}	49.2 ***	5.4
	02:10-02:15 HOUR	52.4 ^{2/}	51.2 ***	49.2 ^{2/}	49.2 ***	<0.8 ^{3/}
	02:15-02:20 HOUR	51.6 ^{2/}	53.3 ***	<0.8 ^{3/}	47.6 ***	<0.8 ^{3/}
	02:20-02:25 HOUR	51.3 ^{2/}	53.3 ***	<0.8 ^{3/}	47.6 ***	<0.8 ^{3/}
	02:25-02:30 HOUR	55.7 ^{2/}	53.3 ***	55.0 ^{2/}	47.6 ***	7.4
	02:30-02:35 HOUR	57.7 ^{2/}	55.7 ***	56.4 ^{2/}	53.7 ***	2.7
	02:35-02:40 HOUR	56.0 ^{2/}	55.7 ***	47.2 ^{2/}	53.7 ***	<0.8 ^{3/}
	02:40-02:45 HOUR	57.3 ^{2/}	55.7 ***	55.2 ^{2/}	53.7 ***	1.5
	02:45-02:50 HOUR	57.9 ^{2/}	57.4 ***	51.3 ^{2/}	55.6 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		วัดตามวงดงคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 22, 2026 T26AG825-0009	NIGHT TIME ^{2/}					
	02:50-02:55 HOUR	57.0 ^{2/}	57.4 ***	<0.8 ^{3/}	55.6 ***	<0.8 ^{3/}
	02:55-03:00 HOUR	59.5 ^{2/}	57.4 ***	58.3 ^{2/}	55.6 ***	2.7
	03:00-03:05 HOUR	59.0 ^{2/}	57.6 ***	56.4 ^{2/}	54.3 ***	2.1
	03:05-03:10 HOUR	56.0 ^{2/}	57.6 ***	<0.8 ^{3/}	54.3 ***	<0.8 ^{3/}
	03:10-03:15 HOUR	58.2 ^{2/}	57.6 ***	52.3 ^{2/}	54.3 ***	<0.8 ^{3/}
	03:15-03:20 HOUR	57.0 ^{2/}	54.3 ***	56.7 ^{2/}	51.9 ***	4.8
	03:20-03:25 HOUR	57.3 ^{2/}	54.3 ***	57.3 ^{2/}	51.9 ***	5.4
	03:25-03:30 HOUR	55.8 ^{2/}	54.3 ***	53.5 ^{2/}	51.9 ***	1.6
	03:30-03:35 HOUR	53.0 ^{2/}	50.5 ***	52.4 ^{2/}	49.0 ***	3.4
	03:35-03:40 HOUR	53.4 ^{2/}	50.5 ***	53.3 ^{2/}	49.0 ***	4.3
	03:40-03:45 HOUR	51.7 ^{2/}	50.5 ***	48.5 ^{2/}	49.0 ***	<0.8 ^{3/}
	03:45-03:50 HOUR	52.0 ^{2/}	50.1 ***	50.5 ^{2/}	48.4 ***	2.1
	03:50-03:55 HOUR	51.0 ^{2/}	50.1 ***	46.7 ^{2/}	48.4 ***	<0.8 ^{3/}
	03:55-04:00 HOUR	51.6 ^{2/}	50.1 ***	49.3 ^{2/}	48.4 ***	0.9
	04:00-04:05 HOUR	53.9 ^{2/}	61.5 ***	<0.8 ^{3/}	59.4 ***	<0.8 ^{3/}
	04:05-04:10 HOUR	63.5 ^{2/}	61.5 ***	62.2 ^{2/}	59.4 ***	2.8
	04:10-04:15 HOUR	65.4 ^{2/}	61.5 ***	66.1 ^{2/}	59.4 ***	6.7
	04:15-04:20 HOUR	59.5 ^{2/}	54.8 ***	60.7 ^{2/}	53.9 ***	6.8
	04:20-04:25 HOUR	58.5 ^{2/}	54.8 ***	59.1 ^{2/}	53.9 ***	5.2
	04:25-04:30 HOUR	56.8 ^{2/}	54.8 ***	55.5 ^{2/}	53.9 ***	1.6
	04:30-04:35 HOUR	53.3 ^{2/}	51.7 ***	51.2 ^{2/}	43.9 ***	7.3
	04:35-04:40 HOUR	53.2 ^{2/}	51.7 ***	50.9 ^{2/}	43.9 ***	7.0
	04:40-04:45 HOUR	48.4 ^{2/}	51.7 ***	<0.8 ^{3/}	43.9 ***	<0.8 ^{3/}
	04:45-04:50 HOUR	45.6 ^{2/}	44.5 ***	42.1 ^{2/}	41.0 ***	1.1
	04:50-04:55 HOUR	45.5 ^{2/}	44.5 ***	41.6 ^{2/}	41.0 ***	<0.8 ^{3/}
	04:55-05:00 HOUR	45.5 ^{2/}	44.5 ***	41.6 ^{2/}	41.0 ***	<0.8 ^{3/}
	05:00-05:05 HOUR	46.7 ^{2/}	53.7 ***	<0.8 ^{3/}	40.1 ***	<0.8 ^{3/}
	05:05-05:10 HOUR	44.8 ^{2/}	53.7 ***	<0.8 ^{3/}	40.1 ***	<0.8 ^{3/}
	05:10-05:15 HOUR	53.9 ^{2/}	53.7 ***	43.4 ^{2/}	40.1 ***	3.3
	05:15-05:20 HOUR	46.2 ^{2/}	43.7 ***	45.6 ^{2/}	38.7 ***	6.9
	05:20-05:25 HOUR	44.5 ^{2/}	43.7 ***	39.8 ^{2/}	38.7 ***	1.1
	05:25-05:30 HOUR	43.9 ^{2/}	43.7 ***	33.4 ^{2/}	38.7 ***	<0.8 ^{3/}
	05:30-05:35 HOUR	44.9 ^{2/}	48.2 ***	<0.8 ^{3/}	39.1 ***	<0.8 ^{3/}
	05:35-05:40 HOUR	45.0 ^{2/}	48.2 ***	<0.8 ^{3/}	39.1 ***	<0.8 ^{3/}
	05:40-05:45 HOUR	43.2 ^{2/}	48.2 ***	<0.8 ^{3/}	39.1 ***	<0.8 ^{3/}
	05:45-05:50 HOUR	53.5 ^{2/}	52.9 ***	47.6 ^{2/}	46.6 ***	1.0
	05:50-05:55 HOUR	53.3 ^{2/}	52.9 ***	45.7 ^{2/}	46.6 ***	<0.8 ^{3/}
	05:55-06:00 HOUR	54.6 ^{2/}	52.9 ***	52.7 ^{2/}	46.6 ***	6.1
	DAY TIME ^{1/}					
	06:00-07:00 HOUR	53.5 ^{1/}	51.4 **	49.3 ^{1/}	42.7 **	6.6
MARCH 22, 2026 T26AG825-0010	DAY TIME ^{1/}					
	07:00-08:00 HOUR	55.9 ^{1/}	55.4 **	46.3 ^{1/}	43.7 **	2.6
	08:00-09:00 HOUR	51.6 ^{1/}	51.1 **	42.0 ^{1/}	42.6 **	<0.8 ^{3/}
	09:00-10:00 HOUR	52.0 ^{1/}	49.6 **	48.3 ^{1/}	42.5 **	5.8
	10:00-11:00 HOUR	50.8 ^{1/}	48.9 **	46.3 ^{1/}	42.3 **	4.0

DATE	TIME*	RESULT (dB(A))				
		วัดตามวงดงคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 22, 2026	DAY TIME ^{1/}					
T26AG825-0010	11:00-12:00 HOUR	54.0 ^{1/}	51.0 **	51.0 ^{1/}	44.8 **	6.2
	12:00-13:00 HOUR	51.2 ^{1/}	49.2 **	46.9 ^{1/}	45.8 **	1.1
	13:00-14:00 HOUR	51.8 ^{1/}	49.6 **	47.8 ^{1/}	44.7 **	3.1
	14:00-15:00 HOUR	55.2 ^{1/}	50.1 **	53.6 ^{1/}	45.8 **	7.8
	15:00-16:00 HOUR	59.5 ^{1/}	56.1 **	56.8 ^{1/}	49.4 **	7.4
	16:00-17:00 HOUR	51.2 ^{1/}	48.5 **	47.9 ^{1/}	42.5 **	5.4
	17:00-18:00 HOUR	48.4 ^{1/}	46.0 **	44.7 ^{1/}	40.9 **	3.8
	18:00-19:00 HOUR	52.0 ^{1/}	51.0 **	45.1 ^{1/}	44.6 **	<0.8 ^{3/}
	19:00-20:00 HOUR	59.3 ^{1/}	56.5 **	56.1 ^{1/}	50.5 **	5.6
	20:00-21:00 HOUR	49.8 ^{1/}	47.5 **	45.9 ^{1/}	43.9 **	2.0
	21:00-22:00 HOUR	50.3 ^{1/}	47.4 **	47.2 ^{1/}	43.5 **	3.7
	NIGHT TIME ^{2/}					
	22:00-22:05 HOUR	52.2 ^{2/}	51.8 ***	44.6 ^{2/}	49.1 ***	<0.8 ^{3/}
	22:05-22:10 HOUR	55.7 ^{2/}	51.8 ***	56.4 ^{2/}	49.1 ***	7.3
	22:10-22:15 HOUR	52.1 ^{2/}	51.8 ***	43.3 ^{2/}	49.1 ***	<0.8 ^{3/}
	22:15-22:20 HOUR	52.1 ^{2/}	56.7 ***	<0.8 ^{3/}	51.7 ***	<0.8 ^{3/}
	22:20-22:25 HOUR	56.9 ^{2/}	56.7 ***	46.4 ^{2/}	51.7 ***	<0.8 ^{3/}
	22:25-22:30 HOUR	57.0 ^{2/}	56.7 ***	48.2 ^{2/}	51.7 ***	<0.8 ^{3/}
	22:30-22:35 HOUR	49.2 ^{2/}	46.5 ***	48.9 ^{2/}	44.0 ***	4.9
	22:35-22:40 HOUR	47.3 ^{2/}	46.5 ***	42.6 ^{2/}	44.0 ***	<0.8 ^{3/}
	22:40-22:45 HOUR	47.3 ^{2/}	46.5 ***	42.6 ^{2/}	44.0 ***	<0.8 ^{3/}
	22:45-22:50 HOUR	51.8 ^{2/}	51.6 ***	41.3 ^{2/}	48.9 ***	<0.8 ^{3/}
	22:50-22:55 HOUR	54.7 ^{2/}	51.6 ***	54.8 ^{2/}	48.9 ***	5.9
	22:55-23:00 HOUR	54.8 ^{2/}	51.6 ***	55.0 ^{2/}	48.9 ***	6.1
	23:00-23:05 HOUR	50.5 ^{2/}	47.0 ***	50.9 ^{2/}	43.9 ***	7.0
	23:05-23:10 HOUR	48.3 ^{2/}	47.0 ***	45.4 ^{2/}	43.9 ***	1.5
	23:10-23:15 HOUR	47.6 ^{2/}	47.0 ***	41.7 ^{2/}	43.9 ***	<0.8 ^{3/}
	23:15-23:20 HOUR	46.5 ^{2/}	45.6 ***	42.2 ^{2/}	42.7 ***	<0.8 ^{3/}
	23:20-23:25 HOUR	48.5 ^{2/}	45.6 ***	48.4 ^{2/}	42.7 ***	5.7
	23:25-23:30 HOUR	46.7 ^{2/}	45.6 ***	43.2 ^{2/}	42.7 ***	<0.8 ^{3/}
	23:30-23:35 HOUR	47.0 ^{2/}	46.7 ***	38.2 ^{2/}	43.8 ***	<0.8 ^{3/}
	23:35-23:40 HOUR	47.7 ^{2/}	46.7 ***	43.8 ^{2/}	43.8 ***	<0.8 ^{3/}
	23:40-23:45 HOUR	48.6 ^{2/}	46.7 ***	47.1 ^{2/}	43.8 ***	3.3
	23:45-23:50 HOUR	51.6 ^{2/}	52.2 ***	<0.8 ^{3/}	47.9 ***	<0.8 ^{3/}
	23:50-23:55 HOUR	55.5 ^{2/}	52.2 ***	55.8 ^{2/}	47.9 ***	7.9
	23:55-00:00 HOUR	53.7 ^{2/}	52.2 ***	51.4 ^{2/}	47.9 ***	3.5
MARCH 23, 2026	NIGHT TIME ^{2/}					
T26AG825-0010	00:00-00:05 HOUR	49.6 ^{2/}	46.9 ***	49.3 ^{2/}	42.1 ***	7.2
	00:05-00:10 HOUR	49.3 ^{2/}	46.9 ***	48.6 ^{2/}	42.1 ***	6.5
	00:10-00:15 HOUR	49.5 ^{2/}	46.9 ***	49.0 ^{2/}	42.1 ***	6.9
	00:15-00:20 HOUR	46.2 ^{2/}	46.0 ***	35.7 ^{2/}	41.8 ***	<0.8 ^{3/}
	00:20-00:25 HOUR	46.7 ^{2/}	46.0 ***	41.4 ^{2/}	41.8 ***	<0.8 ^{3/}
	00:25-00:30 HOUR	47.0 ^{2/}	46.0 ***	43.1 ^{2/}	41.8 ***	1.3
	00:30-00:35 HOUR	47.8 ^{2/}	47.5 ***	39.0 ^{2/}	44.8 ***	<0.8 ^{3/}
	00:35-00:40 HOUR	47.8 ^{2/}	47.5 ***	39.0 ^{2/}	44.8 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		วัดตามวงคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 23, 2026 T26AG825-0010	NIGHT TIME ^{2/}					
	00:40-00:45 HOUR	50.1 ^{2/}	47.5 ***	49.6 ^{2/}	44.8 ***	4.8
	00:45-00:50 HOUR	49.9 ^{2/}	46.2 ***	50.5 ^{2/}	43.1 ***	7.4
	00:50-00:55 HOUR	49.3 ^{2/}	46.2 ***	49.4 ^{2/}	43.1 ***	6.3
	00:55-01:00 HOUR	46.5 ^{2/}	46.2 ***	37.7 ^{2/}	43.1 ***	<0.8 ^{3/}
	01:00-01:05 HOUR	47.5 ^{2/}	44.1 ***	47.8 ^{2/}	41.1 ***	6.7
	01:05-01:10 HOUR	47.8 ^{2/}	44.1 ***	48.4 ^{2/}	41.1 ***	7.3
	01:10-01:15 HOUR	44.8 ^{2/}	44.1 ***	39.5 ^{2/}	41.1 ***	<0.8 ^{3/}
	01:15-01:20 HOUR	44.6 ^{2/}	42.9 ***	42.7 ^{2/}	40.3 ***	2.4
	01:20-01:25 HOUR	45.4 ^{2/}	42.9 ***	44.8 ^{2/}	40.3 ***	4.5
	01:25-01:30 HOUR	45.4 ^{2/}	42.9 ***	44.8 ^{2/}	40.3 ***	4.5
	01:30-01:35 HOUR	45.2 ^{2/}	43.4 ***	43.5 ^{2/}	41.1 ***	2.4
	01:35-01:40 HOUR	45.0 ^{2/}	43.4 ***	42.9 ^{2/}	41.1 ***	1.8
	01:40-01:45 HOUR	45.0 ^{2/}	43.4 ***	42.9 ^{2/}	41.1 ***	1.8
	01:45-01:50 HOUR	44.9 ^{2/}	42.2 ***	44.6 ^{2/}	40.4 ***	4.2
	01:50-01:55 HOUR	43.0 ^{2/}	42.2 ***	38.3 ^{2/}	40.4 ***	<0.8 ^{3/}
	01:55-02:00 HOUR	42.6 ^{2/}	42.2 ***	35.0 ^{2/}	40.4 ***	<0.8 ^{3/}
	02:00-02:05 HOUR	43.1 ^{2/}	42.9 ***	32.6 ^{2/}	40.5 ***	<0.8 ^{3/}
	02:05-02:10 HOUR	44.2 ^{2/}	42.9 ***	41.3 ^{2/}	40.5 ***	0.8
	02:10-02:15 HOUR	45.0 ^{2/}	42.9 ***	43.8 ^{2/}	40.5 ***	3.3
	02:15-02:20 HOUR	43.4 ^{2/}	42.4 ***	39.5 ^{2/}	40.4 ***	<0.8 ^{3/}
	02:20-02:25 HOUR	44.3 ^{2/}	42.4 ***	42.8 ^{2/}	40.4 ***	2.4
	02:25-02:30 HOUR	42.7 ^{2/}	42.4 ***	33.9 ^{2/}	40.4 ***	<0.8 ^{3/}
	02:30-02:35 HOUR	43.0 ^{2/}	42.8 ***	32.5 ^{2/}	40.5 ***	<0.8 ^{3/}
	02:35-02:40 HOUR	43.1 ^{2/}	42.8 ***	34.3 ^{2/}	40.5 ***	<0.8 ^{3/}
	02:40-02:45 HOUR	43.7 ^{2/}	42.8 ***	39.4 ^{2/}	40.5 ***	<0.8 ^{3/}
	02:45-02:50 HOUR	45.6 ^{2/}	43.3 ***	44.7 ^{2/}	40.4 ***	4.3
	02:50-02:55 HOUR	45.1 ^{2/}	43.3 ***	43.4 ^{2/}	40.4 ***	3.0
	02:55-03:00 HOUR	43.6 ^{2/}	43.3 ***	34.8 ^{2/}	40.4 ***	<0.8 ^{3/}
	03:00-03:05 HOUR	44.8 ^{2/}	44.6 ***	34.3 ^{2/}	38.8 ***	<0.8 ^{3/}
	03:05-03:10 HOUR	44.4 ^{2/}	44.6 ***	<0.8 ^{3/}	38.8 ***	<0.8 ^{3/}
	03:10-03:15 HOUR	46.6 ^{2/}	44.6 ***	45.3 ^{2/}	38.8 ***	6.5
	03:15-03:20 HOUR	45.6 ^{2/}	45.5 ***	32.2 ^{2/}	40.8 ***	<0.8 ^{3/}
	03:20-03:25 HOUR	45.7 ^{2/}	45.5 ***	35.2 ^{2/}	40.8 ***	<0.8 ^{3/}
	03:25-03:30 HOUR	45.6 ^{2/}	45.5 ***	32.2 ^{2/}	40.8 ***	<0.8 ^{3/}
	03:30-03:35 HOUR	53.4 ^{2/}	53.2 ***	42.9 ^{2/}	46.3 ***	<0.8 ^{3/}
	03:35-03:40 HOUR	54.7 ^{2/}	53.2 ***	52.4 ^{2/}	46.3 ***	6.1
	03:40-03:45 HOUR	53.4 ^{2/}	53.2 ***	42.9 ^{2/}	46.3 ***	<0.8 ^{3/}
	03:45-03:50 HOUR	54.3 ^{2/}	54.6 ***	<0.8 ^{3/}	50.2 ***	<0.8 ^{3/}
	03:50-03:55 HOUR	54.8 ^{2/}	54.6 ***	44.3 ^{2/}	50.2 ***	<0.8 ^{3/}
	03:55-04:00 HOUR	54.8 ^{2/}	54.6 ***	44.3 ^{2/}	50.2 ***	<0.8 ^{3/}
	04:00-04:05 HOUR	46.4 ^{2/}	45.9 ***	39.8 ^{2/}	42.2 ***	<0.8 ^{3/}
	04:05-04:10 HOUR	49.3 ^{2/}	45.9 ***	49.6 ^{2/}	42.2 ***	7.4
	04:10-04:15 HOUR	46.2 ^{2/}	45.9 ***	37.4 ^{2/}	42.2 ***	<0.8 ^{3/}
	04:15-04:20 HOUR	46.3 ^{2/}	51.6 ***	<0.8 ^{3/}	40.3 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		วัดตากวนคงคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 23, 2026 T26AG825-0010	NIGHT TIME ^{2/}					
	04:20-04:25 HOUR	46.7 ^{2/}	51.6 ***	<0.8 ^{3/}	40.3 ***	<0.8 ^{3/}
	04:25-04:30 HOUR	52.3 ^{2/}	51.6 ***	47.0 ^{2/}	40.3 ***	6.7
	04:30-04:35 HOUR	56.6 ^{2/}	56.4 ***	46.1 ^{2/}	40.7 ***	5.4
	04:35-04:40 HOUR	56.7 ^{2/}	56.4 ***	47.9 ^{2/}	40.7 ***	7.2
	04:40-04:45 HOUR	45.6 ^{2/}	56.4 ***	<0.8 ^{3/}	40.7 ***	<0.8 ^{3/}
	04:45-04:50 HOUR	41.9 ^{2/}	40.0 ***	40.4 ^{2/}	37.4 ***	3.0
	04:50-04:55 HOUR	41.9 ^{2/}	40.0 ***	40.4 ^{2/}	37.4 ***	3.0
	04:55-05:00 HOUR	41.3 ^{2/}	40.0 ***	38.4 ^{2/}	37.4 ***	1.0
	05:00-05:05 HOUR	47.6 ^{2/}	45.9 ***	45.7 ^{2/}	38.3 ***	7.4
	05:05-05:10 HOUR	46.8 ^{2/}	45.9 ***	42.5 ^{2/}	38.3 ***	4.2
	05:10-05:15 HOUR	45.4 ^{2/}	45.9 ***	<0.8 ^{3/}	38.3 ***	<0.8 ^{3/}
	05:15-05:20 HOUR	45.2 ^{2/}	56.0 ***	<0.8 ^{3/}	39.6 ***	<0.8 ^{3/}
	05:20-05:25 HOUR	56.2 ^{2/}	56.0 ***	45.7 ^{2/}	39.6 ***	6.1
	05:25-05:30 HOUR	56.3 ^{2/}	56.0 ***	47.5 ^{2/}	39.6 ***	7.9
	05:30-05:35 HOUR	54.0 ^{2/}	53.9 ***	40.6 ^{2/}	38.9 ***	1.7
	05:35-05:40 HOUR	54.2 ^{2/}	53.9 ***	45.4 ^{2/}	38.9 ***	6.5
	05:40-05:45 HOUR	54.2 ^{2/}	53.9 ***	45.4 ^{2/}	38.9 ***	6.5
	05:45-05:50 HOUR	53.4 ^{2/}	51.8 ***	51.3 ^{2/}	44.3 ***	7.0
	05:50-05:55 HOUR	53.4 ^{2/}	51.8 ***	51.3 ^{2/}	44.3 ***	7.0
	05:55-06:00 HOUR	52.1 ^{2/}	51.8 ***	43.3 ^{2/}	44.3 ***	<0.8 ^{3/}
	DAY TIME ^{1/}					
	06:00-07:00 HOUR	51.2 ^{1/}	48.3 **	48.1 ^{1/}	42.2 **	5.9
MARCH 23, 2026 T26AG825-0011	DAY TIME ^{1/}					
	07:00-08:00 HOUR	53.6 ^{1/}	51.8 **	48.9 ^{1/}	43.6 **	5.3
	08:00-09:00 HOUR	55.5 ^{1/}	52.1 **	52.8 ^{1/}	44.9 **	7.9
	09:00-10:00 HOUR	57.3 ^{1/}	56.9 **	46.7 ^{1/}	44.8 **	1.9
	10:00-11:00 HOUR	62.2 ^{1/}	61.8 **	51.6 ^{1/}	49.7 **	1.9
	11:00-12:00 HOUR	56.6 ^{1/}	52.5 **	54.5 ^{1/}	47.1 **	7.4
	12:00-13:00 HOUR	52.3 ^{1/}	47.6 **	50.5 ^{1/}	43.4 **	7.1
	13:00-14:00 HOUR	55.9 ^{1/}	53.0 **	52.8 ^{1/}	45.0 **	7.8
	14:00-15:00 HOUR	57.6 ^{1/}	53.4 **	55.5 ^{1/}	48.4 **	7.1
	15:00-16:00 HOUR	59.0 ^{1/}	56.3 **	55.7 ^{1/}	48.6 **	7.1
	16:00-17:00 HOUR	51.4 ^{1/}	46.5 **	49.7 ^{1/}	41.8 **	7.9
	17:00-18:00 HOUR	52.4 ^{1/}	49.6 **	49.2 ^{1/}	42.5 **	6.7
	18:00-19:00 HOUR	53.4 ^{1/}	47.6 **	52.1 ^{1/}	44.5 **	7.6
	19:00-20:00 HOUR	58.1 ^{1/}	52.0 **	56.9 ^{1/}	50.3 **	6.6
	20:00-21:00 HOUR	55.5 ^{1/}	49.4 **	54.3 ^{1/}	46.7 **	7.6
	21:00-22:00 HOUR	60.3 ^{1/}	55.4 **	58.6 ^{1/}	51.1 **	7.5
	NIGHT TIME ^{2/}					
	22:00-22:05 HOUR	52.2 ^{2/}	51.9 ***	43.4 ^{2/}	40.3 ***	3.1
	22:05-22:10 HOUR	52.1 ^{2/}	51.9 ***	41.6 ^{2/}	40.3 ***	1.3
	22:10-22:15 HOUR	52.0 ^{2/}	51.9 ***	38.6 ^{2/}	40.3 ***	<0.8 ^{3/}
	22:15-22:20 HOUR	58.7 ^{2/}	58.5 ***	48.2 ^{2/}	44.6 ***	3.6
	22:20-22:25 HOUR	57.9 ^{2/}	58.5 ***	<0.8 ^{3/}	44.6 ***	<0.8 ^{3/}
	22:25-22:30 HOUR	47.9 ^{2/}	58.5 ***	<0.8 ^{3/}	44.6 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		วัดตามวงดงคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 23, 2026 T26AG825-0011	NIGHT TIME ^{2/}					
	22:30-22:35 HOUR	59.1 ^{2/}	58.9 ***	48.6 ^{2/}	52.7 ***	<0.8 ^{3/}
	22:35-22:40 HOUR	61.1 ^{2/}	58.9 ***	60.1 ^{2/}	52.7 ***	7.4
	22:40-22:45 HOUR	59.1 ^{2/}	58.9 ***	48.6 ^{2/}	52.7 ***	<0.8 ^{3/}
	22:45-22:50 HOUR	56.3 ^{2/}	56.2 ***	42.9 ^{2/}	49.3 ***	<0.8 ^{3/}
	22:50-22:55 HOUR	58.1 ^{2/}	56.2 ***	56.6 ^{2/}	49.3 ***	7.3
	22:55-23:00 HOUR	56.5 ^{2/}	56.2 ***	47.7 ^{2/}	49.3 ***	<0.8 ^{3/}
	23:00-23:05 HOUR	43.3 ^{2/}	42.6 ***	38.0 ^{2/}	38.1 ***	<0.8 ^{3/}
	23:05-23:10 HOUR	45.6 ^{2/}	42.6 ***	45.6 ^{2/}	38.1 ***	7.5
	23:10-23:15 HOUR	44.8 ^{2/}	42.6 ***	43.8 ^{2/}	38.1 ***	5.7
	23:15-23:20 HOUR	49.0 ^{2/}	48.8 ***	38.5 ^{2/}	43.8 ***	<0.8 ^{3/}
	23:20-23:25 HOUR	48.9 ^{2/}	48.8 ***	35.5 ^{2/}	43.8 ***	<0.8 ^{3/}
	23:25-23:30 HOUR	48.9 ^{2/}	48.8 ***	35.5 ^{2/}	43.8 ***	<0.8 ^{3/}
	23:30-23:35 HOUR	50.7 ^{2/}	50.5 ***	40.2 ^{2/}	47.7 ***	<0.8 ^{3/}
	23:35-23:40 HOUR	54.6 ^{2/}	50.5 ***	55.5 ^{2/}	47.7 ***	7.8
	23:40-23:45 HOUR	54.5 ^{2/}	50.5 ***	55.3 ^{2/}	47.7 ***	7.6
	23:45-23:50 HOUR	47.4 ^{2/}	43.5 ***	48.1 ^{2/}	40.4 ***	7.7
	23:50-23:55 HOUR	47.5 ^{2/}	43.5 ***	48.3 ^{2/}	40.4 ***	7.9
	23:55-00:00 HOUR	45.7 ^{2/}	43.5 ***	44.7 ^{2/}	40.4 ***	4.3
MARCH 24, 2026 T26AG825-0011	NIGHT TIME ^{2/}					
	00:00-00:05 HOUR	44.8 ^{2/}	40.3 ***	45.9 ^{2/}	38.1 ***	7.8
	00:05-00:10 HOUR	44.8 ^{2/}	40.3 ***	45.9 ^{2/}	38.1 ***	7.8
	00:10-00:15 HOUR	43.5 ^{2/}	40.3 ***	43.7 ^{2/}	38.1 ***	5.6
	00:15-00:20 HOUR	44.0 ^{2/}	42.8 ***	40.8 ^{2/}	37.0 ***	3.8
	00:20-00:25 HOUR	42.9 ^{2/}	42.8 ***	29.5 ^{2/}	37.0 ***	<0.8 ^{3/}
	00:25-00:30 HOUR	43.6 ^{2/}	42.8 ***	38.9 ^{2/}	37.0 ***	1.9
	00:30-00:35 HOUR	47.6 ^{2/}	45.2 ***	46.9 ^{2/}	39.2 ***	7.7
	00:35-00:40 HOUR	47.6 ^{2/}	45.2 ***	46.9 ^{2/}	39.2 ***	7.7
	00:40-00:45 HOUR	45.3 ^{2/}	45.2 ***	31.9 ^{2/}	39.2 ***	<0.8 ^{3/}
	00:45-00:50 HOUR	43.2 ^{2/}	39.7 ***	43.6 ^{2/}	37.5 ***	6.1
	00:50-00:55 HOUR	43.8 ^{2/}	39.7 ***	44.7 ^{2/}	37.5 ***	7.2
	00:55-01:00 HOUR	43.8 ^{2/}	39.7 ***	44.7 ^{2/}	37.5 ***	7.2
	01:00-01:05 HOUR	42.6 ^{2/}	40.7 ***	41.1 ^{2/}	36.9 ***	4.2
	01:05-01:10 HOUR	42.2 ^{2/}	40.7 ***	39.9 ^{2/}	36.9 ***	3.0
	01:10-01:15 HOUR	44.2 ^{2/}	40.7 ***	44.6 ^{2/}	36.9 ***	7.7
	01:15-01:20 HOUR	52.4 ^{2/}	63.5 ***	<0.8 ^{3/}	45.7 ***	<0.8 ^{3/}
	01:20-01:25 HOUR	56.0 ^{2/}	63.5 ***	<0.8 ^{3/}	45.7 ***	<0.8 ^{3/}
	01:25-01:30 HOUR	57.6 ^{2/}	63.5 ***	<0.8 ^{3/}	45.7 ***	<0.8 ^{3/}
	01:30-01:35 HOUR	61.0 ^{2/}	60.3 ***	55.7 ^{2/}	49.0 ***	6.7
	01:35-01:40 HOUR	61.0 ^{2/}	60.3 ***	55.7 ^{2/}	49.0 ***	6.7
	01:40-01:45 HOUR	60.6 ^{2/}	60.3 ***	51.8 ^{2/}	49.0 ***	2.8
	01:45-01:50 HOUR	54.6 ^{2/}	54.2 ***	47.0 ^{2/}	50.5 ***	<0.8 ^{3/}
	01:50-01:55 HOUR	54.6 ^{2/}	54.2 ***	47.0 ^{2/}	50.5 ***	<0.8 ^{3/}
	01:55-02:00 HOUR	57.9 ^{2/}	54.2 ***	58.5 ^{2/}	50.5 ***	8.0
	02:00-02:05 HOUR	43.7 ^{2/}	40.9 ***	43.5 ^{2/}	38.4 ***	5.1

DATE	TIME*	RESULT (dB(A))				
		วัดตามวงศการาม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 24, 2026 T26AG825-0011	NIGHT TIME ^{2/}					
	02:05-02:10 HOUR	45.2 ^{2/}	40.9 ***	46.2 ^{2/}	38.4 ***	7.8
	02:10-02:15 HOUR	44.3 ^{2/}	40.9 ***	44.6 ^{2/}	38.4 ***	6.2
	02:15-02:20 HOUR	43.4 ^{2/}	43.3 ***	30.0 ^{2/}	37.2 ***	<0.8 ^{3/}
	02:20-02:25 HOUR	43.4 ^{2/}	43.3 ***	30.0 ^{2/}	37.2 ***	<0.8 ^{3/}
	02:25-02:30 HOUR	43.5 ^{2/}	43.3 ***	33.0 ^{2/}	37.2 ***	<0.8 ^{3/}
	02:30-02:35 HOUR	51.6 ^{2/}	51.7 ***	<0.8 ^{3/}	38.9 ***	<0.8 ^{3/}
	02:35-02:40 HOUR	51.8 ^{2/}	51.7 ***	38.4 ^{2/}	38.9 ***	<0.8 ^{3/}
	02:40-02:45 HOUR	50.9 ^{2/}	51.7 ***	<0.8 ^{3/}	38.9 ***	<0.8 ^{3/}
	02:45-02:50 HOUR	47.0 ^{2/}	45.3 ***	45.1 ^{2/}	37.3 ***	7.8
	02:50-02:55 HOUR	45.5 ^{2/}	45.3 ***	35.0 ^{2/}	37.3 ***	<0.8 ^{3/}
	02:55-03:00 HOUR	45.4 ^{2/}	45.3 ***	32.0 ^{2/}	37.3 ***	<0.8 ^{3/}
	03:00-03:05 HOUR	43.8 ^{2/}	43.6 ***	33.3 ^{2/}	36.4 ***	<0.8 ^{3/}
	03:05-03:10 HOUR	45.5 ^{2/}	43.6 ***	44.0 ^{2/}	36.4 ***	7.6
	03:10-03:15 HOUR	43.7 ^{2/}	43.6 ***	30.3 ^{2/}	36.4 ***	<0.8 ^{3/}
	03:15-03:20 HOUR	44.4 ^{2/}	41.3 ***	44.5 ^{2/}	36.8 ***	7.7
	03:20-03:25 HOUR	42.7 ^{2/}	41.3 ***	40.1 ^{2/}	36.8 ***	3.3
	03:25-03:30 HOUR	43.7 ^{2/}	41.3 ***	43.0 ^{2/}	36.8 ***	6.2
	03:30-03:35 HOUR	45.0 ^{2/}	44.9 ***	31.6 ^{2/}	35.1 ***	<0.8 ^{3/}
	03:35-03:40 HOUR	45.0 ^{2/}	44.9 ***	31.6 ^{2/}	35.1 ***	<0.8 ^{3/}
	03:40-03:45 HOUR	45.0 ^{2/}	44.9 ***	31.6 ^{2/}	35.1 ***	<0.8 ^{3/}
	03:45-03:50 HOUR	51.0 ^{2/}	50.7 ***	42.2 ^{2/}	37.0 ***	5.2
	03:50-03:55 HOUR	50.6 ^{2/}	50.7 ***	<0.8 ^{3/}	37.0 ***	<0.8 ^{3/}
	03:55-04:00 HOUR	51.0 ^{2/}	50.7 ***	42.2 ^{2/}	37.0 ***	5.2
	04:00-04:05 HOUR	40.9 ^{2/}	40.7 ***	30.4 ^{2/}	34.7 ***	<0.8 ^{3/}
	04:05-04:10 HOUR	40.9 ^{2/}	40.7 ***	30.4 ^{2/}	34.7 ***	<0.8 ^{3/}
	04:10-04:15 HOUR	40.8 ^{2/}	40.7 ***	27.4 ^{2/}	34.7 ***	<0.8 ^{3/}
	04:15-04:20 HOUR	50.1 ^{2/}	51.2 ***	<0.8 ^{3/}	39.0 ***	<0.8 ^{3/}
	04:20-04:25 HOUR	51.3 ^{2/}	51.2 ***	37.9 ^{2/}	39.0 ***	<0.8 ^{3/}
	04:25-04:30 HOUR	51.9 ^{2/}	51.2 ***	46.6 ^{2/}	39.0 ***	7.6
	04:30-04:35 HOUR	42.0 ^{2/}	37.9 ***	42.9 ^{2/}	36.2 ***	6.7
	04:35-04:40 HOUR	41.2 ^{2/}	37.9 ***	41.5 ^{2/}	36.2 ***	5.3
	04:40-04:45 HOUR	40.2 ^{2/}	37.9 ***	39.3 ^{2/}	36.2 ***	3.1
	04:45-04:50 HOUR	41.4 ^{2/}	39.4 ***	40.1 ^{2/}	36.4 ***	3.7
	04:50-04:55 HOUR	41.3 ^{2/}	39.4 ***	39.8 ^{2/}	36.4 ***	3.4
	04:55-05:00 HOUR	43.5 ^{2/}	39.4 ***	44.4 ^{2/}	36.4 ***	8.0
	05:00-05:05 HOUR	48.1 ^{2/}	47.9 ***	37.6 ^{2/}	38.0 ***	<0.8 ^{3/}
	05:05-05:10 HOUR	48.1 ^{2/}	47.9 ***	37.6 ^{2/}	38.0 ***	<0.8 ^{3/}
	05:10-05:15 HOUR	48.1 ^{2/}	47.9 ***	37.6 ^{2/}	38.0 ***	<0.8 ^{3/}
	05:15-05:20 HOUR	52.5 ^{2/}	51.6 ***	48.2 ^{2/}	40.9 ***	7.3
	05:20-05:25 HOUR	52.5 ^{2/}	51.6 ***	48.2 ^{2/}	40.9 ***	7.3
	05:25-05:30 HOUR	51.9 ^{2/}	51.6 ***	43.1 ^{2/}	40.9 ***	2.2
	05:30-05:35 HOUR	46.2 ^{2/}	46.0 ***	35.7 ^{2/}	38.8 ***	<0.8 ^{3/}
	05:35-05:40 HOUR	47.4 ^{2/}	46.0 ***	44.8 ^{2/}	38.8 ***	6.0
	05:40-05:45 HOUR	48.0 ^{2/}	46.0 ***	46.7 ^{2/}	38.8 ***	7.9

DATE	TIME*	RESULT (dB(A))				
		วัดตามวงคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 24, 2026 T26AG825-0011	NIGHT TIME ^{2/}					
	05:45-05:50 HOUR	49.3 ^{2/}	49.1 ***	38.8 ^{2/}	44.3 ***	<0.8 ^{3/}
	05:50-05:55 HOUR	52.0 ^{2/}	49.1 ***	51.9 ^{2/}	44.3 ***	7.6
	05:55-06:00 HOUR	49.2 ^{2/}	49.1 ***	35.8 ^{2/}	44.3 ***	<0.8 ^{3/}
	DAY TIME ^{1/}					
	06:00-07:00 HOUR	50.6 ^{1/}	46.3 **	48.6 ^{1/}	40.6 **	8.0
MARCH 24, 2026 T26AG825-0012	DAY TIME ^{1/}					
	07:00-08:00 HOUR	55.6 ^{1/}	52.9 **	52.3 ^{1/}	45.4 **	6.9
	08:00-09:00 HOUR	55.4 ^{1/}	51.7 **	53.0 ^{1/}	45.8 **	7.2
	09:00-10:00 HOUR	57.6 ^{1/}	56.9 **	49.3 ^{1/}	44.2 **	5.1
	10:00-11:00 HOUR	60.2 ^{1/}	59.6 **	51.3 ^{1/}	43.9 **	7.4
	11:00-12:00 HOUR	57.0 ^{1/}	54.2 **	53.8 ^{1/}	46.6 **	7.2
	12:00-13:00 HOUR	51.4 ^{1/}	49.3 **	47.2 ^{1/}	43.3 **	3.9
	13:00-14:00 HOUR	57.9 ^{1/}	53.7 **	55.8 ^{1/}	48.7 **	7.1
	14:00-15:00 HOUR	57.8 ^{1/}	57.7 **	41.4 ^{1/}	44.4 **	<0.8 ^{3/}
	15:00-16:00 HOUR	56.6 ^{1/}	53.8 **	53.4 ^{1/}	46.1 **	7.3
	16:00-17:00 HOUR	54.0 ^{1/}	51.1 **	50.9 ^{1/}	44.8 **	6.1
	17:00-18:00 HOUR	47.5 ^{1/}	45.2 **	43.6 ^{1/}	40.7 **	2.9
	18:00-19:00 HOUR	54.0 ^{1/}	50.1 **	51.7 ^{1/}	44.3 **	7.4
	19:00-20:00 HOUR	44.7 ^{1/}	42.0 **	41.4 ^{1/}	38.7 **	2.7
	20:00-21:00 HOUR	52.4 ^{1/}	50.3 **	48.2 ^{1/}	43.0 **	5.2
	21:00-22:00 HOUR	51.0 ^{1/}	46.1 **	49.3 ^{1/}	43.5 **	5.8
	NIGHT TIME ^{2/}					
	22:00-22:05 HOUR	46.3 ^{2/}	44.0 ***	45.4 ^{2/}	40.9 ***	4.5
	22:05-22:10 HOUR	44.3 ^{2/}	44.0 ***	35.5 ^{2/}	40.9 ***	<0.8 ^{3/}
	22:10-22:15 HOUR	44.3 ^{2/}	44.0 ***	35.5 ^{2/}	40.9 ***	<0.8 ^{3/}
	22:15-22:20 HOUR	44.5 ^{2/}	43.8 ***	39.2 ^{2/}	41.0 ***	<0.8 ^{3/}
	22:20-22:25 HOUR	45.2 ^{2/}	43.8 ***	42.6 ^{2/}	41.0 ***	1.6
	22:25-22:30 HOUR	45.0 ^{2/}	43.8 ***	41.8 ^{2/}	41.0 ***	0.8
	22:30-22:35 HOUR	53.4 ^{2/}	53.0 ***	45.8 ^{2/}	43.5 ***	2.3
	22:35-22:40 HOUR	50.9 ^{2/}	53.0 ***	<0.8 ^{3/}	43.5 ***	<0.8 ^{3/}
	22:40-22:45 HOUR	53.2 ^{2/}	53.0 ***	42.7 ^{2/}	43.5 ***	<0.8 ^{3/}
	22:45-22:50 HOUR	55.2 ^{2/}	52.5 ***	54.9 ^{2/}	47.6 ***	7.3
	22:50-22:55 HOUR	55.1 ^{2/}	52.5 ***	54.6 ^{2/}	47.6 ***	7.0
	22:55-23:00 HOUR	52.6 ^{2/}	52.5 ***	39.2 ^{2/}	47.6 ***	<0.8 ^{3/}
	23:00-23:05 HOUR	49.7 ^{2/}	47.8 ***	48.2 ^{2/}	41.1 ***	7.1
	23:05-23:10 HOUR	49.8 ^{2/}	47.8 ***	48.5 ^{2/}	41.1 ***	7.4
	23:10-23:15 HOUR	48.0 ^{2/}	47.8 ***	37.5 ^{2/}	41.1 ***	<0.8 ^{3/}
	23:15-23:20 HOUR	47.7 ^{2/}	46.4 ***	44.8 ^{2/}	38.0 ***	6.8
	23:20-23:25 HOUR	46.7 ^{2/}	46.4 ***	37.9 ^{2/}	38.0 ***	<0.8 ^{3/}
	23:25-23:30 HOUR	46.6 ^{2/}	46.4 ***	36.1 ^{2/}	38.0 ***	<0.8 ^{3/}
	23:30-23:35 HOUR	50.4 ^{2/}	50.0 ***	42.8 ^{2/}	40.0 ***	2.8
	23:35-23:40 HOUR	49.3 ^{2/}	50.0 ***	<0.8 ^{3/}	40.0 ***	<0.8 ^{3/}
	23:40-23:45 HOUR	47.7 ^{2/}	50.0 ***	<0.8 ^{3/}	40.0 ***	<0.8 ^{3/}
	23:45-23:50 HOUR	43.8 ^{2/}	42.9 ***	39.5 ^{2/}	39.8 ***	<0.8 ^{3/}
	23:50-23:55 HOUR	46.6 ^{2/}	42.9 ***	47.2 ^{2/}	39.8 ***	7.4

DATE	TIME*	RESULT (dB(A))				
		วัดตามวงศคราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 24, 2026	NIGHT TIME ^{2/}					
T26AG825-0012	23:55-00:00 HOUR	44.0 ^{2/}	42.9 ***	40.5 ^{2/}	39.8 ***	<0.8 ^{3/}
MARCH 25, 2026	NIGHT TIME ^{2/}					
T26AG825-0012	00:00-00:05 HOUR	44.9 ^{2/}	43.0 ***	43.4 ^{2/}	41.4 ***	2.0
	00:05-00:10 HOUR	45.3 ^{2/}	43.0 ***	44.4 ^{2/}	41.4 ***	3.0
	00:10-00:15 HOUR	44.3 ^{2/}	43.0 ***	41.4 ^{2/}	41.4 ***	<0.8 ^{3/}
	00:15-00:20 HOUR	49.3 ^{2/}	49.2 ***	35.9 ^{2/}	42.7 ***	<0.8 ^{3/}
	00:20-00:25 HOUR	49.4 ^{2/}	49.2 ***	38.9 ^{2/}	42.7 ***	<0.8 ^{3/}
	00:25-00:30 HOUR	51.3 ^{2/}	49.2 ***	50.1 ^{2/}	42.7 ***	7.4
	00:30-00:35 HOUR	54.5 ^{2/}	55.2 ***	<0.8 ^{3/}	50.3 ***	<0.8 ^{3/}
	00:35-00:40 HOUR	55.0 ^{2/}	55.2 ***	<0.8 ^{3/}	50.3 ***	<0.8 ^{3/}
	00:40-00:45 HOUR	57.8 ^{2/}	55.2 ***	57.3 ^{2/}	50.3 ***	7.0
	00:45-00:50 HOUR	45.0 ^{2/}	41.4 ***	45.5 ^{2/}	38.0 ***	7.5
	00:50-00:55 HOUR	45.0 ^{2/}	41.4 ***	45.5 ^{2/}	38.0 ***	7.5
	00:55-01:00 HOUR	42.9 ^{2/}	41.4 ***	40.6 ^{2/}	38.0 ***	2.6
	01:00-01:05 HOUR	41.9 ^{2/}	40.8 ***	38.4 ^{2/}	38.3 ***	<0.8 ^{3/}
	01:05-01:10 HOUR	41.3 ^{2/}	40.8 ***	34.7 ^{2/}	38.3 ***	<0.8 ^{3/}
	01:10-01:15 HOUR	41.1 ^{2/}	40.8 ***	32.3 ^{2/}	38.3 ***	<0.8 ^{3/}
	01:15-01:20 HOUR	41.6 ^{2/}	40.2 ***	39.0 ^{2/}	38.2 ***	0.8
	01:20-01:25 HOUR	41.2 ^{2/}	40.2 ***	37.3 ^{2/}	38.2 ***	<0.8 ^{3/}
	01:25-01:30 HOUR	40.8 ^{2/}	40.2 ***	34.9 ^{2/}	38.2 ***	<0.8 ^{3/}
	01:30-01:35 HOUR	40.4 ^{2/}	39.0 ***	37.8 ^{2/}	37.2 ***	<0.8 ^{3/}
	01:35-01:40 HOUR	41.8 ^{2/}	39.0 ***	41.6 ^{2/}	37.2 ***	4.4
	01:40-01:45 HOUR	39.8 ^{2/}	39.0 ***	35.1 ^{2/}	37.2 ***	<0.8 ^{3/}
	01:45-01:50 HOUR	40.6 ^{2/}	39.1 ***	38.3 ^{2/}	37.2 ***	1.1
	01:50-01:55 HOUR	39.3 ^{2/}	39.1 ***	28.8 ^{2/}	37.2 ***	<0.8 ^{3/}
	01:55-02:00 HOUR	39.6 ^{2/}	39.1 ***	33.0 ^{2/}	37.2 ***	<0.8 ^{3/}
	02:00-02:05 HOUR	42.7 ^{2/}	42.4 ***	33.9 ^{2/}	37.9 ***	<0.8 ^{3/}
	02:05-02:10 HOUR	42.6 ^{2/}	42.4 ***	32.1 ^{2/}	37.9 ***	<0.8 ^{3/}
	02:10-02:15 HOUR	42.6 ^{2/}	42.4 ***	32.1 ^{2/}	37.9 ***	<0.8 ^{3/}
	02:15-02:20 HOUR	49.4 ^{2/}	44.3 ***	50.8 ^{2/}	43.4 ***	7.4
	02:20-02:25 HOUR	49.5 ^{2/}	44.3 ***	50.9 ^{2/}	43.4 ***	7.5
	02:25-02:30 HOUR	45.6 ^{2/}	44.3 ***	42.7 ^{2/}	43.4 ***	<0.8 ^{3/}
	02:30-02:35 HOUR	52.2 ^{2/}	52.1 ***	38.8 ^{2/}	47.6 ***	<0.8 ^{3/}
	02:35-02:40 HOUR	50.8 ^{2/}	52.1 ***	<0.8 ^{3/}	47.6 ***	<0.8 ^{3/}
	02:40-02:45 HOUR	55.1 ^{2/}	52.1 ***	55.1 ^{2/}	47.6 ***	7.5
	02:45-02:50 HOUR	44.0 ^{2/}	40.3 ***	44.6 ^{2/}	37.2 ***	7.4
	02:50-02:55 HOUR	41.8 ^{2/}	40.3 ***	39.5 ^{2/}	37.2 ***	2.3
	02:55-03:00 HOUR	40.7 ^{2/}	40.3 ***	33.1 ^{2/}	37.2 ***	<0.8 ^{3/}
	03:00-03:05 HOUR	44.6 ^{2/}	48.1 ***	<0.8 ^{3/}	36.6 ***	<0.8 ^{3/}
	03:05-03:10 HOUR	48.4 ^{2/}	48.1 ***	39.6 ^{2/}	36.6 ***	3.0
	03:10-03:15 HOUR	47.6 ^{2/}	48.1 ***	<0.8 ^{3/}	36.6 ***	<0.8 ^{3/}
	03:15-03:20 HOUR	46.0 ^{2/}	45.9 ***	32.6 ^{2/}	35.7 ***	<0.8 ^{3/}
	03:20-03:25 HOUR	46.2 ^{2/}	45.9 ***	37.4 ^{2/}	35.7 ***	1.7
	03:25-03:30 HOUR	45.4 ^{2/}	45.9 ***	<0.8 ^{3/}	35.7 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		วัดตามวงคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 25, 2026	NIGHT TIME ^{2/}					
T26AG825-0012	03:30-03:35 HOUR	39.5 ^{2/}	39.3 ***	29.0 ^{2/}	35.9 ***	<0.8 ^{3/}
	03:35-03:40 HOUR	39.7 ^{2/}	39.3 ***	32.1 ^{2/}	35.9 ***	<0.8 ^{3/}
	03:40-03:45 HOUR	42.9 ^{2/}	39.3 ***	43.4 ^{2/}	35.9 ***	7.5
	03:45-03:50 HOUR	43.8 ^{2/}	41.7 ***	42.6 ^{2/}	35.4 ***	7.2
	03:50-03:55 HOUR	43.9 ^{2/}	41.7 ***	42.9 ^{2/}	35.4 ***	7.5
	03:55-04:00 HOUR	42.0 ^{2/}	41.7 ***	33.2 ^{2/}	35.4 ***	<0.8 ^{3/}
	04:00-04:05 HOUR	43.9 ^{2/}	43.8 ***	30.5 ^{2/}	35.5 ***	<0.8 ^{3/}
	04:05-04:10 HOUR	43.9 ^{2/}	43.8 ***	30.5 ^{2/}	35.5 ***	<0.8 ^{3/}
	04:10-04:15 HOUR	43.4 ^{2/}	43.8 ***	<0.8 ^{3/}	35.5 ***	<0.8 ^{3/}
	04:15-04:20 HOUR	46.4 ^{2/}	59.9 ***	<0.8 ^{3/}	37.7 ***	<0.8 ^{3/}
	04:20-04:25 HOUR	48.4 ^{2/}	59.9 ***	<0.8 ^{3/}	37.7 ***	<0.8 ^{3/}
	04:25-04:30 HOUR	44.5 ^{2/}	59.9 ***	<0.8 ^{3/}	37.7 ***	<0.8 ^{3/}
	04:30-04:35 HOUR	41.0 ^{2/}	38.1 ***	40.9 ^{2/}	34.5 ***	6.4
	04:35-04:40 HOUR	40.0 ^{2/}	38.1 ***	38.5 ^{2/}	34.5 ***	4.0
	04:40-04:45 HOUR	38.6 ^{2/}	38.1 ***	32.0 ^{2/}	34.5 ***	<0.8 ^{3/}
	04:45-04:50 HOUR	40.6 ^{2/}	39.0 ***	38.5 ^{2/}	34.6 ***	3.9
	04:50-04:55 HOUR	41.6 ^{2/}	39.0 ***	41.1 ^{2/}	34.6 ***	6.5
	04:55-05:00 HOUR	39.9 ^{2/}	39.0 ***	35.6 ^{2/}	34.6 ***	1.0
	05:00-05:05 HOUR	41.2 ^{2/}	41.1 ***	27.8 ^{2/}	35.8 ***	<0.8 ^{3/}
	05:05-05:10 HOUR	43.3 ^{2/}	41.1 ***	42.3 ^{2/}	35.8 ***	6.5
	05:10-05:15 HOUR	42.2 ^{2/}	41.1 ***	38.7 ^{2/}	35.8 ***	2.9
	05:15-05:20 HOUR	42.0 ^{2/}	41.8 ***	31.5 ^{2/}	36.7 ***	<0.8 ^{3/}
	05:20-05:25 HOUR	42.0 ^{2/}	41.8 ***	31.5 ^{2/}	36.7 ***	<0.8 ^{3/}
	05:25-05:30 HOUR	44.4 ^{2/}	41.8 ***	43.9 ^{2/}	36.7 ***	7.2
	05:30-05:35 HOUR	51.4 ^{2/}	51.1 ***	42.6 ^{2/}	38.6 ***	4.0
	05:35-05:40 HOUR	51.7 ^{2/}	51.1 ***	45.8 ^{2/}	38.6 ***	7.2
	05:40-05:45 HOUR	48.6 ^{2/}	51.1 ***	<0.8 ^{3/}	38.6 ***	<0.8 ^{3/}
	05:45-05:50 HOUR	53.2 ^{2/}	52.9 ***	44.4 ^{2/}	43.2 ***	1.2
	05:50-05:55 HOUR	54.0 ^{2/}	52.9 ***	50.5 ^{2/}	43.2 ***	7.3
	05:55-06:00 HOUR	53.2 ^{2/}	52.9 ***	44.4 ^{2/}	43.2 ***	1.2
	DAY TIME ^{1/}					
	06:00-07:00 HOUR	53.3 ^{1/}	50.8 **	49.7 ^{1/}	42.4 **	7.3
MARCH 25, 2026	DAY TIME ^{1/}					
T26AG825-0013	07:00-08:00 HOUR	54.7 ^{1/}	54.2 **	45.1 ^{1/}	44.4 **	<0.8 ^{3/}
	08:00-09:00 HOUR	54.8 ^{1/}	52.6 **	50.8 ^{1/}	46.4 **	4.4
	09:00-10:00 HOUR	59.7 ^{1/}	59.2 **	50.1 ^{1/}	42.8 **	7.3
	10:00-11:00 HOUR	52.0 ^{1/}	49.0 **	49.0 ^{1/}	42.7 **	6.3
	11:00-12:00 HOUR	58.7 ^{1/}	58.6 **	42.3 ^{1/}	45.1 **	<0.8 ^{3/}
	12:00-13:00 HOUR	50.0 ^{1/}	49.4 **	41.1 ^{1/}	44.0 **	<0.8 ^{3/}
	13:00-14:00 HOUR	58.2 ^{1/}	56.9 **	52.3 ^{1/}	46.0 **	6.3
	14:00-15:00 HOUR	61.2 ^{1/}	57.9 **	58.5 ^{1/}	51.5 **	7.0
	15:00-16:00 HOUR	53.2 ^{1/}	51.2 **	48.9 ^{1/}	43.1 **	5.8
	16:00-17:00 HOUR	49.5 ^{1/}	47.5 **	45.2 ^{1/}	43.1 **	2.1
	17:00-18:00 HOUR	49.8 ^{1/}	46.5 **	47.1 ^{1/}	41.5 **	5.6
	18:00-19:00 HOUR	53.2 ^{1/}	48.9 **	51.2 ^{1/}	44.0 **	7.2

DATE	TIME*	RESULT (dB(A))				
		วัดค่าความดังคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 25, 2026 T26AG825-0013	DAY TIME ^{1/}					
	19:00-20:00 HOUR	49.0 ^{1/}	43.4 **	47.6 ^{1/}	40.9 **	6.7
	20:00-21:00 HOUR	48.6 ^{1/}	45.7 **	45.5 ^{1/}	41.9 **	3.6
	21:00-22:00 HOUR	49.2 ^{1/}	44.0 **	47.6 ^{1/}	41.9 **	5.7
	NIGHT TIME ^{2/}					
	22:00-22:05 HOUR	46.0 ^{2/}	42.5 ***	46.4 ^{2/}	40.4 ***	6.0
	22:05-22:10 HOUR	45.7 ^{2/}	42.5 ***	45.9 ^{2/}	40.4 ***	5.5
	22:10-22:15 HOUR	43.9 ^{2/}	42.5 ***	41.3 ^{2/}	40.4 ***	0.9
	22:15-22:20 HOUR	44.9 ^{2/}	44.0 ***	40.6 ^{2/}	40.2 ***	<0.8 ^{3/}
	22:20-22:25 HOUR	44.3 ^{2/}	44.0 ***	35.5 ^{2/}	40.2 ***	<0.8 ^{3/}
	22:25-22:30 HOUR	46.9 ^{2/}	44.0 ***	46.8 ^{2/}	40.2 ***	6.6
	22:30-22:35 HOUR	45.5 ^{2/}	45.4 ***	32.1 ^{2/}	39.5 ***	<0.8 ^{3/}
	22:35-22:40 HOUR	45.5 ^{2/}	45.4 ***	32.1 ^{2/}	39.5 ***	<0.8 ^{3/}
	22:40-22:45 HOUR	46.4 ^{2/}	45.4 ***	42.5 ^{2/}	39.5 ***	3.0
	22:45-22:50 HOUR	57.5 ^{2/}	57.9 ***	<0.8 ^{3/}	54.0 ***	<0.8 ^{3/}
	22:50-22:55 HOUR	59.0 ^{2/}	57.9 ***	55.5 ^{2/}	54.0 ***	1.5
	22:55-23:00 HOUR	54.9 ^{2/}	57.9 ***	<0.8 ^{3/}	54.0 ***	<0.8 ^{3/}
	23:00-23:05 HOUR	52.0 ^{2/}	50.2 ***	50.3 ^{2/}	43.7 ***	6.6
	23:05-23:10 HOUR	51.7 ^{2/}	50.2 ***	49.4 ^{2/}	43.7 ***	5.7
	23:10-23:15 HOUR	50.6 ^{2/}	50.2 ***	43.0 ^{2/}	43.7 ***	<0.8 ^{3/}
	23:15-23:20 HOUR	45.6 ^{2/}	41.8 ***	46.3 ^{2/}	39.5 ***	6.8
	23:20-23:25 HOUR	42.7 ^{2/}	41.8 ***	38.4 ^{2/}	39.5 ***	<0.8 ^{3/}
	23:25-23:30 HOUR	42.1 ^{2/}	41.8 ***	33.3 ^{2/}	39.5 ***	<0.8 ^{3/}
	23:30-23:35 HOUR	43.9 ^{2/}	43.2 ***	38.6 ^{2/}	39.9 ***	<0.8 ^{3/}
	23:35-23:40 HOUR	43.6 ^{2/}	43.2 ***	36.0 ^{2/}	39.9 ***	<0.8 ^{3/}
	23:40-23:45 HOUR	46.0 ^{2/}	43.2 ***	45.8 ^{2/}	39.9 ***	5.9
	23:45-23:50 HOUR	47.1 ^{2/}	48.5 ***	<0.8 ^{3/}	38.6 ***	<0.8 ^{3/}
	23:50-23:55 HOUR	48.7 ^{2/}	48.5 ***	38.2 ^{2/}	38.6 ***	<0.8 ^{3/}
	23:55-00:00 HOUR	48.1 ^{2/}	48.5 ***	<0.8 ^{3/}	38.6 ***	<0.8 ^{3/}
MARCH 26, 2026 T26AG825-0013	NIGHT TIME ^{2/}					
	00:00-00:05 HOUR	54.0 ^{2/}	66.5 ***	<0.8 ^{3/}	41.2 ***	<0.8 ^{3/}
	00:05-00:10 HOUR	50.0 ^{2/}	66.5 ***	<0.8 ^{3/}	41.2 ***	<0.8 ^{3/}
	00:10-00:15 HOUR	47.3 ^{2/}	66.5 ***	<0.8 ^{3/}	41.2 ***	<0.8 ^{3/}
	00:15-00:20 HOUR	42.5 ^{2/}	41.1 ***	39.9 ^{2/}	39.7 ***	<0.8 ^{3/}
	00:20-00:25 HOUR	42.4 ^{2/}	41.1 ***	39.5 ^{2/}	39.7 ***	<0.8 ^{3/}
	00:25-00:30 HOUR	42.1 ^{2/}	41.1 ***	38.2 ^{2/}	39.7 ***	<0.8 ^{3/}
	00:30-00:35 HOUR	42.9 ^{2/}	41.5 ***	40.3 ^{2/}	39.8 ***	<0.8 ^{3/}
	00:35-00:40 HOUR	42.5 ^{2/}	41.5 ***	38.6 ^{2/}	39.8 ***	<0.8 ^{3/}
	00:40-00:45 HOUR	41.7 ^{2/}	41.5 ***	31.2 ^{2/}	39.8 ***	<0.8 ^{3/}
	00:45-00:50 HOUR	47.5 ^{2/}	47.2 ***	38.7 ^{2/}	38.4 ***	<0.8 ^{3/}
	00:50-00:55 HOUR	48.0 ^{2/}	47.2 ***	43.3 ^{2/}	38.4 ***	4.9
	00:55-01:00 HOUR	48.5 ^{2/}	47.2 ***	45.6 ^{2/}	38.4 ***	7.2
	01:00-01:05 HOUR	47.1 ^{2/}	45.6 ***	44.8 ^{2/}	41.3 ***	3.5
	01:05-01:10 HOUR	48.4 ^{2/}	45.6 ***	48.2 ^{2/}	41.3 ***	6.9
	01:10-01:15 HOUR	45.9 ^{2/}	45.6 ***	37.1 ^{2/}	41.3 ***	<0.8 ^{3/}
	01:15-01:20 HOUR	50.2 ^{2/}	52.4 ***	<0.8 ^{3/}	47.3 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		วัดตามวงดงคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 26, 2026	NIGHT TIME ^{2/}					
T26AG825-0013	01:20-01:25 HOUR	52.8 ^{2/}	52.4 ***	45.2 ^{2/}	47.3 ***	<0.8 ^{3/}
	01:25-01:30 HOUR	55.0 ^{2/}	52.4 ***	54.5 ^{2/}	47.3 ***	7.2
	01:30-01:35 HOUR	54.8 ^{2/}	56.1 ***	<0.8 ^{3/}	52.6 ***	<0.8 ^{3/}
	01:35-01:40 HOUR	55.0 ^{2/}	56.1 ***	<0.8 ^{3/}	52.6 ***	<0.8 ^{3/}
	01:40-01:45 HOUR	59.5 ^{2/}	56.1 ***	59.8 ^{2/}	52.6 ***	7.2
	01:45-01:50 HOUR	51.8 ^{2/}	48.3 ***	52.2 ^{2/}	45.5 ***	6.7
	01:50-01:55 HOUR	51.9 ^{2/}	48.3 ***	52.4 ^{2/}	45.5 ***	6.9
	01:55-02:00 HOUR	51.8 ^{2/}	48.3 ***	52.2 ^{2/}	45.5 ***	6.7
	02:00-02:05 HOUR	42.4 ^{2/}	39.0 ***	42.7 ^{2/}	37.0 ***	5.7
	02:05-02:10 HOUR	40.8 ^{2/}	39.0 ***	39.1 ^{2/}	37.0 ***	2.1
	02:10-02:15 HOUR	40.0 ^{2/}	39.0 ***	36.1 ^{2/}	37.0 ***	<0.8 ^{3/}
	02:15-02:20 HOUR	43.5 ^{2/}	43.2 ***	34.7 ^{2/}	37.7 ***	<0.8 ^{3/}
	02:20-02:25 HOUR	43.5 ^{2/}	43.2 ***	34.7 ^{2/}	37.7 ***	<0.8 ^{3/}
	02:25-02:30 HOUR	45.6 ^{2/}	43.2 ***	44.9 ^{2/}	37.7 ***	7.2
	02:30-02:35 HOUR	43.6 ^{2/}	39.7 ***	44.3 ^{2/}	37.2 ***	7.1
	02:35-02:40 HOUR	39.9 ^{2/}	39.7 ***	29.4 ^{2/}	37.2 ***	<0.8 ^{3/}
	02:40-02:45 HOUR	40.0 ^{2/}	39.7 ***	31.2 ^{2/}	37.2 ***	<0.8 ^{3/}
	02:45-02:50 HOUR	41.3 ^{2/}	39.7 ***	39.2 ^{2/}	38.0 ***	1.2
	02:50-02:55 HOUR	41.9 ^{2/}	39.7 ***	40.9 ^{2/}	38.0 ***	2.9
	02:55-03:00 HOUR	40.1 ^{2/}	39.7 ***	32.5 ^{2/}	38.0 ***	<0.8 ^{3/}
	03:00-03:05 HOUR	40.1 ^{2/}	39.6 ***	33.5 ^{2/}	38.7 ***	<0.8 ^{3/}
	03:05-03:10 HOUR	40.0 ^{2/}	39.6 ***	32.4 ^{2/}	38.7 ***	<0.8 ^{3/}
	03:10-03:15 HOUR	40.6 ^{2/}	39.6 ***	36.7 ^{2/}	38.7 ***	<0.8 ^{3/}
	03:15-03:20 HOUR	45.0 ^{2/}	43.0 ***	43.7 ^{2/}	38.2 ***	5.5
	03:20-03:25 HOUR	43.1 ^{2/}	43.0 ***	29.7 ^{2/}	38.2 ***	<0.8 ^{3/}
	03:25-03:30 HOUR	44.8 ^{2/}	43.0 ***	43.1 ^{2/}	38.2 ***	4.9
	03:30-03:35 HOUR	45.0 ^{2/}	44.4 ***	39.1 ^{2/}	38.4 ***	<0.8 ^{3/}
	03:35-03:40 HOUR	44.6 ^{2/}	44.4 ***	34.1 ^{2/}	38.4 ***	<0.8 ^{3/}
	03:40-03:45 HOUR	44.5 ^{2/}	44.4 ***	31.1 ^{2/}	38.4 ***	<0.8 ^{3/}
	03:45-03:50 HOUR	49.2 ^{2/}	48.6 ***	43.3 ^{2/}	37.6 ***	5.7
	03:50-03:55 HOUR	48.7 ^{2/}	48.6 ***	35.3 ^{2/}	37.6 ***	<0.8 ^{3/}
	03:55-04:00 HOUR	48.7 ^{2/}	48.6 ***	35.3 ^{2/}	37.6 ***	<0.8 ^{3/}
	04:00-04:05 HOUR	58.3 ^{2/}	58.2 ***	44.9 ^{2/}	39.8 ***	5.1
	04:05-04:10 HOUR	58.3 ^{2/}	58.2 ***	44.9 ^{2/}	39.8 ***	5.1
	04:10-04:15 HOUR	55.4 ^{2/}	58.2 ***	<0.8 ^{3/}	39.8 ***	<0.8 ^{3/}
	04:15-04:20 HOUR	52.3 ^{2/}	58.0 ***	<0.8 ^{3/}	40.6 ***	<0.8 ^{3/}
	04:20-04:25 HOUR	58.1 ^{2/}	58.0 ***	44.7 ^{2/}	40.6 ***	4.1
	04:25-04:30 HOUR	58.1 ^{2/}	58.0 ***	44.7 ^{2/}	40.6 ***	4.1
	04:30-04:35 HOUR	49.6 ^{2/}	48.9 ***	44.3 ^{2/}	37.7 ***	6.6
	04:35-04:40 HOUR	49.5 ^{2/}	48.9 ***	43.6 ^{2/}	37.7 ***	5.9
	04:40-04:45 HOUR	47.8 ^{2/}	48.9 ***	<0.8 ^{3/}	37.7 ***	<0.8 ^{3/}
	04:45-04:50 HOUR	42.5 ^{2/}	39.3 ***	42.7 ^{2/}	36.0 ***	6.7
	04:50-04:55 HOUR	42.7 ^{2/}	39.3 ***	43.0 ^{2/}	36.0 ***	7.0
	04:55-05:00 HOUR	40.1 ^{2/}	39.3 ***	35.4 ^{2/}	36.0 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		วัดตามวงศคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 26, 2026 T26AG825-0013	NIGHT TIME ^{2/}					
	05:00-05:05 HOUR	42.0 ^{2/}	41.8 ***	31.5 ^{2/}	36.5 ***	<0.8 ^{3/}
	05:05-05:10 HOUR	42.0 ^{2/}	41.8 ***	31.5 ^{2/}	36.5 ***	<0.8 ^{3/}
	05:10-05:15 HOUR	41.9 ^{2/}	41.8 ***	28.5 ^{2/}	36.5 ***	<0.8 ^{3/}
	05:15-05:20 HOUR	46.0 ^{2/}	45.0 ***	42.1 ^{2/}	37.6 ***	4.5
	05:20-05:25 HOUR	45.2 ^{2/}	45.0 ***	34.7 ^{2/}	37.6 ***	<0.8 ^{3/}
	05:25-05:30 HOUR	45.1 ^{2/}	45.0 ***	31.7 ^{2/}	37.6 ***	<0.8 ^{3/}
	05:30-05:35 HOUR	52.4 ^{2/}	52.3 ***	39.0 ^{2/}	39.6 ***	<0.8 ^{3/}
	05:35-05:40 HOUR	49.5 ^{2/}	52.3 ***	<0.8 ^{3/}	39.6 ***	<0.8 ^{3/}
	05:40-05:45 HOUR	52.5 ^{2/}	52.3 ***	42.0 ^{2/}	39.6 ***	2.4
	05:45-05:50 HOUR	53.7 ^{2/}	53.6 ***	40.3 ^{2/}	43.4 ***	<0.8 ^{3/}
	05:50-05:55 HOUR	54.0 ^{2/}	53.6 ***	46.4 ^{2/}	43.4 ***	3.0
	05:55-06:00 HOUR	53.7 ^{2/}	53.6 ***	40.3 ^{2/}	43.4 ***	<0.8 ^{3/}
	DAY TIME ^{1/}					
	06:00-07:00 HOUR	51.5 ^{1/}	50.5 **	44.6 ^{1/}	43.3 **	1.3
MARCH 26, 2026 T26AG825-0014	DAY TIME ^{1/}					
	07:00-08:00 HOUR	52.0 ^{1/}	46.7 **	50.5 ^{1/}	43.0 **	7.5
	08:00-09:00 HOUR	55.6 ^{1/}	54.5 **	49.1 ^{1/}	43.7 **	5.4
	09:00-10:00 HOUR	60.0 ^{1/}	59.8 **	46.5 ^{1/}	42.8 **	3.7
	10:00-11:00 HOUR	52.2 ^{1/}	51.3 **	44.9 ^{1/}	43.4 **	1.5
	11:00-12:00 HOUR	55.9 ^{1/}	53.6 **	52.0 ^{1/}	45.8 **	6.2
	12:00-13:00 HOUR	57.3 ^{1/}	53.0 **	55.3 ^{1/}	47.8 **	7.5
	13:00-14:00 HOUR	54.3 ^{1/}	48.7 **	52.9 ^{1/}	45.4 **	7.5
	14:00-15:00 HOUR	56.0 ^{1/}	54.2 **	51.3 ^{1/}	44.2 **	7.1
	15:00-16:00 HOUR	61.0 ^{1/}	59.4 **	55.9 ^{1/}	48.1 **	7.8
	16:00-17:00 HOUR	57.9 ^{1/}	52.5 **	56.4 ^{1/}	49.0 **	7.4
	17:00-18:00 HOUR	47.0 ^{1/}	45.7 **	41.1 ^{1/}	39.9 **	1.2
	18:00-19:00 HOUR	49.5 ^{1/}	45.6 **	47.2 ^{1/}	39.4 **	7.8
	19:00-20:00 HOUR	59.2 ^{1/}	54.9 **	57.2 ^{1/}	51.0 **	6.2
	20:00-21:00 HOUR	58.0 ^{1/}	51.7 **	56.8 ^{1/}	49.1 **	7.7
	21:00-22:00 HOUR	52.8 ^{1/}	49.9 **	49.7 ^{1/}	47.6 **	2.1
	NIGHT TIME ^{2/}					
	22:00-22:05 HOUR	48.1 ^{2/}	46.4 ***	46.2 ^{2/}	42.3 ***	3.9
	22:05-22:10 HOUR	48.3 ^{2/}	46.4 ***	46.8 ^{2/}	42.3 ***	4.5
	22:10-22:15 HOUR	47.1 ^{2/}	46.4 ***	41.8 ^{2/}	42.3 ***	<0.8 ^{3/}
	22:15-22:20 HOUR	46.1 ^{2/}	44.4 ***	44.2 ^{2/}	41.0 ***	3.2
	22:20-22:25 HOUR	46.5 ^{2/}	44.4 ***	45.3 ^{2/}	41.0 ***	4.3
	22:25-22:30 HOUR	46.1 ^{2/}	44.4 ***	44.2 ^{2/}	41.0 ***	3.2
	22:30-22:35 HOUR	45.8 ^{2/}	46.0 ***	<0.8 ^{3/}	40.4 ***	<0.8 ^{3/}
	22:35-22:40 HOUR	46.3 ^{2/}	46.0 ***	37.5 ^{2/}	40.4 ***	<0.8 ^{3/}
	22:40-22:45 HOUR	46.5 ^{2/}	46.0 ***	39.9 ^{2/}	40.4 ***	<0.8 ^{3/}
	22:45-22:50 HOUR	46.0 ^{2/}	51.1 ***	<0.8 ^{3/}	44.6 ***	<0.8 ^{3/}
	22:50-22:55 HOUR	52.5 ^{2/}	51.1 ***	49.9 ^{2/}	44.6 ***	5.3
	22:55-23:00 HOUR	51.3 ^{2/}	51.1 ***	40.8 ^{2/}	44.6 ***	<0.8 ^{3/}
	23:00-23:05 HOUR	53.5 ^{2/}	53.3 ***	43.0 ^{2/}	50.9 ***	<0.8 ^{3/}
	23:05-23:10 HOUR	53.5 ^{2/}	53.3 ***	43.0 ^{2/}	50.9 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		วัดตากวนคลองคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 26, 2026 T26AG825-0014	NIGHT TIME ^{2/}					
	23:10-23:15 HOUR	53.6 ^{2/}	53.3 ***	44.8 ^{2/}	50.9 ***	<0.8 ^{3/}
	23:15-23:20 HOUR	51.5 ^{2/}	48.5 ***	51.5 ^{2/}	43.6 ***	7.9
	23:20-23:25 HOUR	51.2 ^{2/}	48.5 ***	50.9 ^{2/}	43.6 ***	7.3
	23:25-23:30 HOUR	49.6 ^{2/}	48.5 ***	46.1 ^{2/}	43.6 ***	2.5
	23:30-23:35 HOUR	44.6 ^{2/}	41.6 ***	44.6 ^{2/}	39.2 ***	5.4
	23:35-23:40 HOUR	43.7 ^{2/}	41.6 ***	42.5 ^{2/}	39.2 ***	3.3
	23:40-23:45 HOUR	43.6 ^{2/}	41.6 ***	42.3 ^{2/}	39.2 ***	3.1
	23:45-23:50 HOUR	44.6 ^{2/}	48.6 ***	<0.8 ^{3/}	39.8 ***	<0.8 ^{3/}
	23:50-23:55 HOUR	45.4 ^{2/}	48.6 ***	<0.8 ^{3/}	39.8 ***	<0.8 ^{3/}
	23:55-00:00 HOUR	48.8 ^{2/}	48.6 ***	38.3 ^{2/}	39.8 ***	<0.8 ^{3/}
MARCH 27, 2026 T26AG825-0014	NIGHT TIME ^{2/}					
	00:00-00:05 HOUR	49.0 ^{2/}	46.4 ***	48.5 ^{2/}	44.0 ***	4.5
	00:05-00:10 HOUR	48.7 ^{2/}	46.4 ***	47.8 ^{2/}	44.0 ***	3.8
	00:10-00:15 HOUR	49.3 ^{2/}	46.4 ***	49.2 ^{2/}	44.0 ***	5.2
	00:15-00:20 HOUR	48.6 ^{2/}	47.3 ***	45.7 ^{2/}	45.1 ***	<0.8 ^{3/}
	00:20-00:25 HOUR	48.5 ^{2/}	47.3 ***	45.3 ^{2/}	45.1 ***	<0.8 ^{3/}
	00:25-00:30 HOUR	48.5 ^{2/}	47.3 ***	45.3 ^{2/}	45.1 ***	<0.8 ^{3/}
	00:30-00:35 HOUR	49.5 ^{2/}	47.8 ***	47.6 ^{2/}	45.6 ***	2.0
	00:35-00:40 HOUR	48.3 ^{2/}	47.8 ***	41.7 ^{2/}	45.6 ***	<0.8 ^{3/}
	00:40-00:45 HOUR	48.5 ^{2/}	47.8 ***	43.2 ^{2/}	45.6 ***	<0.8 ^{3/}
	00:45-00:50 HOUR	48.4 ^{2/}	47.6 ***	43.7 ^{2/}	44.7 ***	<0.8 ^{3/}
	00:50-00:55 HOUR	49.1 ^{2/}	47.6 ***	46.8 ^{2/}	44.7 ***	2.1
	00:55-01:00 HOUR	49.7 ^{2/}	47.6 ***	48.5 ^{2/}	44.7 ***	3.8
	01:00-01:05 HOUR	49.1 ^{2/}	55.3 ***	<0.8 ^{3/}	52.9 ***	<0.8 ^{3/}
	01:05-01:10 HOUR	59.4 ^{2/}	55.3 ***	60.3 ^{2/}	52.9 ***	7.4
	01:10-01:15 HOUR	58.9 ^{2/}	55.3 ***	59.4 ^{2/}	52.9 ***	6.5
	01:15-01:20 HOUR	44.7 ^{2/}	40.4 ***	45.7 ^{2/}	38.1 ***	7.6
	01:20-01:25 HOUR	42.4 ^{2/}	40.4 ***	41.1 ^{2/}	38.1 ***	3.0
	01:25-01:30 HOUR	41.8 ^{2/}	40.4 ***	39.2 ^{2/}	38.1 ***	1.1
	01:30-01:35 HOUR	43.5 ^{2/}	39.8 ***	44.1 ^{2/}	38.6 ***	5.5
	01:35-01:40 HOUR	44.7 ^{2/}	39.8 ***	46.0 ^{2/}	38.6 ***	7.4
	01:40-01:45 HOUR	41.1 ^{2/}	39.8 ***	38.2 ^{2/}	38.6 ***	<0.8 ^{3/}
	01:45-01:50 HOUR	42.8 ^{2/}	42.4 ***	35.2 ^{2/}	39.9 ***	<0.8 ^{3/}
	01:50-01:55 HOUR	42.3 ^{2/}	42.4 ***	<0.8 ^{3/}	39.9 ***	<0.8 ^{3/}
	01:55-02:00 HOUR	42.6 ^{2/}	42.4 ***	32.1 ^{2/}	39.9 ***	<0.8 ^{3/}
	02:00-02:05 HOUR	49.7 ^{2/}	49.3 ***	42.1 ^{2/}	46.3 ***	<0.8 ^{3/}
	02:05-02:10 HOUR	52.0 ^{2/}	49.3 ***	51.7 ^{2/}	46.3 ***	5.4
	02:10-02:15 HOUR	52.4 ^{2/}	49.3 ***	52.5 ^{2/}	46.3 ***	6.2
	02:15-02:20 HOUR	48.6 ^{2/}	47.3 ***	45.7 ^{2/}	44.8 ***	0.9
	02:20-02:25 HOUR	48.2 ^{2/}	47.3 ***	43.9 ^{2/}	44.8 ***	<0.8 ^{3/}
	02:25-02:30 HOUR	49.6 ^{2/}	47.3 ***	48.7 ^{2/}	44.8 ***	3.9
	02:30-02:35 HOUR	47.6 ^{2/}	45.9 ***	45.7 ^{2/}	44.1 ***	1.6
	02:35-02:40 HOUR	47.5 ^{2/}	45.9 ***	45.4 ^{2/}	44.1 ***	1.3
	02:40-02:45 HOUR	46.8 ^{2/}	45.9 ***	42.5 ^{2/}	44.1 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		วัดตามวงศคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 27, 2026	NIGHT TIME ^{2/}					
T26AG825-0014	02:45-02:50 HOUR	49.4 ^{2/}	56.2 ***	<0.8 ^{3/}	54.0 ***	<0.8 ^{3/}
	02:50-02:55 HOUR	50.0 ^{2/}	56.2 ***	<0.8 ^{3/}	54.0 ***	<0.8 ^{3/}
	02:55-03:00 HOUR	60.6 ^{2/}	56.2 ***	61.6 ^{2/}	54.0 ***	7.6
	03:00-03:05 HOUR	60.2 ^{2/}	56.6 ***	60.7 ^{2/}	53.6 ***	7.1
	03:05-03:10 HOUR	56.8 ^{2/}	56.6 ***	46.3 ^{2/}	53.6 ***	<0.8 ^{3/}
	03:10-03:15 HOUR	56.8 ^{2/}	56.6 ***	46.3 ^{2/}	53.6 ***	<0.8 ^{3/}
	03:15-03:20 HOUR	57.8 ^{2/}	55.8 ***	56.5 ^{2/}	52.6 ***	3.9
	03:20-03:25 HOUR	59.5 ^{2/}	55.8 ***	60.1 ^{2/}	52.6 ***	7.5
	03:25-03:30 HOUR	49.3 ^{2/}	55.8 ***	<0.8 ^{3/}	52.6 ***	<0.8 ^{3/}
	03:30-03:35 HOUR	47.8 ^{2/}	46.0 ***	46.1 ^{2/}	44.1 ***	2.0
	03:35-03:40 HOUR	48.3 ^{2/}	46.0 ***	47.4 ^{2/}	44.1 ***	3.3
	03:40-03:45 HOUR	47.6 ^{2/}	46.0 ***	45.5 ^{2/}	44.1 ***	1.4
	03:45-03:50 HOUR	47.9 ^{2/}	47.2 ***	42.6 ^{2/}	45.1 ***	<0.8 ^{3/}
	03:50-03:55 HOUR	47.9 ^{2/}	47.2 ***	42.6 ^{2/}	45.1 ***	<0.8 ^{3/}
	03:55-04:00 HOUR	47.6 ^{2/}	47.2 ***	40.0 ^{2/}	45.1 ***	<0.8 ^{3/}
	04:00-04:05 HOUR	49.6 ^{2/}	60.2 ***	<0.8 ^{3/}	57.9 ***	<0.8 ^{3/}
	04:05-04:10 HOUR	64.4 ^{2/}	60.2 ***	65.3 ^{2/}	57.9 ***	7.4
	04:10-04:15 HOUR	64.3 ^{2/}	60.2 ***	65.2 ^{2/}	57.9 ***	7.3
	04:15-04:20 HOUR	60.5 ^{2/}	55.5 ***	61.8 ^{2/}	54.6 ***	7.2
	04:20-04:25 HOUR	57.5 ^{2/}	55.5 ***	56.2 ^{2/}	54.6 ***	1.6
	04:25-04:30 HOUR	56.5 ^{2/}	55.5 ***	52.6 ^{2/}	54.6 ***	<0.8 ^{3/}
	04:30-04:35 HOUR	52.2 ^{2/}	50.9 ***	49.3 ^{2/}	42.8 ***	6.5
	04:35-04:40 HOUR	52.2 ^{2/}	50.9 ***	49.3 ^{2/}	42.8 ***	6.5
	04:40-04:45 HOUR	51.2 ^{2/}	50.9 ***	42.4 ^{2/}	42.8 ***	<0.8 ^{3/}
	04:45-04:50 HOUR	51.0 ^{2/}	49.8 ***	47.8 ^{2/}	41.1 ***	6.7
	04:50-04:55 HOUR	50.1 ^{2/}	49.8 ***	41.3 ^{2/}	41.1 ***	<0.8 ^{3/}
	04:55-05:00 HOUR	46.1 ^{2/}	49.8 ***	<0.8 ^{3/}	41.1 ***	<0.8 ^{3/}
	05:00-05:05 HOUR	47.1 ^{2/}	47.5 ***	<0.8 ^{3/}	37.9 ***	<0.8 ^{3/}
	05:05-05:10 HOUR	45.8 ^{2/}	47.5 ***	<0.8 ^{3/}	37.9 ***	<0.8 ^{3/}
	05:10-05:15 HOUR	48.0 ^{2/}	47.5 ***	41.4 ^{2/}	37.9 ***	3.5
	05:15-05:20 HOUR	49.2 ^{2/}	48.3 ***	44.9 ^{2/}	37.6 ***	7.3
	05:20-05:25 HOUR	48.4 ^{2/}	48.3 ***	35.0 ^{2/}	37.6 ***	<0.8 ^{3/}
	05:25-05:30 HOUR	44.8 ^{2/}	48.3 ***	<0.8 ^{3/}	37.6 ***	<0.8 ^{3/}
	05:30-05:35 HOUR	43.3 ^{2/}	41.8 ***	41.0 ^{2/}	37.2 ***	3.8
	05:35-05:40 HOUR	43.7 ^{2/}	41.8 ***	42.2 ^{2/}	37.2 ***	5.0
	05:40-05:45 HOUR	42.3 ^{2/}	41.8 ***	35.7 ^{2/}	37.2 ***	<0.8 ^{3/}
	05:45-05:50 HOUR	49.2 ^{2/}	46.2 ***	49.2 ^{2/}	41.8 ***	7.4
	05:50-05:55 HOUR	47.1 ^{2/}	46.2 ***	42.8 ^{2/}	41.8 ***	1.0
	05:55-06:00 HOUR	48.5 ^{2/}	46.2 ***	47.6 ^{2/}	41.8 ***	5.8
	DAY TIME ^{1/}					
	06:00-07:00 HOUR	52.1 ^{1/}	50.0 **	47.9 ^{1/}	41.1 **	6.8
MARCH 27, 2026	DAY TIME ^{1/}					
T26AG825-0015	07:00-08:00 HOUR	53.3 ^{1/}	50.6 **	50.0 ^{1/}	42.8 **	7.2
	08:00-09:00 HOUR	51.1 ^{1/}	49.2 **	46.6 ^{1/}	41.1 **	5.5
	09:00-10:00 HOUR	50.0 ^{1/}	46.4 **	47.5 ^{1/}	40.9 **	6.6

DATE	TIME*	RESULT (dB(A))				
		วัดตามถนนสาธารณะ				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 27, 2026	DAY TIME ^{1/}					
T26AG825-0015	10:00-11:00 HOUR	49.7 ^{1/}	48.9 **	42.0 ^{1/}	41.9 **	<0.8 ^{3/}
	11:00-12:00 HOUR	53.0 ^{1/}	50.0 **	50.0 ^{1/}	43.7 **	6.3
	12:00-13:00 HOUR	50.2 ^{1/}	49.7 **	40.6 ^{1/}	44.5 **	<0.8 ^{3/}
	13:00-14:00 HOUR	51.2 ^{1/}	49.5 **	46.3 ^{1/}	43.6 **	2.7
	14:00-15:00 HOUR	56.8 ^{1/}	51.8 **	55.1 ^{1/}	47.6 **	7.5
	15:00-16:00 HOUR	56.5 ^{1/}	54.5 **	52.2 ^{1/}	46.2 **	6.0
	16:00-17:00 HOUR	51.3 ^{1/}	47.6 **	48.9 ^{1/}	41.4 **	7.5
	17:00-18:00 HOUR	48.1 ^{1/}	44.7 **	45.4 ^{1/}	40.0 **	5.4
	18:00-19:00 HOUR	52.3 ^{1/}	46.5 **	51.0 ^{1/}	43.5 **	7.5
	19:00-20:00 HOUR	57.7 ^{1/}	52.7 **	56.0 ^{1/}	49.0 **	7.0
	20:00-21:00 HOUR	50.3 ^{1/}	49.8 **	40.7 ^{1/}	46.5 **	<0.8 ^{3/}
	21:00-22:00 HOUR	50.9 ^{1/}	45.8 **	49.3 ^{1/}	43.0 **	6.3
	NIGHT TIME ^{2/}					
	22:00-22:05 HOUR	50.5 ^{2/}	48.0 ***	49.9 ^{2/}	45.0 ***	4.9
	22:05-22:10 HOUR	50.2 ^{2/}	48.0 ***	49.2 ^{2/}	45.0 ***	4.2
	22:10-22:15 HOUR	50.8 ^{2/}	48.0 ***	50.6 ^{2/}	45.0 ***	5.6
	22:15-22:20 HOUR	47.5 ^{2/}	50.1 ***	<0.8 ^{3/}	44.8 ***	<0.8 ^{3/}
	22:20-22:25 HOUR	47.7 ^{2/}	50.1 ***	<0.8 ^{3/}	44.8 ***	<0.8 ^{3/}
	22:25-22:30 HOUR	51.6 ^{2/}	50.1 ***	49.3 ^{2/}	44.8 ***	4.5
	22:30-22:35 HOUR	48.5 ^{2/}	46.3 ***	47.5 ^{2/}	43.3 ***	4.2
	22:35-22:40 HOUR	47.3 ^{2/}	46.3 ***	43.4 ^{2/}	43.3 ***	<0.8 ^{3/}
	22:40-22:45 HOUR	45.8 ^{2/}	46.3 ***	<0.8 ^{3/}	43.3 ***	<0.8 ^{3/}
	22:45-22:50 HOUR	46.3 ^{2/}	49.2 ***	<0.8 ^{3/}	46.0 ***	<0.8 ^{3/}
	22:50-22:55 HOUR	51.9 ^{2/}	49.2 ***	51.6 ^{2/}	46.0 ***	5.6
	22:55-23:00 HOUR	52.4 ^{2/}	49.2 ***	52.6 ^{2/}	46.0 ***	6.6
	23:00-23:05 HOUR	46.3 ^{2/}	44.6 ***	44.4 ^{2/}	41.2 ***	3.2
	23:05-23:10 HOUR	48.1 ^{2/}	44.6 ***	48.5 ^{2/}	41.2 ***	7.3
	23:10-23:15 HOUR	46.4 ^{2/}	44.6 ***	44.7 ^{2/}	41.2 ***	3.5
	23:15-23:20 HOUR	46.2 ^{2/}	51.1 ***	<0.8 ^{3/}	41.3 ***	<0.8 ^{3/}
	23:20-23:25 HOUR	47.4 ^{2/}	51.1 ***	<0.8 ^{3/}	41.3 ***	<0.8 ^{3/}
	23:25-23:30 HOUR	45.2 ^{2/}	51.1 ***	<0.8 ^{3/}	41.3 ***	<0.8 ^{3/}
	23:30-23:35 HOUR	46.6 ^{2/}	69.3 ***	<0.8 ^{3/}	44.4 ***	<0.8 ^{3/}
	23:35-23:40 HOUR	67.8 ^{2/}	69.3 ***	<0.8 ^{3/}	44.4 ***	<0.8 ^{3/}
	23:40-23:45 HOUR	47.5 ^{2/}	69.3 ***	<0.8 ^{3/}	44.4 ***	<0.8 ^{3/}
	23:45-23:50 HOUR	48.7 ^{2/}	54.8 ***	<0.8 ^{3/}	49.5 ***	<0.8 ^{3/}
	23:50-23:55 HOUR	49.8 ^{2/}	54.8 ***	<0.8 ^{3/}	49.5 ***	<0.8 ^{3/}
	23:55-00:00 HOUR	55.5 ^{2/}	54.8 ***	50.2 ^{2/}	49.5 ***	<0.8 ^{3/}
MARCH 28, 2026	NIGHT TIME ^{2/}					
T26AG825-0015	00:00-00:05 HOUR	50.9 ^{2/}	49.4 ***	48.6 ^{2/}	42.1 ***	6.5
	00:05-00:10 HOUR	47.7 ^{2/}	49.4 ***	<0.8 ^{3/}	42.1 ***	<0.8 ^{3/}
	00:10-00:15 HOUR	49.9 ^{2/}	49.4 ***	43.3 ^{2/}	42.1 ***	1.2
	00:15-00:20 HOUR	45.8 ^{2/}	44.0 ***	44.1 ^{2/}	39.8 ***	4.3
	00:20-00:25 HOUR	45.8 ^{2/}	44.0 ***	44.1 ^{2/}	39.8 ***	4.3
	00:25-00:30 HOUR	44.7 ^{2/}	44.0 ***	39.4 ^{2/}	39.8 ***	<0.8 ^{3/}
	00:30-00:35 HOUR	46.9 ^{2/}	46.1 ***	42.2 ^{2/}	42.7 ***	<0.8 ^{3/}

DATE	TIME*	RESULT (dB(A))				
		วัดตามวงนการารม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 28, 2026 T26AG825-0015	NIGHT TIME ^{2/}					
	00:35-00:40 HOUR	45.6 ^{2/}	46.1 ***	<0.8 ^{3/}	42.7 ***	<0.8 ^{3/}
	00:40-00:45 HOUR	47.9 ^{2/}	46.1 ***	46.2 ^{2/}	42.7 ***	3.5
	00:45-00:50 HOUR	49.1 ^{2/}	45.1 ***	49.9 ^{2/}	42.1 ***	7.8
	00:50-00:55 HOUR	49.0 ^{2/}	45.1 ***	49.7 ^{2/}	42.1 ***	7.6
	00:55-01:00 HOUR	45.4 ^{2/}	45.1 ***	36.6 ^{2/}	42.1 ***	<0.8 ^{3/}
	01:00-01:05 HOUR	46.3 ^{2/}	44.1 ***	45.3 ^{2/}	39.9 ***	5.4
	01:05-01:10 HOUR	47.4 ^{2/}	44.1 ***	47.7 ^{2/}	39.9 ***	7.8
	01:10-01:15 HOUR	45.5 ^{2/}	44.1 ***	42.9 ^{2/}	39.9 ***	3.0
	01:15-01:20 HOUR	43.0 ^{2/}	42.7 ***	34.2 ^{2/}	40.4 ***	<0.8 ^{3/}
	01:20-01:25 HOUR	44.8 ^{2/}	42.7 ***	43.6 ^{2/}	40.4 ***	3.2
	01:25-01:30 HOUR	44.2 ^{2/}	42.7 ***	41.9 ^{2/}	40.4 ***	1.5
	01:30-01:35 HOUR	44.6 ^{2/}	42.1 ***	44.0 ^{2/}	39.8 ***	4.2
	01:35-01:40 HOUR	44.0 ^{2/}	42.1 ***	42.5 ^{2/}	39.8 ***	2.7
	01:40-01:45 HOUR	43.2 ^{2/}	42.1 ***	39.7 ^{2/}	39.8 ***	<0.8 ^{3/}
	01:45-01:50 HOUR	44.5 ^{2/}	41.5 ***	44.5 ^{2/}	39.7 ***	4.8
	01:50-01:55 HOUR	42.9 ^{2/}	41.5 ***	40.3 ^{2/}	39.7 ***	<0.8 ^{3/}
	01:55-02:00 HOUR	41.4 ^{2/}	41.5 ***	<0.8 ^{3/}	39.7 ***	<0.8 ^{3/}
	02:00-02:05 HOUR	42.6 ^{2/}	42.5 ***	29.2 ^{2/}	39.3 ***	<0.8 ^{3/}
	02:05-02:10 HOUR	42.9 ^{2/}	42.5 ***	35.3 ^{2/}	39.3 ***	<0.8 ^{3/}
	02:10-02:15 HOUR	44.5 ^{2/}	42.5 ***	43.2 ^{2/}	39.3 ***	3.9
	02:15-02:20 HOUR	41.4 ^{2/}	39.8 ***	39.3 ^{2/}	37.8 ***	1.5
	02:20-02:25 HOUR	43.2 ^{2/}	39.8 ***	43.5 ^{2/}	37.8 ***	5.7
	02:25-02:30 HOUR	41.2 ^{2/}	39.8 ***	38.6 ^{2/}	37.8 ***	0.8
	02:30-02:35 HOUR	41.3 ^{2/}	41.2 ***	27.9 ^{2/}	38.6 ***	<0.8 ^{3/}
	02:35-02:40 HOUR	41.5 ^{2/}	41.2 ***	32.7 ^{2/}	38.6 ***	<0.8 ^{3/}
	02:40-02:45 HOUR	42.0 ^{2/}	41.2 ***	37.3 ^{2/}	38.6 ***	<0.8 ^{3/}
	02:45-02:50 HOUR	42.3 ^{2/}	41.0 ***	39.4 ^{2/}	37.7 ***	1.7
	02:50-02:55 HOUR	44.7 ^{2/}	41.0 ***	45.3 ^{2/}	37.7 ***	7.6
	02:55-03:00 HOUR	41.7 ^{2/}	41.0 ***	36.4 ^{2/}	37.7 ***	<0.8 ^{3/}
	03:00-03:05 HOUR	42.0 ^{2/}	41.8 ***	31.5 ^{2/}	37.2 ***	<0.8 ^{3/}
	03:05-03:10 HOUR	39.7 ^{2/}	41.8 ***	<0.8 ^{3/}	37.2 ***	<0.8 ^{3/}
	03:10-03:15 HOUR	42.0 ^{2/}	41.8 ***	31.5 ^{2/}	37.2 ***	<0.8 ^{3/}
	03:15-03:20 HOUR	42.2 ^{2/}	42.3 ***	<0.8 ^{3/}	38.8 ***	<0.8 ^{3/}
	03:20-03:25 HOUR	44.1 ^{2/}	42.3 ***	42.4 ^{2/}	38.8 ***	3.6
	03:25-03:30 HOUR	43.8 ^{2/}	42.3 ***	41.5 ^{2/}	38.8 ***	2.7
	03:30-03:35 HOUR	44.3 ^{2/}	50.6 ***	<0.8 ^{3/}	45.7 ***	<0.8 ^{3/}
	03:35-03:40 HOUR	53.0 ^{2/}	50.6 ***	52.3 ^{2/}	45.7 ***	6.6
	03:40-03:45 HOUR	52.2 ^{2/}	50.6 ***	50.1 ^{2/}	45.7 ***	4.4
	03:45-03:50 HOUR	51.5 ^{2/}	54.0 ***	<0.8 ^{3/}	49.6 ***	<0.8 ^{3/}
	03:50-03:55 HOUR	52.8 ^{2/}	54.0 ***	<0.8 ^{3/}	49.6 ***	<0.8 ^{3/}
	03:55-04:00 HOUR	51.8 ^{2/}	54.0 ***	<0.8 ^{3/}	49.6 ***	<0.8 ^{3/}
	04:00-04:05 HOUR	52.0 ^{2/}	49.4 ***	51.5 ^{2/}	44.7 ***	6.8
	04:05-04:10 HOUR	51.2 ^{2/}	49.4 ***	49.5 ^{2/}	44.7 ***	4.8
	04:10-04:15 HOUR	50.4 ^{2/}	49.4 ***	46.5 ^{2/}	44.7 ***	1.8

DATE	TIME*	RESULT (dB(A))				
		วัดตามวงดงคาราม				
		SPECIFIC SOUND LEVEL	RESIDUAL SOUND LEVEL	RATING LEVEL	BACKGROUND SOUND LEVEL	ANNOYANCE SOUND LEVEL
MARCH 28, 2026 T26AG825-0015	NIGHT TIME ^{2/}					
	04:15-04:20 HOUR	49.5 ^{2/}	49.7 ***	<0.8 ^{3/}	45.0 ***	<0.8 ^{3/}
	04:20-04:25 HOUR	51.4 ^{2/}	49.7 ***	49.5 ^{2/}	45.0 ***	4.5
	04:25-04:30 HOUR	52.5 ^{2/}	49.7 ***	52.3 ^{2/}	45.0 ***	7.3
	04:30-04:35 HOUR	51.4 ^{2/}	49.5 ***	49.9 ^{2/}	44.0 ***	5.9
	04:35-04:40 HOUR	51.5 ^{2/}	49.5 ***	50.2 ^{2/}	44.0 ***	6.2
	04:40-04:45 HOUR	52.1 ^{2/}	49.5 ***	51.6 ^{2/}	44.0 ***	7.6
	04:45-04:50 HOUR	50.0 ^{2/}	49.4 ***	44.1 ^{2/}	45.7 ***	<0.8 ^{3/}
	04:50-04:55 HOUR	51.2 ^{2/}	49.4 ***	49.5 ^{2/}	45.7 ***	3.8
	04:55-05:00 HOUR	51.8 ^{2/}	49.4 ***	51.1 ^{2/}	45.7 ***	5.4
	05:00-05:05 HOUR	49.8 ^{2/}	48.2 ***	47.7 ^{2/}	44.8 ***	2.9
	05:05-05:10 HOUR	49.9 ^{2/}	48.2 ***	48.0 ^{2/}	44.8 ***	3.2
	05:10-05:15 HOUR	49.1 ^{2/}	48.2 ***	44.8 ^{2/}	44.8 ***	<0.8 ^{3/}
	05:15-05:20 HOUR	48.6 ^{2/}	48.1 ***	42.0 ^{2/}	45.0 ***	<0.8 ^{3/}
	05:20-05:25 HOUR	50.0 ^{2/}	48.1 ***	48.5 ^{2/}	45.0 ***	3.5
	05:25-05:30 HOUR	50.1 ^{2/}	48.1 ***	48.8 ^{2/}	45.0 ***	3.8
	05:30-05:35 HOUR	49.8 ^{2/}	49.0 ***	45.1 ^{2/}	45.7 ***	<0.8 ^{3/}
	05:35-05:40 HOUR	49.3 ^{2/}	49.0 ***	40.5 ^{2/}	45.7 ***	<0.8 ^{3/}
	05:40-05:45 HOUR	50.8 ^{2/}	49.0 ***	49.1 ^{2/}	45.7 ***	3.4
	05:45-05:50 HOUR	50.7 ^{2/}	50.4 ***	41.9 ^{2/}	46.2 ***	<0.8 ^{3/}
	05:50-05:55 HOUR	50.6 ^{2/}	50.4 ***	40.1 ^{2/}	46.2 ***	<0.8 ^{3/}
	05:55-06:00 HOUR	51.4 ^{2/}	50.4 ***	47.5 ^{2/}	46.2 ***	1.3
	DAY TIME ^{1/}					
	06:00-07:00 HOUR	53.1 ^{1/}	50.4 **	49.8 ^{1/}	46.8 **	3.0

REMARK :

- 1/ CASE 1 CALCULATION (DURING 06:00 TO 22:00 HOUR) : SPECIFIC SOUND LEVEL CONTINUOUSLY OCCUR AT LEAST 1 HOUR, MEASURING AS L_{Aeq} 1 hour.
- 2/ CASE 4 CALCULATION (DURING 22:00 TO 06:00 HOUR) : SPECIFIC SOUND LEVEL OCCUR IN RESTFUL AREA OR NIGHT TIME, MEASURING AS L_{Aeq} 5 minutes.
- 3/ THERE IS NO IMPACT CAUSE ANNOYANCE SOUND LEVEL
- ** PERCENTILE LEVEL 90 (L_{A90}) IS THE MIDDLE VALUE OF 11 TIMES MEASURING.
(55 MINUTES MEASURING DURING 06:00 TO 22:00 HOUR)
AND RESIDUAL SOUND LEVEL (L_{Aeq} 5 minutes) IS CHOSEN AT THE SAME TIME AS PERCENTILE LEVEL 90 ABOVE.
- *** PERCENTILE LEVEL 90 (L_{A90}) IS THE MIDDLE VALUE OF 3 TIMES MEASURING.
(15 MINUTES MEASURING DURING 22:00 TO 06:00 HOUR)
AND RESIDUAL SOUND LEVEL (L_{Aeq} 5 minutes) IS CHOSEN AT THE SAME TIME AS PERCENTILE LEVEL 90 ABOVE.
- **** ISO 1996-1: 2016
- **** NOTIFICATION OF THE NATIONAL ENVIRONMENT BOARD NO. 29 (B.E. 2550) ON ANNOYANCE NOISE LEVELS, DATED 29 JUNE B.E. 2550 (2007)
- **** NOTIFICATION OF THE POLLUTION CONTROL COMMITTEE ON METHODS FOR MEASUREMENT OF BACKGROUND SOUND LEVEL, RESIDUAL SOUND LEVEL, MEASUREMENT AND CALCULATION OF RATING LEVEL, CALCULATION OF ANNOYANCE NOISE LEVEL, AND MEASUREMENT RECORD FORMS, DATED 21 SEPTEMBER B.E. 2565 (2022)
- **** NOTIFICATION OF THE MINISTRY OF INDUSTRY (B.E. 2548) ON ANNOYANCE NOISE LEVELS AND NOISE LEVELS FROM FACTORY OPERATIONS, DATED 27 DECEMBER B.E. 2548 (2005)
- **** NOTIFICATION OF THE DEPARTMENT OF INDUSTRIAL WORKS ON METHODS FOR MEASUREMENT OF ANNOYANCE NOISE LEVEL, 24-HOUR EQUIVALENT CONTINUOUS SOUND LEVEL, AND MAXIMUM SOUND LEVEL FROM FACTORY OPERATIONS, B.E. 2553 (2010), DATED 20 DECEMBER B.E. 2553 (2010)



ISO 9001
Quality
Management
Systems
CERTIFIED

ISO 14001
Environmental
Management
CERTIFIED

ISO 45001
Occupational
Health and Safety
Management
CERTIFIED

- PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
- THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

ภาคผนวก ค-3

คุณภาพน้ำทะเลชายฝั่ง

ANALYSIS REPORT

CUSTOMER NAME : PTT LNG COMPANY LIMITED
ADDRESS :
CONTACT INFORMATION :
SAMPLING SOURCE : WASTEWATER TREATMENT PLANT
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : APRIL 22, 2026
SAMPLING TIME : 14:40 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY :
ANALYZED BY :

RECEIVED DATE : APRIL 23, 2026
ANALYTICAL DATE : APRIL 23-MAY 5, 2026
ISSUE DATE : MAY 8, 2026
REPORT NO. : 2026-U036249
WORK NO. : 2025-010629
ANALYSIS NO. : T26AI488-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			EFFLUENT FROM SEAWATER OUTFALL(EIA) T26AI488-0001		
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.1 (29.7°C)	-	-
TEMPERATURE ^c	°C	THERMOMETER (AT SITE) SM: PART 2550 B	29.7	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	< 2.0	-	2.0
CHEMICAL OXYGEN DEMAND ^c	mg/L	CLOSED REFLUX, TITRIMETRIC METHOD (SM: PART 5220 C)	91.2	-	40.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	< 5.0	-	5.0
TOTAL DISSOLVED SOLIDS ^c	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	36,560	-	25
RESIDUAL CHLORINE ^c	mg/L Cl ₂	MODIFIED DPD COLOURIMETRIC METHOD (AT SITE)	ND	0.1	-
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	ND	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	-	3

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			EFFLUENT FROM SEAWATER OUTFALL(EIA) T26AI488-0001		
METALS					
CADMIUM ^a	mg/L Cd	UAE.TP.HEM.004 BASED ON SM: PART 3030 E AND PART 3111 B	ND	0.005	0.020
LEAD ^a	mg/L Pb	UAE.TP.HEM.004 BASED ON SM: PART 3030 E AND PART 3111 B	ND	0.020	0.200
MERCURY ^a	mg/L Hg	COLD VAPOUR AAS METHOD (SM: PART 3112 B)	ND	0.0005	0.0020
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR YELLOW		


^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

ND : NOT DETECTED.



ANALYSIS REPORT

CUSTOMER NAME : PTT LNG COMPANY LIMITED
ADDRESS :
CONTACT INFORMATION :
SAMPLING SOURCE : WASTEWATER TREATMENT PLANT
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : APRIL 22, 2026
SAMPLING TIME : 14:20 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY :
ANALYZED BY :

RECEIVED DATE : APRIL 23, 2026
ANALYTICAL DATE : APRIL 23-MAY 5, 2026
ISSUE DATE : MAY 8, 2026
REPORT NO. : 2026-U036250
WORK NO. : 2025-010629
ANALYSIS NO. : T26AI488-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			EFFLUENT FROM SEAWATER OUTFALL(EIA) T26AI488-0002		
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.3 (33.2°C)	-	-
TEMPERATURE ^c	°C	THERMOMETER (AT SITE) SM: PART 2550 B	33.2	-	-
BIOCHEMICAL OXYGEN DEMAND ^{*c}	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	5.0	-	2.0
CHEMICAL OXYGEN DEMAND ^a	mg/L	CLOSED REFLUX, COLOURIMETRIC METHOD (SM: PART 5220 D)	31.0	-	25.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	10.7	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	206	-	25
RESIDUAL CHLORINE ^c	mg/L Cl ₂	MODIFIED DPD COLOURIMETRIC METHOD (AT SITE)	ND	0.1	-
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	33.4	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	-	3



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			EFFLUENT FROM SEAWATER OUTFALL(EIA) T26A1488-0002		
METALS					
CADMIUM ^a	mg/L Cd	UAE.TP.HEM.004 BASED ON SM: PART 3030 E AND PART 3111 B	ND	0.005	0.020
LEAD ^a	mg/L Pb	UAE.TP.HEM.004 BASED ON SM: PART 3030 E AND PART 3111 B	ND	0.020	0.200
MERCURY ^a	mg/L Hg	COLD VAPOUR AAS METHOD (SM: PART 3112 B)	ND	0.0005	0.0020
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN		

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)


^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

* : ADDITION OF NITRIFICATION INHIBITION (TCMP) FOLLOW TO THE SM: 5210B.5(e).

ND : NOT DETECTED.



ภาคผนวก ค-4

อาชีพอนามัยและความปลอดภัย

ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE
CUSTOMER NAME : PTT LNG COMPANY LIMITED
ADDRESS :
CONTACT INFORMATION :
MEASURING PLACE : PTT LNG COMPANY LIMITED
MEASURING TYPE : WORKPLACE (HEAT STRESS) **RECEIVED DATE** : APRIL 20, 2026
MEASURING DATE : APRIL 20, 2026 **ANALYTICAL DATE** : APRIL 20, 2026
MEASURING TIME : * **ISSUE DATE** : APRIL 29, 2026
MEASURING METHOD : WET BULB GLOBE TEMPERATURE ** **REPORT NO.** : 2026-U034782
MEASURED BY :
WORK NO. : 2025-010629
ANALYSIS NO. : T26AI736-0001 - T26AI736-0003

ANALYSIS NO.	MEASURING SITE	DURATION TIME*	RESULT (DEGREE CELSIUS)				
			NWB	DB	GT	WBGT	WBGT AVG
T26AI736-0001	ORC	10:00-12:00 HOUR	28.6	33.6	34.5	30.4	30.4
T26AI736-0002	GAS TURBINE A	10:05-12:05 HOUR	28.6	32.6	33.6	30.1	30.1
T26AI736-0003	WARM CHILLED WATER PUMP	10:10-12:10 HOUR	28.6	33.5	34.5	30.4	30.4



ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE
CUSTOMER NAME : PTT LNG COMPANY LIMITED
ADDRESS :
CONTACT INFORMATION :
MEASURING PLACE : PTT LNG COMPANY LIMITED
MEASURING TYPE : WORKPLACE (NOISE) **RECEIVED DATE** : APRIL 20, 2026
MEASURING DATE : APRIL 20, 2026 **ANALYTICAL DATE** : APRIL 20, 2026
MEASURING TIME : * **ISSUE DATE** : APRIL 29, 2026
MEASURING METHOD : INTEGRATED SOUND LEVEL METER ** **REPORT NO.** : 2026-U034783
MEASURED BY :
WORK NO. : 2025-010629
ANALYSIS NO. : T26AI737-0001 - T26AI737-0003

ANALYSIS NO.	MEASURING SITE	TIME* (HOUR)	RESULT (dB(A))	
			L _{Aeq} 8 hours	L _{Amax} 8 hours
T26AI737-0001	ORC	09:00-17:00	79.4	82.4
T26AI737-0002	GAS TURBINE A	09:10-17:10	77.5	79.1
T26AI737-0003	WARM CHILLED WATER PUMP	09:05-17:05	74.3	78.5



ANALYSIS REPORT

PROJECT NAME : IN-PLANT GENERATOR PROJECT IN OPERATION PHASE
CUSTOMER NAME : PTT LNG COMPANY LIMITED
ADDRESS :
CONTACT INFORMATION :
MEASURING PLACE : PTT LNG COMPANY LIMITED
MEASURING TYPE : WORKPLACE (LIGHT INTENSITY)
MEASURING DATE : APRIL 20, 2026
MEASURING TIME : *
MEASURING METHOD : LUX METER **
MEASURED BY :
RECEIVED DATE : APRIL 20, 2026
ANALYTICAL DATE : APRIL 20, 2026
ISSUE DATE : APRIL 29, 2026
REPORT NO. : 2026-U034784
WORK NO. : 2025-010629
ANALYSIS NO. : T26AI738-0001 - T26AI738-0002

ANALYSIS NO.	MEASURING SITE	TIME *	RESULT (LUX)
			LIGHT INTENSITY
			SPOT MEASUREMENT
T26AI738-0001	DAY TIME บริเวณห้องควบคุม (MAIN CONTROL)	09:30 HOUR	605
T26AI738-0002	บริเวณห้องควบคุม (IPG CONTROL)	09:40 HOUR	437

