

ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิติบุคคลอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : JANUARY 22, 2026
SAMPLING TIME : 09:05 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : MR KANAPON KIRANON
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM

RECEIVED DATE : JANUARY 22, 2026
ANALYTICAL DATE : JANUARY 22-30, 2026
ISSUE DATE : JANUARY 30, 2026
REPORT NO. : 2026-U007608
WORK NO. : 2025-009439
ANALYSIS NO. : T26AB259-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			มอดตรวจคุณภาพน้ำ T26AB259-0001			
pH ^a	-	ELECTROMETRIC METHOD (SM: PART 4500 -H ⁺ B)	7.9 (25°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	< 2.0	≤ 30	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	< 5.0	≤ 40	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	234	≤ 1,000	-	25
SETTLEABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	< 5.0	≤ 35	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/CLEAR			
SEDIMENT			BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

Wilailak Srisuk

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิตินุคคณาการชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : JANUARY 22, 2026
SAMPLING TIME : 09:20 HOUR
SAMPLING METHOD ° : GRAB
SAMPLING BY ° : MR KANAPON KIRANON
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM

RECEIVED DATE : JANUARY 22, 2026
ANALYTICAL DATE : JANUARY 22-27, 2026
ISSUE DATE : JANUARY 30, 2026
REPORT NO. : 2026-U007609
WORK NO. : 2025-009439
ANALYSIS NO. : T26AB259-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	LIMIT OF QUANTITATION (LOQ)
			WATER SUPPLY T26AB259-0002	
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	212	25
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

Wilailak Srisuk.

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิตยบุคคลอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JANUARY 22, 2026
SAMPLING TIME : 1/
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR KANAPON KIRANON
ANALYZED BY : MR RATCHATA THONGPIYAPOOM

RECEIVED DATE : JANUARY 22, 2026
ANALYTICAL DATE : JANUARY 22-24, 2026
ISSUE DATE : JANUARY 30, 2026
REPORT NO. : 2026-U007610
WORK NO. : 2025-009439
ANALYSIS NO. : T26AB259-0003 - T26AB259-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		DETECTION LIMIT
			1 09:15 HOUR 1/ T26AB259-0003	2 09:10 HOUR 1/ T26AB259-0004	
MICROBIOLOGY					
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221B, C AND E)	< 1.1	< 1.1	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : SWIMMING POOL (DEEP ZONE)

RESULT 2 : SWIMMING POOL (SHALLOW ZONE)



(MISS CHAWEEVAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิคมอุตสาหกรรมชุด โนเบิล สเตท 39
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : FEBRUARY 19, 2026
SAMPLING TIME : 15:00 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM

RECEIVED DATE : FEBRUARY 19, 2026
ANALYTICAL DATE : FEBRUARY 19-26, 2026
ISSUE DATE : FEBRUARY 27, 2026
REPORT NO. : 2026-U015645
WORK NO. : 2025-009439
ANALYSIS NO. : T26AD434-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			มอดตรวจคุณภาพน้ำ T26AD434-0001			
pH ^a	-	ELECTROMETRIC METHOD (SM: PART 4500 -H ⁺ B)	7.5 (25°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	2.8	≤ 30	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	< 5.0	≤ 40	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	307	≤ 1,000	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	< 5.0	≤ 35	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิคมอุตสาหกรรมบ่อ นีเบล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : FEBRUARY 19, 2026
SAMPLING TIME : 14:50 HOUR
SAMPLING METHOD ^c : GRAB
SAMPLING BY ^c : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : FEBRUARY 19, 2026
ANALYTICAL DATE : FEBRUARY 19-24, 2026
ISSUE DATE : FEBRUARY 27, 2026
REPORT NO. : 2026-U015648
WORK NO. : 2025-009439
ANALYSIS NO. : T26AD434-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	LIMIT OF QUANTITATION (LOQ)
			WATER SUPPLY T26AD434-0002	
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	207	25
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิติบุคคลอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : FEBRUARY 19, 2026
SAMPLING TIME : 1/
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS CHATTRAPORN RATCHANET
RECEIVED DATE : FEBRUARY 19, 2026
ANALYTICAL DATE : FEBRUARY 19-23, 2026
ISSUE DATE : FEBRUARY 27, 2026
REPORT NO. : 2026-U015649
WORK NO. : 2025-009439
ANALYSIS NO. : T26AD434-0003 - T26AD434-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		DETECTION LIMIT
			1 14:40 HOUR 1/ T26AD434-0003	2 14:45 HOUR 1/ T26AD434-0004	
MICROBIOLOGY					
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	< 1.1	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : SWIMMING POOL (DEEP ZONE)

RESULT 2 : SWIMMING POOL (SHALLOW ZONE)


(MISS CHAWEewan BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิคมคลองอาครชุด โนเบิล สเตท 39
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : MARCH 19, 2026
SAMPLING TIME : 14:20 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : MR CHOKCHAI PHUMSAWAI
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : MARCH 19, 2026
ANALYTICAL DATE : MARCH 19-25, 2026
ISSUE DATE : MARCH 27, 2026
REPORT NO. : 2026-U024107
WORK NO. : 2025-009439
ANALYSIS NO. : T26AF861-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			มอดตรวจคุณภาพน้ำ T26AF861-0001			
pH ^a	-	ELECTROMETRIC METHOD (SM: PART 4500 -H ⁺ B)	7.3 (25°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	4.3	≤ 30	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	< 5.0	≤ 40	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	268	≤ 1,000	-	25
SETTLEABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	< 5.0	≤ 35	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิติบุคคลอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : MARCH 19, 2026
SAMPLING TIME : 14:00 HOUR
SAMPLING METHOD ^c : GRAB
SAMPLING BY ^c : MR CHOKCHAI PHUMSAWAI
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : MARCH 19, 2026
ANALYTICAL DATE : MARCH 19-25, 2026
ISSUE DATE : MARCH 27, 2026
REPORT NO. : 2026-U024108
WORK NO. : 2025-009439
ANALYSIS NO. : T26AF861-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	LIMIT OF QUANTITATION (LOQ)
			WATER SUPPLY T26AF861-0002	
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	153	25
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิติบุคคลอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MARCH 19, 2026
SAMPLING TIME : 1/
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : MR CHOKCHAI PHUMSAWAI
ANALYZED BY : MISS BUSSAKORN MAJAI
RECEIVED DATE : MARCH 19, 2026
ANALYTICAL DATE : MARCH 19-25, 2026
ISSUE DATE : MARCH 27, 2026
REPORT NO. : 2026-U024109
WORK NO. : 2025-009439
ANALYSIS NO. : T26AF861-0003 - T26AF861-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		DETECTION LIMIT
			1 13:55 HOUR 1/ T26AF861-0003	2 13:50 HOUR 1/ T26AF861-0004	
MICROBIOLOGY					
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	< 1.1	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : SWIMMING POOL (DEEP ZONE)

RESULT 2 : SWIMMING POOL (SHALLOW ZONE)



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิคมอุตสาหกรรมชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : MARCH 19, 2026
SAMPLING TIME : 14:20 HOUR
SAMPLING METHOD ^c : GRAB, GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : MR CHOKCHAI PHUMSAWAI
ANALYZED BY : MISS BUSSAKORN MAJAI

RECEIVED DATE : MARCH 19, 2026
ANALYTICAL DATE : MARCH 19-25, 2026
ISSUE DATE : MARCH 30, 2026
REPORT NO. : 2026-U023928
WORK NO. : 2025-009439
ANALYSIS NO. : T26AF862-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ถังเก็บน้ำชั้นใต้ดิน ถัง 1 T26AF862-0001			
TURBIDITY ^c	NTU	NEPHELOMETRIC METHOD (SM: PART 2130 B)	< 0.5	≤ 1.0	-	0.5
TASTE AND ODOUR ^c	-	OBSERVATION METHOD	WOULD NOT BE OBJECTIONABLE	WOULD NOT BE OBJECTIONABLE	-	-
APPARENT COLOUR ^c	Pt-Co	SINGLE-WAVELENGTH METHOD (PROPOSED); (SM: PART 2120 C)	< 5.00	≤ 15	1.00	5.00
MICROBIOLOGY						
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-	-
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR			
SEDIMENT			YELLOW			

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : CRITERIA OF WATER SUPPLY QUALITY, NOTIFICATION OF THE METROPOLITAN WATERWORKS AUTHORITY, B.E. 2565 (2022).



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิติบุคคลอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : MARCH 19, 2026
SAMPLING TIME : 14:15 HOUR
SAMPLING METHOD ^c : GRAB, GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : MR CHOKCHAI PHUMSAWAI
ANALYZED BY : MISS BUSSAKORN MAJAI
RECEIVED DATE : MARCH 19, 2026
ANALYTICAL DATE : MARCH 19-25, 2026
ISSUE DATE : MARCH 30, 2026
REPORT NO. : 2026-U023931
WORK NO. : 2025-009439
ANALYSIS NO. : T26AF862-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ส่งเก็บน้ำขึ้นไต้ดิน ถึง 2 T26AF862-0002			
TURBIDITY ^c	NTU	NEPHELOMETRIC METHOD (SM: PART 2130 B)	0.6	≤ 1.0	-	0.5
TASTE AND ODOUR ^c	-	OBSERVATION METHOD	WOULD NOT BE OBJECTIONABLE	WOULD NOT BE OBJECTIONABLE	-	-
APPARENT COLOUR ^c	Pt-Co	SINGLE-WAVELENGTH METHOD (PROPOSED); (SM: PART 2120 C)	< 5.00	≤ 15	1.00	5.00
MICROBIOLOGY						
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-	-
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR			
SEDIMENT			YELLOW			

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : CRITERIA OF WATER SUPPLY QUALITY, NOTIFICATION OF THE METROPOLITAN WATERWORKS AUTHORITY, B.E. 2565 (2022).


(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิติบุคคลอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : MARCH 19, 2026
SAMPLING TIME : 13:40 HOUR
SAMPLING METHOD ^c : GRAB, GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : MR CHOKCHAI PHUMSAWAI
ANALYZED BY : MISS BUSSAKORN MAJAI
RECEIVED DATE : MARCH 19, 2026
ANALYTICAL DATE : MARCH 19-25, 2026
ISSUE DATE : MARCH 30, 2026
REPORT NO. : 2026-U023932
WORK NO. : 2025-009439
ANALYSIS NO. : T26AF862-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ถังเก็บน้ำชั้นคาตฟ้า ถัง 1 T26AF862-0003			
TURBIDITY ^c	NTU	NEPHELOMETRIC METHOD (SM: PART 2130 B)	< 0.5	≤ 1.0	-	0.5
TASTE AND ODOUR ^c	-	OBSERVATION METHOD	WOULD NOT BE OBJECTIONABLE	WOULD NOT BE OBJECTIONABLE	-	-
APPARENT COLOUR ^c	Pt-Co	SINGLE-WAVELENGTH METHOD (PROPOSED); (SM: PART 2120 C)	< 5.00	≤ 15	1.00	5.00
MICROBIOLOGY						
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-	-
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR			
SEDIMENT			YELLOW			

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : CRITERIA OF WATER SUPPLY QUALITY, NOTIFICATION OF THE METROPOLITAN WATERWORKS AUTHORITY, B.E. 2565 (2022).



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิคมอุตสาหกรรมชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : MARCH 19, 2026
SAMPLING TIME : 13:35 HOUR
SAMPLING METHOD ^c : GRAB, GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : MR CHOKCHAI PHUMSAWAI
ANALYZED BY : MISS BUSSAKORN MAJAI

RECEIVED DATE : MARCH 19, 2026
ANALYTICAL DATE : MARCH 19-25, 2026
ISSUE DATE : MARCH 30, 2026
REPORT NO. : 2026-U023933
WORK NO. : 2025-009439
ANALYSIS NO. : T26AF862-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ส่งเก็บน้ำขึ้นตลาดฟ้า ถึง 2 T26AF862-0004			
TURBIDITY ^c	NTU	NEPHELOMETRIC METHOD (SM: PART 2130 B)	< 0.5	≤ 1.0	-	0.5
TASTE AND ODOUR ^c	-	OBSERVATION METHOD	WOULD NOT BE OBJECTIONABLE	WOULD NOT BE OBJECTIONABLE	-	-
APPARENT COLOUR ^c	Pt-Co	SINGLE-WAVELENGTH METHOD (PROPOSED); (SM: PART 2120 C)	< 5.00	≤ 15	1.00	5.00
MICROBIOLOGY						
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-	-
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR			
SEDIMENT			YELLOW			

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : CRITERIA OF WATER SUPPLY QUALITY, NOTIFICATION OF THE METROPOLITAN WATERWORKS AUTHORITY, B.E. 2565 (2022).



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิติบุคคลอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : APRIL 23, 2026
SAMPLING TIME : 10:30 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : MR ACHITA SAENGJAN
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM

RECEIVED DATE : APRIL 23, 2026
ANALYTICAL DATE : APRIL 23-MAY 2, 2026
ISSUE DATE : MAY 5, 2026
REPORT NO. : 2026-U035683
WORK NO. : 2025-009439
ANALYSIS NO. : T26AI515-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			บดตรวจคุณภาพน้ำ T26AI515-0001			
pH ^a	-	ELECTROMETRIC METHOD (SM: PART 4500 -H ⁺ B)	7.6 (25°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	2.7	≤ 30	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	< 5.0	≤ 40	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	279	≤ 1,000	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	6.9	≤ 35	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

Wilailak Srisuk

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิติบุคคลอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : APRIL 23, 2026
SAMPLING TIME : 10:20 HOUR
SAMPLING METHOD ° : GRAB
SAMPLING BY ° : MR ACHITA SAENGJAN
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM

RECEIVED DATE : APRIL 23, 2026
ANALYTICAL DATE : APRIL 23-27, 2026
ISSUE DATE : MAY 5, 2026
REPORT NO. : 2026-U035684
WORK NO. : 2025-009439
ANALYSIS NO. : T26AI515-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	LIMIT OF QUANTITATION (LOQ)
			WATER SUPPLY T26AI515-0002	
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	105	25
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

Wilailak Srisuk

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิคมอุตสาหกรรม นอเบิล สเตท 39
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : APRIL 23, 2026
SAMPLING TIME : 1/
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR ACHITA SAENGJAN
ANALYZED BY : MR THANAPOL GESAMOON
RECEIVED DATE : APRIL 23, 2026
ANALYTICAL DATE : APRIL 23-26, 2026
ISSUE DATE : MAY 5, 2026
REPORT NO. : 2026-U035685
WORK NO. : 2025-009439
ANALYSIS NO. : T26AI515-0003 - T26AI515-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		DETECTION LIMIT
			1 10:10 HOUR 1/ T26AI515-0003	2 10:15 HOUR 1/ T26AI515-0004	
MICROBIOLOGY					
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	< 1.1	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	COLOURLESS/CLEAR	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : SWIMMING POOL (DEEP ZONE)

RESULT 2 : SWIMMING POOL (SHALLOW ZONE)



(MISS CHAWEEVAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME	: NOBLE STATE 39	RECEIVED DATE	: MAY 21, 2026
ADDRESS	: NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110	ANALYTICAL DATE	: MAY 21-29, 2026
CONTACT INFORMATION	: TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th	ISSUE DATE	: MAY 29, 2026
SAMPLING SOURCE	: นิคมอุตสาหกรรมชุด โนเบิล สเตท 39	REPORT NO.	: 2026-U045775
SAMPLE TYPE	: EFFLUENT	WORK NO.	: 2025-009439
SAMPLING DATE	: MAY 21, 2026	ANALYSIS NO.	: T26AL044-0001
SAMPLING TIME	: 10:40 HOUR		
SAMPLING METHOD	: GRAB		
SAMPLING BY	: MR ACHITA SAENGJAN		
ANALYZED BY	: MISS NAPAPORN KHUNNOKKHUM		

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			มาตรฐานคุณภาพน้ำ T26AL044-0001			
pH ^a	-	ELECTROMETRIC METHOD (SM: PART 4500-H ⁺ B)	7.0 (25°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	3.2	≤ 30	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	5.9	≤ 40	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	211	≤ 1,000	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	5.5	≤ 35	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/CLEAR			
SEDIMENT			BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

Wilailak Srisuk

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิตบุคคณาการชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : MAY 21, 2026
SAMPLING TIME : 10:30 HOUR
SAMPLING METHOD ^c : GRAB
SAMPLING BY ^c : MR ACHITA SAENGJAN
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : MAY 21, 2026
ANALYTICAL DATE : MAY 21-27, 2026
ISSUE DATE : MAY 29, 2026
REPORT NO. : 2026-U045776
WORK NO. : 2025-009439
ANALYSIS NO. : T26AL044-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	LIMIT OF QUANTITATION (LOQ)
			WATER SUPPLY T26AL044-0002	
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	155	25
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

Wilailak Srisuk

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME	: NOBLE STATE 39	RECEIVED DATE	: MAY 21, 2026
ADDRESS	: NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110	ANALYTICAL DATE	: MAY 21-25, 2026
CONTACT INFORMATION	: TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th	ISSUE DATE	: JUNE 4, 2026
SAMPLING SOURCE	: นิคมอุตสาหกรรมชุด โนเบิล สเตท 39	REPORT NO.	: 2026-U045777
SAMPLE TYPE	: WATER SAMPLE FROM SWIMMING POOL	WORK NO.	: 2025-009439
SAMPLING DATE	: MAY 21, 2026	ANALYSIS NO.	: T26AL044-0003 - T26AL044-0004
SAMPLING TIME	: 1/		
SAMPLING METHOD °	: GRAB AND STERILE TECHNIQUE		
SAMPLING BY °	: MR ACHITA SAENGJAN		
ANALYZED BY	: MISS CHATRAPORN RATCHANET		

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		DETECTION LIMIT
			1 10:25 HOUR 1/ T26AL044-0003	2 10:20 HOUR 1/ T26AL044-0004	
MICROBIOLOGY					
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	< 1.1	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR	COLOURLESS/CLEAR	
SEDIMENT			-	-	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : SWIMMING POOL (DEEP ZONE)

RESULT 2 : SWIMMING POOL (SHALLOW ZONE)


.....
(MISS CHAWEewan BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิติบุคคลอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : JUNE 18, 2026
SAMPLING TIME : 14:05 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : MR KANAPON KIRANON
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : JUNE 18, 2026
ANALYTICAL DATE : JUNE 18-26, 2026
ISSUE DATE : JUNE 26, 2026
REPORT NO. : 2026-U056332
WORK NO. : 2025-009439
ANALYSIS NO. : T26AN749-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			มอดตรวจคุณภาพน้ำ T26AN749-0001			
pH ^a	-	ELECTROMETRIC METHOD (SM: PART 4500 -H ⁺ B)	7.6 (25°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	< 2.0	≤ 30	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	< 5.0	≤ 40	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	242	≤ 1,000	-	25
SETTLEABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ₂ -F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	5.0	≤ 35	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/CLEAR			
SEDIMENT			BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR

ISO 9001:2015 CERTIFIED
ISO 14001:2015 CERTIFIED
ISO 45001:2018 CERTIFIED

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิตยบุคคลอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : JUNE 18, 2026
SAMPLING TIME : 13:45 HOUR
SAMPLING METHOD ° : GRAB
SAMPLING BY ° : MR KANAPON KIRANON
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM

RECEIVED DATE : JUNE 18, 2026
ANALYTICAL DATE : JUNE 18-23, 2026
ISSUE DATE : JUNE 26, 2026
REPORT NO. : 2026-U056333
WORK NO. : 2025-009439
ANALYSIS NO. : T26AN749-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	LIMIT OF QUANTITATION (LOQ)
			WATER SUPPLY T26AN749-0002	
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	176	25
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

Piyapat S.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR

ISO 9001:2015 CERTIFIED
ISO 14001:2015 CERTIFIED
ISO 45001:2018 CERTIFIED

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

1/1



- End of Analysis Report -

ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิติบุคคลอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JUNE 18, 2026
SAMPLING TIME : 1/
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR KANAPON KIRANON
ANALYZED BY : MR RATCHATA THONGPIYAPOOM
RECEIVED DATE : JUNE 18, 2026
ANALYTICAL DATE : JUNE 18-24, 2026
ISSUE DATE : JUNE 26, 2026
REPORT NO. : 2026-U056334
WORK NO. : 2025-009439
ANALYSIS NO. : T26AN749-0003 - T26AN749-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		DETECTION LIMIT
			1 13:40 HOUR 1/ T26AN749-0003	2 13:35 HOUR 1/ T26AN749-0004	
MICROBIOLOGY					
FAECAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B, C AND E)	< 1.1	< 1.1	1.1
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : SWIMMING POOL (DEEP ZONE)

RESULT 2 : SWIMMING POOL (SHALLOW ZONE)



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ISO 9001:2015 CERTIFIED
ISO 14001:2015 CERTIFIED
ISO 45001:2018 CERTIFIED

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิติบุคคลอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : JUNE 18, 2026
SAMPLING TIME : 13:50 HOUR
SAMPLING METHOD ° : GRAB, GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR KANAPON KIRANON
ANALYZED BY : MISS JITSAMON NGAMKANA
RECEIVED DATE : JUNE 18, 2026
ANALYTICAL DATE : JUNE 18-24, 2026
ISSUE DATE : JUNE 26, 2026
REPORT NO. : 2026-U056506
WORK NO. : 2025-009439
ANALYSIS NO. : T26AN750-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ถังเก็บน้ำชั้นใต้ดิน ถัง 1 T26AN750-0001			
TURBIDITY ^c	NTU	NEPHELOMETRIC METHOD (SM: PART 2130 B)	0.6	≤ 1.0	-	0.5
TASTE AND ODOUR ^c	-	OBSERVATION METHOD	WOULD NOT BE OBJECTIONABLE	WOULD NOT BE OBJECTIONABLE	-	-
APPARENT COLOUR ^c	Pt-Co	SINGLE-WAVELENGTH METHOD (PROPOSED); (SM: PART 2120 C)	5.46	≤ 15	1.00	5.00
MICROBIOLOGY						
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-	-
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR			
SEDIMENT			YELLOW			

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : CRITERIA OF WATER SUPPLY QUALITY, NOTIFICATION OF THE METROPOLITAN WATERWORKS AUTHORITY, B.E. 2565 (2022).



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ISO 9001:2015 CERTIFIED
ISO 14001:2015 CERTIFIED
ISO 45001:2018 CERTIFIED

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิคมอุตสาหกรรมชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : JUNE 18, 2026
SAMPLING TIME : 13:55 HOUR
SAMPLING METHOD ° : GRAB, GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR KANAPON KIRANON
ANALYZED BY : MISS JITSAMON NGAMKANA
RECEIVED DATE : JUNE 18, 2026
ANALYTICAL DATE : JUNE 18-24, 2026
ISSUE DATE : JUNE 26, 2026
REPORT NO. : 2026-U056507
WORK NO. : 2025-009439
ANALYSIS NO. : T26AN750-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ถึงเก็บน้ำขึ้นใต้ดิน ถึง 2 T26AN750-0002			
TURBIDITY ^c	NTU	NEPHELOMETRIC METHOD (SM: PART 2130 B)	1.5	≤ 1.0	-	0.5
TASTE AND ODOUR ^c	-	OBSERVATION METHOD	WOULD NOT BE OBJECTIONABLE	WOULD NOT BE OBJECTIONABLE	-	-
APPARENT COLOUR ^c	Pt-Co	SINGLE-WAVELENGTH METHOD (PROPOSED); (SM: PART 2120 C)	8.32	≤ 15	1.00	5.00
MICROBIOLOGY						
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-	-
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR			
SEDIMENT			YELLOW			

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : CRITERIA OF WATER SUPPLY QUALITY, NOTIFICATION OF THE METROPOLITAN WATERWORKS AUTHORITY, B.E. 2565 (2022).



(MISS CHAWEEVAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTHANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิตินคคอาคารชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : JUNE 18, 2026
SAMPLING TIME : 13:20 HOUR
SAMPLING METHOD ° : GRAB, GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR KANAPON KIRANON
ANALYZED BY : MISS JITSAMON NGAMKANA
RECEIVED DATE : JUNE 18, 2026
ANALYTICAL DATE : JUNE 18-24, 2026
ISSUE DATE : JUNE 26, 2026
REPORT NO. : 2026-U056508
WORK NO. : 2025-009439
ANALYSIS NO. : T26AN750-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ส่งเก็บน้ำขึ้นตลาดฟ้า ถึง 1 T26AN750-0003			
TURBIDITY ^c	NTU	NEPHELOMETRIC METHOD (SM: PART 2130 B)	0.5	≤ 1.0	-	0.5
TASTE AND ODOUR ^c	-	OBSERVATION METHOD	WOULD NOT BE OBJECTIONABLE	WOULD NOT BE OBJECTIONABLE	-	-
APPARENT COLOUR ^c	Pt-Co	SINGLE-WAVELENGTH METHOD (PROPOSED); (SM: PART 2120 C)	6.18	≤ 15	1.00	5.00
MICROBIOLOGY						
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-	-
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR			
SEDIMENT			YELLOW			

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : CRITERIA OF WATER SUPPLY QUALITY, NOTIFICATION OF THE METROPOLITAN WATERWORKS AUTHORITY, B.E. 2565 (2022).



(MISS CHAWEEVAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : NOBLE STATE 39
ADDRESS : NO. 35 SUKHUMVIT 39 KHLONG TAN NUEA WATTANA BANGKOK 10110
CONTACT INFORMATION : TEL : 09 5504 8844 e-mail : bm.nb39@senses.co.th
SAMPLING SOURCE : นิคมอุตสาหกรรมชุด โนเบิล สเตท 39
SAMPLE TYPE : WATER SUPPLY
SAMPLING DATE : JUNE 18, 2026
SAMPLING TIME : 13:30 HOUR
SAMPLING METHOD ° : GRAB, GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR KANAPON KIRANON
ANALYZED BY : MISS JITSAMON NGAMKANA
RECEIVED DATE : JUNE 18, 2026
ANALYTICAL DATE : JUNE 18-24, 2026
ISSUE DATE : JUNE 26, 2026
REPORT NO. : 2026-U056509
WORK NO. : 2025-009439
ANALYSIS NO. : T26AN750-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ส่งเก็บน้ำขึ้นตลาดฟ้า ถึง 2 T26AN750-0004			
TURBIDITY ^c	NTU	NEPHELOMETRIC METHOD (SM: PART 2130 B)	0.8	≤ 1.0	-	0.5
TASTE AND ODOUR ^c	-	OBSERVATION METHOD	WOULD NOT BE OBJECTIONABLE	WOULD NOT BE OBJECTIONABLE	-	-
APPARENT COLOUR ^c	Pt-Co	SINGLE-WAVELENGTH METHOD (PROPOSED); (SM: PART 2120 C)	6.54	≤ 15	1.00	5.00
MICROBIOLOGY						
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-	-
SAMPLE CONDITION						
WATER'S COLOUR/TURBID						
SEDIMENT						

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : CRITERIA OF WATER SUPPLY QUALITY, NOTIFICATION OF THE METROPOLITAN WATERWORKS AUTHORITY, B.E. 2565 (2022).

Chaweevan B.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ISO 9001:2015 CERTIFIED
ISO 14001:2015 CERTIFIED
ISO 45001:2018 CERTIFIED

• PROHIBITED TO PARTIALLY COPY ANALYSIS REPORT PRIOR TO WRITTEN PERMISSION BY THE LABORATORY.
• THIS ANALYSIS REPORT APPROVES ONLY FOR THE SAMPLES AS RECEIVED.

1/1



- End of Analysis Report -