

ภาคผนวก ง

ผลการตรวจสอบคุณภาพน้ำ



คุณภาพน้ำทิ้ง



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เนีย บาย แสนสิริ
Project Name : โครงการ เนีย บาย แสนสิริ (NIA BY SANSIRI)
Address Project : เลขที่ 117/36 ซอยปริติพณมยงค์ 2 แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อพักน้ำสุดท้ายก่อนระบายออกจากโครงการ
GPS. Coordinate : 47 P 673003 E 1516817 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68032
Sample No. : W68032/1
Sample Type : Wastewater
Sampling Date : 03 July 2025
Sampling Time : 12.08 p.m.
Received Date : 04 July 2025
Analytical Date : 04 – 15 July 2025
Report Date : 16 July 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 26.8 °C	-	Electrometric Method (4500-H ⁺ B)	6.9	5.5-9.0
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	376	≤ 1,000
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	15.0	≤ 40
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	15.5	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Settleable Solid *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	16	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024). , Building type B

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิตติบุคคลอาคารชุด เนีย บาย แสนสิริ
Project Name : โครงการ เนีย บาย แสนสิริ (NIA BY SANSIRI)
Address Project : เลขที่ 117/36 ซอยปรีดิพนมยงค์ 2 แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อพักน้ำสุดท้ายก่อนระบายออกจากโครงการ
GPS. Coordinate : 47 P 673018 E 1516810 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68032
Sample No. : W68032/1
Sample Type : Wastewater
Sampling Date : 05 August 2025
Sampling Time : 03.06 p.m.
Received Date : 06 August 2025
Analytical Date : 06 – 19 August 2025
Report Date : 19 August 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.3 °C	-	Electrometric Method (4500-H ⁺ B)	7.5	5.5-9.0
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	388	≤ 1,000
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	17.7	≤ 40
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	17.0	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Settleable Solid *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	10	≤ 35
Sample Appearance		Yellow/Turbid/Little Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024). , Building type B

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เนีย บาย แสนสิริ
Project Name : โครงการ เนีย บาย แสนสิริ (NIA BY SANSIRI)
Address Project : เลขที่ 117/36 ซอยปรีดิพนมยงค์ 2 แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อพักน้ำสุดท้ายก่อนระบายออกจากโครงการ
GPS. Coordinate : 47 P 673011 E 1516810 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68032
Sample No. : W68032/1
Sample Type : Wastewater
Sampling Date : 09 September 2025
Sampling Time : 03.46 p.m.
Received Date : 10 September 2025
Analytical Date : 10 – 24 September 2025
Report Date : 25 September 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.8 °C	-	Electrometric Method (4500-H ⁺ B)	6.5	5.5-9.0
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	360	≤ 1,000
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	31.0	≤ 40
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	26.9	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Settleable Solid *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	13	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type B

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เนีย บาย แสนสิริ
Project Name : โครงการ เนีย บาย แสนสิริ (NIA BY SANSIRI)
Address Project : เลขที่ 117/36 ซอยปรีดีพนมยงค์ 2 แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อพักน้ำสุดท้ายก่อนระบายออกจากโครงการ
GPS. Coordinate : 47 P 673004 E 1516807 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68032
Sample No. : W68032/1
Sample Type : Wastewater
Sampling Date : 30 October 2025
Sampling Time : 01.11 p.m.
Received Date : 31 October 2025
Analytical Date : 31 October – 11 November 2025
Report Date : 12 November 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.0 °C	-	Electrometric Method (4500-H ⁺ B)	6.2	5.5-9.0
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	436	≤ 1,000
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	31.2	≤ 40
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	29.1	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Settleable Solid *	mL/L	Imhoff Cone (2540 F)	0.7	-
Total Kjeldahl Nitrogen * ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	12	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024). , Building type B.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิตบุคคลาคารชุด เนีย บาย แสนสิริ
Project Name : โครงการ เนีย บาย แสนสิริ (NIA BY SANSIRI)
Address Project : เลขที่ 117/36 ซอยปรีดิพนมยงค์ 2 แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อพักน้ำสุดท้ายก่อนระบายออกจากโครงการ
GPS. Coordinate : 47 P 673008 E 1516812 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68032
Sample No. : W68032/1
Sample Type : Wastewater
Sampling Date : 06 November 2025
Sampling Time : 04.50 p.m.
Received Date : 07 November 2025
Analytical Date : 07 – 26 November 2025
Report Date : 27 November 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.0 °C	-	Electrometric Method (4500-H ⁺ B)	6.6	5.5-9.0
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	340	≤ 1,000
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	22.7	≤ 40
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	28.4	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	0.8	-
Total Kjeldahl Nitrogen *, ^{2/}	mg/L	APHA:4500-Norg (B) ^{3/}	8.4	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024) , Building type B.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เนีย บาย แสนสิริ
Project Name : โครงการ เนีย บาย แสนสิริ (NIA BY SANSIRI)
Address Project : เลขที่ 117/36 ซอยปรีดิพนมยงค์ 2 แขวงพระโขนงเหนือ
 เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บ่อกักน้ำสุดท้ายก่อนระบายออกจากโครงการ
GPS. Coordinate : 47 P 673003 E 1516796 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W68032
Sample No. : W68032/1
Sample Type : Wastewater
Sampling Date : 02 December 2025
Sampling Time : 01.57 p.m.
Received Date : 03 December 2025
Analytical Date : 03 - 16 December 2025
Report Date : 17 December 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.0 °C	-	Electrometric Method (4500-H ⁺ B)	7.1	5.5-9.0
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	293	≤ 1,000
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	38.6	≤ 40
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	27.4	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Settleable Solid *	mL/L	Imhoff Cone (2540 F)	11	-
Total Kjeldahl Nitrogen ^{*, 2/}	mg/L	APHA:4500-Norg (B) ^{3/}	27	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024). , Building type B

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{3/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



คุณภาพน้ำสะอาด



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เนีย บาย แสนสิริ
Project Name : โครงการ เนีย บาย แสนสิริ (NIA BY SANSIRI)
Address Project : เลขที่ 117/36 ซอยปรีดิพนมยงค์ 2 แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนเล็ก
GPS. Coordinate : 47 P 672994 E 15167805 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68032
Sample No : W68032/2
Sample Type : Swimming pool Water
Sampling Date : 03 July 2025
Sampling Time : 12.04 p.m.
Received Date : 04 July 2025
Analytical Date : 04 – 15 July 2025
Report Date : 16 July 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by BUREAU VERITAS AQ LAB (THAILAND) COMPANY LIMITED. registration number Wo-313

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เนีย บาย แสนสิริ
Project Name : โครงการ เนีย บาย แสนสิริ (NIA BY SANSIRI)
Address Project : เลขที่ 117/36 ซอยปรีดิพนมยงค์ 2 แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 672994 E 15167805 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68032
Sample No : W68032/2
Sample Type : Swimming pool Water
Sampling Date : 03 July 2025
Sampling Time : 12.04 p.m.
Received Date : 04 July 2025
Analytical Date : 04 – 15 July 2025
Report Date : 16 July 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by BUREAU VERITAS AQ LAB (THAILAND) COMPANY LIMITED. registration number Wo-313

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เนีย บาย แสนสิริ
Project Name : โครงการ เนีย บาย แสนสิริ (NIA BY SANSIRI)
Address Project : เลขที่ 117/36 ซอยปรีดิพนมยงค์ 2 แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนเล็ก
GPS. Coordinate : 47 P 672989 E 1516764 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68032
Sample No : W68032/2
Sample Type : Swimming pool Water
Sampling Date : 05 August 2025
Sampling Time : 02.57 p.m.
Received Date : 06 August 2025
Analytical Date : 06 – 19 August 2025
Report Date : 19 August 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by BUREAU VERITAS AQ LAB (THAILAND) COMPANY LIMITED. registration number Wo-313

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เนีย บาย แสนสิริ
Project Name : โครงการ เนีย บาย แสนสิริ (NIA BY SANSIRI)
Address Project : เลขที่ 117/36 ซอยปรีดีพนมยงค์ 2 แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673020 E 1516812 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68032
Sample No : W68032/2
Sample Type : Swimming pool Water
Sampling Date : 09 September 2025
Sampling Time : 03.42 p.m.
Received Date : 10 September 2025
Analytical Date : 10 – 23 September 2025
Report Date : 24 September 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> * ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by BUREAU VERITAS AQ LAB (THAILAND) COMPANY LIMITED. registration number Wo-313

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เนีย บาย แสนสิริ
Project Name : โครงการ เนีย บาย แสนสิริ (NIA BY SANSIRI)
Address Project : เลขที่ 117/36 ซอยปรีดิพนมยงค์ 2 แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 672989 E 1516781 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68032
Sample No : W68032/2
Sample Type : Swimming pool Water
Sampling Date : 30 October 2025
Sampling Time : 01.19 p.m.
Received Date : 31 October 2025
Analytical Date : 31 October – 11 November 2025
Report Date : 12 November 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by BUREAU VERITAS AQ LAB (THAILAND) COMPANY LIMITED. registration number Wo-313

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิตบุศคลอการชุด เนีย บาย แสนสิริ
Project Name : โครงการ เนีย บาย แสนสิริ (NIA BY SANSIRI)
Address Project : เลขที่ 117/36 ซอยปรีดิพนมยงค์ 2 แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 672984 E 1516789 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68032
Sample No : W68032/2
Sample Type : Swimming pool Water
Sampling Date : 06 November 2025
Sampling Time : 04.44 p.m.
Received Date : 07 November 2025
Analytical Date : 07 – 26 November 2025
Report Date : 27 November 2025


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by BUREAU VERITAS AQ LAB (THAILAND) COMPANY LIMITED. registration number Wo-313

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เนีย บาย แสนสิริ
Project Name : โครงการ เนีย บาย แสนสิริ (NIA BY SANSIRI)
Address Project : เลขที่ 117/36 ซอยปรีดิพนมยงค์ 2 แขวงพระโขนงเหนือ
เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 672984 E 1516807 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W68032
Sample No : W68032/2
Sample Type : Swimming pool Water
Sampling Date : 02 December 2025
Sampling Time : 02.04 p.m.
Received Date : 03 December 2025
Analytical Date : 03 - 16 December 2025
Report Date : 17 December 2025

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *. ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *. ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Total Chlorine *	mg/L	Iodometric Method (4500-Cl B)	5.7	0.6 - 1.0
Chloride *	mg/L	Argentometric Method (4500-Cl ⁻ B)	632	≤ 600
N-Ammonia *. ^{3/}	mg/L	APHA:4500-NH ₃ (C) ^{4/}	< 0.14	≤ 20
Nitrate *. ^{3/}	mg/L	APHA:4500-NO ₃ (D) ^{4/}	5.6	≤ 50
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by BUREAU VERITAS AQ LAB (THAILAND) COMPANY LIMITED. registration number Wo-313

^{3/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

^{4/} Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 23rd edition 2017.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.