

ภาคผนวก ง

ผลการติดตามตรวจสอบคุณภาพสิ่งแวดล้อม



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : จุดรวบรวมน้ำเสียเข้าระบบบำบัด
GPS. Coordinate : 47 P 657470 E 1517113 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling


Data Provided by Laboratory

Report No. : W69021
Sample No. : W69021/1
Sample Type : Wastewater
Sampling Date : 13 January 2026
Sampling Time : 11.44 a.m.
Received Date : 14 January 2026
Analytical Date : 14 – 26 January 2026
Report Date : 27 January 2026

Parameter	Unit	Analytical Method ^{1/}	Result
pH at 25.1 °C	-	Electrometric Method (4500-H ⁺ B)	8.4
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	113
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	157
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.6
Volume Flow rate *	m ³ /s	Flow Meter	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-CL D)	< 0.5
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : จุดระบายน้ำออกจากระบบ
GPS. Coordinate : 47 P 657488 E 1517088 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W69021
Sample No. : W69021/2
Sample Type : Wastewater
Sampling Date : 13 January 2026
Sampling Time : 11.40 a.m.
Received Date : 14 January 2026
Analytical Date : 14 – 26 January 2026
Report Date : 27 January 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.5 °C	-	Electrometric Method (4500-H ⁺ B)	7.6	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	25.7	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	10.3	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Volume Flow rate *	m ³ /s	Flow Meter	-	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-CL D)	< 0.5	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : บ่อพักน้ำสุดท้ายก่อนระบายออกท่อสาธารณะ
GPS. Coordinate : 47 P 657503 E 1517100 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W69021
Sample No. : W69021/3
Sample Type : Wastewater
Sampling Date : 13 January 2026
Sampling Time : 11.53 a.m.
Received Date : 14 January 2026
Analytical Date : 14 – 26 January 2026
Report Date : 27 January 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.7 °C	-	Electrometric Method (4500-H ⁺ B)	7.8	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	5.2	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	8.1	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Volume Flow rate *	m ³ /s	Flow Meter	-	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-Cl D)	< 0.5	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
 Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
 Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
 เขตภาษีเจริญ กรุงเทพมหานคร 10160
 Sampling Point : จุดรวบรวมน้ำเสียเข้าระบบบำบัด
 GPS. Coordinate : 47 P 657460 E 1517131 N
 Sampling By : TNP ENVIRONMENT CO., LTD.
 Sampling Method : Grab Sampling


Data Provided by Laboratory

Report No. : W69021
 Sample No. : W69021/1
 Sample Type : Wastewater
 Sampling Date : 20 February 2026
 Sampling Time : 04.51 p.m.
 Received Date : 21 February 2026
 Analytical Date : 21 February – 17 March 2026
 Report Date : 18 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result
pH at 24.5 °C	-	Electrometric Method (4500-H ⁺ B)	8.5
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	95.3
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	133
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.3
Volume Flow rate *	m ³ /s	Flow Meter	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-Cl D)	< 0.5
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชนครินทร์-เพชรเกษม
 Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชนครินทร์-เพชรเกษม
 Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
 เขตภาษีเจริญ กรุงเทพมหานคร 10160
 Sampling Point : จุดระบายน้ำออกจากระบบ
 GPS. Coordinate : 47 P 657510 E 1517094 N
 Sampling By : TNP ENVIRONMENT CO., LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W69021
 Sample No. : W69021/2
 Sample Type : Wastewater
 Sampling Date : 20 February 2026
 Sampling Time : 04.47 p.m.
 Received Date : 21 February 2026
 Analytical Date : 21 February – 17 March 2026
 Report Date : 18 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.2 °C	-	Electrometric Method (4500-H ⁺ B)	8.0	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	10.8	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	13.5	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Volume Flow rate *	m ³ /s	Flow Meter	-	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-Cl D)	< 0.5	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024) Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชนครินทร์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชนครินทร์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : บ่อพักน้ำสุดท้ายก่อนระบายออกท่อสาธารณะ
GPS. Coordinate : 47 P 657438 E 1517144 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W69021
Sample No. : W69021/3
Sample Type : Wastewater
Sampling Date : 20 February 2026
Sampling Time : 04.40 p.m.
Received Date : 21 February 2026
Analytical Date : 21 February – 17 March 2026
Report Date : 18 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.5 °C	-	Electrometric Method (4500-H ⁺ B)	7.6	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	8.0	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	16.4	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Volume Flow rate *	m ³ /s	Flow Meter	-	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-Cl D)	< 0.5	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024) Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย-ปาร์ค ราชพฤกษ์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
 เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : จุดรวบรวมน้ำเสียเข้าระบบบำบัด
GPS. Coordinate : 47 P 657468 E 1517131 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling


Data Provided by Laboratory

Report No. : W69021
Sample No. : W69021/1
Sample Type : Wastewater
Sampling Date : 05 March 2026
Sampling Time : 10.41 a.m.
Received Date : 06 March 2026
Analytical Date : 06 – 25 March 2026
Report Date : 26 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result
pH at 24.7 °C	-	Electrometric Method (4500-H ⁺ B)	9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	154
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	311
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0
Volume Flow rate *	m ³ /s	Flow Meter	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-Cl D)	< 0.5
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
 เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : จุดระบายน้ำออกจากระบบ
GPS. Coordinate : 47 P 657546 E 1517106 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W69021
Sample No. : W69021/2
Sample Type : Wastewater
Sampling Date : 05 March 2026
Sampling Time : 10.35 a.m.
Received Date : 06 March 2026
Analytical Date : 06 – 25 March 2026
Report Date : 26 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.5 °C	-	Electrometric Method (4500-H ⁺ B)	8.1	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	12.3	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	6.5	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Volume Flow rate *	m ³ /s	Flow Meter	-	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-Cl D)	< 0.5	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	54,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act,
 B.E. 2567 (2024) Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
 Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
 Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
 เขตภาษีเจริญ กรุงเทพมหานคร 10160
 Sampling Point : บ่อพักน้ำสุดท้ายก่อนระบายออกท่อสาธารณะ
 GPS. Coordinate : 47 P 657405 E 1517154 N
 Sampling By : TNP ENVIRONMENT CO., LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W69021
 Sample No. : W69021/3
 Sample Type : Wastewater
 Sampling Date : 05 March 2026
 Sampling Time : 10.51 a.m.
 Received Date : 06 March 2026
 Analytical Date : 06 – 25 March 2026
 Report Date : 26 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.5 °C	-	Electrometric Method (4500-H ⁺ B)	7.7	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	10.4	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	19.5	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Volume Flow rate *	m ³ /s	Flow Meter	-	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-Cl D)	< 0.5	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Smelly		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : จุดรวบรวมน้ำเสียเข้าระบบบำบัด
GPS. Coordinate : 47 P 657469 E 1517095 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling


Data Provided by Laboratory

Report No. : W69021
Sample No. : W69021/1
Sample Type : Wastewater
Sampling Date : 23 April 2026
Sampling Time : 03.03 p.m.
Received Date : 24 April 2026
Analytical Date : 24 April – 05 May 2026
Report Date : 06 May 2026

Parameter	Unit	Analytical Method ^{1/}	Result
pH at 24.7 °C	-	Electrometric Method (4500-H ⁺ B)	9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	159
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	79.2
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.0
Volume Flow rate *	m ³ /s	Flow Meter	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-Cl D)	< 0.5
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000
Sample Appearance		Green/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : จุดระบายน้ำออกจากระบบ
GPS. Coordinate : 47 P 657507 E 1517092 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W69021
Sample No. : W69021/2
Sample Type : Wastewater
Sampling Date : 23 April 2026
Sampling Time : 02.58 p.m.
Received Date : 24 April 2026
Analytical Date : 24 April – 05 May 2026
Report Date : 06 May 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.6 °C	-	Electrometric Method (4500-H ⁺ B)	7.9	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	7.2	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	< 2.0	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Volume Flow rate *	m ³ /s	Flow Meter	-	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-CL D)	< 0.5	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	54,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act,
B.E. 2567 (2024) Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : บ่อพักน้ำสุดท้ายก่อนระบายออกท่อสาธารณะ
GPS. Coordinate : 47 P 657415 E 1517160 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W69021
Sample No. : W69021/3
Sample Type : Wastewater
Sampling Date : 23 April 2026
Sampling Time : 02.50 p.m.
Received Date : 24 April 2026
Analytical Date : 24 April – 05 May 2026
Report Date : 06 May 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.9 °C	-	Electrometric Method (4500-H ⁺ B)	7.4	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	11.8	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	66.3	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Volume Flow rate *	m ³ /s	Flow Meter	-	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-CL D)	< 0.5	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	92,000	-
Sample Appearance		White/Turbid/Sediment/Smelly		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024) Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : จุดรวบรวมน้ำเสียเข้าระบบบำบัด
GPS. Coordinate : 47 P 657451 E 1517130 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling


Data Provided by Laboratory

Report No. : W69021
Sample No. : W69021/1
Sample Type : Wastewater
Sampling Date : 26 May 2026
Sampling Time : 10.40 a.m.
Received Date : 27 May 2026
Analytical Date : 27 May – 12 June 2026
Report Date : 15 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result
pH at 24.9 °C	-	Electrometric Method (4500-H ⁺ B)	9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	314
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	203
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	4.5
Volume Flow rate *	m ³ /s	Flow Meter	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-CL D)	< 0.5
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : จุดระบายน้ำออกจากระบบ
GPS. Coordinate : 47 P 657516 E 1517084 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W69021
Sample No. : W69021/2
Sample Type : Wastewater
Sampling Date : 26 May 2026
Sampling Time : 10.33 a.m.
Received Date : 27 May 2026
Analytical Date : 27 May – 12 June 2026
Report Date : 15 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.4 °C	-	Electrometric Method (4500-H ⁺ B)	7.8	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	7.1	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	3.1	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Volume Flow rate *	m ³ /s	Flow Meter	-	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-CL D)	< 0.5	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	92,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024) Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
 Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
 Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
 เขตภาษีเจริญ กรุงเทพมหานคร 10160
 Sampling Point : บ่อพักน้ำสุดท้ายก่อนระบายออกท่อสาธารณะ
 GPS. Coordinate : 47 P 657409 E 1517162 N
 Sampling By : TNP ENVIRONMENT CO., LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W69021
 Sample No. : W69021/3
 Sample Type : Wastewater
 Sampling Date : 26 May 2026
 Sampling Time : 10.53 a.m.
 Received Date : 27 May 2026
 Analytical Date : 27 May – 12 June 2026
 Report Date : 15 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.5 °C	-	Electrometric Method (4500-H ⁺ B)	7.1	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	10.0	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	12.8	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Volume Flow rate *	m ³ /s	Flow Meter	-	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-Cl D)	< 0.5	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	92,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024) Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชนครินทร์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชนครินทร์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : จุดรวบรวมน้ำเสียเข้าระบบบำบัด
GPS. Coordinate : 47 P 657456 E 1517126 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling


Data Provided by Laboratory

Report No. : W69021
Sample No. : W69021/1
Sample Type : Wastewater
Sampling Date : 22 June 2026
Sampling Time : 10.24 a.m.
Received Date : 23 June 2026
Analytical Date : 23 June – 09 July 2026
Report Date : 10 July 2026

Parameter	Unit	Analytical Method ^{1/}	Result
pH at 24.5 °C	-	Electrometric Method (4500-H ⁺ B)	8.3
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	120
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	98.7
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	3.0
Volume Flow rate *	m ³ /s	Flow Meter	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-CL D)	< 0.5
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : จุดระบายน้ำออกจากระบบ
GPS. Coordinate : 47 P 657508 E 1517094 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Report No. : W69021
Sample No. : W69021/2
Sample Type : Wastewater
Sampling Date : 22 June 2026
Sampling Time : 10.20 a.m.
Received Date : 23 June 2026
Analytical Date : 23 June – 09 July 2026
Report Date : 10 July 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.4 °C	-	Electrometric Method (4500-H ⁺ B)	7.5	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	< 5.0	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	< 2.0	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Volume Flow rate *	m ³ /s	Flow Meter	-	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-Cl D)	< 0.5	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	92,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024) Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Project Name : โครงการอาคารชุด ศุภาลัย ปาร์ค ราชพฤกษ์-เพชรเกษม
Address Project : เลขที่ 1/999 ถนนเพชรเกษม แขวงบางหว้า
เขตภาษีเจริญ กรุงเทพมหานคร 10160
Sampling Point : บ่อพักน้ำสุดท้ายก่อนระบายออกท่อสาธารณะ
GPS. Coordinate : 47 P 657411 E 1517158 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69021
Sample No. : W69021/3
Sample Type : Wastewater
Sampling Date : 22 June 2026
Sampling Time : 10.34 a.m.
Received Date : 23 June 2026
Analytical Date : 23 June – 09 July 2026
Report Date : 10 July 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.3 °C	-	Electrometric Method (4500-H ⁺ B)	7.0	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	14.9	≤ 30
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	19.7	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.1	≤ 20
Volume Flow rate *	m ³ /s	Flow Meter	-	-
Combine Chlorine *	mg/L	Amperometric Titration Method (4500-CL D)	< 0.5	-
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	160,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024) Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

