

ภาคผนวก ง

ผลการติดตามตรวจสอบคุณภาพสิ่งแวดล้อม



คุณภาพน้ำทิ้งของโครงการ



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิตินุศลาคารชุต เขียวล้ำ เจริญนคร
Project Name : โครงการเขียล้ำ เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : จุดรวบรวมน้ำเสียเข้าระบบบำบัดน้ำเสีย
GPS. Coordinate : 47 P 662465 E 1518648 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69025
Sample No. : W69025/1
Sample Type : Wastewater
Sampling Date : 07 January 2026
Sampling Time : 01.20 p.m.
Received Date : 08 January 2026
Analytical Date : 08 – 22 January 2026
Report Date : 23 January 2026


Parameter	Unit	Analytical Method ^{1/}	Result
pH at 23.9 °C	-	Electrometric Method (4500-H ⁺ B)	7.9
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	19.1
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	163
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	50.2
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.1
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	1.26
Total Kjeldahl Nitrogen *, ^{3/}	mg/L	APHA:4500-Norg (B) ^{2/}	64
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA., WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA., WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co., Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เขียวลำ เจริญนคร
Project Name : โครงการเขียวลำ เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : จุดระบายน้ำเสียออกจากระบบบำบัดน้ำเสีย
GPS. Coordinate : 47 P 662466 E 1518640 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69025
Sample No. : W69025/2
Sample Type : Wastewater
Sampling Date : 07 January 2026
Sampling Time : 01.25 p.m.
Received Date : 08 January 2026
Analytical Date : 08 – 22 January 2026
Report Date : 23 January 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.2 °C	-	Electrometric Method (4500-H ⁺ B)	7.7	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	20.0	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	165	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	33.8	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	3.3	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	0.91	≤ 1.0
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{2/}	51	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000	-
Sample Appearance		Yellow/Turbid/Sediment/Smelly		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type B.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA., WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA., WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co., Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เขียวล้ำ เจริญนคร
Project Name : โครงการเขียวล้ำ เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : จุดตรวจวัดคุณภาพน้ำก่อนระบายออกจาโครงการ
GPS. Coordinate : 47 P 662462 E 1518614 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69025
Sample No. : W69025/3
Sample Type : Wastewater
Sampling Date : 07 January 2026
Sampling Time : 01.30 p.m.
Received Date : 08 January 2026
Analytical Date : 08 – 22 January 2026
Report Date : 23 January 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 23.5 °C	-	Electrometric Method (4500-H ⁺ B)	7.5	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	8.8	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	114	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	12.3	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Total Kjeldahl Nitrogen *, ^{3/}	mg/L	APHA:4500-Norg (B) ^{2/}	10	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	92,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type B.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA., WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA., WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co., Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เขียวลำ เจริญนคร
Project Name : โครงการเขียวลำ เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอฯ แขวงคลองสาน
เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : จุดรวบรวมน้ำเสียเข้าระบบบำบัดน้ำเสีย
GPS. Coordinate : 47 P 662475 E 1518644 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69025
Sample No. : W69025/1
Sample Type : Wastewater
Sampling Date : 10 February 2026
Sampling Time : 10.37 a.m.
Received Date : 11 February 2026
Analytical Date : 11 – 27 February 2026
Report Date : 02 March 2026


Parameter	Unit	Analytical Method ^{1/}	Result
pH at 24.2 °C	-	Electrometric Method (4500-H ⁺ B)	7.7
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	12.8
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	345
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	35.2
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	0.71
Total Kjeldahl Nitrogen *, ^{3/}	mg/L	APHA:4500-Norg (B) ^{2/}	34
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Odorless	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co., Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เขียวล้ำ เจริญนคร
Project Name : โครงการเขียวล้ำ เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : จุดระบายน้ำเสียออกจากระบบบำบัดน้ำเสีย
GPS. Coordinate : 47 P 662474 E 1518654 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69025
Sample No. : W69025/2
Sample Type : Wastewater
Sampling Date : 10 February 2026
Sampling Time : 10.40 a.m.
Received Date : 11 February 2026
Analytical Date : 11 – 27 February 2026
Report Date : 02 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.6 °C	-	Electrometric Method (4500-H ⁺ B)	7.7	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	12.3	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	324	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	24.2	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Total Kjeldahl Nitrogen *, ^{3/}	mg/L	APHA:4500-Norg (B) ^{2/}	28	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type B.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co., Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เซียล่า เจริญนคร
Project Name : โครงการเซียล่า เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : จุดตรวจวัดคุณภาพน้ำก่อนระบายออกจากโครงการ
GPS. Coordinate : 47 P 662463 E 1518615 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69025
Sample No. : W69025/3
Sample Type : Wastewater
Sampling Date : 10 February 2026
Sampling Time : 10.44 a.m.
Received Date : 11 February 2026
Analytical Date : 11 – 27 February 2026
Report Date : 02 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.4 °C	-	Electrometric Method (4500-H ⁺ B)	7.2	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	9.5	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	239	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	27.2	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	0.61	≤ 1.0
Total Kjeldahl Nitrogen *, ^{3/}	mg/L	APHA:4500-Norg (B) ^{2/}	4.2	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000	-
Sample Appearance		Yellow/Turbid/Little Sediment/Smelly		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type B.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co., Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เขียวล่า เจริญนคร
 Project Name : โครงการเขียวล่า เจริญนคร (CIELA Charoen Nakhon)
 Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอฯ แขวงคลองสาน
 เขตคลองสาน กรุงเทพมหานคร 10600
 Sampling Point : จุดรวบรวมน้ำเสียเข้าระบบบำบัดน้ำเสีย
 GPS. Coordinate : 47 P 662475 E 1518648 N
 Sampling By : TNP ENVIRONMENT CO., LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69025
 Sample No. : W69025/1
 Sample Type : Wastewater
 Sampling Date : 10 March 2026
 Sampling Time : 11.35 a.m.
 Received Date : 11 March 2026
 Analytical Date : 11 - 30 March 2026
 Report Date : 31 March 2026


Parameter	Unit	Analytical Method ^{1/}	Result
pH at 25.1 °C	-	Electrometric Method (4500-H ⁺ B)	7.3
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	42.9
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	394
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	69.3
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.1
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	1.71
Total Kjeldahl Nitrogen *, ^{3/}	mg/L	APHA:4500-Norg (B) ^{2/}	62
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co., Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เขียวลำ เจริญนคร
Project Name : โครงการเขียวลำ เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : จุดระบายน้ำเสียออกจากระบบบำบัดน้ำเสีย
GPS. Coordinate : 47 P 662491 E 1518649 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69025
Sample No. : W69025/2
Sample Type : Wastewater
Sampling Date : 10 March 2026
Sampling Time : 11.38 a.m.
Received Date : 11 March 2026
Analytical Date : 11 - 30 March 2026
Report Date : 31 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 25.2 °C	-	Electrometric Method (4500-H ⁺ B)	7.1	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	22.5	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	388	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	19.3	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Total Kjeldahl Nitrogen ^{*, 3/}	mg/L	APHA:4500-Norg (B) ^{2/}	9.8	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000	-
Sample Appearance		Yellow/Turbid/Little Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type B.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co., Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เขียวล้ำ เจริญนคร
 Project Name : โครงการเขียวล้ำ เจริญนคร (CIELA Charoen Nakhon)
 Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอฯ แขวงคลองสาน
 เขตคลองสาน กรุงเทพมหานคร 10600
 Sampling Point : จุดตรวจวัดคุณภาพน้ำก่อนระบายออกจากโครงการ
 GPS. Coordinate : 47 P 662483 E 1518619 N
 Sampling By : TNP ENVIRONMENT CO., LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69025
 Sample No. : W69025/3
 Sample Type : Wastewater
 Sampling Date : 10 March 2026
 Sampling Time : 11.42 a.m.
 Received Date : 11 March 2026
 Analytical Date : 11 - 30 March 2026
 Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.7 °C	-	Electrometric Method (4500-H ⁺ B)	7.4	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	5.7	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	336	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	8.5	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Total Kjeldahl Nitrogen ^{*,3/}	mg/L	APHA:4500-Norg (B) ^{2/}	< 0.28	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type B.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co., Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เซียะลำ เจริญนคร
Project Name : โครงการเซียะลำ เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : จุดรวบรวมน้ำเสียเข้าระบบบำบัดน้ำเสีย
GPS. Coordinate : 47 P 662470 E 1518650 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69025
Sample No. : W69025/1
Sample Type : Wastewater
Sampling Date : 09 April 2026
Sampling Time : 09.47 a.m.
Received Date : 10 April 2026
Analytical Date : 10 - 27 April 2026
Report Date : 28 April 2026


Parameter	Unit	Analytical Method ^{1/}	Result
pH at 25.1 °C	-	Electrometric Method (4500-H ⁺ B)	7.6
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	45.2
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	378
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	81.3
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	1.21
Total Kjeldahl Nitrogen *. ^{3/}	mg/L	APHA:4500-Norg (B) ^{2/}	19
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000
Sample Appearance		Yellow/Turbid/Sediment/Smelly	

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co., Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.





TNP ENVIRONMENT CO.,LTD.

เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273

E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่



NSC-TISI-TIS 17025

Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เขียวลำ เจริญนคร
Project Name : โครงการเขียวลำ เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : จุดระบายน้ำเสียออกจากระบบบำบัดน้ำเสีย
GPS. Coordinate : 47 P 662475 E 1518643 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69025
Sample No. : W69025/2
Sample Type : Wastewater
Sampling Date : 09 April 2026
Sampling Time : 09.49 a.m.
Received Date : 10 April 2026
Analytical Date : 10 - 27 April 2026
Report Date : 28 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.7 °C	-	Electrometric Method (4500-H ⁺ B)	6.9	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	35.4	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	375	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	22.6	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Total Kjeldahl Nitrogen *. ^{3/}	mg/L	APHA:4500-Norg (B) ^{2/}	< 0.28	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000	-
Sample Appearance		Yellow/Turbid/Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type B.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co., Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.





TNP ENVIRONMENT CO.,LTD.

เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273

E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่



NSC-TISI-TIS 17025

Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เขียวลำ เจริญนคร
Project Name : โครงการเขียวลำ เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : จุดตรวจวัดคุณภาพน้ำก่อนระบายออกจากโครงการ
GPS. Coordinate : 47 P 662465 E 1518616 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69025
Sample No. : W69025/3
Sample Type : Wastewater
Sampling Date : 09 April 2026
Sampling Time : 09.54 a.m.
Received Date : 10 April 2026
Analytical Date : 10 - 27 April 2026
Report Date : 28 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.8 °C	-	Electrometric Method (4500-H ⁺ B)	7.4	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	10.2	≤ 40
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	310	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	14.3	≤ 30
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Total Kjeldahl Nitrogen ^{2/}	mg/L	APHA:4500-Norg (B) ^{2/}	< 0.28	≤ 35
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	> 160,000	-
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type B.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co., Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



คุณภาพน้ำสระว่ายน้ำ



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เซียล่า เจริญนคร
Project Name : โครงการเซียล่า เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 662465 E 1518659 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69025
Sample No : W69025/4
Sample Type : Swimming pool Water
Sampling Date : 07 January 2026
Sampling Time : 01.35 p.m.
Received Date : 08 January 2026
Analytical Date : 08 – 16 January 2026
Report Date : 19 January 2026


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/ Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิตินุศคลอาคารชุด เขียวล่า เจริญนคร
Project Name : โครงการเขียวล่า เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : สระว่ายน้ำส่วนต้น
GPS. Coordinate : 47 P 662474 E 1518656 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69025
Sample No : W69025/5
Sample Type : Swimming pool Water
Sampling Date : 07 January 2026
Sampling Time : 01.36 p.m.
Received Date : 08 January 2026
Analytical Date : 08 – 16 January 2026
Report Date : 19 January 2026


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เซียล่า เจริญนคร
Project Name : โครงการเซียล่า เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 662515 E 1518651 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69025
Sample No : W69025/4
Sample Type : Swimming pool Water
Sampling Date : 10 February 2026
Sampling Time : 10.35 a.m.
Received Date : 11 February 2026
Analytical Date : 11 – 27 February 2026
Report Date : 02 March 2026


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เขียวลำ เจริญนคร
Project Name : โครงการเขียวลำ เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ แขวงคลองสาน
เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : สระว่ายน้ำส่วนต้น
GPS. Coordinate : 47 P 662481 E 1518646 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69025
Sample No : W69025/5
Sample Type : Swimming pool Water
Sampling Date : 10 February 2026
Sampling Time : 10.36 a.m.
Received Date : 11 February 2026
Analytical Date : 11 – 27 February 2026
Report Date : 02 March 2026


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เขียวลำ เจริญนคร
Project Name : โครงการเขียวลำ เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : สระว่ายน้ำส่วนเล็ก
GPS. Coordinate : 47 P 662466 E 1518658 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69025
Sample No : W69025/4
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 11.31 a.m.
Received Date : 11 March 2026
Analytical Date : 11 - 30 March 2026
Report Date : 31 March 2026


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/ Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เขียวล่า เจริญนคร
Project Name : โครงการเขียวล่า เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : สระว่ายน้ำส่วนต้น
GPS. Coordinate : 47 P 662471 E 1518644 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69025
Sample No : W69025/5
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 11.32 a.m.
Received Date : 11 March 2026
Analytical Date : 11 - 30 March 2026
Report Date : 31 March 2026


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เซียะลำ เจริญนคร
Project Name : โครงการเซียะลำ เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 662479 E 1518646 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69025
Sample No : W69025/4
Sample Type : Swimming pool Water
Sampling Date : 09 April 2026
Sampling Time : 09.43 a.m.
Received Date : 10 April 2026
Analytical Date : 10 - 27 April 2026
Report Date : 28 April 2026


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/ Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เซียล่า เจริญนคร
Project Name : โครงการเซียล่า เจริญนคร (CIELA Charoen Nakhon)
Address Project : เลขที่ 289 ถนนสมเด็จพระเจ้าพี่นางเธอ เจ้าฟ้ากัลยาณิวัฒนา แขวงคลองสาน เขตคลองสาน กรุงเทพมหานคร 10600
Sampling Point : สระว่ายน้ำส่วนต้น
GPS. Coordinate : 47 P 662474 E 1518654 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69025
Sample No : W69025/5
Sample Type : Swimming pool Water
Sampling Date : 09 April 2026
Sampling Time : 09.44 a.m.
Received Date : 10 April 2026
Analytical Date : 10 - 27 April 2026
Report Date : 28 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Company Limited registration number Wo-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

