

ภาคผนวก ง

เอกสารประกอบการปฏิบัติตามมาตรการติดตามตรวจสอบ

ผลกระทบสิ่งแวดล้อม

ภาคผนวก ง-1

ผลการติดตามตรวจสอบคุณภาพน้ำเสียและน้ำทิ้ง

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : JANUARY 8, 2026
SAMPLING TIME : 1/
SAMPLING METHOD : GRAB
SAMPLING BY : MR NAPAT TEMEYABUTR
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : JANUARY 8, 2026
ANALYTICAL DATE : JANUARY 8-14, 2026
ISSUE DATE : JANUARY 16, 2026
REPORT NO. : 2026-U003434
WORK NO. : 2025-008822
ANALYSIS NO. : T26AA233-0001 - T26AA233-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 09:40 HOUR 1/ T26AA233-0001	2 09:25 HOUR 1/ T26AA233-0002			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.0 (30.0°C)	7.2 (29.7°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	62.2	91.2	≤ 30	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	10.2	20.3	≤ 40	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	354	351	≤ 1,000	-	25
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	14.0	21.4	≤ 35	1.5	5.0



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 09:40 HOUR 1/ T26AA233-0001	2 09:25 HOUR 1/ T26AA233-0002			
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN	YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : จดระบายนํ้าออกจากระบบบำบัดนํ้าเสีย

RESULT 2 : บ่อพักนํ้าสุดท้ายของระบบระบายนํ้าของโครงการ

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : FEBRUARY 5, 2026
SAMPLING TIME : 1/
SAMPLING METHOD : GRAB
SAMPLING BY : MR ACHITA SAENGJAN
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : FEBRUARY 6, 2026
ANALYTICAL DATE : FEBRUARY 6-13, 2026
ISSUE DATE : FEBRUARY 16, 2026
REPORT NO. : 2026-U011680
WORK NO. : 2025-008822
ANALYSIS NO. : T26AC330-0001 - T26AC330-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 11:25 HOUR 1/ T26AC330-0001	2 11:10 HOUR 1/ T26AC330-0002			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	6.5 (33.5°C)	7.1 (31.8°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	34.9	39.2	≤ 30	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	17.8	8.4	≤ 40	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	363	293	≤ 1,000	-	25
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	34.7	19.5	≤ 35	1.5	5.0



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 11:25 HOUR 1/ T26AC330-0001	2 11:10 HOUR 1/ T26AC330-0002			
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN	YELLOW/CLEAR BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : จดระบายนํ้าออกจากระบบบำบัดนํ้าเสีย

RESULT 2 : บ่อพักนํ้าสุดท้ายของระบบระบายนํ้าของโครงการ

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : MARCH 5, 2026
SAMPLING TIME : 1/
SAMPLING METHOD : GRAB
SAMPLING BY : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : MARCH 5, 2026
ANALYTICAL DATE : MARCH 5-12, 2026
ISSUE DATE : MARCH 13, 2026
REPORT NO. : 2026-U018943
WORK NO. : 2025-008822
ANALYSIS NO. : T26AE449-0001 - T26AE449-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 10:25 HOUR 1/ T26AE449-0001	2 10:15 HOUR 1/ T26AE449-0002			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	6.9 (33.0°C)	7.0 (30.1°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	36.0	15.9	≤ 30	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	5.5	7.3	≤ 40	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	360	324	≤ 1,000	-	25
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	9.4	8.5	≤ 35	1.5	5.0

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 10:25 HOUR 1/ T26AE449-0001	2 10:15 HOUR 1/ T26AE449-0002			
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN	YELLOW/CLEAR BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : จดระบายนํ้าออกจากระบบบำบัดนํ้าเสีย

RESULT 2 : บ่อพักนํ้าสุดท้ายของระบบระบายนํ้าของโครงการ

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : APRIL 2, 2026
SAMPLING TIME : 1/
SAMPLING METHOD : GRAB
SAMPLING BY : MR WEERAYUT MOKKAEW
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : APRIL 2, 2026
ANALYTICAL DATE : APRIL 2-10, 2026
ISSUE DATE : APRIL 16, 2026
REPORT NO. : 2026-U028906
WORK NO. : 2025-008822
ANALYSIS NO. : T26AH028-0001 - T26AH028-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 13:55 HOUR 1/ T26AH028-0001	2 13:50 HOUR 1/ T26AH028-0002			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.4 (34.8°C)	7.5 (31.1°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	29.5	14.5	≤ 30	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	11.4	13.4	≤ 40	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	317	320	≤ 1,000	-	25
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	31.1	22.6	≤ 35	1.5	5.0



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 13:55 HOUR 1/ T26AH028-0001	2 13:50 HOUR 1/ T26AH028-0002			
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN	YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : จดระบายนํ้าออกจากระบบบำบัดนํ้าเสีย

RESULT 2 : บ่อพักนํ้าสุดท้ายของระบบระบายนํ้าของโครงการ

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME	: THE RESERVE SATHORN	RECEIVED DATE	: MAY 7, 2026
ADDRESS	: 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120	ANALYTICAL DATE	: MAY 7-15, 2026
CONTACT INFORMATION	: TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com	ISSUE DATE	: MAY 15, 2026
SAMPLING SOURCE	: -	REPORT NO.	: 2026-U039669
SAMPLE TYPE	: WASTEWATER	WORK NO.	: 2025-008822
SAMPLING DATE	: MAY 7, 2026	ANALYSIS NO.	: T26AJ706-0001 - T26AJ706-0002
SAMPLING TIME	: 1/		
SAMPLING METHOD	: GRAB		
SAMPLING BY	: MR SITTHIPOL PROMPOCHENBOON		
ANALYZED BY	: MISS NAPAPORN KHUNNOKKHUM		

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 10:15 HOUR 1/ T26AJ706-0001	2 10:10 HOUR 1/ T26AJ706-0002			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.2 (33.2°C)	7.3 (31.2°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	16.0	13.9	≤ 30	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	10.0	8.2	≤ 40	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	310	265	≤ 1,000	-	25
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	27.4	18.5	≤ 35	1.5	5.0



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 10:15 HOUR 1/ T26AJ706-0001	2 10:10 HOUR 1/ T26AJ706-0002			
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN	YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : จดระบายนํ้าออกจากระบบบำบัดนํ้าเสีย

RESULT 2 : บ่อพักนํ้าสุดท้ายของระบบระบายนํ้าของโครงการ

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

(MRS PIYAPAT SUTTAMANUTWONG)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WASTEWATER
SAMPLING DATE : JUNE 9, 2026
SAMPLING TIME : 1/
SAMPLING METHOD : GRAB
SAMPLING BY : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS NAPAPORN KHUNNOKKHUM
RECEIVED DATE : JUNE 9, 2026
ANALYTICAL DATE : JUNE 9-17, 2026
ISSUE DATE : JUNE 17, 2026
REPORT NO. : 2026-U052528
WORK NO. : 2025-008822
ANALYSIS NO. : T26AM654-0001 - T26AM654-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 10:05 HOUR 1/ T26AM654-0001	2 09:55 HOUR 1/ T26AM654-0002			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.0 (34.0°C)	7.2 (31.8°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	79.4	30.8	≤ 30	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	32.4	5.6	≤ 40	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	344	260	≤ 1,000	-	25
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	18.3	9.1	≤ 35	1.5	5.0



PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT		REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			1 10:05 HOUR 1/ T26AM654-0001	2 09:55 HOUR 1/ T26AM654-0002			
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN	YELLOW/CLEAR BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

RESULT 1 : จดระบายนํ้าออกจากระบบบำบัดนํ้าเสีย

RESULT 2 : บ่อดักนํ้าสุดท้ายของระบบระบายนํ้าของโครงการ

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS B, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

(MISS WILAILAK SRISUK)
LABORATORY SUPERVISOR

ภาคผนวก ง-2

ผลการติดตามตรวจสอบคุณภาพน้ำสระว่ายนํ้า

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JANUARY 8, 2026
SAMPLING TIME : 09:15 HOUR
SAMPLING METHOD ° : GRAB
SAMPLING BY ° : MR NAPAT TEMEYABUTR
ANALYZED BY : MISS BUSSAKORN MAJAI

RECEIVED DATE : JANUARY 8, 2026
ANALYTICAL DATE : JANUARY 8-13, 2026
ISSUE DATE : JANUARY 16, 2026
REPORT NO. : 2026-U003437
WORK NO. : 2025-008822
ANALYSIS NO. : T26AA233-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สระว่ายน้ำสวนต้น T26AA233-0004		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORM BACTERIA ^c	/100 mL	PRESENCE-ABSENCE (P-A) COLIFORM TEST (SM: PART 9221 D AND E)	NOT DETECTED	-	-
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

...

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JANUARY 8, 2026
SAMPLING TIME : 09:15 HOUR
SAMPLING METHOD * : GRAB
SAMPLING BY * : MR NAPAT TEMEYABUTR
ANALYZED BY : MISS BUSSAKORN MAJAI
RECEIVED DATE : JANUARY 8, 2026
ANALYTICAL DATE : JANUARY 8-11, 2026
ISSUE DATE : JANUARY 16, 2026
REPORT NO. : 2026-U003438
WORK NO. : 2025-008822
ANALYSIS NO. : T26AA233-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			สรุป่ายน้ำส่วนดิน T26AA233-0004	
MICROBIOLOGY				
Staphylococcus aureus	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

THE LABORATORY HAS BEEN ACCEPTED AS AN ACCREDITED LABORATORY COMPLYING WITH THE ISO/IEC 17025.

* : TEST METHOD ARE NOT COVERED COMPLYING WITH THE ISO/IEC 17025, VERIFIED BY OWN LABORATORY QUALITY SYSTEM.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JANUARY 8, 2026
SAMPLING TIME : 09:20 HOUR
SAMPLING METHOD ° : GRAB
SAMPLING BY ° : MR NAPAT TEMEYABUTR
ANALYZED BY : MISS BUSSAKORN MAJAI

RECEIVED DATE : JANUARY 8, 2026
ANALYTICAL DATE : JANUARY 8-13, 2026
ISSUE DATE : JANUARY 16, 2026
REPORT NO. : 2026-U003435
WORK NO. : 2025-008822
ANALYSIS NO. : T26AA233-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรุบน้ำส่วนลึก T26AA233-0003		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORM BACTERIA ^c	/100 mL	PRESENCE-ABSENCE (P-A) COLIFORM TEST (SM: PART 9221 D AND E)	NOT DETECTED	-	-
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JANUARY 8, 2026
SAMPLING TIME : 09:20 HOUR
SAMPLING METHOD * : GRAB
SAMPLING BY * : MR NAPAT TEMEYABUTR
ANALYZED BY : MISS BUSSAKORN MAJAI
RECEIVED DATE : JANUARY 8, 2026
ANALYTICAL DATE : JANUARY 8-11, 2026
ISSUE DATE : JANUARY 16, 2026
REPORT NO. : 2026-U003436
WORK NO. : 2025-008822
ANALYSIS NO. : T26AA233-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			สระว่ายน้ำน้ำส่วนลึก T26AA233-0003	
MICROBIOLOGY				
Staphylococcus aureus	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

THE LABORATORY HAS BEEN ACCEPTED AS AN ACCREDITED LABORATORY COMPLYING WITH THE ISO/IEC 17025.

* : TEST METHOD ARE NOT COVERED COMPLYING WITH THE ISO/IEC 17025, VERIFIED BY OWN LABORATORY QUALITY SYSTEM.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : FEBRUARY 5, 2026
SAMPLING TIME : 11:30 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR ACHITA SAENGJAN
ANALYZED BY : MR RATCHATA THONGPIYAPOOM
RECEIVED DATE : FEBRUARY 6, 2026
ANALYTICAL DATE : FEBRUARY 6-10, 2026
ISSUE DATE : FEBRUARY 16, 2026
REPORT NO. : 2026-U011684
WORK NO. : 2025-008822
ANALYSIS NO. : T26AC330-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรุปว่าน้ำสวนต้น T26AC330-0004		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORM BACTERIA ^c	/100 mL	PRESENCE-ABSENCE (P-A) COLIFORM TEST (SM: PART 9221 D AND E)	NOT DETECTED	-	-
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

.. [Signature] ...

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : FEBRUARY 5, 2026
SAMPLING TIME : 11:30 HOUR
SAMPLING METHOD * : GRAB AND STERILE TECHNIQUE
SAMPLING BY * : MR ACHITA SAENGJAN
ANALYZED BY : MISS JITSAMON NGAMKANA
RECEIVED DATE : FEBRUARY 6, 2026
ANALYTICAL DATE : FEBRUARY 6-9, 2026
ISSUE DATE : FEBRUARY 16, 2026
REPORT NO. : 2026-U011685
WORK NO. : 2025-008822
ANALYSIS NO. : T26AC330-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			สรุบน้ำส่วนต้น T26AC330-0004	
MICROBIOLOGY				
<i>Staphylococcus aureus</i>	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

THE LABORATORY HAS BEEN ACCEPTED AS AN ACCREDITED LABORATORY COMPLYING WITH THE ISO/IEC 17025.

* : TEST METHOD ARE NOT COVERED COMPLYING WITH THE ISO/IEC 17025, VERIFIED BY OWN LABORATORY QUALITY SYSTEM.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

[Signature]

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : FEBRUARY 5, 2026
SAMPLING TIME : 11:35 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR ACHITA SAENGJAN
ANALYZED BY : MR RATCHATA THONGPIYAPOOM

RECEIVED DATE : FEBRUARY 6, 2026
ANALYTICAL DATE : FEBRUARY 6-10, 2026
ISSUE DATE : FEBRUARY 16, 2026
REPORT NO. : 2026-U011681
WORK NO. : 2025-008822
ANALYSIS NO. : T26AC330-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรุบายนำส่วนลึก T26AC330-0003		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORM BACTERIA ^c	/100 mL	PRESENCE-ABSENCE (P-A) COLIFORM TEST (SM: PART 9221D AND E)	NOT DETECTED	-	-
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221D AND F)	NOT DETECTED	NOT DETECTED	-
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		
			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : FEBRUARY 5, 2026
SAMPLING TIME : 11:35 HOUR
SAMPLING METHOD * : GRAB AND STERILE TECHNIQUE
SAMPLING BY * : MR ACHITA SAENGJAN
ANALYZED BY : MISS JITSAMON NGAMKANA
RECEIVED DATE : FEBRUARY 6, 2026
ANALYTICAL DATE : FEBRUARY 6-9, 2026
ISSUE DATE : FEBRUARY 16, 2026
REPORT NO. : 2026-U011682
WORK NO. : 2025-008822
ANALYSIS NO. : T26AC330-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			สรุบน้ำส่วนลึก T26AC330-0003	
MICROBIOLOGY				
Staphylococcus aureus	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

THE LABORATORY HAS BEEN ACCEPTED AS AN ACCREDITED LABORATORY COMPLYING WITH THE ISO/IEC 17025.

* : TEST METHOD ARE NOT COVERED COMPLYING WITH THE ISO/IEC 17025, VERIFIED BY OWN LABORATORY QUALITY SYSTEM.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MARCH 5, 2026
SAMPLING TIME : 10:35 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS BUSSAKORN MAJAI
RECEIVED DATE : MARCH 5, 2026
ANALYTICAL DATE : MARCH 5-10, 2026
ISSUE DATE : MARCH 16, 2026
REPORT NO. : 2026-U018939
WORK NO. : 2025-008822
ANALYSIS NO. : T26AE449-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรุปว่าน้ำส่วนต้น T26AE449-0004		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORM BACTERIA ^c	/100 mL	PRESENCE-ABSENCE (P-A) COLIFORM TEST (SM: PART 9221 D AND E)	NOT DETECTED	-	-
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR		
SEDIMENT			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRICTIONAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MARCH 5, 2026
SAMPLING TIME : 10:35 HOUR
SAMPLING METHOD * : GRAB AND STERILE TECHNIQUE
SAMPLING BY * : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS BUSSAKORN MAJAI
RECEIVED DATE : MARCH 5, 2026
ANALYTICAL DATE : MARCH 5-8, 2026
ISSUE DATE : MARCH 16, 2026
REPORT NO. : 2026-U018940
WORK NO. : 2025-008822
ANALYSIS NO. : T26AE449-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			ตรวจว่าน้ำส่วนต้น T26AE449-0004	
MICROBIOLOGY				
Staphylococcus aureus	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

THE LABORATORY HAS BEEN ACCEPTED AS AN ACCREDITED LABORATORY COMPLYING WITH THE ISO/IEC 17025.

* : TEST METHOD ARE NOT COVERED COMPLYING WITH THE ISO/IEC 17025, VERIFIED BY OWN LABORATORY QUALITY SYSTEM.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MARCH 5, 2026
SAMPLING TIME : 10:40 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS BUSSAKORN MAJAI

RECEIVED DATE : MARCH 5, 2026
ANALYTICAL DATE : MARCH 5-10, 2026
ISSUE DATE : MARCH 16, 2026
REPORT NO. : 2026-U018935
WORK NO. : 2025-008822
ANALYSIS NO. : T26AE449-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรุบน้ำส่วนลึก T26AE449-0003		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORM BACTERIA ^c	/100 mL	PRESENCE-ABSENCE (P-A) COLIFORM TEST (SM: PART 9221 D AND E)	NOT DETECTED	-	-
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRICTIONAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MARCH 5, 2026
SAMPLING TIME : 10:40 HOUR
SAMPLING METHOD * : GRAB AND STERILE TECHNIQUE
SAMPLING BY * : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS BUSSAKORN MAJAI
RECEIVED DATE : MARCH 5, 2026
ANALYTICAL DATE : MARCH 5-8, 2026
ISSUE DATE : MARCH 16, 2026
REPORT NO. : 2026-U018937
WORK NO. : 2025-008822
ANALYSIS NO. : T26AE449-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			สรุบน้ำส่วนลึก T26AE449-0003	
MICROBIOLOGY				
<i>Staphylococcus aureus</i>	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

THE LABORATORY HAS BEEN ACCEPTED AS AN ACCREDITED LABORATORY COMPLYING WITH THE ISO/IEC 17025.

* : TEST METHOD ARE NOT COVERED COMPLYING WITH THE ISO/IEC 17025, VERIFIED BY OWN LABORATORY QUALITY SYSTEM.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : APRIL 2, 2026
SAMPLING TIME : 14:10 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR WEERAYUT MOKKAEW
ANALYZED BY : MR RATCHATA THONGPIYAPOOM

RECEIVED DATE : APRIL 2, 2026
ANALYTICAL DATE : APRIL 2-13, 2026
ISSUE DATE : APRIL 17, 2026
REPORT NO. : 2026-U028909
WORK NO. : 2025-008822
ANALYSIS NO. : T26AH028-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สระว่ายนํ้าสวนต้น T26AH028-0004		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORM BACTERIA ^c	/100 mL	PRESENCE-ABSENCE (P-A) COLIFORM TEST (SM: PART 9221 D AND E)	NOT DETECTED	-	-
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : APRIL 2, 2026
SAMPLING TIME : 14:10 HOUR
SAMPLING METHOD * : GRAB AND STERILE TECHNIQUE
SAMPLING BY * : MR WEERAYUT MOKKAEW
ANALYZED BY : MISS JITSAMON NGAMKANA
RECEIVED DATE : APRIL 2, 2026
ANALYTICAL DATE : APRIL 2-5, 2026
ISSUE DATE : APRIL 17, 2026
REPORT NO. : 2026-U028910
WORK NO. : 2025-008822
ANALYSIS NO. : T26AH028-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			สระว่ายนํ้าส่วนค้ด T26AH028-0004	
MICROBIOLOGY				
Staphylococcus aureus	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

THE LABORATORY HAS BEEN ACCEPTED AS AN ACCREDITED LABORATORY COMPLYING WITH THE ISO/IEC 17025.

* : TEST METHOD ARE NOT COVERED COMPLYING WITH THE ISO/IEC 17025, VERIFIED BY OWN LABORATORY QUALITY SYSTEM.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

.. [Signature] ..

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : APRIL 2, 2026
SAMPLING TIME : 14:15 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR WEERAYUT MOKKAEW
ANALYZED BY : MR RATCHATA THONGPIYAPOOM

RECEIVED DATE : APRIL 2, 2026
ANALYTICAL DATE : APRIL 2-13, 2026
ISSUE DATE : APRIL 17, 2026
REPORT NO. : 2026-U028907
WORK NO. : 2025-008822
ANALYSIS NO. : T26AH028-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรุบน้ำส่วนลึก T26AH028-0003		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	1.1	< 10	1.1
FAECAL COLIFORM BACTERIA ^c	/100 mL	PRESENCE-ABSENCE (P-A) COLIFORM TEST (SM: PART 9221 D AND E)	NOT DETECTED	-	-
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		
			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

.. [REDACTED] ...

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : APRIL 2, 2026
SAMPLING TIME : 14:15 HOUR
SAMPLING METHOD * : GRAB AND STERILE TECHNIQUE
SAMPLING BY * : MR WEERAYUT MOKKAEW
ANALYZED BY : MISS JITSAMON NGAMKANA
RECEIVED DATE : APRIL 2, 2026
ANALYTICAL DATE : APRIL 2-5, 2026
ISSUE DATE : APRIL 17, 2026
REPORT NO. : 2026-U028908
WORK NO. : 2025-008822
ANALYSIS NO. : T26AH028-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			สรุปว่าขนำส่วนลึก T26AH028-0003	
MICROBIOLOGY				
Staphylococcus aureus	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

THE LABORATORY HAS BEEN ACCEPTED AS AN ACCREDITED LABORATORY COMPLYING WITH THE ISO/IEC 17025.

* : TEST METHOD ARE NOT COVERED COMPLYING WITH THE ISO/IEC 17025, VERIFIED BY OWN LABORATORY QUALITY SYSTEM.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 7, 2026
SAMPLING TIME : 10:25 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS SUJIRA PRASERTSUKHO
RECEIVED DATE : MAY 7, 2026
ANALYTICAL DATE : MAY 7-12, 2026
ISSUE DATE : MAY 15, 2026
REPORT NO. : 2026-U039674
WORK NO. : 2025-008822
ANALYSIS NO. : T26AJ706-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรุปว่าน้ำส่วนดิน T26AJ706-0004		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORM BACTERIA ^c	/100 mL	PRESENCE-ABSENCE (P-A) COLIFORM TEST (SM: PART 9221 D AND E)	NOT DETECTED	-	-
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		
			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.



(MISS CHAWEEVAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 7, 2026
SAMPLING TIME : 10:25 HOUR
SAMPLING METHOD * : GRAB AND STERILE TECHNIQUE
SAMPLING BY * : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS JITSAMON NGAMKANA
RECEIVED DATE : MAY 7, 2026
ANALYTICAL DATE : MAY 7-12, 2026
ISSUE DATE : MAY 15, 2026
REPORT NO. : 2026-U039676
WORK NO. : 2025-008822
ANALYSIS NO. : T26AJ706-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			สำรวจน้ำส่วนดิน T26AJ706-0004	
MICROBIOLOGY				
Staphylococcus aureus	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

THE LABORATORY HAS BEEN ACCEPTED AS AN ACCREDITED LABORATORY COMPLYING WITH THE ISO/IEC 17025.

* : TEST METHOD ARE NOT COVERED COMPLYING WITH THE ISO/IEC 17025, VERIFIED BY OWN LABORATORY QUALITY SYSTEM.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.



(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 7, 2026
SAMPLING TIME : 10:30 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS SUJIRA PRASERTSUKHO
RECEIVED DATE : MAY 7, 2026
ANALYTICAL DATE : MAY 7-12, 2026
ISSUE DATE : MAY 15, 2026
REPORT NO. : 2026-U039671
WORK NO. : 2025-008822
ANALYSIS NO. : T26AJ706-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สระว่ายน้ำส่วนลึก T26AJ706-0003		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORM BACTERIA ^c	/100 mL	PRESENCE-ABSENCE (P-A) COLIFORM TEST (SM: PART 9221 D AND E)	NOT DETECTED	-	-
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-
<i>Pseudomonas aeruginosa</i> ^c	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		
			-		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 7, 2026
SAMPLING TIME : 10:30 HOUR
SAMPLING METHOD * : GRAB AND STERILE TECHNIQUE
SAMPLING BY * : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS JITSAMON NGAMKANA
RECEIVED DATE : MAY 7, 2026
ANALYTICAL DATE : MAY 7-12, 2026
ISSUE DATE : MAY 15, 2026
REPORT NO. : 2026-U039673
WORK NO. : 2025-008822
ANALYSIS NO. : T26AJ706-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			สระว่ายน้ำส่วนลึก T26AJ706-0003	
MICROBIOLOGY				
Staphylococcus aureus	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

THE LABORATORY HAS BEEN ACCEPTED AS AN ACCREDITED LABORATORY COMPLYING WITH THE ISO/IEC 17025.

* : TEST METHOD ARE NOT COVERED COMPLYING WITH THE ISO/IEC 17025, VERIFIED BY OWN LABORATORY QUALITY SYSTEM.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JUNE 9, 2026
SAMPLING TIME : 10:15 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS SUJIRA PRASERTSUKHO
RECEIVED DATE : JUNE 9, 2026
ANALYTICAL DATE : JUNE 9-16, 2026
ISSUE DATE : JUNE 18, 2026
REPORT NO. : 2026-U052533
WORK NO. : 2025-008822
ANALYSIS NO. : T26AM654-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สำรวจน้ำส่วนต้น T26AM654-0004		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORM BACTERIA ^c	/100 mL	PRESENCE-ABSENCE (P-A) COLIFORM TEST (SM: PART 9221 D AND E)	NOT DETECTED	-	-
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-
<i>Pseudomonas aeruginosa</i> ^b	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	NOT DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)

LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JUNE 9, 2026
SAMPLING TIME : 10:15 HOUR
SAMPLING METHOD * : GRAB AND STERILE TECHNIQUE
SAMPLING BY * : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS JITSAMON NGAMKANA
RECEIVED DATE : JUNE 9, 2026
ANALYTICAL DATE : JUNE 9-15, 2026
ISSUE DATE : JUNE 18, 2026
REPORT NO. : 2026-U052534
WORK NO. : 2025-008822
ANALYSIS NO. : T26AM654-0004

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			ตรวจว่าน้ำส่วนดิน T26AM654-0004	
MICROBIOLOGY				
Staphylococcus aureus	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

THE LABORATORY HAS BEEN ACCEPTED AS AN ACCREDITED LABORATORY COMPLYING WITH THE ISO/IEC 17025.

* : TEST METHOD ARE NOT COVERED COMPLYING WITH THE ISO/IEC 17025, VERIFIED BY OWN LABORATORY QUALITY SYSTEM.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ANALYSIS REPORT

CUSTOMER NAME : THE RESERVE SATHORN
ADDRESS : 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JUNE 9, 2026
SAMPLING TIME : 10:20 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : MR SITTHIPOL PROMPOCHENBOON
ANALYZED BY : MISS SUJIRA PRASERTSUKHO
RECEIVED DATE : JUNE 9, 2026
ANALYTICAL DATE : JUNE 9-16, 2026
ISSUE DATE : JUNE 18, 2026
REPORT NO. : 2026-U052530
WORK NO. : 2025-008822
ANALYSIS NO. : T26AM654-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT
			สรุบน้ำส่วนลึก T26AM654-0003		
MICROBIOLOGY					
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	< 10	1.1
FAECAL COLIFORM BACTERIA ^c	/100 mL	PRESENCE-ABSENCE (P-A) COLIFORM TEST (SM: PART 9221 D AND E)	NOT DETECTED	-	-
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	NOT DETECTED	-
<i>Pseudomonas aeruginosa</i> ^b	/100 mL	MEMBRANE FILTER TECHNIQUE FOR PSEUDOMONAS AERUGINOSA (SM: PART 9213 E)	DETECTED	1/	-
SAMPLE CONDITION					
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR		

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH, B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR



ANALYSIS REPORT

CUSTOMER NAME	: THE RESERVE SATHORN		
ADDRESS	: 2 SOI SUAN PHLU, THUNG MAHA MEK SATHON BANGKOK 10120		
CONTACT INFORMATION	: TEL : 08 1145 2247 e-mail : juristic@thereservesathorn.com		
SAMPLING SOURCE	: -		
SAMPLE TYPE	: WATER SAMPLE FROM SWIMMING POOL	RECEIVED DATE	: JUNE 9, 2026
SAMPLING DATE	: JUNE 9, 2026	ANALYTICAL DATE	: JUNE 9-15, 2026
SAMPLING TIME	: 10:20 HOUR	ISSUE DATE	: JUNE 18, 2026
SAMPLING METHOD *	: GRAB AND STERILE TECHNIQUE	REPORT NO.	: 2026-U052532
SAMPLING BY *	: MR SITTHIPOL PROMPOCHENBOON	WORK NO.	: 2025-008822
ANALYZED BY	: MISS JITSAMON NGAMKANA	ANALYSIS NO.	: T26AM654-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD
			สระว่ายน้ำน้ำส่วนลึก T26AM654-0003	
MICROBIOLOGY				
Staphylococcus aureus	/100 mL	STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER. APHA, AWWA, WEF. 24th EDITION, 2023. PART 9213 B.	NOT DETECTED	1/
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

THE LABORATORY HAS BEEN ACCEPTED AS AN ACCREDITED LABORATORY COMPLYING WITH THE ISO/IEC 17025.

* : TEST METHOD ARE NOT COVERED COMPLYING WITH THE ISO/IEC 17025. VERIFIED BY OWN LABORATORY QUALITY SYSTEM.

REGULATORY STANDARD : BANGKOK METROPOLITAN REGULATIONS FOR THE BUSINESS DISTRIMENTAL TO HEALTH. B.E. 2530 (1987).

1/ : DISEASE-CAUSING BACTERIA IS NOT DETECTED.

(MISS CHAWEEWAN BOONLA)
LABORATORY SUPERVISOR

ภาคผนวก ง-3

ผลการติดตามตรวจสอบคุณภาพน้ำระวายน้ํา CL2

Swimming Pool Daily Checklist

ใบรายงานการตรวจสอบสระว่ายน้ำ



Sheet No. / แผ่นที่ ...1...

Month / เดือน กุมภาพันธ์ Year / ปี 2569

Building / อาคาร เดอะ รีเจนท์ สวาท

Date วันที่	Time เวลา	Status Record บันทึกค่า			Adding / การเติม			Condition of Equipment / สภาพของอุปกรณ์										Recorded By บันทึกโดย	Checked By ตรวจสอบโดย
		CL (1-1.5)	PH (7.2-7.6)	SALT 3,600ppm	Salt เกลือ (กรละสอบ)	Chlorine คลอรีน (kg.)	Soda Ash โซดา-แอส (kg.)	Pump Set ชุดปั๊มกรอง		Pump Set ชุดปั๊ม Jacuzzi			Pump Set ชุดปั๊มน้ำสัน			Pressure Tank แรงดันถัง (PSI)			
								No.1	No.2	No.1	No.2	No.3	No.1	No.2	No.3	No.1	No.2		
1	08.14	1.5	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
2	07.45	0.2	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	16	N/A		
3	09.15	3.0	8.2	N/A	-	2	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
4	09.39	9.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
5	07.52	2.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
6	07.59	1.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
7	04.53	0	8.2	N/A	-	4	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
8	07.39	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
9	07.48	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	16	N/A		
10	09.23	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
11	08.56	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
12	09.24	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
13	08.30	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
14	07.41	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	16	N/A		
15	06.02	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	18	N/A		
16	07.43	1.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	16	N/A		
17	09.11	0.5	7.2	N/A	-	4	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
18	06.52	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
19	8.40	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
20	07.18	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
21	09.30	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
22	07.46	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
23	07.46	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	16	N/A		
24	09.39	0.5	8.2	N/A	-	4	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
25	11.04	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
26	09.09	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
27	09.41	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		
28	09.37	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A		

รวม

Remark / หมายเหตุ :

Used within month / Remain (ปริมาณที่ใช้จริงในรอบเดือน / ยอดคงเหลือ)

Chlorine (คลอรีน) 14 kg Salt (เกลือ) กระสอบ Hydrochloric Acid (กรดเกลือ) Litre

Soda Ash (โซดา-แอส) kg

Note : Please Mark N/A if not applicable, ✓ Normal, ✗ Abnormal / กรุณาใส่ N/A ถ้าไม่มีข้อมูล, ✓ ปกติ, ✗ ไม่ปกติ

Verified By / ทบทวนตรวจสอบโดย

Signature / ลายเซ็น (BM / ผู้จัดการอาคาร)

Date / วันที่ 6 / 11 / 2569

F-ENG-PSW-001



Swimming Pool Daily Checklist

ใบรายงานการตรวจสอบสระว่ายน้ำ

Sheet No. / แผ่นที่ ...1...

Month / เดือน มกราคม Year / ปี 2569

Building / อาคาร เดอะ รีเจนท์ สวาท

Date วันที่	Time เวลา	Status Record			Adding / การเติม			Condition of Equipment / สภาพของอุปกรณ์										Recorded By บันทึกโดย	Checked By ตรวจสอบโดย
		บันทึกค่า			Salt เกลือ (กรละสอบ)	Chlorine คลอรีน (kg.)	Soda Ash โซดา-แอส (kg.)	Pump Set ชุดปั๊มกรอง		Pump Set ชุดปั๊ม Jacuzzi			Pump Set ชุดปั๊มน้ำสัน			Pressure Tank แรงดันถัง(PSI)			
		CL (1-1.5)	PH (7.2-7.6)	SALT 3,600ppm				No.1	No.2	No.1	No.2	No.3	No.1	No.2	No.3	No.1	No.2		
1	08.00	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A	
2	09.00	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A	
3	09.00	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A	
4	07.44	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A	
5	07.59	1.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	17	N/A	
6	08.51	0.5	7.6	N/A	-	3	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A	
7	08.41	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A	
8	09.09	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A	
9	09.28	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A	
10	07.33	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	17	N/A	
11	07.23	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	17	N/A	
12	08.00	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	17	N/A	
13	08.51	2.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	19	N/A	
14	08.45	1.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	14	N/A	
15	09.03	0.5	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	14	N/A	
16	09.32	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	14	N/A	
17	09.50	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A	
18	07.32	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A	
19	07.33	N/A	N/A	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	0	N/A	
20	07.48	-	-	-	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	0	N/A	
21	07.28	-	-	-	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	0	N/A	
22	07.40	-	-	-	-	4	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	0	N/A	
23	09.22	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A	
24	09.00	3.0	7.8	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A	
25	08.03	3.0	7.8	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A	
26	07.45	0.6	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A	
27	09.59	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A	
28	09.10	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A	
29	08.50	7.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A	
30	08.49	3.0	8.8	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A	
31	11.07	2.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A	

รวม

Remark / หมายเหตุ :

Used within month / Remain (ปริมาณที่ใช้จริงในรอบเดือน / ยอดคงเหลือ)

Chlorine (คลอรีน) 7 kg Salt (เกลือ) กระสอบ Hydrochloric Acid (กรดเกลือ) Litre

Soda Ash (โซดา-แอส) kg

Note : Please Mark N/A if not applicable, ✓ Normal, ✗ Abnormal / กรุณาใส่ N/A ถ้าไม่มีข้อมูล, ✓ ปกติ, ✗ ไม่ปกติ

Verified By / ทบทวนตรวจสอบโดย

Signature / ลายเซ็น (BM / ผู้จัดการอาคาร)

Date / วันที่ 22 / 2 / 2569

F-ENG-PSW-001

Swimming Pool Daily Checklist

ใบรายงานการตรวจสอบสระว่ายน้ำ

Month / เดือน เมษายน Year / ปี 2569

Building / อาคาร เดอะ รีเจนท์ สโมสร

Date วันที่	Time เวลา	Status Record			Adding / การเติม			Condition of Equipment / สภาพของอุปกรณ์										Recorded By บันทึกโดย	Checked By ตรวจสอบโดย
		บันทึกค่า			Salt เกล็ด (กรรลอน)	Chlorine คลอรีน (kg)	Soda Ash โซดา-แอช (kg.)	Pump Set ชุดปั๊มกรอง		Pump Set ชุดปั๊ม Jazzuci			Pump Set ชุดปั๊มน้ำขึ้น			Pressure Tank แรงดันถัง(Psi)			
		CL (1-1.5)	PH (7.2-7.6)	SALT 3,600ppm				No.1	No.2	No.1	No.2	No.3	No.1	No.2	No.3	No.1	No.2		
1	8.00	3.0	7.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
2	8.00	3.0	7.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
3	8.00	3.0	7.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
4	8.00	3.0	7.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
5	08.26	3.0	7.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
6	08.00	2.0	7.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	18	N/A		
7	08.00	0.9	7.2	N/A	-	2	-	/	N/A	/	/	/	/	/	/	19	N/A		
8	09.00	3.0	7.6	N/A	-	-	2	/	N/A	/	/	/	/	/	/	16	N/A		
9	08.00	3.0	7.6	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
10	01.32	3.0	7.6	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
11	10.05	3.0	7.6	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
12	07.52	3.0	7.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	16	N/A		
13	07.38	3.0	7.6	N/A	-	-	-	/	N/A	/	/	/	/	/	/	16	N/A		
14	07.30	3.0	7.8	N/A	-	-	-	/	N/A	/	/	/	/	/	/	17	N/A		
15	07.57	1.5	7.8	N/A	-	1.5	-	/	N/A	/	/	/	/	/	/	17	N/A		
16	07.43	3.0	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	18	N/A		
17	07.49	3.0	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
18	10.30	3.0	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
19	07.43	3.0	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
20	9.53	3.0	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
21	09.28	3.0	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
22	09.30	3.0	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
23	09.50	3.0	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
24	10.30	3.0	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
25	10.29	3.0	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
26	07.43	1.5	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	18	N/A		
27	9.56	0.5	8.2	N/A	-	2	-	/	N/A	/	/	/	/	/	/	19	N/A		
28	9.32	3.0	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
29	8.30	3.0	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
30	9.28	3.0	8.2	N/A	-	-	-	/	N/A	/	/	/	/	/	/	19	N/A		
31					-	-	-	-	N/A	-	-	-	-	-	-	-	N/A		

รวม

Remark / หมายเหตุ :

Used within month / Remain (ปริมาณที่ใช้จริงในรอบเดือน / ยอดคงเหลือ)

Chlorine (คลอรีน) 5.5 kg. Salt (เกล็ด) 2 kg. กรรณ Hydrochloric Acid (กรดเกลือ) Litre

Soda Ash (โซดาแอช) kg.

Note : Please Mark N/A if not applicable, ✓ Normal, ✗ Abnormal / กรุณาใส่ N/A ถ้าไม่เกี่ยวข้อง, ✓ ปกติ ✗ ไม่ปกติ

Verified By / ทบทวนตรวจสอบโดย

Signature / ลงนาม (RM / ผู้จัดการอาคาร)

Date / วันที่ 25.6.2569

F-ENG-PSW-001



Swimming Pool Daily Checklist

ใบรายงานการตรวจสอบสระว่ายน้ำ

Month / เดือน มีนาคม Year / ปี 2569

Building / อาคาร เดอะ รีเจนท์ สโมสร

Date วันที่	Time เวลา	Status Record			Adding / การเติม			Condition of Equipment / สภาพของอุปกรณ์										Recorded By	บันทึกโดย	Checked By	ตรวจสอบโดย
		บันทึกค่า			Salt เกลือ (gr/lb)	Chlorine คลอรีน (kg)	Soda Ash โซดาแอช (kg)	Pump Set		Pump Set			Pump Set			Pressure Tank					
		CL (1-1.5)	PH (7.2-7.6)	SALT 3,600ppm				ชุดปั๊มกรอง	ชุดปั๊ม Jazuczi	ชุดปั๊มน้ำดื่ม			แรงดันถัง (PSI)								
								No.1	No.2	No.1	No.2	No.3	No.1	No.2	No.3	No.1	No.2				
1	08.09	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
2	07.35	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	16	N/A				
3	10.26	1.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
4	09.49	0.5	7.2	N/A	-	4	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
5	08.10	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	19	N/A				
6	08.16	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
7	09.23	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
8	07.47	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	18	N/A				
9	07.40	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	18	N/A				
10	9.00	2.0	7.2	N/A	-	1	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
11	08.50	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
12	07.35	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
13	10.00	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
14	07:55	1.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	16	N/A				
15	07.46	0.2	6.8	N/A	-	1.5	-	✓	N/A	✓	✓	✓	✓	✓	✓	16	N/A				
16	10.35	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	19	N/A				
17	10.11	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
18	09.32	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
19	09.43	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
20	08.59	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
21	08.30	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	16	N/A				
22	08.00	4.5	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	16	N/A				
23	08.50	1.0	7.2	N/A	-	4	-	✓	N/A	✓	✓	✓	✓	✓	✓	19	N/A				
24	09.36	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
25	10.00	3.0	7.2	N/A	-	-	1	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
26	08.49	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
27	08.20	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
28	09.45	3.0	7.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
29	08.17	3.0	7.6	N/A	✓	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
30	12.27	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				
31	09.31	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	15	N/A				

รวม

Remark / หมายเหตุ :

Used within month / Remain (ปริมาณที่ใช้จริงในรอบเดือน / ยอดคงเหลือ)

Chlorine (คลอรีน) 10.5 kg. Salt (เกล็ด) กรรณ Hydrochloric Acid (กรดเกลือ) Litre

Soda Ash (โซดาแอช) 1 kg

Note : Please Mark N/A if not applicable, ✓ Normal, ✗ Abnormal / กรุณาใส่ N/A ถ้าไม่เกี่ยวข้อง, ✓ ปกติ ✗ ไม่ปกติ

Verified By / ทบทวนตรวจสอบโดย

Signature / ลงนาม (RM / ผู้จัดการอาคาร)

Date / วันที่ 23.6.2569



F-ENG-PSW-001

Swimming Pool Daily Checklist

ใบรายงานการตรวจสอบสระว่ายน้ำ

Sheet No. / แผ่นที่ ...1...

Month / เดือน มิถุนายน Year / ปี 2569

Building / อาคาร เดอะ ริเวอร์ฟ สาท

Date วันที่	Time เวลา	Status Record			Adding / การเติม			Condition of Equipment / สภาพของอุปกรณ์												Recorded By	บันทึกโดย	Checked By	ตรวจสอบโดย
		บันทึกค่า			Salt เกลือ (กระสอบ)	Chlorine คลอรีน (kg.)	Soda Ash โซดา-แอช (kg.)	Pump Set ชุดปั๊มกรอง			Pump Set ชุดปั๊ม Jazzuci			Pump Set ชุดปั๊มน้ำสัน			Pressure Tank แรงดันถัง(PSI)						
		CL (1-1.5)	PH (7.2-7.6)	SALT 3,600ppm				No.1	No.2	No.3	No.1	No.2	No.3	No.1	No.2	No.3	No.1	No.2					
1	09.00	0.0	7.6	N/A	-	1	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	19	N/A					
2	09.52	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
3	09.57	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
4	09.30	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
5	08.57	1.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
6	09.32	0.5	7.6	N/A	-	1	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
7	09.13	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A					
8	09.00	3.0	7.6	N/A	-	2	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	17	N/A					
9	08.57	2.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
10	08.17	0.6	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
11	09.51	0.0	7.6	N/A	-	1	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
12	10.00	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
13	08.55	3.0	6.8	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
14	08.09	3.0	7.8	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A					
15	08.39	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
16	08.10	3.0	7.8	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
17	09.20	2.0	7.8	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
18	08.50	3.0	8.2	N/A	-	2	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
19	08.21	3.0	7.8	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
20	10.01	3.0	7.8	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
21	09.40	7.0	7.8	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
22	09.20	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
23	09.23	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
24	09.57	1.0	7.6	N/A	-	1	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
25	10.32	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
26	09.56	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
27	08.50	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	17	N/A					
28	08.03	0.2	6.8	N/A	-	1	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A					
29	08.29	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
30	10.40	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					
31					-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A					

รวม

Remark / หมายเหตุ :

Used within month / Remain (ปริมาณที่ใช้จริงในรอบเดือน / ยอดคงเหลือ)

Chlorine (คลอรีน) kg

Salt (เกล็ด) กระสอบ

Hydrochloric Acid(กรดเกลือ) Litre

Note : Please Mark N/A if not applicable, ✓ Normal, ✗ Abnormal / กรุณาใส่ N/A ถ้าไม่มีข้อมูล, ✓ ปกติ, ✗ ไม่ปกติ

Verified By / ทบทวนตรวจสอบโดย

Signature / ลายเซ็น (BM / ผู้จัดการอาคาร)

Date / วันที่ 23 ก.ค. 2569

F-ENG-PSW-001



Swimming Pool Daily Checklist

ใบรายงานการตรวจสอบสระว่ายน้ำ

Sheet No. / แผ่นที่ ...1...

Month / เดือน พฤษภาคม Year / ปี 2569

Building / อาคาร เดอะ ริเวอร์ฟ สาท

Date วันที่	Time เวลา	Status Record บันทึกค่า			Adding / การเติม			Condition of Equipment / สภาพของอุปกรณ์										Recorded By บันทึกโดย	Checked By ตรวจสอบโดย		
		CL. (1-1.5)	PH (7.2-7.6)	SALT 3,600ppm	Salt (กระสอบ)	Chlorine (kg)	Soda Ash (kg)	Pump Set ชุดปั๊มกรอง			Pump Set ชุดปั๊ม Jazzuci			Pump Set ชุดปั๊มน้ำสัน			Pressure Tank แรงดันถัง(PSI)				
								No.1	No.2	No.3	No.1	No.2	No.3	No.1	No.2	No.3	No.1	No.2			
1	07.34	1.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A			
2	10.00	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	13	N/A			
3	07.43	3.0	7.8	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
4	09.40	3.0	7.6	N/A	-	1	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	13	N/A			
5	09.00	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
6	12.00	1.0	7.6	N/A	-	1	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	13	N/A			
7	09.35	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
8	09.40	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
9	08.10	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
10	08.40	3.0	7.8	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A			
11	10.08	3.0	7.8	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A			
12	08.24	0.5	7.6	N/A	-	1	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	16	N/A			
13	08.24	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
14	08.24	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
15	08.59	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
16	09.28	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
17	07.33	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	17	N/A			
18	11.00	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
19	10.32	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
20	09.48	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
21	09.00	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
22	09.35	2.5	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
23	09.52	1.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
24	08.47	0.2	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
25	10.38	3.0	7.6	N/A	-	2	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
26	09.00	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
27	08.01	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	14	N/A			
28	9.59	2.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
29	10.00	0.5	7.6	N/A	-	2	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
30	09.03	3.0	7.6	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			
31	07.37	3.0	8.2	N/A	-	-	-	✓	N/A	✓	✓	✓	✓	✓	✓	✓	15	N/A			

รวม

Remark / หมายเหตุ :

Used within month / Remain (ปริมาณที่ใช้จริงในรอบเดือน / ยอดคงเหลือ)

Chlorine (คลอรีน) 8.0 kg

Salt (เกล็ด) กระสอบ

Hydrochloric Acid(กรดเกลือ) Litre

Note : Please Mark N/A if not applicable, ✓ Normal, ✗ Abnormal / กรุณาใส่ N/A ถ้าไม่มีข้อมูล, ✓ ปกติ, ✗ ไม่ปกติ

Verified By / ทบทวนตรวจสอบโดย

Signature / ลายเซ็น (BM / ผู้จัดการอาคาร)

Date / วันที่ 23 ก.ค. 2569

F-ENG-PSW-001