

ภาคผนวกที่ 7

แบบบันทึกการตรวจสอบ FHC

PREVENTIVE MAINTENANCE CHECK LIST (FHC)

Jun-26

Approved by : Assistant Safety & Security Manager

GRAND MERCURE

PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month: June., 2026

DESCRIPTION		Fire Extinguisher	Axe	Hose Reel	Fire Hoses	Jet Nozzle	Hydrant Cover	Factory Hydrant	Public Hydrant	Chalk	Remark
		ถังดับเพลิง	ขวาน	สายฉีดแบบม้วน	สายดับเพลิง	หัวฉีดเจ็ท	ฝาครอบท่อและข้อ	หัวจ่ายน้ำดับเพลิง	หัวรับน้ำดับเพลิง	ชอล์ก	
Fire Hose Cabinet Main building											
FHC-01	Louding Laundry	/	/	/	/	NA	/	/	NA	/	ชำรุด
FHC-02	Front Engineering Office	/	/	/	/	/	/	/	NA	/	
FHC-03	Allday Right	/	/	/	/	/	/	/	NA	/	
FHC-04	Allday Left	/	/	/	/	/	/	/	NA	/	
FHC-05	Training Room	/	NA	/	/	/	/	/	NA	/	
FHC-06	Pump Room	/	/	/	/	/	/	/	NA	/	
FHC-07	Lift Service Block.A FL.1	/	/	/	/	/	/	/	NA	/	
FHC-16	Meeting Room	/	/	/	NA	NA	/	/	NA	/	
FHC-17	Meeting Room	/	/	/	NA	NA	/	/	NA	/	
FHC-20	Daily Shop	/	/	/	NA	NA	/	/	NA	/	
Fire Hose Cabinet block A											
FHC-21	Block A FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-31	Block A FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-41	Block A FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-51	Block A FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-61	Block A FL.6	/	NA	/	/	NA	/	/	NA	/	
Fire Hose Cabinet block B											
FHC-09	Lift block B FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-08	Block B FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-23	Lift block B FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-22	Block B FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-33	Lift block B FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-32	Block B FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-43	Lift block B FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-42	Block B FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-53	Lift block B FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-52	Block B FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-63	Lift block B FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-62	Block B FL.6	/	NA	/	/	NA	/	/	NA	/	
FHC-71	Lift block B FL.7	/	NA	/	/	NA	/	/	NA	/	
Fire Hose Cabinet block C											
FHC-10	Lift block C FL.1	/	NA	/	/	/	NA	/	NA	/	
FHC-24	Lift block C FL.2	/	NA	/	NA	NA	NA	/	NA	/	
FHC-34	Lift block C FL.3	/	NA	/	NA	NA	NA	/	NA	/	
FHC-44	Lift block C FL.4	/	NA	/	NA	NA	NA	/	NA	/	
FHC-54	Lift block C FL.5	/	NA	/	NA	NA	NA	/	NA	/	
FHC-64	Lift block C FL.6	/	NA	/	NA	NA	NA	/	NA	/	
FHC-72	Lift block C FL.7	/	NA	/	/	NA	NA	/	NA	/	
Fire Hose Cabinet block D											
FHC-11	Block D FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-25	Block D FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-35	Block D FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-45	Block D FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-55	Block D FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-65	Block D FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-73	Block D FL.7	/	NA	/	/	NA	/	/	NA	/	

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month..June.,2026

DESCRIPTION		Fire	Axe	Hose Reel	Fire Hoses	Jet Nozzle	Hydrant	Factory	Public	Chalk	Remark
		Extinguisher					Cover	Hydrant	Hydrant		
		ถังดับเพลิง	ขวาน	สายฉีดแบบม้วน	สายดับเพลิง	หัวฉีดเจ็ท	ฝาครอบและข้อต่อ	หัวจ่ายน้ำดับเพลิง	หัวรับน้ำดับเพลิง	ชอล์ก	
Fire Hose Cabinet block E											
FHC-12	Block E FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-26	Block E FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-36	Block E FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-46	Block E FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-56	Block E FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-66	Block E FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-74	Block E FL.7	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block F											
FHC-13	Block F FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-27	Block F FL.2	/	NA	/	NA	NA	/	/	NA	/	Cabinet cannot be locked
FHC-37	Block F FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-47	Block F FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-57	Block F FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-67	Block F FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-75	Block F FL.7	/	NA	/	/	/	/	/	NA	/	
FHC-76	Lift block G FL.7	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block G											
FHC-14	Lift block G FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-15	Block G FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-28	Lift block G FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-29	Block G FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-38	Lift block G FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-39	Block G FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-48	Lift block G FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-49	Block G FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-58	Lift block G FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-59	Block G FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-68	Lift block G FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-69	Block G FL.6	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block H											
FHC-77	Owner Office FL.3	/	/	/	NA	NA	/	/	NA	/	
FHC-30	Lift block H FL.2	/	NA	/	NA	NA	/	/	NA	/	Cabinet cannot be locked
FHC-40	Lift block H FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-50	Lift block H FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-60	Lift block H FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-70	Lift block H FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-02	Panty Poom of Buliding C	NA	NA	NA	/	NA	NA	NA	NA	NA	
FHC-01	Panty Poom infont villa	NA	NA	NA	/	NA	NA	NA	NA	NA	

Security Check.....

Asst. Safety & Security Manager.....

Security Check.....

Date.....

Date..... 12/06/26

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month..June, 2026

No.	Description	Factory Hydrant		Public Hydrant		Remarks
		ข้อต่อ	ฝาดรอป	ข้อต่อ	ฝาดรอป	
1	Factory Hydrant in front of Chiller room FL.3	✓	✓			
2	Public Hydrant in front of parking Area M.2			✓	✓	
3	Factory Hydrant in front of parking Area M.2	✓	✓			
4	Public Hydrant in front of Building B			✓	✓	
5	Factory Hydrant in front of Building B	✓	✓			
6	Factory Hydrant in front of Building C	✓	✓			
7	Factory Hydrant in Walk way Villa 914	✓	✓			
8	Factory Hydrant in Walk way Villa 901	✓	✓			
9	Factory Hydrant in Walk way Villa 902	✓	✓			
10	Factory Hydrant in Walk way Security M.4	N/A	N/A			
11	Factory Hydrant in front of Office Owner FL.3	✓	✓			
12	Factory Hydrant in front of parking Area M.1	✓	✓			
13	Public Hydrant in front of parking Area M.1			✓	✓	
14	Factory Hydrant in front of Building F	✓	✓			
15	Public Hydrant in front of Hotel Water pipes M.1			✓	N/A	
16	Factory Hydrant in front of Roof Block A	✓	✓			
17	Factory Hydrant in front of Roof Block B	✓	✓			
18	Factory Hydrant in front of Roof Block C	✓	✓			
19	Factory Hydrant in front of Roof Block D	✓	✓			
20	Factory Hydrant in front of Roof Block E	✓	✓			
21	Factory Hydrant in front of Roof Block F	✓	✓			
22	Factory Hydrant in front of Roof Block G	✓	✓			
23	Factory Hydrant in front of Roof Block H	✓	✓			

Security Supervisor Check.....  Asst. Safety & Security Manager.....

Date..... 13/06/26

Date.....

GRAND MERCURE

PHUKET PATONG

Fire Extinguishers Inspection

Month..June.,2026

Place	Type	Condition	Pressure	Remarks
Fire Pump	Dry Chemical	OK	OK	
	CO2	OK	OK	
Generator Room	Dry Chemical	OK	OK	
	CO2	OK	OK	
Kitchen Main	Fire Blanket	OK	OK	
	Form	OK	OK	
Bubble Restaurant	Fire Blanket	OK	OK	
	Form	OK	OK	
Gas Store	Dry Chemical	OK	OK	
	Dry Chemical	OK	OK	
Laundry	Dry Chemical	OK	OK	
Villa Club	Halon FL.2	OK	OK	
	Halon FL.3	NA	NA	
IT Office	Fireade2000	OK	OK	
M1	Dry Chemical	OK	OK	
M2	Dry Chemical	OK	OK	
Security Office	Fireade2000	OK	OK	
Spa	Dry Chemical	OK	OK	
Kitchen Canteen	Fire Blanket	OK	OK	
Begery Room	Fire Blanket	OK	OK	
Accounting Office	Fireade2000	OK	OK	
Server Room	Fireade2000	OK	OK	
Gardener's Office	Fireade2000	OK	OK	
Parking Area M1	Dry Chemical	OK	OK	
Parking Area M2	Dry Chemical	OK	OK	
Building B Rooftop	Halon	OK	OK	
Building G Rooftop	Halon	OK	OK	

Security Supervisor..... Asst. Safety & Security Manager.....

Date.....13/06/26.....

Date.....

GRAND MERCURE
PHUKET PATONG

Fire Extinguishers Inspection

Month..June.,2026

Place	Type	Condition	Pressure	Remarks
Villa 901	Dry Chemical	ok	ok	
Villa 902	Dry Chemical	ok	ok	
Villa 903	Dry Chemical	ok	ok	
Villa 904	Dry Chemical	ok	ok	
Villa 905	Dry Chemical	ok	ok	
Villa 906	Dry Chemical	ok	ok	
Villa 907	Dry Chemical	ok	ok	
Villa 908	Dry Chemical	ok	ok	
Villa 909	Dry Chemical	ok	ok	
Villa 910	Dry Chemical	ok	ok	
Villa 911	Dry Chemical	ok	ok	
Villa 912	Dry Chemical	ok	ok	
Villa 913	Dry Chemical	ok	ok	
Villa 914	Dry Chemical	ok	ok	

Security Check

Safety&Security Manager.....

Security Check 

Date.....

Date..... 27/06/26

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST (FHC)

Month

May-26

Inspection by : Security Supervisor



Approved by : Assistant Safety & Security Manager

GRAND MERCURE

PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month.May.,2026

DESCRIPTION		Fire Extinguisher	Axe	Hose Reel	Fire Hoses	Jet Nozzle	Hydrant Cover	Factory Hydrant	Public Hydrant	Chalk	Remark
		ถังดับเพลิง	ขวาน	สายฉีดแบบม้วน	สายดับเพลิง	หัวฉีดเจ็ท	ฝาครอบท่อและข้อ	หัวจ่ายน้ำดับเพลิง	หัวรับน้ำดับเพลิง	ชอล์ก	
Fire Hose Cabinet Main building											
FHC-01	Louding Laundry	/	/	/	/	NA	/	/	NA	/	8/5/26
FHC-02	Front Engineering Office	/	/	/	/	/	/	/	NA	/	
FHC-03	Allday Right	/	/	/	/	/	/	/	NA	/	
FHC-04	Allday Left	/	/	/	/	/	/	/	NA	/	
FHC-05	Training Room	/	/	/	/	/	/	/	NA	/	
FHC-06	Pump Room	/	/	/	/	/	/	/	NA	/	
FHC-07	Lift Service Block.A FL.1	/	/	/	/	/	/	/	NA	/	
FHC-16	Meeting Room	/	/	/	NA	NA	/	/	NA	/	
FHC-17	Meeting Room	/	/	/	NA	NA	/	/	NA	/	
FHC-20	Daily Shop	/	/	/	NA	NA	/	/	NA	/	
Fire Hose Cabinet block A											
FHC-21	Block A FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-31	Block A FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-41	Block A FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-51	Block A FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-61	Block A FL.6	/	NA	/	/	NA	/	/	NA	/	
Fire Hose Cabinet block B											
FHC-09	Lift block B FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-08	Block B FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-23	Lift block B FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-22	Block B FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-33	Lift block B FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-32	Block B FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-43	Lift block B FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-42	Block B FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-53	Lift block B FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-52	Block B FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-63	Lift block B FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-62	Block B FL.6	/	NA	/	/	NA	/	/	NA	/	
FHC-71	Lift block B FL.7	/	NA	/	/	NA	/	/	NA	/	
Fire Hose Cabinet block C											
FHC-10	Lift block C FL.1	/	NA	/	/	/	NA	/	NA	/	
FHC-24	Lift block C FL.2	/	NA	/	NA	NA	NA	/	NA	/	
FHC-34	Lift block C FL.3	/	NA	/	NA	NA	NA	/	NA	/	
FHC-44	Lift block C FL.4	/	NA	/	NA	NA	NA	/	NA	/	
FHC-54	Lift block C FL.5	/	NA	/	NA	NA	NA	/	NA	/	
FHC-64	Lift block C FL.6	/	NA	/	NA	NA	NA	/	NA	/	
FHC-72	Lift block C FL.7	/	NA	/	/	NA	NA	/	NA	/	
Fire Hose Cabinet block D											
FHC-11	Block D FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-25	Block D FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-35	Block D FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-45	Block D FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-55	Block D FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-65	Block D FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-73	Block D FL.7	/	NA	/	/	NA	/	/	NA	/	

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month..May.,2026

DESCRIPTION		Fire	Axe	Hose Reel	Fire Hoses	Jet Nozzle	Hydrant	Factory	Public	Chalk	Remark
		Extinguisher					Cover	Hydrant	Hydrant		
		ถังดับเพลิง	ขวาน	สายฉีดแบบม้วน	สายดับเพลิง	หัวฉีดเชือก	ฝาครอบและข้อต่อ	หัวจ่ายน้ำดับเพลิง	หัวรับน้ำดับเพลิง	ชอล์ก	
Fire Hose Cabinet block E											
FHC-12	Block E FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-26	Block E FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-36	Block E FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-46	Block E FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-56	Block E FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-66	Block E FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-74	Block E FL.7	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block F											
FHC-13	Block F FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-27	Block F FL.2	/	NA	/	NA	NA	/	/	NA	/	Cabinet cannot be locked.
FHC-37	Block F FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-47	Block F FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-57	Block F FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-67	Block F FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-75	Block F FL.7	/	NA	/	/	/	/	/	NA	/	
FHC-76	Lift block G FL.7	/	NA	/	/	/	/	/	NA	/	Fire extinguisher pressure is low.
Fire Hose Cabinet block G											
FHC-14	Lift block G FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-15	Block G FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-28	Lift block G FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-29	Block G FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-38	Lift block G FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-39	Block G FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-48	Lift block G FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-49	Block G FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-58	Lift block G FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-59	Block G FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-68	Lift block G FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-69	Block G FL.6	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block H											
FHC-77	Owner Office FL.3	/	/	/	NA	NA	/	/	NA	/	
FHC-30	Lift block H FL.2	/	NA	/	NA	NA	/	/	NA	/	Cabinet cannot be locked.
FHC-40	Lift block H FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-50	Lift block H FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-60	Lift block H FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-70	Lift block H FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-02	Panty Poom of Buliding C	NA	NA	NA	/	NA	NA	NA	NA	NA	
FHC-01	Panty Poom infont villa	NA	NA	NA	/	NA	NA	NA	NA	NA	

Security Check.....Maxisolep

Asst. Safety & Security Manager.....

Security Check.....

Date.....

Date.....04/05/26

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month..May, 2026

No.	Description	Factory Hydrant		Public Hydrant		Remarks
		ข้อต่อ	ฝาครอบ	ข้อต่อ	ฝาครอบ	
1	Factory Hydrant in front of Chiller room FL.3	✓	✓			
2	Public Hydrant in front of parking Area M.2			✓	✓	
3	Factory Hydrant in front of parking Area M.2	✓	✓			
4	Public Hydrant in front of Building B			✓	✓	
5	Factory Hydrant in front of Building B	✓	✓			
6	Factory Hydrant in front of Building C	✓	✓			
7	Factory Hydrant in Walk way Villa 914	✓	✓			
8	Factory Hydrant in Walk way Villa 901	✓	✓			
9	Factory Hydrant in Walk way Villa 902	✓	✓			
10	Factory Hydrant in Walk way Security M.4	N/A	N/A			
11	Factory Hydrant in front of Office Owner FL.3	✓	✓			
12	Factory Hydrant in front of parking Area M.1	✓	✓			
13	Public Hydrant in front of parking Area M.1			✓	✓	
14	Factory Hydrant in front of Building F	✓	✓			
15	Public Hydrant in front of Hotel Water pipes M.1			✓	N/A	
16	Factory Hydrant in front of Roof Block A	✓	✓			
17	Factory Hydrant in front of Roof Block B	✓	✓			
18	Factory Hydrant in front of Roof Block C	✓	✓			
19	Factory Hydrant in front of Roof Block D	✓	✓			
20	Factory Hydrant in front of Roof Block E	✓	✓			
21	Factory Hydrant in front of Roof Block F	✓	✓			
22	Factory Hydrant in front of Roof Block G	✓	✓			
23	Factory Hydrant in front of Roof Block H	✓	✓			

Security Supervisor Check..... Asst. Safety & Security Manager.....

Date..... 18/05/26

Date.....

GRAND MERCURE

PHUKET PATONG

Fire Extinguishers Inspection

Month..May.,2026

Place	Type	Condition	Pressure	Remarks
Fire Pump	Dry Chemical	OK	OK	
	CO2	OK	OK	
Generator Room	Dry Chemical	OK	OK	
	CO2	OK	OK	
Kitchen Main	Fire Blanket	OK	OK	
	Form	OK	OK	
Bubble Restaurant	Fire Blanket	OK	OK	
	Form	OK	OK	
Gas Store	Dry Chemical	OK	OK	
	Dry Chemical	OK	OK	
Laundry	Dry Chemical	OK	OK	
Villa Club	Halon FL.2	OK	OK	
	Halon FL.3	NA	NA	
IT Office	Fireade2000	OK	OK	
M1	Dry Chemical	OK	OK	
M2	Dry Chemical	OK	OK	
Security Office	Fireade2000	OK	OK	
Spa	Dry Chemical	OK	OK	
Kitchen Canteen	Fire Blanket	OK	OK	
Begery Room	Fire Blanket	OK	OK	
Accounting Office	Fireade2000	OK	OK	
Server Room	Fireade2000	OK	OK	
Gardener's Office	Fireade2000	OK	OK	
Parking Area M1	Dry Chemical	OK	OK	
Parking Area M2	Dry Chemical	OK	OK	
Building B Rooftop	Halon			Use to practice.
Building G Rooftop	Halon			Use to practice.

Security Supervisor..... Asst. Safety & Security Manager.....

Date.....18/05/26..... Date.....

GRAND MERCURE
PHUKET PATONG

Fire Extinguishers Inspection

Month..May.,2026

Place	Type	Condition	Pressure	Remarks
Villa 901	Dry Chemical	ok	ok	
Villa 902	Dry Chemical	ok	ok	
Villa 903	Dry Chemical	ok	ok	
Villa 904	Dry Chemical	ok	ok	
Villa 905	Dry Chemical	ok	ok	
Villa 906	Dry Chemical	ok	ok	
Villa 907	Dry Chemical	ok	ok	
Villa 908	Dry Chemical	ok	ok	
Villa 909	Dry Chemical	ok	ok	
Villa 910	Dry Chemical	ok	ok	
Villa 911	Dry Chemical	ok	ok	
Villa 912	Dry Chemical	ok	ok	
Villa 913	Dry Chemical	ok	ok	
Villa 914	Dry Chemical	ok	ok	

Security Check Marsusalee

Safety&Security Manager.....

Security Check

Date.....

Date... 12/06/2026

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST (FHC)

Month

Apr-26

Inspection by : Security Supervisor



Approved by : Assistant Safety & Security Manager

GRAND MERCURE

PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month. April., 2026

DESCRIPTION		Fire Extinguisher	Axe	Hose Reel	Fire Hoses	Jet Nozzle	Hydrant Cover	Factory Hydrant	Public Hydrant	Chalk	Remark
		ถังดับเพลิง	ขวาน	สายฉีดแบบม้วน	สายดับเพลิง	หัวฉีดเจ็ท	ฝาครอบท่อและข้อ	หัวจ่ายน้ำดับเพลิง	หัวรับน้ำดับเพลิง	ชอล์ก	
Fire Hose Cabinet Main building											
FHC-01	Louding Laundry	/	/	/	/	NA	/	/	NA	/	87307
FHC-02	Front Engineering Office	/	/	/	/	/	/	/	NA	/	
FHC-03	Allday Right	/	/	/	/	/	/	/	NA	/	
FHC-04	Allday Left	/	/	/	/	/	/	/	NA	/	
FHC-05	Training Room	/	NA	/	/	/	/	/	NA	/	
FHC-06	Pump Room	/	/	/	/	/	/	/	NA	/	
FHC-07	Lift Service Block.A FL.1	/	/	/	/	/	/	/	NA	/	
FHC-16	Meeting Room	/	/	/	NA	NA	/	/	NA	/	
FHC-17	Meeting Room	/	/	/	NA	NA	/	/	NA	/	
FHC-20	Daily Shop	/	/	/	NA	NA	/	/	NA	/	
Fire Hose Cabinet block A											
FHC-21	Block A FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-31	Block A FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-41	Block A FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-51	Block A FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-61	Block A FL.6	/	NA	/	/	NA	/	/	NA	/	
Fire Hose Cabinet block B											
FHC-09	Lift block B FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-08	Block B FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-23	Lift block B FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-22	Block B FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-33	Lift block B FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-32	Block B FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-43	Lift block B FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-42	Block B FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-53	Lift block B FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-52	Block B FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-63	Lift block B FL.6	/	NA	/	NA	NA	/	/	NA	/	*
FHC-62	Block B FL.6	/	NA	/	/	NA	/	/	NA	/	
FHC-71	Lift block B FL.7	/	NA	/	/	NA	/	/	NA	/	
Fire Hose Cabinet block C											
FHC-10	Lift block C FL.1	/	NA	/	/	/	NA	/	NA	/	
FHC-24	Lift block C FL.2	/	NA	/	NA	NA	NA	/	NA	/	
FHC-34	Lift block C FL.3	/	NA	/	NA	NA	NA	/	NA	/	
FHC-44	Lift block C FL.4	/	NA	/	NA	NA	NA	/	NA	/	
FHC-54	Lift block C FL.5	/	NA	/	NA	NA	NA	/	NA	/	
FHC-64	Lift block C FL.6	/	NA	/	NA	NA	NA	/	NA	/	
FHC-72	Lift block C FL.7	/	NA	/	/	NA	NA	/	NA	/	
Fire Hose Cabinet block D											
FHC-11	Block D FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-25	Block D FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-35	Block D FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-45	Block D FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-55	Block D FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-65	Block D FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-73	Block D FL.7	/	NA	/	/	NA	/	/	NA	/	

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month..April.,2026

DESCRIPTION		Fire Extinguisher	Axe	Hose Reel	Fire Hoses	Jet Nozzle	Hydrant Cover	Factory Hydrant	Public Hydrant	Chalk	Remark
		ถังดับเพลิง	ขวาน	สายฉีดแบบม้วน	สายดับเพลิง	หัวฉีดเจ้า	ฝาครอบและข้อต่อ	หัวจ่ายน้ำดับเพลิง	หัวรับน้ำดับเพลิง	ชอล์ก	
Fire Hose Cabinet block E											
FHC-12	Block E FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-26	Block E FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-36	Block E FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-46	Block E FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-56	Block E FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-66	Block E FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-74	Block E FL.7	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block F											
FHC-13	Block F FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-27	Block F FL.2	/	NA	/	NA	NA	/	/	NA	/	Cabinet cannot be locked.
FHC-37	Block F FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-47	Block F FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-57	Block F FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-67	Block F FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-75	Block F FL.7	/	NA	/	/	/	/	/	NA	/	
FHC-76	Lift block G FL.7	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block G											
FHC-14	Lift block G FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-15	Block G FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-28	Lift block G FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-29	Block G FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-38	Lift block G FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-39	Block G FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-48	Lift block G FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-49	Block G FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-58	Lift block G FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-59	Block G FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-68	Lift block G FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-69	Block G FL.6	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block H											
FHC-77	Owner Office FL.3	/	/	/	NA	NA	/	/	NA	/	Cabinet cannot be locked.
FHC-30	Lift block H FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-40	Lift block H FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-50	Lift block H FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-60	Lift block H FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-70	Lift block H FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-02	Panty Poom of Bulding C	NA	NA	NA	/	NA	NA	NA	NA		
FHC-01	Panty Poom infont villa	NA	NA	NA	/	NA	NA	NA	NA		

Security Check.....

Asst. Safety & Security Manager.....

Security Check.....

Date.....

Date..... 03/04/26

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month..April, 2026

No.	Description	Factory Hydrant		Public Hydrant		Remarks
		ข้อต่อ	ฝาดรอม	ข้อต่อ	ฝาดรอม	
1	Factory Hydrant in front of Chiller room FL.3	✓	✓			
2	Public Hydrant in front of parking Area M.2			✓	✓	
3	Factory Hydrant in front of parking Area M.2	✓	✓			
4	Public Hydrant in front of Building B			✓	✓	
5	Factory Hydrant in front of Building B	✓	✓			
6	Factory Hydrant in front of Building C	✓	✓			
7	Factory Hydrant in Walk way Villa 914	✓	✓			
8	Factory Hydrant in Walk way Villa 901	✓	✓			
9	Factory Hydrant in Walk way Villa 902	✓	✓			
10	Factory Hydrant in Walk way Security M.4	N/A	N/A			
11	Factory Hydrant in front of Office Owner FL.3	✓	✓			
12	Factory Hydrant in front of parking Area M.1	✓	✓			
13	Public Hydrant in front of parking Area M.1			✓	✓	
14	Factory Hydrant in front of Building F	✓	✓			
15	Public Hydrant in front of Hotel Water pipes M.1			✓	N/A	
16	Factory Hydrant in front of Roof Block A	✓	✓			
17	Factory Hydrant in front of Roof Block B	✓	✓			
18	Factory Hydrant in front of Roof Block C	✓	✓			
19	Factory Hydrant in front of Roof Block D	✓	✓			
20	Factory Hydrant in front of Roof Block E	✓	✓			
21	Factory Hydrant in front of Roof Block F	✓	✓			
22	Factory Hydrant in front of Roof Block G	✓	✓			
23	Factory Hydrant in front of Roof Block H	✓	✓			

Security Supervisor Check..... Asst. Safety & Security Manager.....

Date..... 23/04/26

Date.....

GRAND MERCURE

PHUKET PATONG

Fire Extinguishers Inspection

Month..April.,2026

Place	Type	Condition	Pressure	Remarks
Fire Pump	Dry Chemical	OK	OK	
	CO2	OK	OK	
Generator Room	Dry Chemical	OK	OK	
	CO2	OK	OK	
Kitchen Main	Fire Blanket	OK	OK	
	Form	OK	OK	
Bubble Restaurant	Fire Blanket	OK	OK	
	Form	OK	OK	
Gas Store	Dry Chemical	OK	OK	
	Dry Chemical	OK	OK	
Laundry	Dry Chemical	OK	OK	
Villa Club	Halon FL.2	OK	OK	
	Halon FL.3	NA	NA	
IT Office	Fireade2000	OK	OK	
M1	Dry Chemical	OK	OK	
M2	Dry Chemical	OK	OK	
Security Office	Fireade2000	OK	OK	
Spa	Dry Chemical	OK	OK	
Kitchen Canteen	Fire Blanket	OK	OK	
Begery Room	Fire Blanket	OK	OK	
Accounting Office	Fireade2000	OK	OK	
Server Room	Fireade2000	OK	OK	
Gardener's Office	Fireade2000	OK	OK	
Parking Area M1	Dry Chemical	OK	OK	
Parking Area M2	Dry Chemical	OK	OK	
Building B Rooftop	Halon			
Building G Rooftop	Halon			

Security Supervisor..... Asst. Safety & Security Manager.....

Date..... 23/04/26

Date.....

GRAND MERCURE

PHUKET PATONG

Fire Extinguishers Inspection

Month..April.,2026

Place	Type	Condition	Pressure	Remarks
Villa 901	Dry Chemical	ok	ok	
Villa 902	Dry Chemical	ok	ok	
Villa 903	Dry Chemical	ok	ok	
Villa 904	Dry Chemical	ok	ok	
Villa 905	Dry Chemical	ok	ok	
Villa 906	Dry Chemical	ok	ok	
Villa 907	Dry Chemical	ok	ok	
Villa 908	Dry Chemical	ok	ok	
Villa 909	Dry Chemical	ok	ok	
Villa 910	Dry Chemical	ok	ok	
Villa 911	Dry Chemical	ok	ok	
Villa 912	Dry Chemical	ok	ok	
Villa 913	Dry Chemical	ok	ok	
Villa 914	Dry Chemical	ok	ok	

Security CheckMaxusder

Safety&Security Manager.....S.M.S.

Security Check

Date.....

Date.30/04/2026

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST (FHC)

Month

Mar-26

Inspection by : Security Supervisor



Approved by : Assistant Safety & Security Manager

GRAND MERCURE

PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month.March.,2026

DESCRIPTION		Fire Extinguisher	Axe	Hose Reel	Fire Hoses	Jet Nozzle	Hydrant Cover	Factory Hydrant	Public Hydrant	Chalk	Remark
		ถังดับเพลิง	ขวาน	สายฉีดแบบม้วน	สายดับเพลิง	หัวฉีดเจ็ท	ฝาครอบท่อและข้อ	หัวจ่ายน้ำดับเพลิง	หัวรับน้ำดับเพลิง	ชอล์ก	
Fire Hose Cabinet Main building											
FHC-01	Louding Laundry	/	/	/	/	NA	/	/	NA	/	8750
FHC-02	Front Engineering Office	/	/	/	/	/	/	/	NA	/	
FHC-03	Allday Right	/	/	/	/	/	/	/	NA	/	
FHC-04	Allday Left	/	/	/	/	/	/	/	NA	/	
FHC-05	Training Room	/	NA	/	/	/	/	/	NA	/	
FHC-06	Pump Room	/	/	/	/	/	/	/	NA	/	
FHC-07	Lift Service Block.A FL.1	/	/	/	/	/	/	/	NA	/	
FHC-16	Meeting Room	/	/	/	NA	NA	/	/	NA	/	
FHC-17	Meeting Room	/	/	/	NA	NA	/	/	NA	/	
FHC-20	Daily Shop	/	/	/	NA	NA	/	/	NA	/	
Fire Hose Cabinet block A											
FHC-21	Block A FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-31	Block A FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-41	Block A FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-51	Block A FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-61	Block A FL.6	/	NA	/	/	NA	/	/	NA	/	
Fire Hose Cabinet block B											
FHC-09	Lift block B FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-08	Block B FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-23	Lift block B FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-22	Block B FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-33	Lift block B FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-32	Block B FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-43	Lift block B FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-42	Block B FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-53	Lift block B FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-52	Block B FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-63	Lift block B FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-62	Block B FL.6	/	NA	/	/	NA	/	/	NA	/	
FHC-71	Lift block B FL.7	/	NA	/	/	NA	/	/	NA	/	
Fire Hose Cabinet block C											
FHC-10	Lift block C FL.1	/	NA	/	/	/	NA	/	NA	/	
FHC-24	Lift block C FL.2	/	NA	/	NA	NA	NA	/	NA	/	
FHC-34	Lift block C FL.3	/	NA	/	NA	NA	NA	/	NA	/	
FHC-44	Lift block C FL.4	/	NA	/	NA	NA	NA	/	NA	/	
FHC-54	Lift block C FL.5	/	NA	/	NA	NA	NA	/	NA	/	
FHC-64	Lift block C FL.6	/	NA	/	NA	NA	NA	/	NA	/	
FHC-72	Lift block C FL.7	/	NA	/	/	NA	NA	/	NA	/	
Fire Hose Cabinet block D											
FHC-11	Block D FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-25	Block D FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-35	Block D FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-45	Block D FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-55	Block D FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-65	Block D FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-73	Block D FL.7	/	NA	/	/	NA	/	/	NA	/	

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month..March.,2026

DESCRIPTION		Fire	Axe	Hose Reel	Fire Hoses	Jet Nozzle	Hydrant	Factory	Public	Chalk	Remark
		Extinguisher					Cover	Hydrant	Hydrant		
		ถังดับเพลิง	ขวาน	สายฉีดแบบม้วน	สายดับเพลิง	หัวฉีดเจ็ท	ฝาครอบและข้อต่อ	หัวจ่ายน้ำดับเพลิง	หัวรับน้ำดับเพลิง	ชอล์ก	
Fire Hose Cabinet block E											
FHC-12	Block E FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-26	Block E FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-36	Block E FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-46	Block E FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-56	Block E FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-66	Block E FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-74	Block E FL.7	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block F											
FHC-13	Block F FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-27	Block F FL.2	/	NA	/	NA	NA	/	/	NA	/	Cabinet cannot be locked.
FHC-37	Block F FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-47	Block F FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-57	Block F FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-67	Block F FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-75	Block F FL.7	/	NA	/	/	/	/	/	NA	/	
FHC-76	Lift block G FL.7	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block G											
FHC-14	Lift block G FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-15	Block G FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-28	Lift block G FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-29	Block G FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-38	Lift block G FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-39	Block G FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-48	Lift block G FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-49	Block G FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-58	Lift block G FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-59	Block G FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-68	Lift block G FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-69	Block G FL.6	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block H											
FHC-77	Owner Office FL.3	/	/	/	NA	NA	/	/	NA	/	
FHC-30	Lift block H FL.2	/	NA	/	NA	NA	/	/	NA	/	Cabinet cannot be locked.
FHC-40	Lift block H FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-50	Lift block H FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-60	Lift block H FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-70	Lift block H FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-02	Panty Poom of Bulding C	NA	NA	NA	/	NA	NA	NA	NA	NA	
FHC-01	Panty Poom infont villa	NA	NA	NA	/	NA	NA	NA	NA	NA	

Security Check.....*Marusde*.....

Asst. Safety & Security Manager.....*Sam P.*.....

Security Check.....*[Signature]*.....

Date.....

Date.....*15/03/26*.....

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month..March, 2026

No.	Description	Factory Hydrant		Public Hydrant		Remarks
		ข้อต่อ	ฝาครอบ	ข้อต่อ	ฝาครอบ	
1	Factory Hydrant in front of Chiller room FL.3	✓	✓			
2	Public Hydrant in front of parking Area M.2			✓	✓	
3	Factory Hydrant in front of parking Area M.2	✓	✓			
4	Public Hydrant in front of Building B			✓	✓	
5	Factory Hydrant in front of Building B	✓	✓			
6	Factory Hydrant in front of Building C	✓	✓			
7	Factory Hydrant in Walk way Villa 914	✓	✓			
8	Factory Hydrant in Walk way Villa 901	✓	✓			
9	Factory Hydrant in Walk way Villa 902	✓	✓			
10	Factory Hydrant in Walk way Security M.4	N/A	N/A			
11	Factory Hydrant in front of Office Owner FL.3	✓	✓			
12	Factory Hydrant in front of parking Area M.1	✓	✓			
13	Public Hydrant in front of parking Area M.1			✓	✓	
14	Factory Hydrant in front of Building F	✓	✓			
15	Public Hydrant in front of Hotel Water pipes M.1			✓	N/A	
16	Factory Hydrant in front of Roof Block A	✓	✓			
17	Factory Hydrant in front of Roof Block B	✓	✓			
18	Factory Hydrant in front of Roof Block C	✓	✓			
19	Factory Hydrant in front of Roof Block D	✓	✓			
20	Factory Hydrant in front of Roof Block E	✓	✓			
21	Factory Hydrant in front of Roof Block F	✓	✓			
22	Factory Hydrant in front of Roof Block G	✓	✓			
23	Factory Hydrant in front of Roof Block H	✓	✓			

Security Supervisor Check..... Asst. Safety & Security Manager.....

Date..... 12/03/26

Date.....

GRAND MERCURE

PHUKET PATONG

Fire Extinguishers Inspection

Month..March.,2026

Place	Type	Condition	Pressure	Remarks
Fire Pump	Dry Chemical	OK	OK	
	CO2	OK	OK	
Generator Room	Dry Chemical	OK	OK	
	CO2	OK	OK	
Kitchen Main	Fire Blanket	OK	OK	
	Form	OK	OK	
Bubble Restaurant	Fire Blanket	OK	OK	
	Form	OK	OK	
Gas Store	Dry Chemical	OK	OK	
	Dry Chemical	OK	OK	
Laundry	Dry Chemical	OK	OK	
Villa Club	Halon FL.2	OK	OK	
	Halon FL.3	NA	NA	
IT Office	Fireade 2000	OK	OK	
M1	Dry Chemical	OK	OK	
M2	Dry Chemical	OK	OK	
Security Office	Fireade 2000	OK	OK	
Spa	Dry Chemical	OK	OK	
Kitchen Canteen	Fire Blanket	OK	OK	
Begery Room	Fire Blanket	OK	OK	
Accounting Office	Fireade2000	OK	OK	
Server Room	Fireade2000	OK	OK	
Gardener's Office	Fireade2000	OK	OK	
Parking Area M1	Dry Chemical	OK	OK	
Parking Area M2	Dry Chemical	OK	OK	
Building B Rooftop	Halon	OK	OK	
Building G Rooftop	Halon	OK	OK	

Security Supervisor..... Asst. Safety & Security Manager.....

Date..... 12/03/26

Date.....

GRAND MERCURE
PHUKET PATONG

Fire Extinguishers Inspection

Month..March.,2026

Place	Type	Condition	Pressure	Remarks
Villa 901	Dry Chemical	ok	ok	
Villa 902	Dry Chemical	ok	ok	
Villa 903	Dry Chemical	ok	ok	
Villa 904	Dry Chemical	ok	ok	
Villa 905	Dry Chemical	ok	ok	
Villa 906	Dry Chemical	ok	ok	
Villa 907	Dry Chemical	ok	ok	
Villa 908	Dry Chemical	ok	ok	
Villa 909	Dry Chemical	ok	ok	
Villa 910	Dry Chemical	ok	ok	
Villa 911	Dry Chemical	ok	ok	
Villa 912	Dry Chemical	ok	ok	
Villa 913	Dry Chemical	ok	ok	
Villa 914	Dry Chemical	ok	ok	

Security Check *Manusder*

Safety&Security Manager.....

Security Check

Date.....

Date *31/03/2026*


GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST (FHC)

Month

Feb-26

Inspection by : Security Supervisor



Approved by : Assistant Safety & Security Manager

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month: February, 2026

DESCRIPTION		Fire Extinguisher ถังดับเพลิง	Axe ขวาน	Hose Reel สายฉีดแบบม้วน	Fire Hoses สายดับเพลิง	Jet Nozzle หัวฉีดเจ็ท	Hydrant Cover ฝาครอบท่อและข้อ	Factory Hydrant หัวจ่ายน้ำดับเพลิง	Public Hydrant หัวรับน้ำดับเพลิง	Chalk ชอล์ก	Remark
Fire Hose Cabinet Main building											
FHC-01	Loading Laundry	/	/	/	/	NA	/	/	NA	/	8/8/26
FHC-02	Front Engineering Office	/	/	/	/	/	/	/	NA	/	
FHC-03	Allday Right	/	/	/	/	/	/	/	NA	/	
FHC-04	Allday Left	/	/	/	/	/	/	/	NA	/	
FHC-05	Training Room	/	NA	/	/	/	/	/	NA	/	
FHC-06	Pump Room	/	/	/	/	/	/	/	NA	/	
FHC-07	Lift Service Block A FL.1	/	/	/	/	/	/	/	NA	/	
FHC-16	Meeting Room	/	/	/	NA	NA	/	/	NA	/	
FHC-17	Meeting Room	/	/	/	NA	NA	/	/	NA	/	
FHC-20	Daily Shop	/	/	/	NA	NA	/	/	NA	/	
Fire Hose Cabinet block A											
FHC-21	Block A FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-31	Block A FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-41	Block A FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-51	Block A FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-61	Block A FL.6	/	NA	/	/	NA	/	/	NA	/	
Fire Hose Cabinet block B											
FHC-09	Lift block B FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-08	Block B FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-23	Lift block B FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-22	Block B FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-33	Lift block B FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-32	Block B FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-43	Lift block B FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-42	Block B FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-53	Lift block B FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-52	Block B FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-63	Lift block B FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-62	Block B FL.6	/	NA	/	/	NA	/	/	NA	/	
FHC-71	Lift block B FL.7	/	NA	/	/	NA	/	/	NA	/	
Fire Hose Cabinet block C											
FHC-10	Lift block C FL.1	/	NA	/	/	/	NA	/	NA	/	
FHC-24	Lift block C FL.2	/	NA	/	NA	NA	NA	/	NA	/	
FHC-34	Lift block C FL.3	/	NA	/	NA	NA	NA	/	NA	/	
FHC-44	Lift block C FL.4	/	NA	/	NA	NA	NA	/	NA	/	
FHC-54	Lift block C FL.5	/	NA	/	NA	NA	NA	/	NA	/	
FHC-64	Lift block C FL.6	/	NA	/	NA	NA	NA	/	NA	/	
FHC-72	Lift block C FL.7	/	NA	/	/	NA	NA	/	NA	/	
Fire Hose Cabinet block D											
FHC-11	Block D FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-25	Block D FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-35	Block D FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-45	Block D FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-55	Block D FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-65	Block D FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-73	Block D FL.7	/	NA	/	/	NA	/	/	NA	/	

GRAND MERCURE

PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month..February.,2026

DESCRIPTION		Fire Extinguisher	Axe	Hose Reel	Fire Hoses	Jet Nozzle	Hydrant Cover	Factory Hydrant	Public Hydrant	Chalk	Remark
		ถังดับเพลิง	ขวาน	สายฉีดแบบม้วน	สายดับเพลิง	หัวฉีดเจ้า	ฝาครอบและข้อต่อ	หัวจ่ายน้ำดับเพลิง	หัวรับน้ำดับเพลิง	ชอล์ก	
Fire Hose Cabinet block E											
FHC-12	Block E FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-26	Block E FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-36	Block E FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-46	Block E FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-56	Block E FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-66	Block E FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-74	Block E FL.7	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block F											
FHC-13	Block F FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-27	Block F FL.2	/	NA	/	NA	NA	/	/	NA	/	Cabinet cannot be locked.
FHC-37	Block F FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-47	Block F FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-57	Block F FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-67	Block F FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-75	Block F FL.7	/	NA	/	/	/	/	/	NA	/	
FHC-76	Lift block G FL.7	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block G											
FHC-14	Lift block G FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-15	Block G FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-28	Lift block G FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-29	Block G FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-38	Lift block G FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-39	Block G FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-48	Lift block G FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-49	Block G FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-58	Lift block G FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-59	Block G FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-68	Lift block G FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-69	Block G FL.6	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block H											
FHC-77	Owner Office FL.3	/	/	/	NA	NA	/	/	NA	/	
FHC-30	Lift block H FL.2	/	NA	/	NA	NA	/	/	NA	/	Cabinet cannot be locked.
FHC-40	Lift block H FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-50	Lift block H FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-60	Lift block H FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-70	Lift block H FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-02	Panty Poom of Building C	NA	NA	NA	/	NA	NA	NA	NA	NA	
FHC-01	Panty Poom infont villa	NA	NA	NA	/	NA	NA	NA	NA	NA	

Security Check.....Maxwider

Asst. Safety & Security Manager.....

Security Check.....

Date.....22/2/26

Date.....13/02/26

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month..February, 2026

No.	Description	Factory Hydrant		Public Hydrant		Remarks
		ข้อต่อ	ฝาดรอป	ข้อต่อ	ฝาดรอป	
1	Factory Hydrant in front of Chiller room FL.3	✓	✓			
2	Public Hydrant in front of parking Area M.2			✓	✓	
3	Factory Hydrant in front of parking Area M.2	✓	✓			
4	Public Hydrant in front of Building B			✓	✓	
5	Factory Hydrant in front of Building B	✓	✓			
6	Factory Hydrant in front of Building C	✓	✓			
7	Factory Hydrant in Walk way Villa 914	✓	✓			
8	Factory Hydrant in Walk way Villa 901	✓	✓			
9	Factory Hydrant in Walk way Villa 902	✓	✓			
10	Factory Hydrant in Walk way Security M.4	✓	✓			
11	Factory Hydrant in front of Office Owner FL.3	✓	✓			
12	Factory Hydrant in front of parking Area M.1	✓	✓			
13	Public Hydrant in front of parking Area M.1			✓	✓	
14	Factory Hydrant in front of Building F	✓	✓			
15	Public Hydrant in front of Hotel Water pipes M.1			✓	N/A	
16	Factory Hydrant in front of Roof Block A	✓	✓			
17	Factory Hydrant in front of Roof Block B	✓	✓			
18	Factory Hydrant in front of Roof Block C	✓	✓			
19	Factory Hydrant in front of Roof Block D	✓	✓			
20	Factory Hydrant in front of Roof Block E	✓	✓			
21	Factory Hydrant in front of Roof Block F	✓	✓			
22	Factory Hydrant in front of Roof Block G	✓	✓			
23	Factory Hydrant in front of Roof Block H	✓	✓			

Security Supervisor Check..... Asst. Safety & Security Manager.....

Date.....15/02/26.....

Date.....20/2/26.....

GRAND MERCURE

PHUKET PATONG

Fire Extinguishers Inspection

Month..February.,2026

Place	Type	Condition	Pressure	Remarks
Fire Pump	Dry Chemical	OK	OK	
	CO2	OK	OK	
Generator Room	Dry Chemical	OK	OK	
	CO2	OK	OK	
Kitchen Main	Fire Blanket	OK	OK	
	Form	OK	OK	
Bubble Restaurant	Fire Blanket	OK	OK	
	Form	OK	OK	
Gas Store	Dry Chemical	OK	OK	
	Dry Chemical	OK	OK	
Laundry	Dry Chemical	OK	OK	
Villa Club	Halon FL.2	OK	OK	
	Halon FL.3	NA	NA	
IT Office	Halon	OK	OK	
M1	Dry Chemical	OK	OK	
M2	Dry Chemical	OK	OK	
Security Office	Halon	OK	OK	
Spa	Dry Chemical	OK	OK	
Kitchen Canteen	Fire Blanket	OK	OK	
Begery Room	Fire Blanket	OK	OK	
Accounting Office	Fireade2000	OK	OK	
Server Room	Fireade2000	OK	OK	
Gardener's Office	Fireade2000	OK	OK	
Parking Area M1	Dry Chemical	OK	OK	
Parking Area M2	Dry Chemical	OK	OK	

Security Supervisor..... Asst. Safety & Security Manager.....

Date..... 15/02/26

Date..... 22/2/26

GRAND MERCURE
PHUKET PATONG

Fire Extinguishers Inspection

Month..February.,2026

Place	Type	Condition	Pressure	Remarks
Villa 901	Dry Chemical	ok	ok	
Villa 902	Dry Chemical	ok	ok	
Villa 903	Dry Chemical	ok	ok	
Villa 904	Dry Chemical	ok	ok	
Villa 905	Dry Chemical	ok	ok	
Villa 906	Dry Chemical	ok	ok	
Villa 907	Dry Chemical	ok	ok	
Villa 908	Dry Chemical	ok	ok	
Villa 909	Dry Chemical	ok	ok	
Villa 910	Dry Chemical	ok	ok	
Villa 911	Dry Chemical	ok	ok	
Villa 912	Dry Chemical	ok	ok	
Villa 913	Dry Chemical	ok	ok	
Villa 914	Dry Chemical	ok	ok	

Security Check *Manroder*

Safety&Security Manager..... *SMG*

Security Check

Date..... *24/2/26.*

Date..... *23/02/2026*

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST (FHC)

Month

Jan-26

Inspection by : Security Officer



Approved by : Assistant Safety & Security Manager

GRAND MERCURE

PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month: January, 2026

DESCRIPTION		Fire Extinguisher	Axe	Hose Reel	Fire Hoses	Jet Nozzle	Hydrant Cover	Factory Hydrant	Public Hydrant	Chalk	Remark
		ถังดับเพลิง	ขวาน	สายฉีดแบบม้วน	สายดับเพลิง	หัวฉีดเจ็ท	ฝาครอบท่อและข้อ	หัวจ่ายน้ำดับเพลิง	หัวรับน้ำดับเพลิง	ชอล์ก	
Fire Hose Cabinet Main building											
FHC-01	Loading Laundry	/	/	/	/	NA	/	/	NA	/	8757
FHC-02	Front Engineering Office	/	/	/	/	/	/	/	NA	/	
FHC-03	Allday Right	/	/	/	/	/	/	/	NA	/	
FHC-04	Allday Left	/	/	/	/	/	/	/	NA	/	
FHC-05	Training Room	/	NA	/	/	/	/	/	NA	/	
FHC-06	Pump Room	/	/	/	/	/	/	/	NA	/	
FHC-07	Lift Service Block.A FL.1	/	/	/	/	/	/	/	NA	/	
FHC-16	Meeting Room	/	/	/	NA	NA	/	/	NA	/	
FHC-17	Meeting Room	/	/	/	NA	NA	/	/	NA	/	
FHC-20	Daily Shop	/	/	/	NA	NA	/	/	NA	/	
Fire Hose Cabinet block A											
FHC-21	Block A FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-31	Block A FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-41	Block A FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-51	Block A FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-61	Block A FL.6	/	NA	/	/	NA	/	/	NA	/	
Fire Hose Cabinet block B											
FHC-09	Lift block B FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-08	Block B FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-23	Lift block B FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-22	Block B FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-33	Lift block B FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-32	Block B FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-43	Lift block B FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-42	Block B FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-53	Lift block B FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-52	Block B FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-63	Lift block B FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-62	Block B FL.6	/	NA	/	/	NA	/	/	NA	/	
FHC-71	Lift block B FL.7	/	NA	/	/	NA	/	/	NA	/	
Fire Hose Cabinet block C											
FHC-10	Lift block C FL.1	/	NA	/	/	/	NA	/	NA	/	
FHC-24	Lift block C FL.2	/	NA	/	NA	NA	NA	/	NA	/	
FHC-34	Lift block C FL.3	/	NA	/	NA	NA	NA	/	NA	/	
FHC-44	Lift block C FL.4	/	NA	/	NA	NA	NA	/	NA	/	
FHC-54	Lift block C FL.5	/	NA	/	NA	NA	NA	/	NA	/	
FHC-64	Lift block C FL.6	/	NA	/	NA	NA	NA	/	NA	/	
FHC-72	Lift block C FL.7	/	NA	/	/	NA	NA	/	NA	/	
Fire Hose Cabinet block D											
FHC-11	Block D FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-25	Block D FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-35	Block D FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-45	Block D FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-55	Block D FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-65	Block D FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-73	Block D FL.7	/	NA	/	/	NA	/	/	NA	/	

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month..January..2026

DESCRIPTION		Fire	Axe	Hose Reel	Fire Hoses	Jet Nozzle	Hydrant	Factory	Public	Chalk	Remark
		Extinguisher					Cover	Hydrant	Hydrant		
		ถังดับเพลิง	ขวาน	สายฉีดแบบม้วน	สายดับเพลิง	หัวฉีดเจ็ท	ฝาครอบและข้อต่อ	หัวจ่ายน้ำดับเพลิง	หัวรับน้ำดับเพลิง	ชอล์ก	
Fire Hose Cabinet block E											
FHC-12	Block E FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-26	Block E FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-36	Block E FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-46	Block E FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-56	Block E FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-66	Block E FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-74	Block E FL.7	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block F											
FHC-13	Block F FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-27	Block F FL.2	/	NA	/	NA	NA	/	/	NA	/	Cabinet cannot be locked
FHC-37	Block F FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-47	Block F FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-57	Block F FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-67	Block F FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-75	Block F FL.7	/	NA	/	/	/	/	/	NA	/	
FHC-76	Lift block G FL.7	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block G											
FHC-14	Lift block G FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-15	Block G FL.1	/	NA	/	/	/	/	/	NA	/	
FHC-28	Lift block G FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-29	Block G FL.2	/	NA	/	NA	NA	/	/	NA	/	
FHC-38	Lift block G FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-39	Block G FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-48	Lift block G FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-49	Block G FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-58	Lift block G FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-59	Block G FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-68	Lift block G FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-69	Block G FL.6	/	NA	/	/	/	/	/	NA	/	
Fire Hose Cabinet block H											
FHC-77	Owner Office FL.3	/	/	/	NA	NA	/	/	NA	/	
FHC-30	Lift block H FL.2	/	NA	/	NA	NA	/	/	NA	/	Cabinet cannot be locked
FHC-40	Lift block H FL.3	/	NA	/	NA	NA	/	/	NA	/	
FHC-50	Lift block H FL.4	/	NA	/	NA	NA	/	/	NA	/	
FHC-60	Lift block H FL.5	/	NA	/	NA	NA	/	/	NA	/	
FHC-70	Lift block H FL.6	/	NA	/	NA	NA	/	/	NA	/	
FHC-02	Panty Poom of Bulding C	NA	NA	NA	/	NA	NA	NA	NA	NA	
FHC-01	Panty Poom infont villa	NA	NA	NA	/	NA	NA	NA	NA	NA	

Security Check.....*Manusol*

Asst. Safety & Security Manager.....*G.M.T.*

Security Check.....*ST*

Date.....*25/1/26*

Date.....*03/01/26*

GRAND MERCURE
PHUKET PATONG

PREVENTIVE MAINTENANCE CHECK LIST

Month..January, 2026

No.	Description	Factory Hydrant		Public Hydrant		Remarks
		ข้อต่อ	ฝาดรอป	ข้อต่อ	ฝาดรอป	
1	Factory Hydrant in front of Chiller room FL.3	✓	✓			
2	Public Hydrant in front of parking Area M.2			✓	✓	
3	Factory Hydrant in front of parking Area M.2	✓	✓			
4	Public Hydrant in front of Building B			✓	✓	
5	Factory Hydrant in front of Building B	✓	✓			
6	Factory Hydrant in front of Building C	✓	✓			
7	Factory Hydrant in Walk way Villa 914	✓	✓			
8	Factory Hydrant in Walk way Villa 901	✓	✓			
9	Factory Hydrant in Walk way Villa 902	✓	✓			
10	Factory Hydrant in Walk way Security M.4	N/A	N/A			
11	Factory Hydrant in front of Office Owner FL.3	✓	✓			
12	Factory Hydrant in front of parking Area M.1	✓	✓			
13	Public Hydrant in front of parking Area M.1			✓	✓	
14	Factory Hydrant in front of Building F	✓	✓			
15	Public Hydrant in front of Hotel Water pipes M.1			✓	N/A	
16	Factory Hydrant in front of Roof Block A	✓	✓			
17	Factory Hydrant in front of Roof Block B	✓	✓			
18	Factory Hydrant in front of Roof Block C	✓	✓			
19	Factory Hydrant in front of Roof Block D	✓	✓			
20	Factory Hydrant in front of Roof Block E	✓	✓			
21	Factory Hydrant in front of Roof Block F	✓	✓			
22	Factory Hydrant in front of Roof Block G	✓	✓			
23	Factory Hydrant in front of Roof Block H	✓	✓			

Security Officer Check.....  Asst. Safety & Security Manager..... 

Date..... 08/07/26.....

Date..... 25/1/26.....

GRAND MERCURE

PHUKET PATONG

Fire Extinguishers Inspection

Month...January.,2026

Place	Type	Condition	Pressure	Remarks
Fire Pump	Dry Chemical	OK	OK	
	CO2	OK	OK	
Generator Room	Dry Chemical	OK	OK	
	CO2	OK	OK	
Kitchen Main	Fire Blanket	OK	OK	
	Form	OK	OK	
Bubble Restaurant	Fire Blanket	OK	OK	
	Form	OK	OK	
Gas Store	Dry Chemical	OK	OK	
	Dry Chemical	OK	OK	
Laundry	Dry Chemical	OK	OK	
Villa Club	Halon FL.2	OK	OK	
	Halon FL.3	NA	NA	
IT Office	Halon	OK	OK	
M1	Dry Chemical	OK	OK	
M2	Dry Chemical	OK	OK	
Security Office	Halon	OK	OK	
Spa	Dry Chemical	OK	OK	
Kitchen Canteen	Fire Blanket	OK	OK	
Begery Room	Fire Blanket	OK	OK	
Accounting Office	Fireade2000	OK	OK	
Server Room	Fireade2000	OK	OK	
Gardener's Office	Fireade2000	OK	OK	
Parking Area M1	Dry Chemical	OK	OK	
Parking Area M2	Dry Chemical	OK	OK	

Security Officer.....

Asst. Safety & Security Manager.....

Date.....08/01/26

Date.....25/1/26

GRAND MERCURE

PHUKET PATONG

Fire Extinguishers Inspection

Month..January.,2026

Place	Type	Condition	Pressure	Remarks
Villa 901	Dry Chemical	ok	ok	
Villa 902	Dry Chemical	ok	ok	
Villa 903	Dry Chemical	ok	ok	
Villa 904	Dry Chemical	ok	ok	
Villa 905	Dry Chemical	ok	ok	
Villa 906	Dry Chemical	ok	ok	
Villa 907	Dry Chemical	ok	ok	
Villa 908	Dry Chemical	ok	ok	
Villa 909	Dry Chemical	ok	ok	
Villa 910	Dry Chemical	ok	ok	
Villa 911	Dry Chemical	ok	ok	
Villa 912	Dry Chemical	ok	ok	
Villa 913	Dry Chemical	ok	ok	
Villa 914	Dry Chemical	ok	ok	

Security Check *Marusder*

Safety&Security Manager.....

Security Check

Date.....

Date. *27/01/2026*