

## เอกสารแนบ 4

---

เอกสารผลการตรวจวัดคุณภาพสิ่งแวดล้อม




## ANALYSIS REPORT

CUSTOMER NAME : เดอะ ไลน์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.  
SAMPLING LOCATION : ป่อเกรอะ  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : ดำ ขุ่นมาก มีตะกอนมาก มีกลิ่นเหม็นรุนแรง  
SAMPLING DATE : JANUARY 29, 2026  
SAMPLING TIME : 12:00  
SAMPLING BY :   
REPORT NO. : RN260110150  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : JANUARY 29, 2026  
ANALYTICAL DATE : JANUARY 29 - FEBRUARY 05, 2026  
REPORT DATE : FEBRUARY 06, 2026

| PARAMETER                   | UNIT       | METHODS OF ANALYSIS                                     | RESULT                 | MDL | STANDARD* |
|-----------------------------|------------|---------------------------------------------------------|------------------------|-----|-----------|
| pH <sup>a</sup>             | -          | Electrometric (SM: 4500-H <sup>+</sup> B.)              | 6.8 at 25°C            | -   | -         |
| Biochemical Oxygen Demand   | mg/l       | Azide Modification (SM: 4500-O C, 5210 B.)              | 320.0                  | 2.0 | -         |
| Total Suspended Solids      | mg/l       | Total Suspended Solids Dried at 103-105°C (SM: 2540 D.) | 8,070.0                | -   | -         |
| Sulfide as H <sub>2</sub> S | mg/l       | Iodometric (SM: 4500-S <sup>2-</sup> F.)                | Not Detected           | -   | -         |
| Total Kjeldahl Nitrogen     | mg/l       | Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)            | 167.0                  | -   | -         |
| Oil & Grease                | mg/l       | Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)       | 4.6                    | 1.4 | -         |
| Total Coliform Bacteria     | MPN/100 ml | MPN Test                                                | >2.4 x 10 <sup>6</sup> | -   | -         |

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24<sup>th</sup> ED.,2023 (AWWA,APHA, WEF)

- Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. <sup>#</sup>ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)






## ANALYSIS REPORT

CUSTOMER NAME : เดอะ ไลน์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.  
SAMPLING LOCATION : บ่อพักน้ำใส  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : น้ำตาล ชุน ไม่มีตะกอน มีกลิ่นเหม็นเล็กน้อย  
SAMPLING DATE : JANUARY 29, 2026  
SAMPLING TIME : 12:00  
SAMPLING BY :   
REPORT NO. : RN260110151  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : JANUARY 29, 2026  
ANALYTICAL DATE : JANUARY 29 - FEBRUARY 05, 2026  
REPORT DATE : FEBRUARY 06, 2026

| PARAMETER                           | UNIT       | METHODS OF ANALYSIS                                     | RESULT                | MDL | STANDARD* |
|-------------------------------------|------------|---------------------------------------------------------|-----------------------|-----|-----------|
| pH <sup>#</sup>                     | -          | Electrometric (SM: 4500-H <sup>+</sup> B.)              | 7.9 at 25°C           | -   | 5.5-9.0   |
| Biochemical Oxygen Demand           | mg/l       | Azide Modification (SM: 4500-O C, 5210 B.)              | 25.2                  | 2.0 | ≤20       |
| Total Suspended Solids <sup>#</sup> | mg/l       | Total Suspended Solids Dried at 103-105°C (SM: 2540 D.) | 25.0                  | -   | ≤30       |
| Sulfide as H <sub>2</sub> S         | mg/l       | Iodometric (SM: 4500-S <sup>2-</sup> F.)                | Not Detected          | -   | ≤1.0      |
| Total Kjeldahl Nitrogen             | mg/l       | Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)            | 11.0                  | -   | ≤35       |
| Oil & Grease                        | mg/l       | Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)       | 1.4                   | 1.4 | ≤20       |
| Total Coliform Bacteria             | MPN/100 ml | MPN Test                                                | 7.5 x 10 <sup>3</sup> | -   | -         |

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24<sup>th</sup> ED.,2023 (AWWA,APHA, WEF)

Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)  
2. <sup>#</sup>ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)






## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.  
SAMPLING LOCATION : บ่อเกรอะ  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : ด้ำ ชื้นมาก มีตะกอนมาก มีกลิ่นเหม็นรุนแรง  
SAMPLING DATE : FEBRUARY 17, 2026  
SAMPLING TIME : 12:00  
SAMPLING BY :   
REPORT NO. : RN260210342  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : FEBRUARY 17, 2026  
ANALYTICAL DATE : FEBRUARY 17-26, 2026  
REPORT DATE : FEBRUARY 27, 2026

| PARAMETER                           | UNIT       | METHODS OF ANALYSIS                                     | RESULT                 | MDL | STANDARD* |
|-------------------------------------|------------|---------------------------------------------------------|------------------------|-----|-----------|
| pH <sup>#</sup>                     | -          | Electrometric (SM: 4500-H <sup>+</sup> B.)              | 7.4 at 25°C            | -   | -         |
| Biochemical Oxygen Demand           | mg/l       | Azide Modification (SM: 4500-O C, 5210 B.)              | 230.0                  | 2.0 | -         |
| Total Suspended Solids <sup>#</sup> | mg/l       | Total Suspended Solids Dried at 103-105°C (SM: 2540 D.) | 870.0                  | -   | -         |
| Sulfide as H <sub>2</sub> S         | mg/l       | Iodometric (SM: 4500-S <sup>2-</sup> F.)                | Not Detected           | -   | -         |
| Total Kjeldahl Nitrogen             | mg/l       | Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)            | 99.0                   | -   | -         |
| Oil & Grease                        | mg/l       | Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)       | 2.8                    | 1.4 | -         |
| Total Coliform Bacteria             | MPN/100 ml | MPN Test                                                | >2.4 x 10 <sup>6</sup> | -   | -         |

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24<sup>th</sup> ED.,2023 (AWWA,APHA, WEF)

- Remark : 1. \* Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. <sup>#</sup> ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)





## ANALYSIS REPORT


CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.  
SAMPLING LOCATION : บ่อพักน้ำใส  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เหลือง ชุ่นเล็กน้อย ไม่มีตะกอนมาก ไม่มีกลิ่น  
SAMPLING DATE : FEBRUARY 17, 2026  
SAMPLING TIME : 12:00  
SAMPLING BY : 

REPORT NO. : RN260210343  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : FEBRUARY 17, 2026  
ANALYTICAL DATE : FEBRUARY 17-26, 2026  
REPORT DATE : FEBRUARY 27, 2026

| PARAMETER                           | UNIT       | METHODS OF ANALYSIS                                     | RESULT                | MDL | STANDARD* |
|-------------------------------------|------------|---------------------------------------------------------|-----------------------|-----|-----------|
| pH <sup>#</sup>                     | -          | Electrometric (SM: 4500-H <sup>+</sup> B.)              | 7.6 at 25°C           | -   | 5.5-9.0   |
| Biochemical Oxygen Demand           | mg/l       | Azide Modification (SM: 4500-O C, 5210 B.)              | 51.0                  | 2.0 | ≤20       |
| Total Suspended Solids <sup>#</sup> | mg/l       | Total Suspended Solids Dried at 103-105°C (SM: 2540 D.) | 18.0                  | -   | ≤30       |
| Sulfide as H <sub>2</sub> S         | mg/l       | Iodometric (SM: 4500-S <sup>2-</sup> F.)                | Not Detected          | -   | ≤1.0      |
| Total Kjeldahl Nitrogen             | mg/l       | Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)            | 37.0                  | -   | ≤35       |
| Oil & Grease                        | mg/l       | Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)       | 2.0                   | 1.4 | ≤20       |
| Total Coliform Bacteria             | MPN/100 ml | MPN Test                                                | 1.1 × 10 <sup>6</sup> | -   | -         |

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24<sup>th</sup> ED.,2023 (AWWA,APHA, WEF)

- Remark : 1. \* Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. <sup>#</sup> ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)






## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.  
SAMPLING LOCATION : ปอกระจะ  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : ดำ ขุ่นมาก มีตะกอน มีกลิ่นเหม็นรุนแรง  
SAMPLING DATE : MARCH 17, 2026  
SAMPLING TIME : 13:00  
SAMPLING BY :   
REPORT NO. : RN260310553  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : MARCH 17, 2026  
ANALYTICAL DATE : MARCH 17-30, 2026  
REPORT DATE : MARCH 31, 2026

| PARAMETER                           | UNIT       | METHODS OF ANALYSIS                                     | RESULT                 | MDL | STANDARD* |
|-------------------------------------|------------|---------------------------------------------------------|------------------------|-----|-----------|
| pH <sup>#</sup>                     | -          | Electrometric (SM: 4500-H <sup>+</sup> B.)              | 7.3 at 25°C            | -   | -         |
| Biochemical Oxygen Demand           | mg/l       | Membrane Electrode (SM: 4500-O G, 5210 B.)              | 662.0                  | 2.0 | -         |
| Total Suspended Solids <sup>#</sup> | mg/l       | Total Suspended Solids Dried at 103-105°C (SM: 2540 D.) | 406.0                  | -   | -         |
| Sulfide as H <sub>2</sub> S         | mg/l       | Iodometric (SM: 4500-S <sup>2-</sup> F.)                | Not Detected           | -   | -         |
| Total Kjeldahl Nitrogen             | mg/l       | Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)            | 251.0                  | -   | -         |
| Oil & Grease                        | mg/l       | Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)       | 2.8                    | 1.4 | -         |
| Total Coliform Bacteria             | MPN/100 ml | MPN Test                                                | >2.4 x 10 <sup>6</sup> | -   | -         |

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24<sup>th</sup> ED., 2023 (AWWA, APHA, WEF)

- Remark : 1. <sup>\*</sup> Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. <sup>#</sup> ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)






## ANALYSIS REPORT

CUSTOMER NAME : เดอะ ไลน์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.  
SAMPLING LOCATION : บ่อพักน้ำใส  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เหลืองใส ไม่มีตะกอน ไม่มีกลิ่น  
SAMPLING DATE : MARCH 17, 2026  
SAMPLING TIME : 13:00  
SAMPLING BY :   
REPORT NO. : RN260310554  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : MARCH 17, 2026  
ANALYTICAL DATE : MARCH 17-30, 2026  
REPORT DATE : MARCH 31, 2026

| PARAMETER                           | UNIT       | METHODS OF ANALYSIS                                     | RESULT                | MDL | STANDARD* |
|-------------------------------------|------------|---------------------------------------------------------|-----------------------|-----|-----------|
| pH <sup>#</sup>                     | -          | Electrometric (SM: 4500-H <sup>+</sup> B.)              | 7.5 at 25°C           | -   | 5.5-9.0   |
| Biochemical Oxygen Demand           | mg/l       | Membrane Electrode (SM: 4500-O G, 5210 B.)              | 12.6                  | 2.0 | ≤20       |
| Total Suspended Solids <sup>#</sup> | mg/l       | Total Suspended Solids Dried at 103-105°C (SM: 2540 D.) | 17.0                  | -   | ≤30       |
| Sulfide as H <sub>2</sub> S         | mg/l       | Iodometric (SM: 4500-S <sup>2-</sup> F.)                | Not Detected          | -   | ≤1.0      |
| Total Kjeldahl Nitrogen             | mg/l       | Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)            | 7.3                   | -   | ≤35       |
| Oil & Grease                        | mg/l       | Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)       | 2.4                   | 1.4 | ≤20       |
| Total Coliform Bacteria             | MPN/100 ml | MPN Test                                                | 9.0 x 10 <sup>3</sup> | -   | -         |

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24<sup>th</sup> ED.,2023 (AWWA,APHA, WEF)

- Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)  
2. <sup>#</sup>ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)






## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.  
SAMPLING LOCATION : บ่อเกรอะ  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : ดำ ขุ่นมาก มีตะกอนมาก มีกลิ่นเหม็นรุนแรง  
SAMPLING DATE : APRIL 30, 2026  
SAMPLING TIME : 15:30  
SAMPLING BY :   
REPORT NO. : RN260410866  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : APRIL 30, 2026  
ANALYTICAL DATE : APRIL 30 - MAY 8 , 2026  
REPORT DATE : May 11, 2026

| PARAMETER                           | UNIT       | METHODS OF ANALYSIS                                     | RESULT                 | MDL | STANDARD* |
|-------------------------------------|------------|---------------------------------------------------------|------------------------|-----|-----------|
| pH <sup>#</sup>                     | -          | Electrometric (SM: 4500-H <sup>+</sup> B.)              | 7.1 at 25°C            | -   | -         |
| Biochemical Oxygen Demand           | mg/l       | Membrane Electrode (SM: 4500-O G, 5210 B.)              | 241.0                  | -   | -         |
| Total Suspended Solids <sup>#</sup> | mg/l       | Total Suspended Solids Dried at 103-105°C (SM: 2540 D.) | 1,700.0                | -   | -         |
| Sulfide as H <sub>2</sub> S         | mg/l       | Iodometric (SM: 4500-S <sup>2-</sup> F.)                | Not Detected           | -   | -         |
| Total Kjeldahl Nitrogen             | mg/l       | Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)            | 143.0                  | -   | -         |
| Oil & Grease                        | mg/l       | Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)       | 2.8                    | -   | -         |
| Total Coliform Bacteria             | MPN/100 ml | MPN Test                                                | >2.4 x 10 <sup>6</sup> | -   | -         |

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24<sup>th</sup> ED.,2023 (AWWA,APHA, WEF)

- Remark: 1. \* Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. <sup>#</sup> ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)






## ANALYSIS REPORT

CUSTOMER NAME : เดอะ ไลน์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.  
SAMPLING LOCATION : บ่อพักน้ำใส  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : เหลือง ใส ไม่มีตะกอน ไม่มีกลิ่น  
SAMPLING DATE : APRIL 30, 2026  
SAMPLING TIME : 15:30  
SAMPLING BY :   
REPORT NO. : RN260410867  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : APRIL 30, 2026  
ANALYTICAL DATE : APRIL 30 - MAY 8, 2026  
REPORT DATE : May 11, 2026

| PARAMETER                           | UNIT       | METHODS OF ANALYSIS                                     | RESULT                | MDL | STANDARD* |
|-------------------------------------|------------|---------------------------------------------------------|-----------------------|-----|-----------|
| pH <sup>#</sup>                     | -          | Electrometric (SM: 4500-H <sup>+</sup> B.)              | 7.3 at 25°C           | -   | 5.5-9.0   |
| Biochemical Oxygen Demand           | mg/l       | Membrane Electrode (SM: 4500-O G, 5210 B.)              | 22.7                  | -   | ≤20       |
| Total Suspended Solids <sup>#</sup> | mg/l       | Total Suspended Solids Dried at 103-105°C (SM: 2540 D.) | 12.0                  | -   | ≤30       |
| Sulfide as H <sub>2</sub> S         | mg/l       | Iodometric (SM: 4500-S <sup>2-</sup> F.)                | Not Detected          | -   | ≤1.0      |
| Total Kjeldahl Nitrogen             | mg/l       | Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)            | 13.0                  | -   | ≤35       |
| Oil & Grease                        | mg/l       | Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)       | 0.2                   | -   | ≤20       |
| Total Coliform Bacteria             | MPN/100 ml | MPN Test                                                | 9.0 x 10 <sup>3</sup> | -   | -         |

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24<sup>th</sup> ED., 2023 (AWWA, APHA, WEF)

- Remark: 1. \* Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. <sup>#</sup> ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)






## ANALYSIS REPORT

CUSTOMER NAME : เดอะ ไกลน์ พลลโยอิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพลลโยอิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.  
SAMPLING LOCATION : ป่อเกรอะ  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : น้ำตาล ชุนมาก มีตะกอนมาก มีกลิ่นเหม็นรุนแรง  
SAMPLING DATE : MAY 20, 2026  
SAMPLING TIME : 12:00  
SAMPLING BY :   
SAMPLE NO. : 05133  
REPORT NO. : RN260590128  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : MAY 20, 2026  
ANALYTICAL DATE : MAY 20 - 28, 2026  
REPORT DATE : MAY 29, 2026

| PARAMETER                           | UNIT       | METHODS OF ANALYSIS                                     | RESULT                 | MDL | STANDARD* |
|-------------------------------------|------------|---------------------------------------------------------|------------------------|-----|-----------|
| pH <sup>#</sup>                     | -          | Electrometric (SM: 4500-H <sup>+</sup> B.)              | 7.1 at 25°C            | -   | -         |
| Biochemical Oxygen Demand           | mg/l       | Membrane Electrode (SM: 4500-O G, 5210 B.)              | 356.0                  | -   | -         |
| Total Suspended Solids <sup>#</sup> | mg/l       | Total Suspended Solids Dried at 103-105°C (SM: 2540 D.) | 1,095.0                | -   | -         |
| Sulfide as H <sub>2</sub> S         | mg/l       | Iodometric (SM: 4500-S <sup>2-</sup> F.)                | Not Detected           | -   | -         |
| Total Kjeldahl Nitrogen             | mg/l       | Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)            | 197.0                  | -   | -         |
| Oil & Grease                        | mg/l       | Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)       | 2.8                    | -   | -         |
| Total Coliform Bacteria             | MPN/100 ml | MPN Test                                                | >2.4 x 10 <sup>6</sup> | -   | -         |

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24<sup>th</sup> ED.,2023 (AWWA,APHA, WEF)

- Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. <sup>#</sup>ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)





ห้องปฏิบัติการวิเคราะห์บริษัท โอกลา เทสติ้ง แอนด์ คอนซัลติง เซอร์วิส จำกัด

63/13 เพชรเกษม ซอย 7 แขวงวัดท่าพระ เขตบางกอกใหญ่ กรุงเทพฯ 10600

Tel: 0 2868 1246 Fax: 0 2868 0860 www.okla-testing.com J-NAC Group



TESTING  
No.0334


## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.  
SAMPLING LOCATION : บ่อพักน้ำใส  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : น้ำตาล ชุ่มเล็กน้อย มีตะกอน ไม่มีกลิ่น  
SAMPLING DATE : MAY 20, 2026  
SAMPLING TIME : 12:00  
SAMPLING BY :   
SAMPLE NO. : 05134  
REPORT NO. : RN260590129  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : MAY 20, 2026  
ANALYTICAL DATE : MAY 20 - 28, 2026  
REPORT DATE : MAY 29, 2026

| PARAMETER                           | UNIT       | METHODS OF ANALYSIS                                     | RESULT                | MDL | STANDARD* |
|-------------------------------------|------------|---------------------------------------------------------|-----------------------|-----|-----------|
| pH <sup>#</sup>                     | -          | Electrometric (SM: 4500-H <sup>+</sup> B.)              | 7.8 at 25°C           | -   | 5.5-9.0   |
| Biochemical Oxygen Demand           | mg/l       | Membrane Electrode (SM: 4500-O <sub>2</sub> G, 5210 B.) | 23.0                  | -   | ≤20       |
| Total Suspended Solids <sup>#</sup> | mg/l       | Total Suspended Solids Dried at 103-105°C (SM: 2540 D.) | 38.0                  | -   | ≤30       |
| Sulfide as H <sub>2</sub> S         | mg/l       | Iodometric (SM: 4500-S <sup>2-</sup> F.)                | Not Detected          | -   | ≤1.0      |
| Total Kjeldahl Nitrogen             | mg/l       | Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)            | 11.0                  | -   | ≤35       |
| Oil & Grease                        | mg/l       | Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)       | 0.4                   | -   | ≤20       |
| Total Coliform Bacteria             | MPN/100 ml | MPN Test                                                | 2.0 x 10 <sup>4</sup> | -   | -         |

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24<sup>th</sup> ED.,2023 (AWWA,APHA, WEF)

- Remark : 1. <sup>\*</sup> Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. <sup>#</sup> ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)



\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory. \*\*\*



ห้องปฏิบัติการวิเคราะห์บริษัท โอกลา เทสติ้ง แอนด์ คอนซัลติง เซอร์วิส จำกัด

63/13 เพชรเกษม ซอย 7 แขวงวัดท่าพระ เขตบางกอกใหญ่ กรุงเทพฯ 10600

Tel: 0 2868 1246 Fax: 0 2868 0860 www.okla-testing.com J-NAC Group



TESTING  
No.0334


## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.  
SAMPLING LOCATION : ปอเกรอะ  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : ดำ ชุ่มมาก มีตะกอนมาก มีกลิ่นเหม็นรุนแรง  
SAMPLING DATE : JUNE 11, 2026  
SAMPLING TIME : 13:00  
SAMPLING BY :   
SAMPLE NO. : 06144  
REPORT NO. : RN260690143  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : JUNE 11, 2026  
ANALYTICAL DATE : JUNE 11 - 18, 2026  
REPORT DATE : JUNE 19, 2026

| PARAMETER                           | UNIT       | METHODS OF ANALYSIS                                     | RESULT                 | MDL | STANDARD |
|-------------------------------------|------------|---------------------------------------------------------|------------------------|-----|----------|
| pH <sup>#</sup>                     | -          | Electrometric (SM: 4500-H <sup>+</sup> B.)              | 7.3 at 25°C            | -   | -        |
| Biochemical Oxygen Demand           | mg/l       | Membrane Electrode (SM: 4500-O <sub>2</sub> G, 5210 B.) | 151.0                  | -   | -        |
| Total Suspended Solids <sup>#</sup> | mg/l       | Total Suspended Solids Dried at 103-105°C (SM: 2540 D.) | 670.0                  | -   | -        |
| Sulfide as H <sub>2</sub> S         | mg/l       | Iodometric (SM: 4500-S <sup>2-</sup> F.)                | Not Detected           | -   | -        |
| Total Kjeldahl Nitrogen             | mg/l       | Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)            | 62.0                   | -   | -        |
| Oil & Grease                        | mg/l       | Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)       | 6                      | -   | -        |
| Total Coliform Bacteria             | MPN/100 ml | MPN Test                                                | >2.4 x 10 <sup>6</sup> | -   | -        |

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24<sup>th</sup> ED.,2023 (AWWA,APHA, WEF)

- Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. <sup>#</sup> ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)



\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory. \*\*\*



ห้องปฏิบัติการวิเคราะห์บริษัท โอกลา เทสติ้ง แอนด์ คอนซัลติง เซอร์วิส จำกัด

63/13 เพชรเกษม ซอย 7 แขวงวัดท่าพระ เขตบางกอกใหญ่ กรุงเทพฯ 10600

Tel: 0 2868 1246 Fax: 0 2868 0860 www.okla-testing.com J-NAC Group



TESTING  
No.0334


## ANALYSIS REPORT

CUSTOMER NAME : เดอะ โกลด์ พหลโยธิน พาร์ค (อาคาร ดี)  
ADDRESS : ถนนพหลโยธิน แขวงจอมพล เขตจตุจักร กรุงเทพมหานคร 10900.  
SAMPLING LOCATION : บ่อกักน้ำใส  
SAMPLING METHOD : GRAB  
SAMPLING CONDITION : NORMAL  
CHARACTERISTICS OF WATER : น้ำตาล ชุ่มเล็กน้อย ไม่มีตะกอน มีกลิ่นเหม็นเล็กน้อย  
SAMPLING DATE : JUNE 11, 2026  
SAMPLING TIME : 13:00  
SAMPLING BY :   
SAMPLE NO. : 06145  
REPORT NO. : RN260690144  
SAMPLING SOURCE : WASTEWATER  
RECEIVED DATE : JUNE 11, 2026  
ANALYTICAL DATE : JUNE 11 - 18, 2026  
REPORT DATE : JUNE 19, 2026

| PARAMETER                           | UNIT       | METHODS OF ANALYSIS                                     | RESULT                | MDL | STANDARD* |
|-------------------------------------|------------|---------------------------------------------------------|-----------------------|-----|-----------|
| pH <sup>#</sup>                     | -          | Electrometric (SM: 4500-H <sup>+</sup> B.)              | 7.8 at 25°C           | -   | 5.5-9.0   |
| Biochemical Oxygen Demand           | mg/l       | Membrane Electrode (SM: 4500-O G, 5210 B.)              | 38.0                  | -   | ≤20       |
| Total Suspended Solids <sup>#</sup> | mg/l       | Total Suspended Solids Dried at 103-105°C (SM: 2540 D.) | 38.0                  | -   | ≤30       |
| Sulfide as H <sub>2</sub> S         | mg/l       | Iodometric (SM: 4500-S <sup>2-</sup> F.)                | Not Detected          | -   | ≤1.0      |
| Total Kjeldahl Nitrogen             | mg/l       | Macro Kjeldahl (SM: 4500-N <sub>org</sub> B)            | 22.0                  | -   | ≤35       |
| Oil & Grease                        | mg/l       | Liquid-Liquid Partition-Gravimetric (SM: 5520 B.)       | 2.4                   | -   | ≤20       |
| Total Coliform Bacteria             | MPN/100 ml | MPN Test                                                | 2.9 x 10 <sup>5</sup> | -   | -         |

SM : STANDARD METHODS FOR EXAMINATION OF WATER AND WASTEWATER 24<sup>th</sup> ED., 2023 (AWWA, APHA, WEF)

- Remark : 1. Notification of the Ministry of Natural Resources and Environment, dated June 28, B.E. 2567 (2024), which was published in the Royal Government Gazette, Vol. 141, Part 233D dated August 27, B.E. 2567 (2024) . (Category A)
2. <sup>#</sup> ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)



LABORATORY SUPERVISOR

\*\*\* Reported analysis refers to submitted sample only. Report analysis shall not be reproduced except in full, without written approval of Laboratory. \*\*\*