

ภาคผนวก จ

Pool Daily Check List

POOL DAILY CHECK LIST



SUKHUMVIT 11

MONTH/YEAR:

Jan-26

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1/1/69	3.2	7.2	16	/	/	/	/	P	1.6	7.2	12	/	/	/	/	MON
2/1/69	3.0	7.2	14	/	/	/	/	mon	0.2	6-8	12	/	/	/	/	To
3/1/69	3.0	7.2	12	/	/	/	/	To	2.2	7.2	12	/	/	/	/	mon
4/1/69	3.0	7.2	12	/	/	/	/	mon	3.0	7.2	12	/	/	/	/	mon
5/1/69	3.0	7.2	13	/	/	/	/	mon	2.0	7.2	13	/	/	/	/	mon
6/1/69	3.0	7.2	12	/	/	/	/	mon	2.0	7.2	13	/	/	/	/	mon
7/1/69	3.0	7.2	12	/	/	/	/	mon	3.0	7.2	13	/	/	/	/	mon
8/1/69	3.0	7.2	12	/	/	/	/	mon	3.0	7.2	14	/	/	/	/	Beer
9/1/69	3.0	7.2	13	/	/	/	/	Beer	1.5	7.2	13	/	/	/	/	Beer
10/1/69	3.0	7.2	14	/	/	/	/	Beer	0.5	7.2	14	/	/	/	/	Beer
11/1/69	3.0	7.2	16	/	/	/	/	Beer	0.5	7.2	13	/	/	/	/	Beer
12/1/69	3.0	7.2	13	/	/	/	/	Beer	0.0	7.2	13	/	/	/	/	mon
13/1/69	3.0	7.2	14	/	/	/	/	mon	0.6	7.2	13	/	/	/	/	mon
14/1/69	3.0	7.2	14	/	/	/	/	mon	0.9	7.2	14	/	/	/	/	Beer
15/1/69	3.0	7.2	15	/	/	/	/	Beer	1.0	7.2	13	/	/	/	/	Beer
16/1/69	3.0	7.2	14	/	/	/	/	Beer	1.0	7.2	14	/	/	/	/	Beer
17/1/69	3.0	7.2	15	/	/	/	/	Beer	0.2	7.2	16	/	/	/	/	Beer
18/1/69	3.0	7.2	13	/	/	/	/	Beer	1.0	7.2	11	/	/	/	/	Beer
19/1/69	3.0	7.2	15	/	/	/	/	Beer	0.0	7.2	12	/	/	/	/	mon
20/1/69	3.0	7.2	14	/	/	/	/	mon	0.6	7.2	12	/	/	/	/	mon
21/1/69	3.0	7.2	13	/	/	/	/	mon	0.5	7.2	14	/	/	/	/	Beer
22/1/69	3.0	7.2	12	/	/	/	/	Beer	1.0	7.2	12	/	/	/	/	Beer
23/1/69	3.0	7.2	14	/	/	/	/	Beer	0.0	7.2	13	/	/	/	/	mon
24/1/69	3.0	7.2	14	/	/	/	/	mon	0.0	7.2	12	/	/	/	/	mon
25/1/69	3.0	7.2	12	/	/	/	/	mon	0.2	7.2	12	/	/	/	/	mon
26/1/69	3.0	7.2	12	/	/	/	/	mon	0.1	7.2	13	/	/	/	/	mon
27/1/69	3.0	7.2	13	/	/	/	/	mon	0.2	7.2	13	/	/	/	/	mon
28/1/69	3.0	7.2	12	/	/	/	/	mon	1.0	7.2	14	/	/	/	/	Beer
29/1/69	3.0	7.2	15	/	/	/	/	Beer	1.0	7.2	15	/	/	/	/	Beer
30/1/69	3.0	7.2	14	/	/	/	/	Beer	1.5	7.2	12	/	/	/	/	Beer
31/1/69	3.0	7.2	11	/	/	/	/	Beer	1.6	7.2	13	/	/	/	/	Beer

REMARK

Verified by Chief Engineer

Date

9/1/26

POOL DAILY CHECK LIST



Travelodge

SUKHUMVIT 11

MONTH/YEAR:

Feb-26

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1/2/69	3.0	7.2	12	/	/	/	/	MON	2.5	7.2	12	/	/	/	/	MON
2/2/69	3.0	7.2	12	/	/	/	/	MON	2.6	7.2	13	/	/	/	/	MON
3/2/69	3.0	7.2	12	/	/	/	/	MON	3.0	7.2	14	/	/	/	/	MON
4/2/69	3.0	7.2	12	/	/	/	/	MON	1.5	7.2	14	/	/	/	/	MON
5/2/69	3.0	7.2	12	/	/	/	/	MON	0.5	7.2	15	/	/	/	/	Beer
6/2/69	3.0	7.2	14	/	/	/	/	Beer	0.2	7.2	15	/	/	/	/	Beer
7/2/69	3.0	7.2	15	/	/	/	/	Beer	0.0	7.2	13	/	/	/	/	MON
8/2/69	3.0	7.2	14	/	/	/	/	MON	0.0	7.2	12	/	/	/	/	MON
9/2/69	3.0	7.2	12	/	/	/	/	MON	0.2	7.2	14	/	/	/	/	MON
10/2/69	3.0	7.2	12	/	/	/	/	MON	2.0	7.2	13	/	/	/	/	MON
11/2/69	3.0	7.2	12	/	/	/	/	MON	0.2	7.2	14	/	/	/	/	Beer
12/2/69	3.0	7.2	14	/	/	/	/	Beer	0.5	7.2	13	/	/	/	/	Beer
13/2/69	3.0	7.2	15	/	/	/	/	Beer	0.5	7.2	14	/	/	/	/	Beer
14/2/69	3.0	7.2	14	/	/	/	/	Beer	0.5	7.2	13	/	/	/	/	Beer
15/2/69	3.0	7.2	13	/	/	/	/	Beer	0.5	7.2	12	/	/	/	/	Beer
16/2/69	3.0	7.2	15	/	/	/	/	Beer	0.6	7.2	12	/	/	/	/	MON
17/2/69	3.0	7.2	14	/	/	/	/	MON	0.2	7.2	12	/	/	/	/	MON
18/2/69	3.0	7.2	12	/	/	/	/	MON	0.1	7.2	12	/	/	/	/	MON
19/2/69	3.0	7.2	13	/	/	/	/	MON	0.5	7.2	13	/	/	/	/	Beer
20/2/69	1.5	7.2	15	/	/	/	/	Beer	1.0	7.2	12	/	/	/	/	Beer
21/2/69	3.0	7.2	14	/	/	/	/	Beer	0.0	7.2	12	/	/	/	/	MON
22/2/69	3.0	7.2	12	/	/	/	/	MON	0.1	7.2	12	/	/	/	/	MON
23/2/69	3.0	7.2	12	/	/	/	/	MON	0.0	7.2	12	/	/	/	/	MON
24/2/69	3.0	7.2	13	/	/	/	/	MON	0.1	7.2	12	/	/	/	/	MON
25/2/69	3.0	7.2	12	/	/	/	/	MON	0.1	7.2	13	/	/	/	/	MON
26/2/69	3.0	7.2	12	/	/	/	/	MON	1.0	7.2	15	/	/	/	/	Beer
27/2/69	3.0	7.2	14	/	/	/	/	Beer	0.1	7.2	14	/	/	/	/	Beer
28/2/69	3.0	7.2	13	/	/	/	/	Beer	0.1	7.2	12	/	/	/	/	MON

REMARK

Verified by Chief Engineer

Date

28/2/26

POOL DAILY CHECK LIST



SUKHUMVIT 11

MONTH/YEAR:

Mar-26

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1/3/69	3.0	7.2	12	/	/	/	/	MON	0.1	7.2	13	/	/	/	/	MON
2/3/69	3.0	7.2	13	/	/	/	/	MON	0.1	7.2	12	/	/	/	/	MON
3/3/69	3.0	7.2	13	/	/	/	/	MON	0.1	7.2	13	/	/	/	/	MON
4/3/69	3.0	7.2	12	/	/	/	/	MON	0.1	7.2	13	/	/	/	/	MON
5/3/69	3.0	7.2	12	/	/	/	/	MON	0.1	7.2	12	/	/	/	/	Beel
6/3/69	3.0	7.2	14	/	/	/	/	Beel	0.1	7.2	11	/	/	/	/	Beel
7/3/69	3.0	7.2	12	/	/	/	/	Beel	0.2	7.8	14	/	/	/	/	AS
8/3/69	3.0	7.2	14	/	/	/	/	AS	1.0	7.2	12	/	/	/	/	AS
9/3/69	3.0	7.2	12	/	/	/	/	AS	1.0	7.2	18	/	/	/	/	Chang
10/3/69	3.0	7.2	12	/	/	/	/	Chang	1.5	7.2	18	/	/	/	/	Chang
11/3/69	3.0	7.2	12	/	/	/	/	Chang	1.5	7.2	18	/	/	/	/	AS
12/3/69	3.0	7.2	14	/	/	/	/	AS	1.0	7.2	16	/	/	/	/	AS
13/3/69	3.0	7.2	14	/	/	/	/	AS	1.0	7.2	12	/	/	/	/	AS
14/3/69	3.0	7.2	16	/	/	/	/	AS	0.5	7.2	16	/	/	/	/	AS
15/3/69	3.0	7.2	18	/	/	/	/	AS	0.5	7.2	14	/	/	/	/	AS
16/3/69	3.0	7.2	16	/	/	/	/	AS	0.5	7.2	18	/	/	/	/	Chang
17/3/69	3.0	7.2	14	/	/	/	/	Chang	1.5	7.2	14	/	/	/	/	Chang
18/3/69	3.0	7.2	16	/	/	/	/	Chang	0.1	7.2	14	/	/	/	/	AS
19/3/69	3.0	7.2	18	/	/	/	/	AS	0.1	7.2	15	/	/	/	/	AS
20/3/69	3.0	7.2	14	/	/	/	/	AS	2.2	7.2	14	/	/	/	/	AS
21/3/69	3.0	7.2	16	/	/	/	/	AS	0.1	7.2	15	/	/	/	/	AS
22/3/69	3.0	7.2	16	/	/	/	/	AS	0.1	7.2	15	/	/	/	/	AS
23/3/69	3.0	7.2	14	/	/	/	/	AS	0.2	7.2	18	/	/	/	/	Chang
24/3/69	3.0	7.2	14	/	/	/	/	Chang	0.2	7.2	17	/	/	/	/	AS
25/3/69	3.0	7.2	14	/	/	/	/	AS	0.1	7.2	14	/	/	/	/	AS
26/3/69	3.0	7.2	13	/	/	/	/	AS	0.2	7.2	15	/	/	/	/	AS
27/3/69	3.0	7.2	13	/	/	/	/	AS	0.5	7.2	13	/	/	/	/	AS
28/3/69	3.0	7.2	12	/	/	/	/	AS	0.4	7.2	12	/	/	/	/	AS
29/3/69	3.0	7.2	14	/	/	/	/	AS	0.5	7.2	13	/	/	/	/	AS
30/3/69	3.0	7.2	14	/	/	/	/	AS	1.5	7.2	16	/	/	/	/	Chang
31/3/69	3.0	7.2	14	/	/	/	/	Chang	1.5	7.2	18	/	/	/	/	Chang

REMARK

Verified by Chief Engineer

Date

31/3/26

POOL DAILY CHECK LIST



SUKHUMVIT 11

MONTH/YEAR:

Apr-26

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1/4/69	3.0	7.2	14	/	/	/	/	Chang	1.0	7.2	18	/	/	/	/	Chang
2/4/69	3.0	7.2	14	/	/	/	/	Chang	1.0	7.2	16	/	/	/	/	Beer
3/4/69	3.0	7.2	18	/	/	/	/	Beer	1.0	7.2	14	/	/	/	/	Beer
4/4/69	3.0	7.2	13	/	/	/	/	Beer	1.0	7.2	18	/	/	/	/	Chang
5/4/69	3.0	7.2	14	/	/	/	/	Chang	1.0	7.2	14	/	/	/	/	Chang
6/4/69	3.0	7.2	18	/	/	/	/	Chang	1.0	7.2	18	/	/	/	/	Chang
7/4/69	3.0	7.2	14	/	/	/	/	Chang	1.0	7.2	16	/	/	/	/	Chang
8/4/69	3.0	7.2	18	/	/	/	/	Chang	1.0	7.2	18	/	/	/	/	Chang
9/4/69	3.0	7.2	14	/	/	/	/	Chang	1.0	7.2	16	/	/	/	/	Beer
10/4/69	3.0	7.2	14	/	/	/	/	Beer	1.0	7.2	15	/	/	/	/	Beer
11/4/69	3.0	7.2	15	/	/	/	/	Beer	1.5	7.2	18	/	/	/	/	Chang
12/4/69	3.0	7.2	14	/	/	/	/	Chang	1.5	7.2	16	/	/	/	/	Chang
13/4/69	3.0	7.2	18	/	/	/	/	Chang	1.0	7.2	18	/	/	/	/	Chang
14/4/69	3.0	7.2	14	/	/	/	/	Chang	1.5	7.2	18	/	/	/	/	Chang
15/4/69	3.0	7.2	14	/	/	/	/	Chang	1.5	7.2	19	/	/	/	/	Beer
16/4/69	3.0	7.2	13	/	/	/	/	Beer	1.5	7.2	20	/	/	/	/	Beer
17/4/69	3.0	7.2	14	/	/	/	/	Beer	1.5	7.2	16	/	/	/	/	Beer
18/4/69	3.0	7.2	14	/	/	/	/	Beer	1.5	7.2	14	/	/	/	/	Chang
19/4/69	3.0	7.2	14	/	/	/	/	Chang	1.0	7.2	18	/	/	/	/	Chang
20/4/69	3.0	7.2	14	/	/	/	/	Chang	1.0	7.2	18	/	/	/	/	Chang
21/4/69	3.0	7.2	16	/	/	/	/	Chang	1.0	7.2	18	/	/	/	/	Chang
22/4/69	3.0	7.2	14	/	/	/	/	Chang	1.0	7.2	16	/	/	/	/	Chang
23/4/69	3.0	7.2	16	/	/	/	/	Chang	1.0	7.2	15	/	/	/	/	Beer
24/4/69	3.0	7.2	14	/	/	/	/	Beer	1.0	7.2	16	/	/	/	/	Beer
25/4/69	3.0	7.2	14	/	/	/	/	Beer	1.0	7.2	14	/	/	/	/	Chang
26/4/69	3.0	7.2	16	/	/	/	/	Chang	1.5	7.2	18	/	/	/	/	Chang
27/4/69	3.0	7.2	14	/	/	/	/	Chang	1.5	7.2	18	/	/	/	/	Chang
28/4/69	3.0	7.2	18	/	/	/	/	Chang	1.0	7.2	18	/	/	/	/	Chang
29/4/69	3.0	7.2	14	/	/	/	/	Chang	1.0	7.2	18	/	/	/	/	Chang
30/4/69	3.0	7.2	16	/	/	/	/	Chang	1.0	7.2	18	/	/	/	/	Beer

REMARK

Verified by Chief Engineer

[Signature]

Date

30/4/26

POOL DAILY CHECK LIST



SUKHUMVIT 11

MONTH/YEAR:

May-26

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water $\sqrt{X}$	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water $\sqrt{X}$	Record by
1/5/69	3.0	7.2	15	/	/	/	/	Beer	1.0	7.2	18	/	/	/	/	Beer
2/5/69	3.0	7.2	14	/	/	/	/	Beer	1.5	7.2	16	/	/	/	/	Beer
3/5/69	3.0	7.2	15	/	/	/	/	Beer	1.5	7.2	16	/	/	/	/	Beer
4/5/69	3.0	7.2	14	/	/	/	/	Beer	1.5	7.2	16	/	/	/	/	Beer
5/5/69	3.0	7.2	15	/	/	/	/	Beer	1.5	7.2	15	/	/	/	/	Beer
6/5/69	3.0	7.2	14	/	/	/	/	Beer	1.5	7.2	15	/	/	/	/	Beer
7/5/69	3.0	7.2	16	/	/	/	/	Beer	1.5	7.2	17	/	/	/	/	Beer
8/5/69	3.0	7.2	14	/	/	/	/	Beer	1.5	7.2	16	/	/	/	/	Beer
9/5/69	3.0	7.2	14	/	/	/	/	Beer	1.5	7.2	15	/	/	/	/	Beer
10/5/69	3.0	7.2	15	/	/	/	/	Beer	1.5	7.2	14	/	/	/	/	Beer
11/5/69	3.0	7.2	15	/	/	/	/	Beer	1.5	7.2	15	/	/	/	/	Beer
12/5/69	3.0	7.2	15	/	/	/	/	Beer	0.5	7.2	16	/	/	/	/	Beer
13/5/69	3.0	7.2	14	/	/	/	/	Beer	1.5	7.2	15	/	/	/	/	Beer
14/5/69	3.0	7.2	16	/	/	/	/	Beer	1.0	7.2	16	/	/	/	/	Beer
15/5/69	3.0	7.2	14	/	/	/	/	Beer	1.0	7.2	14	/	/	/	/	Beer
16/5/69	3.0	7.2	15	/	/	/	/	Beer	0.9	7.2	15	/	/	/	/	Beer
17/5/69	3.0	7.2	16	/	/	/	/	Beer	0.3	7.2	14	/	/	/	/	Beer
18/5/69	3.0	7.2	16	/	/	/	/	Beer	0.5	7.2	14	/	/	/	/	Beer
19/5/69	3.0	7.2	16	/	/	/	/	Beer	0.5	7.2	16	/	/	/	/	Beer
20/5/69	3.0	7.2	14	/	/	/	/	Beer	1.0	7.2	14	/	/	/	/	Beer
21/5/69	3.0	7.2	15	/	/	/	/	Beer	0.5	7.2	16	/	/	/	/	Beer
22/5/69	3.0	7.2	14	/	/	/	/	Beer	1.0	7.2	15	/	/	/	/	Beer
23/5/69	3.0	7.2	14	/	/	/	/	Beer	0.5	7.2	14	/	/	/	/	Beer
24/5/69	3.0	7.2	15	/	/	/	/	Beer	0.9	7.2	14	/	/	/	/	Beer
25/5/69	3.0	7.2	15	/	/	/	/	Beer	0.2	7.2	15	/	/	/	/	Beer
26/5/69	3.0	7.2	16	/	/	/	/	Beer	0.5	7.2	14	/	/	/	/	Beer
27/5/69	3.0	7.2	15	/	/	/	/	Beer	1.0	7.2	16	/	/	/	/	Beer
28/5/69	3.0	7.2	13	/	/	/	/	Beer	0.5	7.2	15	/	/	/	/	Beer
29/5/69	3.0	7.2	13	/	/	/	/	Beer	0.5	7.2	17	/	/	/	/	Beer
30/5/69	3.0	7.2	14	/	/	/	/	Beer	1.0	7.2	16	/	/	/	/	Beer
31/5/69	3.0	7.2	15	/	/	/	/	Beer								

REMARK

Verified by Chief Engineer

[Signature]

Date

31/5/26

Dan 4/6/26

POOL DAILY CHECK LIST



Travelodge

SUKHUMVIT 11

MONTH/YEAR:

Jun-26

DATE	TIME															
	04.00								14.00							
	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Clear Water ✓/X	Filter Pump	Filter Back wash	Main switch board	Record by	CL (1-3)	PH (7.2-7.6)	Filter Press (8-18 Psi)	Filter Pump	Filter Back wash	Main switch board	Clear Water ✓/X	Record by
1/6/69	3.0	7.2	15	/	/	/	/	DS	0.2	7.2	16	/	/	/	/	DS
2/6/69	3.0	7.2	14	/	/	/	/	DS	0.2	7.2	15	/	/	/	/	DS
3/6/69	3.0	7.2	15	/	/	/	/	DS	0.2	7.2	16	/	/	/	/	DS
4/6/69	3.0	7.2	16	/	/	/	/	DS	0.5	7.2	15	/	/	/	/	DS
5/6/69	3.0	7.2	16	/	/	/	/	DS	0.2	7.2	14	/	/	/	/	DS
6/6/69	3.0	7.2	16	/	/	/	/	DS	0.1	7.2	14	/	/	/	/	MON
7/6/69	3.0	7.2	13	/	/	/	/	MON	0.2	7.2	14	/	/	/	/	MON
8/6/69	3.0	7.2	12	/	/	/	/	MON	0.1	7.2	12	/	/	/	/	MON
9/6/69	3.0	7.2	13	/	/	/	/	MON	0.1	7.2	14	/	/	/	/	MON
10/6/69	3.0	7.2	16	/	/	/	/	MON	0.1	7.2	14	/	/	/	/	MON
11/6/69	3.0	7.2	13	/	/	/	/	MON	1.0	7.2	15	/	/	/	/	DS
12/6/69	3.0	7.2	14	/	/	/	/	DS	0.5	7.2	14	/	/	/	/	DS
13/6/69	3.0	7.2	15	/	/	/	/	DS	0.1	7.2	14	/	/	/	/	MON
14/6/69	3.0	7.2	14	/	/	/	/	MON	3.0	7.2	14	/	/	/	/	MON
15/6/69	3.0	7.2	14	/	/	/	/	MON	3.0	7.2	14	/	/	/	/	MON
16/6/69	3.0	7.2	14	/	/	/	/	MON	3.0	7.2	14	/	/	/	/	MON
17/6/69	3.0	7.2	12	/	/	/	/	MON	0.5	7.2	14	/	/	/	/	MON
18/6/69	3.0	7.2	12	/	/	/	/	MON	2.5	7.2	14	/	/	/	/	DS
19/6/69	3.0	7.2	16	/	/	/	/	DS	0.7	7.2	14	/	/	/	/	DS
20/6/69	3.0	7.2	18	/	/	/	/	DS	2.0	7.2	13	/	/	/	/	MON
21/6/69	3.0	7.2	16	/	/	/	/	MON	2.0	7.2	14	/	/	/	/	MON
22/6/69	3.0	7.2	14	/	/	/	/	MON	2.0	7.2	13	/	/	/	/	MON
23/6/69	3.0	7.2	14	/	/	/	/	MON	1.6	7.2	14	/	/	/	/	MON
24/6/69	3.0	7.2	14	/	/	/	/	MON	1.6	7.2	14	/	/	/	/	MON
25/6/69	3.0	7.2	14	/	/	/	/	MON	1.0	7.2	14	/	/	/	/	MON
26/6/69	3.0	7.2	14	/	/	/	/	MON	0.5	7.2	15	/	/	/	/	DS
27/6/69	3.0	7.2	14	/	/	/	/	DS	0.2	7.2	15	/	/	/	/	DS
28/6/69	3.0	7.2	15	/	/	/	/	DS	0.0	7.2	14	/	/	/	/	DS
29/6/69	3.0	7.2	14	/	/	/	/	DS	3.0	7.2	14	/	/	/	/	DS
30/6/69	3.0	7.2	14	/	/	/	/	DS	1.0	7.2	14	/	/	/	/	DS
1/7/69	3.0	7.2	14	/	/	/	/	DS								

REMARK

Verified by Chief Engineer DS

Date 30/6/21

DS