

ภาคผนวก ข

การป้องกันอัคคีภัย

ภาคผนวก ช-1

รายงานผลการฝึกอบรมการดับเพลิงขั้นต้น

และรายงานผลการฝึกซ้อมดับเพลิง

และฝึกซ้อมอพยพหนีไฟ



ที่ กท ๑๘๐๕/๒๕๕๗

สำนักป้องกันและบรรเทาสาธารณภัย

๗๗/๑ ถนนพระราม ๖ กทม.๑๐๕๐๐

๒๘ กันยายน ๒๕๖๘

เรื่อง รายงานสรุปผลการจัดฝึกอบรมการดับเพลิงขั้นต้น และฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ

เรียน ผู้จัดการ โรงแรม เทรเวล ลอดจ์ สุขุมวิท ๑๑

- | | |
|---|---------------|
| สิ่งที่ส่งมาด้วย ๑. รายงานสรุปผลการจัดฝึกอบรมการดับเพลิงขั้นต้น | จำนวน ๑ ฉบับ |
| ๒. รายงานสรุปผลการจัดฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ | จำนวน ๑ ฉบับ |
| ๓. วุฒิบัตรสำหรับหน่วยงานที่ผ่านการฝึกซ้อมดับเพลิงฯ | จำนวน ๑ ฉบับ |
| ๔. วุฒิบัตรสำหรับหน่วยงานที่ผ่านการฝึกอบรมการดับเพลิงขั้นต้น | จำนวน ๒๓ ฉบับ |

ตามที่ โรงแรม เทรเวล ลอดจ์ สุขุมวิท ๑๑ ขอรับการสนับสนุนวิทยากรเพื่อทำฝึกอบรมการดับเพลิงขั้นต้นและฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ ให้กับพนักงานของอาคาร ในวันที่ ๑๕ กันยายน ๒๕๖๘ นั้น

สำนักป้องกันและบรรเทาสาธารณภัย กรุงเทพมหานคร ในฐานะนิติบุคคลผู้ให้บริการฝึกอบรมฯ ของกรุงเทพมหานคร ได้ดำเนินการฝึกอบรมการดับเพลิงขั้นต้น และฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ ให้กับพนักงานของ โรงแรม เทรเวล ลอดจ์ สุขุมวิท ๑๑ เมื่อวันที่ ๑๕ กันยายน ๒๕๖๘ เรียบร้อยแล้ว รายละเอียดตามสิ่งที่ส่งมาด้วย

จึงเรียนมาเพื่อทราบ

ขอแสดงความนับถือ

(นายสุริยชัย รวีวรรณ)

ผู้อำนวยการสำนักป้องกันและบรรเทาสาธารณภัย

กองปฏิบัติการดับเพลิงและกู้ภัย ๒

โทรศัพท์ ๐ ๒๓๕๔ ๖๘๔๖

โทรสาร ๐ ๒๓๕๔ ๖๘๔๖



ที่ กท ๑๘๐๕/๒๕๕๘

สำนักป้องกันและบรรเทาสาธารณภัย

๗๗/๑ ถนนพระราม ๖ กทม.๑๐๕๐๐

๒๗ กันยายน ๒๕๖๘

เรื่อง รายงานสรุปผลการฝึกอบรมการดับเพลิงขั้นต้น และฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ

เรียน ผู้อำนวยการกองความปลอดภัยแรงงาน กรมสวัสดิการและคุ้มครองแรงงาน

สิ่งที่ส่งมาด้วย ๑. รายงานสรุปผลการจัดอบรมการดับเพลิงขั้นต้น จำนวน ๑ ฉบับ

๒. รายงานสรุปผลการจัดฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ จำนวน ๑ ฉบับ

ด้วย โรงแรมเทรเวลลอดจ์ สุขุมวิท ๑๑ ขอรับการสนับสนุนวิทยากรการฝึกอบรมการดับเพลิงขั้นต้น และฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ เพื่อดำเนินการให้เป็นไปตามกฎกระทรวงกำหนดมาตรฐานในการบริหาร จัดการและดำเนินการความปลอดภัย อาชีวอนามัย และสภาพแวดล้อมในการทำงานเกี่ยวกับการป้องกันและระงับอัคคีภัย พ.ศ.๒๕๕๕

สำนักป้องกันและบรรเทาสาธารณภัย กรุงเทพมหานคร ในฐานะนิติบุคคลผู้ให้บริการฝึกอบรมฯ ของกรุงเทพมหานคร ได้ดำเนินการฝึกอบรมการดับเพลิงขั้นต้น และฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ ให้กับพนักงานของ โรงแรม เทรเวล ลอดจ์ สุขุมวิท ๑๑ เมื่อวันที่ ๑๕ กันยายน ๒๕๖๘ รายละเอียดตามสิ่งที่ส่งมาด้วย

จึงเรียนมาโปรดเพื่อทราบ

ขอแสดงความนับถือ

(นายสุริชัย รวีวรรณ)

ผู้อำนวยการสำนักป้องกันและบรรเทาสาธารณภัย

กองปฏิบัติการดับเพลิงและกู้ภัย ๒

โทรศัพท์ ๐ ๒๓๕๔ ๖๘๔๖

โทรสาร ๐ ๒๓๕๔ ๖๘๔๖

การรายงานสรุปผลการจัดฝึกอบรมการดับเพลิงขั้นต้น

เขียนที่ สถานีดับเพลิงและกู้ภัยคลองเตย.....

วันที่ ๑๖ เดือน กันยายน พ.ศ. ๒๕๖๘

ส่วนที่ ๑ ข้อมูลผู้รับใบอนุญาต

ชื่อผู้รับใบอนุญาต กรุงเทพมหานคร (สำนักป้องกันและบรรเทาสาธารณภัย).....

เลขทะเบียนนิติบุคคล ๐-๙๙๔๐-๐๐๑๖๐-๑๕-๑

ใบอนุญาตเลขที่ ๐๑๐๑-๐๒-๒๕๖๗-๐๑๔๑ วันอนุญาต ๑๙ กรกฎาคม ๒๕๖๗ วันหมดอายุ ๑๘ กรกฎาคม ๒๕๗๐

ตั้งอยู่เลขที่ ๑๗๓ หมู่ที่ ๑๑ ตรอก/ซอย - ถนน ดินสอ แขวง/ตำบล เสาชิงช้า เขต/อำเภอ พระนคร

จังหวัด กรุงเทพมหานคร รหัสไปรษณีย์ ๑๐๒๐๐ โทรศัพท์ ๐-๒๒๗๙ ๗๓๐๓ โทรสาร ๐-๒๒๗๙ ๗๓๐๔

E-mail fireinspectionbma@gmail.com

ส่วนที่ ๒ การดำเนินการจัดฝึกอบรมการดับเพลิงขั้นต้น

สถานที่จัดฝึกอบรม (ภาคทฤษฎี) โรงแรม เทรเวล ลอดจ์ สุขุมวิท ๑๑

ตั้งอยู่ เลขที่ ๓๐/๙-๑๐ หมู่ที่ ๑๑ - ตรอก/ซอย สุขุมวิท ๑๑ (ไชยยศ) ถนน สุขุมวิท

แขวง/ตำบล คลองเตยเหนือ เขต/อำเภอ วัฒนา จังหวัด กรุงเทพมหานคร

รหัสไปรษณีย์ ๑๐๑๑๐ โทรศัพท์ - โทรสาร -

สถานที่จัดฝึกอบรม (ภาคปฏิบัติ) โรงแรม เทรเวล ลอดจ์ สุขุมวิท ๑๑

ตั้งอยู่ เลขที่ ๓๐/๙-๑๐ หมู่ที่ ๑๑ - ตรอก/ซอย สุขุมวิท ๑๑ (ไชยยศ) ถนน สุขุมวิท

แขวง/ตำบล คลองเตยเหนือ เขต/อำเภอ วัฒนา จังหวัด กรุงเทพมหานคร

รหัสไปรษณีย์ ๑๐๑๑๐ โทรศัพท์ - โทรสาร -

กำหนดการจัดฝึกอบรมการดับเพลิงขั้นต้น เมื่อวันที่ ๑๕ เดือน กันยายน พ.ศ. ๒๕๖๘

ผู้เข้ารับการฝึกอบรม จำนวน ๒๓ คน ชาย ๙ คน หญิง ๑๔ คน

ส่วนที่ ๓ เอกสารหรือหลักฐานที่ต้องแนบ ดังนี้

๑. สำเนาแบบแจ้งกำหนดการจัดฝึกอบรมการดับเพลิงขั้นต้น (แบบ ภ.ร.ง.๑)

๒. รายชื่อผู้ผ่านการฝึกอบรม

๓. รายชื่อวิทยากร (ภาคทฤษฎีและภาคปฏิบัติ)



(ถ้ามี)

ลงชื่อ

ผู้รับใบอนุญาต

ผู้อำนวยการสำนักป้องกันและบรรเทาสาธารณภัย

วันที่ ๑๖ เดือน กันยายน พ.ศ. ๒๕๖๘

หมายเหตุ ๑. กรณีเป็นนิติบุคคลที่มีหนังสือรับรองนิติบุคคลให้ประทับตรา จะต้องมีการประทับพร้อมลงนาม



















๒. ให้รายงานสรุปผลการให้บริการจัดฝึกอบรมการดับเพลิงขั้นต้น ให้แจ้งตามแบบ ภ.ร.ง.๑ ต่อการให้บริการ ๑ ครั้ง ทั้งนี้ ภายใน ๓๐ วันนับแต่วันที่เสร็จสิ้นการให้บริการ

รายชื่อพนักงานเข้าร่วมการอบรมดับเพลิงขั้นต้นและฝึกซ้อมอพยพหนีไฟ ประจำปี 2568

โรงแรม เทรเวล ลอตซ์ สุขุมวิท 11

วันที่ 15 กันยายน เวลา 09.00 - 17.00 น.

ณ ห้องฝึกอบรม

ที่	ชื่อพนักงาน	แผนก	ลงชื่อลายเซ็นต์	ลงชื่อลายเซ็นต์	คะแนน pre test	คะแนน Post test
1	นายประชา เรืองกลัด	EN			12	18
2	นายวิเชียร พานจันทร์	EN			14	20
3	นายเรืองวิทย์ ชำรัมย์	EN			16	20
4	นายอดิศร อะทอยรัมย์	EN			8	18
5	น.ส.ปภารัตน์ งามเลิศศิรัชย์	FO			11	20
6	น.ส.วัชรพร เหล่าแหลม	FO			11	19
7	นายสยมภู พุ่มเจริญ	FO			14	19
8	น.ส.สมาลี เกษ	FO			8	19
9	น.ส.ฐิติรัตน์ จิตปรีชา	HR			14	20
10	น.ส.เกวารินทร์ ยุวะพุกกะ	FBS			12	20
11	น.ส.ปภัสสร สังเผือก	FBS			13	16
12	น.ส.จิราภรณ์ สาริบุญ	FBS			12	19
13	นายวีรวัฒน์ ท่าจอหอ	FBS			9	19
14	นายคชาวุฒิ เกิดสุวรรณ	HK			14	20
15	นายวัฒน์ชรา ะวีวัฒน์	HK			12	20
16	นายปริญญาฉัตร พลเกล็ด	HK			10	20
17	น.ส.วรรณลดา แสงพล	HK			10	20
18	น.ส.ชลธิชา เขียวทองอินทร์	HK			10	20
19	น.ส.ปณทริกา ลีนกุล	AD			10	20
20	น.ส.วฤณดา คุ่มถนอม	SM			10	19
21	น.ส.ชิตาภรณ์ บุญเกื้อ	SM			11	20
22	น.ส.พาราซีลา มานะ	AC			-	-
23	น.ส.อานีฟ เจ๊ะมู	AC			6	19
24	นายคณาธิป วรผล	KT			-	-

ดร. น.ส. อารุณี สิริมอญะม ๐๓





เจ้าหน้าที่ย่อย

(วชรพงษ์ ศรีสะอาด)

เจ้าพนักงานป้องกันและบรรเทาสาธารณภัยชำนาญการ
สถานีดับเพลิงและกู้ภัยคลองเตย กองปฏิบัติการดับเพลิงและกู้ภัย ๒
สำนักป้องกันและบรรเทาสาธารณภัย

รายงานสรุปผลการจัดฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ

เขียนที่ สถานีดับเพลิงและกู้ภัยคลองเตย.....

วันที่ ๑๖ เดือน กันยายน พ.ศ.๒๕๖๘

ส่วนที่ ๑ ข้อมูลผู้รับใบอนุญาต

ชื่อผู้รับใบอนุญาต กรุงเทพมหานคร (สำนักป้องกันและบรรเทาสาธารณภัย).....

เลขทะเบียนนิติบุคคล

๐-๙๙๔๐-๐๐๐๑๖๐-๑๕-๑

ใบอนุญาตเลขที่ ๐๑๐๒-๐๒-๒๕๖๗-๐๑๕๑ วันอนุญาต ๑๙ กรกฎาคม ๒๕๖๗ วันหมดอายุ ๑๙ กรกฎาคม ๒๕๗๐

ตั้งอยู่เลขที่ ๑๗๓ หมู่ที่ ๑ ตรอก/ซอย - ถนน ดินสอ แขวง/ตำบล เสาชิงช้า เขต/อำเภอ พระนคร

จังหวัด กรุงเทพมหานคร รหัสไปรษณีย์ ๑๐๒๐๐ โทรศัพท์ ๐ ๒๒๗๙ ๗๓๐๓ โทรสาร ๐ ๒๒๗๙ ๗๓๐๔

E-mail fireinspectionbma@gmail.comส่วนที่ ๒ การดำเนินการจัดฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ (ทำเครื่องหมาย ✓ ในช่อง ☐)☒ กรณีสถานประกอบกิจการเดียวชื่อสถานประกอบกิจการ โรงแรมเทรเวลลอดจ์ สุขุมวิท ๑๑.....

ประเภทกิจการ.....บริการห้องพัก.....

ตั้งอยู่เลขที่ ๓๐/๙-๑๐ หมู่ที่ - ตรอก/ซอย สุขุมวิท ๑๑ (ไชยยศ) ถนน สุขุมวิท

แขวง/ตำบล คลองเตยเหนือ เขต/อำเภอ วัฒนา จังหวัด กรุงเทพมหานคร

รหัสไปรษณีย์ ๑๐๑๑๐ โทรศัพท์ - โทรสาร -

E-mail -

ลูกจ้างทั้งหมด จำนวน ๖๕ คน ผู้เข้ารับการฝึกซ้อมทั้งหมด จำนวน ๔๑ คน

ชาย ๑๖ คน หญิง ๒๕ คน ใช้เวลาในการฝึกซ้อม ๕ นาที

ผลการดำเนินการฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ

☐ ไม่ดี ☐ พอใช้ ☒ ดี ☐ ดีมาก☐ กรณีสถานที่ที่มีหลายสถานประกอบกิจการตั้งอยู่ร่วมกัน

ระบุชื่ออาคาร/สถานที่.....

ตั้งอยู่เลขที่ หมู่ที่ ตรอก/ซอย ถนน

แขวง/ตำบล เขต/อำเภอ จังหวัด

รหัสไปรษณีย์ โทรศัพท์ โทรสาร

E-mail

สถานประกอบกิจการที่เข้าร่วมทั้งหมด จำนวน แห่ง ประกอบด้วย

๑. ชื่อสถานประกอบกิจการ.....

ลูกจ้างทั้งหมด จำนวน คน ผู้เข้ารับการฝึกซ้อมทั้งหมด จำนวน คน

๒. ชื่อสถานประกอบกิจการ.....

ลูกจ้างทั้งหมด จำนวน คน ผู้เข้ารับการฝึกซ้อมทั้งหมด จำนวน คน

๓. ชื่อสถานประกอบกิจการ.....

ลูกจ้างทั้งหมด จำนวน คน ผู้เข้ารับการฝึกซ้อมทั้งหมด จำนวน คน

(กรณีมีสถานประกอบกิจการเข้าร่วมฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟหลายแห่ง สามารถเพิ่มข้อมูลหรือจัดทำเอกสารแนบเพิ่มเติมได้)

กำหนดการจัดฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ วันที่ ๑๕ เดือน กันยายน พ.ศ. ๒๕๖๘

ส่วนที่ ๓ เอกสารหรือหลักฐานที่ต้องแนบ ดังนี้

๑. สำเนาแบบแจ้งกำหนดการจัดฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ (แบบ กภ.จ.๒)
๒. รายชื่อวิทยากร
๓. รายละเอียดและผลการประเมินการฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ



(ถ้ามี)

ลงชื่อ

(นายสุริยชัย รวีวรรณ)

ผู้รับใบอนุญาต

ผู้อำนวยการสำนักป้องกันและบรรเทาสาธารณภัย

วันที่ ๒๙ เดือน ก.ย. ๒๕๖๘

หมายเหตุ ๑. กรณีเป็นนิติบุคคลที่มีหนังสือรับรองนิติบุคคลให้ประทับตรา จะต้องมีการประทับพร้อมลงนาม

๒. ให้รายงานสรุปผลการให้บริการจัดฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ ตามแบบ แบบ กภ.รง.๒ ต่อการให้บริการ ๑ ครั้ง ทั้งนี้ ภายใน ๓๐ วันนับแต่วันที่เสร็จสิ้นการให้บริการ

รายชื่อพนักงานเข้าร่วมการฝึกซ้อมอพยพหนีไฟ ประจำปี 2568

โรงแรม เทรเวล ลอตซ์ สุขุมวิท 11

วันที่ 15 กันยายน เวลา 09.00 - 17.00 น.

ณ ห้องฝึกอบรม

ที่	ชื่อพนักงาน	แผนก
1	นายประชา เรืองกลัด	EN
2	นายวิเชียร พานจันทร์	EN
3	นายเรืองวิทย์ ชำรัมย์	EN
4	นายอดิศร อะทอยรัมย์	EN
5	น.ส.ปภารัตน์ งามเลิศศิริชัย	FO
6	น.ส.วัชรพร เหล่าเข้ม	FO
7	นายสยมภู พุ่มเจริญ	FO
8	น.ส.สุมาลี เกษี	FO
9	อรอนงค์ ทองธนะเศรษฐ์	FO
10	ลักษณาลิน วิจิตรกิจการ	FO
11	ชนิตา เกียรติบำรุงกุล	FO
12	น.ส.ฐิติรัตน์ จิตปรีชา	HR
13	น.ส.เกวารินทร์ ยูวะพุกกะ	FBS
14	น.ส.ปภัสสร ส้มเผือก	FBS
15	น.ส.จิราภรณ์ สาริบุญ	FBS
16	นายวีรวัฒน์ ทำจอหอ	FBS
17	อนิมา บัวเทศ	FBS
18	ฐาปกรณ์ ภูผกา	FBS
19	เกียรติศักดิ์ พรหมมาอาจ	FBS
20	นายคชาวุฒิ เกิดสุวรรณ	HK
21	นายวัฒน์ชรา ะวิวัฒน์	HK
22	นายปริญญาฉัตร พลเกิ้ล	HK
23	น.ส.วรรณลดา แสงพล	HK
24	น.ส.ชลธิชา เขียวทองอินทร์	HK
25	ฐากร ภัทรโชคธราดล	HK

รายชื่อพนักงานเข้าร่วมการฝึกซ้อมอพยพหนีไฟ ประจำปี 2568

โรงแรม เทรเวล สตจ้ สุภูมิวิท 11

วันที่ 15 กันยายน เวลา 09.00 - 17.00 น.

ณ ห้องฝึกอบรม

ที่	ชื่อพนักงาน	แผนก
26	ลาภิสรา ไททอง	HK
27	นพรดา คล้ายเอี่ยม	HK
28	ธนศักดิ์ พ.ศ.ธร	HK
29	ศรีแพร ไชยจันทร์	HK
30	น.ส.ดารุณี สิริมอรุณ	AG
31	น.ส.ปทุมทริกา สีนุกูล	AD
32	น.ส.วฤณดา คุ่มถนอม	SM
33	น.ส.ชิตาภรณ์ บุญเกื้อ	SM
34	น.ส.ฟาราซีลา มานะ	AC
35	น.ส.อานีฟ เจ๊ะมู	AC
36	น.ส.ภาวิณี เจิดกระโทก	AC
37	น.ส.ฟาราซีลา มานา	AC
38	นายนิฮัลลีซ กะลู่แป	AC
39	น.ส.ศิริกร ทองเจริญ	AC
40	น.ส.อัมภา พิมพร	KT
41	นายวุฒิชัย จันทรธรรม	KT

ว่าที่ร้อยเอก

(วชรพงษ์ ศรีสอาด)

เจ้าพนักงานป้องกันและบรรเทาสาธารณภัยชำนาญการ
สถานีดับเพลิงและกู้ภัยคลองเตย กองปฏิบัติการดับเพลิงและกู้ภัย ๒
สำนักป้องกันและบรรเทาสาธารณภัย



กรุงเทพมหานคร



ได้รับใบอนุญาตจากกรมสวัสดิการและคุ้มครองแรงงาน ใบอนุญาตเลขที่ ๐๑๐๒-๐๒-๒๕๖๗-๐๑๕๑
ขอรับรองว่า

โรงแรม เทรเวล ลอตจ์ สุขุมวิท ๑๑

ตั้งอยู่เลขที่ ๓๐/๙-๑๐ ซอยสุขุมวิท ๑๑ (ซอยศ) ถนนสุขุมวิท แขวงคลองเตยเหนือ เขตวัฒนา กรุงเทพมหานคร ๑๐๑๑๐

ได้ดำเนินการฝึกซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ

ตามกฎกระทรวงกำหนดมาตรฐานในการบริหาร จัดการ และดำเนินการด้านความปลอดภัย อาชีวอนามัย
และสภาพแวดล้อมในการทำงานเกี่ยวกับการป้องกันและระงับอัคคีภัย พ.ศ. ๒๕๕๕ ลงวันที่ ๗ ธันวาคม พ.ศ. ๒๕๕๕

มีผู้เข้ารับการฝึกอบรม จำนวน ๔๑ คน

เมื่อวันที่ ๑๕ กันยายน ๒๕๖๘

ให้ไว้ ณ วันที่ ๒๙ กย. ๒๕๖๘


(นายสุริยชัย รวีวรรณ)

ผู้อำนวยการสำนักป้องกันและบรรเทาสาธารณภัย
ปฏิบัติราชการแทนผู้ว่าราชการกรุงเทพมหานคร

ภาคผนวก ช-2

รายงานผลการซ้อมดับเพลิงและฝึกซ้อมอพยพหนีไฟ

ภายในโครงการ

Internal Action fire alarm and evacuation on 22.05.2026

- 15.10 hrs. Start testing the fire alarm using a Smoking Tester Spray in Room 1308 by Fire brigade and then fire alarm panel notifications by smoke detector found that smoking in Room 1308
 - The engineering team were alerted by the smoke detection system control panel.
 - The engineering team inspected the room, knocked on the door, and entered to find smoke inside. They inspected the room with fire extinguishers. However, it was assessed that the fire could not be contained as it was spreading rapidly.
 - The engineering team informed the situation with the Front Desk, and then the Front Desk informed the firefighting team.
 - The firefighting support team checked the incident location, equipped with fire extinguisher canisters and protective gear, reached the scene, connected to the water line, and fought the fire.
 - The firefighting support team reported that the fire couldn't be extinguished and informed the Front Desk.
- 16.15 hrs. Fire Alarm notifications by Siren at Building B on 1st, 3rd fl. That is sandwich notification.
 - The Front Desk call Klongtoey Fire Station at 086-321-1199.
 - The Front Desk informed GM and MOD to request approval for evacuation plan.
- 16.18 hrs. Siren signal and the evacuation announcement is made through the speakers, notifying people in both buildings to evacuate.
- 16.20 hrs. The elevators at building A and B descend and stop at the G floor in step 3 with the doors open and held.
- Turn off the fire alarm testing and reset the system back to normal standby mode.
- Conclusion, the counting time from incident detection to evacuation notification was 10 minutes.
 - Step 1 = 5 minutes
 - Step 2 = 3 minutes
 - Step 3 = 2 minutes

Remark:

- The inspection of the incident alert devices throughout Buildings A and B revealed that all points are functioning normally.


**การดำเนินการภายใน: สัญญาณเตือนไฟไหม้และการอพยพ เมื่อวันที่ 22 พฤษภาคม 2569**

- เวลา 15.10 น. เริ่มทดสอบสัญญาณเตือนไฟไหม้โดยใช้สเปกตรัมทดสอบควันในห้อง 1308 โดยหน่วยดับเพลิง จากนั้นแจ้งควบคุมสัญญาณเตือนไฟไหม้ได้รับการแจ้งเตือนจากเครื่องตรวจจับควัน พบว่ามีการสูบบุหรี่ในห้อง 1308
 - ทีมวิศวกรได้รับการแจ้งเตือนจากแผงควบคุมระบบตรวจจับควัน
 - ทีมวิศวกรตรวจสอบห้อง เคาะประตู และเข้าไปข้างใน พบว่ามีควันอยู่ภายใน พวกเขาตรวจสอบห้องด้วยถังดับเพลิง อย่างไรก็ตาม ประเมินแล้วว่าไม่สามารถควบคุมไฟได้ เนื่องจากไฟกำลังลุกลามอย่างรวดเร็ว
 - ทีมวิศวกรแจ้งสถานการณ์ให้แผนกต้อนรับทราบ จากนั้นแผนกต้อนรับจึงแจ้งทีมดับเพลิง
 - ทีมสนับสนุนการดับเพลิงตรวจสอบสถานที่เกิดเหตุ พร้อมด้วยถังดับเพลิงและอุปกรณ์ป้องกัน เดินทางไปยังที่เกิดเหตุ ต่อสายน้ำ และทำการดับเพลิง
 - ทีมสนับสนุนการดับเพลิงรายงานว่าไม่สามารถดับไฟได้ และแจ้งให้แผนกต้อนรับทราบ
- เวลา 16.15 น. มีสัญญาณเตือนภัยไฟไหม้ดังมาจากไซเรนที่อาคาร B ชั้น 1 และชั้น 3 ซึ่งเป็นการแจ้งเตือนแบบซ้อน (sandwich notification)
 - แผนกต้อนรับโทรแจ้งสถานีดับเพลิงคลองเตยที่หมายเลข 086-321-1199
 - แผนกต้อนรับแจ้งผู้จัดการทั่วไปและผู้จัดการเวรเพื่อขออนุมัติแผนการอพยพ
- เวลา 16.18 น. มีสัญญาณไซเรนและประกาศการอพยพผ่านลำโพง แจ้งให้ผู้คนในทั้งสองอาคารอพยพ
- เวลา 16.20 น. ลิฟต์ในอาคาร A และ B ลงและหยุดที่ชั้น G ชั้นที่ 3 โดยประตูเปิดและค้างอยู่
- ปิดการทดสอบสัญญาณเตือนไฟไหม้และรีเซ็ตระบบกลับสู่โหมดสแตนด์บายปกติ
- สรุป เวลาตั้งแต่ตรวจพบเหตุการณ์จนถึงการแจ้งเตือนการอพยพคือ 10 นาที
 - ชั้นตอนที่ 1 = 5 นาที
 - ชั้นตอนที่ 2 = 3 นาที
 - ชั้นตอนที่ 3 = 2 นาที


หมายเหตุ:

- การตรวจสอบอุปกรณ์แจ้งเตือนเหตุการณ์ทั่วทั้งอาคาร A และ B พบว่าทุกจุดทำงานได้ตามปกติ

Proposed by,


Khun Pracha Ruengglad
Engineering Manager

Approved by,


Khun Darunee Sarimarun
General Manager

Travelodge Sukhumvit 11
30/9-10 Soi Sukhumvit 11 (Chaiyos
Klongtoey-Nua, Wattana, Bangkok 10110 Thailand
T +66 2 491 39



TRAINING ATTENDANCE RECORD

TRAINING ATTENDANCE RECORD

Topic : Internal Fire Evacuation Training (Simulation)

Date : 22/5/2026

Time : 14.45 hrs. - 15.00 hrs.

Venue : TLGB.

Trainer : K. Prachya. & HRM.

No.	Name	Position	Department	Signature
ลำดับ	ชื่อ-สกุล	ตำแหน่ง	แผนก	ลายเซ็น
1	Piathip Khrueamvang	Asst. Hk Mgr	Hk	Piathip
2	Atisorn Atoyram	ช่างเทคนิค	Eng	Atisorn
3	วัฒนศิริ วัฒนศิริ	PA	HK	วัฒนศิริ
4	Kitchapong Kuaha	commis II	KC	Kitchapong
5	นพธำมศ ธรรมะจารุณ	Es. chef	lec	นพธำมศ
6	Papharat Ngamlertsirichai	FOM	FO	Papharat
7	วิภากร ชัยทอง	Hk Sep	Hk	วิภากร
8	ณัฐพร งามทอง	PA	HK	ณัฐพร
9	ณัฐพร งามทอง	R/S	HK	ณัฐพร
10	ณัฐพร งามทอง	R/A	HK	ณัฐพร
11	ณัฐพร งามทอง	SR. Room Attendant	Hk	ณัฐพร
12	ณัฐพร งามทอง	PA	HK	ณัฐพร
13	ณัฐพร งามทอง	PA	HK	ณัฐพร
14	ณัฐพร งามทอง	PA	HK	ณัฐพร
15	ณัฐพร งามทอง	PA	HK	ณัฐพร
16	ณัฐพร งามทอง	PA	HK	ณัฐพร
17	ณัฐพร งามทอง	Commis	KC	ณัฐพร
18	ณัฐพร งามทอง	Commis	KC	ณัฐพร
19				
20				

Prepared by : _____

Department Trainer

Department Heads

Acknowledged by : _____

Human Resources Manager

Please return original copy to HR Dept. on the next day after the session was completed.

TRAINING ATTENDANCE RECORD

Topic : Internal Fire Evacuation Training (simulation).

Date : 22/5/2026.

Time : 1500 hr

Venue : TLBB.

Trainer : HRM & ENM.

No.	Name	Position	Department	Signature
ลำดับ	ชื่อ-สกุล	ตำแหน่ง	แผนก	ลายเซ็น
1	Pantarika Leendkool	Admin Assis	AG	Pantarika
2	MRONGCHAI TREJARUMAP	Ex. chef	KC	Mrongchai
3	Orawan Khvachan	Restaurant Mgr.	PB	Orawan
4	Amilyn Chemu	Cost	AC	Amilyn
5	Postatorn Jamsrikan	Store	AC	Postatorn
6	Postatorn Jamsrikan	Trainee	AC	Postatorn
7	Aspakorn Phakhumponz	Purchasing	AC	Aspakorn
8	Nisiny Kalupae	AP	AC	Nisiny
9	Pracha Ruengplad	Gen	Fuz	Pracha
10	Wichian Phanchan	Sup Eng	Eng	Wichian
11	Papharat N.	FOM	FO	Papharat
12	Chanita K.	Sup FO	FO	Chanita
13	Oranong T.	RSVN Mgr	FO	Oranong
14	Sumalee K.	RSVN Sup	FO	Sumalee
15	Peerada Amnuaysit	RSVN	FO	Peerada
16	Laksanalin Visitkijkam	GSA	FO	Laksanalin
17	Kitchapong Kuana	commis II	KC	Kitchapong
18	Pornnatcha Raksa-pon	commis II	KC	Pornnatcha
19	Phong Phak Welunwanarak	Commis II	KC	Phong Phak
20	Wuttichai Chan Tharn	Steward	KC	Wuttichai

Prepared by : _____

Department Trainer

Department Heads

Acknowledged by : _____

Human Resources Manager

Please return original copy to HR Dept. on the next day after the session was completed.



Trainer : Thitirat Chitprijia & Natcha Ruengglad

Please return original copy to HR Dept. on the next day after the session was completed.

ภาคผนวก ช-3

การตรวจสอบอุปกรณ์ดับเพลิง

EQUIPMENT NAME :



ลำดับ	รายการตรวจเช็ค	■ □ □ □ M Q S Y	■ □ □ □ M Q S Y	■ □ □ □ M Q S Y	■ □ □ □ M Q S Y	■ □ □ □ M Q S Y	■ □ □ □ M Q S Y	■ □ □ □ M Q S Y	■ □ □ □ M Q S Y	■ □ □ □ M Q S Y	■ □ □ □ M Q S Y	■ □ □ □ M Q S Y
		วันที่ 1/1/26	วันที่ 2/2/26	วันที่ 1/3/26	วันที่ 1/4/26	วันที่ 2/5/26	วันที่ 1/6/26	วันที่	วันที่	วันที่	วันที่	วันที่
1	เสียดับเพลิงกันไฟ 3 ชุด	/	/	/	/	/	/					
2	หมวกดับเพลิง 3 ใบ	/	/	/	/	/	/					
3	ถุงมือดับเพลิง 3 คู่	/	/	/	/	/	/					
4	รองเท้าดับเพลิง 3 คู่	/	/	/	/	/	/					
5	หน้ากาก MOLDX 1 อัน	/	/	/	/	/	/					
6	เปลเคลื่อนย้ายผู้ป่วย 1 อัน	/	/	/	/	/	/					
7	เทปกั้นเขตพื้นที่ (จำนวน)	2	2	1	1	1	1					
8	ไฟฉาย 1 อัน	/	/	/	/	/	/					
ผู้ดำเนินการ (Technicain / Senior Technicain)		To	To	Boor	Boor	Chng	Mon					
ผู้ตรวจสอบ (หัวหน้าหน่วย)		R	R	R	R	R	R					

หมายเหตุ M. = ดำเนินการทุก 1 เดือน
 Q. = ดำเนินการทุก 3 เดือน
 S. = ดำเนินการทุก 6 เดือน
 Y. = ดำเนินการทุก 1 ปี

**Travelodge**

SUKHUMVIT 11

TRAVELODGE SUKHUMVIT11

ENGINEERING DEPARTMENT

EXTINGUISHERS CHECKLIST

Tower A				Tower B			
Locations	Pressure Psi.	Equipment in the fire extinguisher	Remark	Locations	Pressure Psi.	Equipment in the fire extinguisher	Remark
Roof FHC(1)	195	/		FL.8 FHC Pump room	199	/	
Roof FHC(2)	199	/		FL.8 FHC	199	/	
FL.8 FHC 2801	195	/		FL.7 corridor	100		
FL.8 FHC 2821	195	/		FL.7 FHC	199	/	
FL.8 staff lift	100			FL.6 corridor	100		
FL.7 FHC 2701	199	/		FL.6 FHC	199	/	
FL.7 FHC 2721	199	/		FL.5 corridor	100		
FL.7 staff lift	100			FL.5 FHC	199	/	
FL.6 FHC 2601	199	/		FL.4 corridor	100		
FL.6 FHC 2621	195	/		FL.4 FHC	199	/	
FL.6 staff lift	100			FL.3 corridor	100		
FL.5 FHC 2501	199	/		FL.3 FHC	195	/	
FL.5 FHC 2521	199	/		FL.2 corridor	100		
FL.5 staff lift	100			FL.2 FHC	199	/	
FL.4 FHC 2401	199	/		FL.G FHC security	199	/	
FL.4 FHC 2421	199	/		FL.G FHC restaurant	199	/	
FL.4 staff lift	100			FL.B1 FHC	199	/	
FL.3 FHC 2301	199	/		FL.B1 kitchen (1)	100		
FL.3 FHC 2321	199	/		FL.B1 kitchen (2)	100		
FL.3 staff lift	100			FL.B1 staff lift	100		
FL.2 FHC 2201	199	/		FL.B2 staff lift	100		
FL.2 FHC 2221	199	/		FL.B2 FHC	199	/	
FL.2 staff lift	100			FL.B2 FHC fire pump	199	/	
FL.G FHC lobby	199	/		Generator room	100		
FHC front office	199	/		MDB room	100		
FL.B1 (1) FHC car park	199	/		MDB room	100		
FL.B1 (2) FHC car park	199	/					
FL.B2 (1) FHC car park	199	/					
FL.B2 (2) FHC car park	199	/					

Checked By Supervisor		Date	30/6/26
Approve By Chief Engineer		Date	30/6/26

Daw 4/6/26

Tower A				Tower B			
Locations	Pressure Psi.	Equipment in the fire extinguisher	Remark	Locations	Pressure Psi.	Equipment in the fire extinguisher	Remark
Roof FHC(1)	190	/		FL.8 FHC Pump room		/	
Roof FHC(2)	190	/		FL.8 FHC	190	/	
FL.8 FHC 2801	190	/		FL.7 corridor	100		
FL.8 FHC 2821	190	/		FL.7 FHC	190	/	
FL.8 staff lift	100			FL.6 corridor	100		
FL.7 FHC 2701	190	/		FL.6 FHC	190	/	
FL.7 FHC 2721	125	/		FL.5 corridor	100		
FL.7 staff lift	100			FL.5 FHC	190	/	
FL.6 FHC 2601	190	/		FL.4 corridor	100		
FL.6 FHC 2621	190	/		FL.4 FHC	190	✓	
FL.6 staff lift	100			FL.3 corridor	100		
FL.5 FHC 2501	165	/		FL.3 FHC	190	/	
FL.5 FHC 2521	185	/		FL.2 corridor	100		
FL.5 staff lift	100			FL.2 FHC	190	/	
FL.4 FHC 2401	190	/		FL.G FHC security	190	✓	
FL.4 FHC 2421	190	/		FL.G FHC restaurant	190	/	
FL.4 staff lift	100			FL.B1 FHC	190	/	
FL.3 FHC 2301	190	/		FL.B1 kitchen (1)	100		
FL.3 FHC 2321	190	/		FL.B1 kitchen (2)	190		
FL.3 staff lift	100			FL.B1 staff lift	100		
FL.2 FHC 2201	190	/		FL.B2 staff lift	100		
FL.2 FHC 2221	190	/		FL.B2 FHC	190	/	
FL.2 staff lift	100			FL.B2 FHC fire pump	185	/	
FL.G FHC lobby	190	/		Generator room	100		
FHC front office	190	/		MDB room	100		
FL.B1 (1) FHC car park	190	/		MDB room	100		
FL.B1 (2) FHC car park	190	/					
FL.B2 (1) FHC car park	190	/					
FL.B2 (2) FHC car park	190	/					

Checked By Supervisor	<i>To</i>	Date	1/11/26
Approve By Chief Engineer	<i>Am</i>	Date	2/11/26

Tower A				Tower B			
Locations	Pressure Psi.	Equipment in the fire extinguisher	Remark	Locations	Pressure Psi.	Equipment in the fire extinguisher	Remark
Roof FHC(1)	190	/		FL.8 FHC Pump room	190	/	
Roof FHC(2)	190	/		FL.8 FHC	190	/	
FL.8 FHC 2801	190	/		FL.7 corridor	100		
FL.8 FHC 2821	190	/		FL.7 FHC	190	/	
FL.8 staff lift	100			FL.6 corridor	100		
FL.7 FHC 2701	190	/		FL.6 FHC	190	/	
FL.7 FHC 2721	190	/		FL.5 corridor	100		
FL.7 staff lift	100			FL.5 FHC	190	/	
FL.6 FHC 2601	190	/		FL.4 corridor	100		
FL.6 FHC 2621	190	/		FL.4 FHC	190	/	
FL.6 staff lift	100			FL.3 corridor	100		
FL.5 FHC 2501	190	/		FL.3 FHC	190	/	
FL.5 FHC 2521	190	/		FL.2 corridor	100		
FL.5 staff lift	100			FL.2 FHC	190	/	
FL.4 FHC 2401	190	/		FL.G FHC security	190	/	
FL.4 FHC 2421	190	/		FL.G FHC restaurent	190	/	
FL.4 staff lift	100			FL.B1 FHC	190	/	
FL.3 FHC 2301	190	/		FL.B1 kitchen (1)	100		
FL.3 FHC 2321	190	/		FL.B1 kitchen (2)	100		
FL.3 staff lift	100			FL.B1 staff lift	100		
FL.2 FHC 2201	190	/		FL.B2 staff lift	100		
FL.2 FHC 2221	190	/		FL.B2 FHC	190	/	
FL.2 staff lift	100			FL.B2 FHC fire pump	190	/	
FL.G FHC lobby	190	/		Generator room	100		
FHC front office	190	/		MDB room	100		
FL.B1 (1) FHC car park	190	/		MDB room	100		
FL.B1 (2) FHC car park	190	/					
FL.B2 (1) FHC car park	190	/					
FL.B2 (2) FHC car park	190	/					

Checked By Supervisor	<i>to</i>	Date	1/11/26
Approve By Chief Engineer	<i>R.1</i>	Date	1/12/26

Tower A				Tower B			
Locations	Pressure Psi.	Equipment in the fire extinguisher	Remark	Locations	Pressure Psi.	Equipment in the fire extinguisher	Remark
Roof FHC(1)	190	/		FL.8 FHC Pump room	190	/	
Roof FHC(2)	190	/		FL.8 FHC	190	/	
FL.8 FHC 2801	190	/		FL.7 corridor	100		
FL.8 FHC 2821	190	/		FL.7 FHC	190	/	
FL.8 staff lift	100			FL.6 corridor	100		
FL.7 FHC 2701	190	/		FL.6 FHC	190	/	
FL.7 FHC 2721	190	/		FL.5 corridor	100		
FL.7 staff lift	100			FL.5 FHC	190	/	
FL.6 FHC 2601	190	/		FL.4 corridor	100		
FL.6 FHC 2621	190	/		FL.4 FHC	190	/	
FL.6 staff lift	100			FL.3 corridor	100		
FL.5 FHC 2501	190	/		FL.3 FHC	190	/	
FL.5 FHC 2521	190	/		FL.2 corridor	100		
FL.5 staff lift	100			FL.2 FHC	190	/	
FL.4 FHC 2401	190	/		FL.G FHC security	190	/	
FL.4 FHC 2421	190	/		FL.G FHC restaurant	190	/	
FL.4 staff lift	100			FL.B1 FHC	190	/	
FL.3 FHC 2301	190	/		FL.B1 kitchen (1)	100		
FL.3 FHC 2321	190	/		FL.B1 kitchen (2)	100		
FL.3 staff lift	100			FL.B1 staff lift	100		
FL.2 FHC 2201	190	/		FL.B2 staff lift	100		
FL.2 FHC 2221	190	/		FL.B2 FHC	190	/	
FL.2 staff lift	100			FL.B2 FHC fire pump	190	/	
FL.G FHC lobby	190	/		Generator room	100		
FHC front office	190	/		MDB room	100		
FL.B1 (1) FHC car park	190	/		MDB room	100		
FL.B1 (2) FHC car park	190	/				/	
FL.B2 (1) FHC car park	190	/					
FL.B2 (2) FHC car park	160	/					

Checked By Supervisor	<i>to</i>	Date	31/3/26
Approve By Chief Engineer	<i>Pub 1</i>	Date	31/3/26

Tower A				Tower B			
Locations	Pressure Psi.	Equipment in the fire extinguisher	Remark	Locations	Pressure Psi.	Equipment in the fire extinguisher	Remark
Roof FHC(1)	195	✓		FL.8 FHC Pump room	195	✓	
Roof FHC(2)	195	✓		FL.8 FHC	195	✓	
FL.8 FHC 2801	195	✓		FL.7 corridor	195		
FL.8 FHC 2821	195	✓		FL.7 FHC	195	✓	
FL.8 staff lift	100			FL.6 corridor	195		
FL.7 FHC 2701	195	✓		FL.6 FHC	195	✓	
FL.7 FHC 2721	195	✓		FL.5 corridor	195		
FL.7 staff lift	100			FL.5 FHC	195	✓	
FL.6 FHC 2601	195	✓		FL.4 corridor	100		
FL.6 FHC 2621	195	✓		FL.4 FHC	195	✓	
FL.6 staff lift	100			FL.3 corridor	100		
FL.5 FHC 2501	195	✓		FL.3 FHC	195	✓	
FL.5 FHC 2521	195	✓		FL.2 corridor	100		
FL.5 staff lift	100			FL.2 FHC	195	✓	
FL.4 FHC 2401	195	✓		FL.G FHC security	195	✓	
FL.4 FHC 2421	195	✓		FL.G FHC restaurant	105	✓	
FL.4 staff lift	100			FL.B1 FHC	195	✓	
FL.3 FHC 2301	195	✓		FL.B1 kitchen (1)	100		
FL.3 FHC 2321	195	✓		FL.B1 kitchen (2)	100		
FL.3 staff lift	100			FL.B1 staff lift	102		
FL.2 FHC 2201	195	✓		FL.B2 staff lift	102		
FL.2 FHC 2221	195	✓		FL.B2 FHC	195	✓	
FL.2 staff lift	100			FL.B2 FHC fire pump	195	✓	
FL.G FHC lobby	195	✓		Generator room	102		
FHC front office	195	✓		MDB room	102		
FL.B1 (1) FHC car park	195/195	✓		MDB room	102		
FL.B1 (2) FHC car park	195/195	✓					
FL.B2 (1) FHC car park	195/195	✓					
FL.B2 (2) FHC car park	195/195	✓					

Checked By Supervisor	To	Date	3/2/26
Approve By Chief Engineer	Phub	Date	3/2/26

Tower A				Tower B			
Locations	Pressure Psi.	Equipment in the fire extinguisher	Remark	Locations	Pressure Psi.	Equipment in the fire extinguisher	Remark
Roof FHC(1)	195	/		FL.8 FHC Pump room	195	/	
Roof FHC(2)	195	/		FL.8 FHC	195	/	
FL.8 FHC 2801	195	/		FL.7 corridor	195		
FL.8 FHC 2821	195	/		FL.7 FHC	195	/	
FL.8 staff lift	100			FL.6 corridor	195		
FL.7 FHC 2701	195	/		FL.6 FHC	195	/	
FL.7 FHC 2721	195	/		FL.5 corridor	195		
FL.7 staff lift	100			FL.5 FHC	195	/	
FL.6 FHC 2601	195	/		FL.4 corridor	100		
FHC 2621	195	/		FL.4 FHC	195	/	
FL.6 staff lift	100			FL.3 corridor	100		
FL.5 FHC 2501	195	/		FL.3 FHC	195	/	
FL.5 FHC 2521	195	/		FL.2 corridor	100		
FL.5 staff lift	100			FL.2 FHC	195	/	
FL.4 FHC 2401	195	/		FL.G FHC security	195	/	
FL.4 FHC 2421	195	/		FL.G FHC restaurant	195	/	
FL.4 staff lift	100			FL.B1 FHC	195	/	
FL.3 FHC 2301	195	/		FL.B1 kitchen (1)	100		
FL.3 FHC 2321	195	/		FL.B1 kitchen (2)	100		
FL.3 staff lift	100			FL.B1 staff lift	CO2		
FL.2 FHC 2201	195	/		FL.B2 staff lift	CO2		
FL.2 FHC 2221	195	/		FL.B2 FHC	195	/	
FL.2 staff lift	100			FL.B2 FHC fire pump	195	/	
FL.G FHC lobby	195	/		Generator room	CO2		
FHC front office	195	/		MDB room	CO2		
FL.B1 (1) FHC car park	195-190	/		MDB room	CO2		
FL.B1 (2) FHC car park	105-195	/					
FL.B2 (1) FHC car park	185-190	/					
FL.B2 (2) FHC car park	195-180	/					

Checked By Supervisor	TO	Date	2/1/26
Approve By Chief Engineer		Date	2/1/26



Travelodge

SUKHUMVIT 11

TRAVELODGE SUKHUMVIT11

ENGINEERING DEPARTMENT

EMERGENCY LIGHTING & EXIT LIGHT

Emergency light Tower B				Emergency light Tower A			
Locations	Test	Inspector	Remark	Locations	Test	Inspector	Remark
	Y/N				Y/N		
Exit Stair FL-B1	Y	To		Exit Stair FL-B1	Y	To	
Exit Stair FL-B2	Y	To		Exit Stair FL-B2	Y	To	
Exit Stair FL-G	Y	To		Exit Stair FL-G	Y	To	
Exit Stair FL-2	Y	To		Exit Stair FL-2	Y	To	
Exit Stair FL-3	Y	To		Exit Stair FL-3	Y	To	
Exit Stair FL-4	Y	To		Exit Stair FL-4	Y	To	
Exit Stair FL-5	Y	To		Exit Stair FL-5	Y	To	
Exit Stair FL-6	Y	To		Exit Stair FL-6	Y	To	
Exit Stair FL-7	Y	To		Exit Stair FL-7	Y	To	
Exit Stair FL-8	Y	To		Exit Stair FL-8	Y	To	
Main Stair FL-B1#1	Y	To		Main Stair FL-B1#1	Y	To	
Main Stair FL-B1#2	Y	To		Main Stair FL-B1#2	Y	To	
Main Stair FL-B2	Y	To		Main Stair FL-B2	Y	To	
Main Stair FL-G	Y	To		Main Stair FL-G	Y	To	
Main Stair FL-2	Y	To		Main Stair FL-2	Y	To	
Main Stair FL-3	Y	To		Main Stair FL-3	Y	To	
Main Stair FL-4	Y	To		Main Stair FL-4	Y	To	
Main Stair FL-5	Y	To		Main Stair FL-5	Y	To	
Main Stair FL-6	Y	To		Main Stair FL-6	Y	To	
Main Stair FL-7	Y	To		Main Stair FL-7	Y	To	
Main Stair FL-8	X	To		Main Stair FL-8	Y	To	
Hall lift staff FL-B1	Y	To		Owner Office	Y	To	
Hall lift staff FL-B2	Y	To		GM Office	Y	To	
Lift Hall tower A EL.B1	Y	To		FC Office	Y	To	
Lift Hall tower A EL.B2	Y	To		AC Office	Y	To	
Car lift FL-B1	Y	To		HK Office	Y	To	
Fire pump room	Y	To		FO Office	Y	To	
Store Eng.	X	To		HR Office	Y	To	
FB Store	Y	To		Canteen	Y	To	
HK Store	Y	To		Car park P3 #1	Y	To	
Kitchen Store	Y	To		Car park P3 #2	Y	To	
Sever Room	Y	To		Car park P3 #3	Y	To	
Main Kitchen#1	X	To		Car park P3 #4	Y	To	
Main Kitchen#2	Y	To		Car park P4 #1	Y	To	
Generator room	X	To		Car park P4 #2	Y	To	
MDB room 1	Y	To		Car park P4 #3	Y	To	
MDB room 2	X	To		Car park P4 #4	Y	To	

Checked By Supervisor

To
Pun

Date

2/1/26

Approve By Chief Engineer

Date

3/1/26



Travelodge

SUKHUMVIT 11

TRAVELODGE SUKHUMVIT11

ENGINEERING DEPARTMENT

EMERGENCY LIGHTING & EXIT LIGHT

Emergency light Tower B				Emergency light Tower A			
Locations	Test	Inspector	Remark	Locations	Test	Inspector	Remark
	Y/N				Y/N		
Exit Stair FL-B1	X	บจก		Exit Stair FL-B1	X	บจก	11/20/2022
Exit Stair FL-B2	X	บจก		Exit Stair FL-B2	X	บจก	
Exit Stair FL-G	X	บจก		Exit Stair FL-G	X	บจก	
Exit Stair FL-2	X	บจก		Exit Stair FL-2	X	บจก	
Exit Stair FL-3	X	บจก		Exit Stair FL-3	X	บจก	
Exit Stair FL-4	X	บจก		Exit Stair FL-4	X	บจก	
Exit Stair FL-5	X	บจก		Exit Stair FL-5	X	บจก	
Exit Stair FL-6	X	บจก		Exit Stair FL-6	X	บจก	
Exit Stair FL-7	N	บจก	11/20/2022	Exit Stair FL-7	X	บจก	
Exit Stair FL-8	X	บจก		Exit Stair FL-8	X	บจก	
Main Stair FL-B1#1	X	บจก		Main Stair FL-B1#1	X	บจก	
Main Stair FL-B1#2	X	บจก		Main Stair FL-B1#2	X	บจก	
Main Stair FL-B2	X	บจก		Main Stair FL-B2	X	บจก	
Main Stair FL-G	X	บจก		Main Stair FL-G	X	บจก	
Main Stair FL-2	X	บจก		Main Stair FL-2	X	บจก	
Main Stair FL-3	X	บจก		Main Stair FL-3	X	บจก	
Main Stair FL-4	X	บจก		Main Stair FL-4	N	บจก	11/20/2022
Main Stair FL-5	X	บจก		Main Stair FL-5	X	บจก	
Main Stair FL-6	X	บจก		Main Stair FL-6	X	บจก	
Main Stair FL-7	X	บจก		Main Stair FL-7	X	บจก	
Main Stair FL-8	X	บจก		Main Stair FL-8	X	บจก	
Hall lift staff FL-B1	X	บจก		Owner Office	N	บจก	11/20/2022
Hall lift staff FL-B2	X	บจก		GM Office	X	บจก	
Lift Hall tower A EL.B1	N	บจก	11/20/2022	FC Office	X	บจก	
Lift Hall tower A EL.B2	X	บจก		AC Office	X	บจก	
Car lift FL-B1	X	บจก		HK Office	X	บจก	
Fire pump room	X	บจก		FO Office	X	บจก	
Store Eng.	X	บจก		HR Office	X	บจก	
FB Store	X	บจก		Canteen	X	บจก	
HK Store	X	บจก		Car park P3 #1	N	บจก	11/20/2022
Kitchen Store	X	บจก		Car park P3 #2	X	บจก	
Sever Room	X	บจก		Car park P3 #3	X	บจก	
Main Kitchen#1	X	บจก		Car park P3 #4	X	บจก	
Main Kitchen#2	X	บจก		Car park P4 #1	X	บจก	
Generator room	X	บจก		Car park P4 #2	X	บจก	
MDB room 1	X	บจก		Car park P4 #3	X	บจก	
MDB room 2	X	บจก		Car park P4 #4	X	บจก	

Checked By Supervisor

Date

Approve By Chief Engineer

Date

3/2/26

3/2/26

Emergency light Tower B				Emergency light Tower A			
Locations	Test	Inspector	Remark	Locations	Test	Inspector	Remark
	Y/N				Y/N		
Exit Stair FL-B1	X	Chang		Exit Stair FL-B1	X	Man	
Exit Stair FL-B2	X	Chang		Exit Stair FL-B2	N	Man	11/20/126
Exit Stair FL-G	X	Chang		Exit Stair FL-G	X	Man	
Exit Stair FL-2	X	Chang		Exit Stair FL-2	X	Man	
Exit Stair FL-3	X	Chang		Exit Stair FL-3	X	Man	
Exit Stair FL-4	X	Chang		Exit Stair FL-4	X	Man	
Exit Stair FL-5	X	Chang		Exit Stair FL-5	X	Man	
Exit Stair FL-6	X	Chang		Exit Stair FL-6	X	Man	
Exit Stair FL-7	X	Chang		Exit Stair FL-7	X	Man	
Exit Stair FL-8	X	Chang		Exit Stair FL-8	X	Man	
Main Stair FL-B1#1	X	Chang		Main Stair FL-B1#1	X	Man	
Main Stair FL-B1#2	X	Chang		Main Stair FL-B1#2	X	Man	
Main Stair FL-B2	X	Chang		Main Stair FL-B2	X	Man	
Main Stair FL-G	X	Chang		Main Stair FL-G	X	Man	
Main Stair FL-2	X	Chang		Main Stair FL-2	X	Man	
Main Stair FL-3	X	Chang		Main Stair FL-3	X	Man	
Main Stair FL-4	X	Chang		Main Stair FL-4	X	Man	
Main Stair FL-5	X	Chang		Main Stair FL-5	X	Man	
Main Stair FL-6	X	Chang		Main Stair FL-6	X	Man	
Main Stair FL-7	X	Chang		Main Stair FL-7	X	Man	
Main Stair FL-8	X	Chang		Main Stair FL-8	X	Man	
Hall lift staff FL-B1	X	Chang		Owner Office	N	Man	NS
Hall lift staff FL-B2	X	Chang		GM Office	N	Man	NS
Lift Hall tower A EL.B1	X	Chang		FC Office	N	Man	NS
Lift Hall tower A EL.B2	N	Chang	10/30/126	AC Office	X	Man	
Car lift FL-B1	X	Chang		HK Office	X	Man	
Fire pump room	X	Chang		FO Office	N	Man	NS
Store Eng.	N	Chang	10/30/126	HR Office	X	Man	
FB Store	N	Chang	11/20/126	Canteen	X	Man	
HK Store	N	Chang	11/20/126	Car park P3 #1	X	Man	
Kitchen Store	X	Chang		Car park P3 #2	X	Man	
Sever Room	X	Chang		Car park P3 #3	X	Man	
Main Kitchen#1	X	Chang		Car park P3 #4	X	Man	
Main Kitchen#2	X	Chang		Car park P4 #1	X	Man	
Generator room	N	Chang	10/30/126	Car park P4 #2	X	Man	
MDB room 1	X	Chang		Car park P4 #3	X	Man	
MDB room 2	X	Chang		Car park P4 #4	X	Man	

Checked By Supervisor

Date

11/3/26

Approve By Chief Engineer

Date

2/9/26

Emergency light Tower B				Emergency light Tower A			
Locations	Test	Inspector	Remark	Locations	Test	Inspector	Remark
	Y/N				Y/N		
Exit Stair FL-B1	Y	Peach		Exit Stair FL-B1	Y	Chang	
Exit Stair FL-B2	Y	Peach		Exit Stair FL-B2	Y	Chang	11/20/26
Exit Stair FL-G	Y	Peach		Exit Stair FL-G	Y	Chang	
Exit Stair FL-2	Y	Peach		Exit Stair FL-2	Y	Chang	
Exit Stair FL-3	Y	Peach		Exit Stair FL-3	Y	Chang	
Exit Stair FL-4	Y	Peach		Exit Stair FL-4	Y	Chang	
Exit Stair FL-5	Y	Peach		Exit Stair FL-5	Y	Chang	
Exit Stair FL-6	Y	Peach		Exit Stair FL-6	Y	Chang	
Exit Stair FL-7	Y	Peach		Exit Stair FL-7	Y	Chang	
Exit Stair FL-8	Y	Peach		Exit Stair FL-8	Y	Chang	
Main Stair FL-B1#1	Y	Peach		Main Stair FL-B1#1	Y	Chang	
Main Stair FL-B1#2	Y	Peach		Main Stair FL-B1#2	Y	Chang	
Main Stair FL-B2	Y	Peach		Main Stair FL-B2	Y	Chang	
Main Stair FL-G	Y	Peach		Main Stair FL-G	Y	Chang	
Main Stair FL-2	Y	Peach		Main Stair FL-2	Y	Chang	
Main Stair FL-3	Y	Peach		Main Stair FL-3	Y	Chang	
Main Stair FL-4	Y	Peach		Main Stair FL-4	Y	Chang	
Main Stair FL-5	Y	Peach		Main Stair FL-5	Y	Chang	
Main Stair FL-6	Y	Peach		Main Stair FL-6	Y	Chang	
Main Stair FL-7	Y	Peach		Main Stair FL-7	Y	Chang	
Main Stair FL-8	Y	Peach		Main Stair FL-8	N	Chang	11/20/26
Hall lift staff FL-B1	Y	Peach		Owner Office	N	Chang	11/20/26
Hall lift staff FL-B2	Y	Peach		GM Office	N	Chang	11/20/26
Lift Hall tower A EL.B1	Y	Peach		FC Office	Y	Chang	
Lift Hall tower A EL.B2	N	Peach	11/20/26	AC Office	Y	Chang	
Car lift FL-B1	Y	Peach		HK Office	N	Chang	11/20/26
Fire pump room	Y	Peach		FO Office	Y	Chang	
Store Eng.	N	Peach	11/20/26	HR Office	Y	Chang	
FB Store	N	Peach	11/20/26	Canteen	Y	Chang	
HK Store	N	Peach	11/20/26	Car park P3 #1	Y	Chang	
Kitchen Store	Y	Peach		Car park P3 #2	Y	Chang	
Sever Room	Y	Peach		Car park P3 #3	Y	Chang	
Main Kitchen#1	Y	Peach		Car park P3 #4	Y	Chang	
Main Kitchen#2	Y	Peach		Car park P4 #1	Y	Chang	
Generator room	N	Peach	11/20/26	Car park P4 #2	Y	Chang	
MDB room 1	Y	Peach		Car park P4 #3	Y	Chang	
MDB room 2	Y	Peach		Car park P4 #4	Y	Chang	

Checked By Supervisor

Date

2/4/26

Approve By Chief Engineer

Date

3/4/26

Emergency light Tower B				Emergency light Tower A			
Locations	Test	Inspector	Remark	Locations	Test	Inspector	Remark
	Y/N				Y/N		
Exit Stair FL-B1	Y	to		Exit Stair FL-B1	Y	Man	
Exit Stair FL-B2	Y	to		Exit Stair FL-B2	N	Man	6/2/17 6/2/17
Exit Stair FL-G	Y	to		Exit Stair FL-G	Y	Man	
Exit Stair FL-2	Y	to		Exit Stair FL-2	Y	Man	
Exit Stair FL-3	Y	to		Exit Stair FL-3	Y	Man	
Exit Stair FL-4	Y	to		Exit Stair FL-4	Y	Man	
Exit Stair FL-5	Y	to		Exit Stair FL-5	Y	Man	
Exit Stair FL-6	Y	to		Exit Stair FL-6	Y	Man	
Exit Stair FL-7	Y	to		Exit Stair FL-7	Y	Man	
Exit Stair FL-8	Y	to		Exit Stair FL-8	Y	Man	
Main Stair FL-B1#1	Y	to		Main Stair FL-B1#1	Y	Man	
Main Stair FL-B1#2	Y	to		Main Stair FL-B1#2	Y	Man	
Main Stair FL-B2	Y	to		Main Stair FL-B2	Y	Man	
Main Stair FL-G	Y	to		Main Stair FL-G	Y	Man	
Main Stair FL-2	Y	to		Main Stair FL-2	Y	Man	
Main Stair FL-3	Y	to		Main Stair FL-3	Y	Man	
Main Stair FL-4	Y	to		Main Stair FL-4	Y	Man	
Main Stair FL-5	Y	to		Main Stair FL-5	Y	Man	
Main Stair FL-6	Y	to		Main Stair FL-6	Y	Man	
Main Stair FL-7	Y	to		Main Stair FL-7	Y	Man	
Main Stair FL-8	Y	to		Main Stair FL-8	Y	Man	
Hall lift staff FL-B1	Y	to		Owner Office	N	Man	6/2/17
Hall lift staff FL-B2	N	to	6/2/17 6/2/17	GM Office	N	Man	6/2/17
Lift Hall tower A EL.B1	Y	to		FC Office	N	Man	6/2/17
Lift Hall tower A EL.B2	N	to	6/2/17 6/2/17	AC Office	Y	Man	
Car lift FL-B1	Y	to		HK Office	Y	Man	
Fire pump room	Y	to		FO Office	N	Man	6/2/17
Store Eng.	N	to	6/2/17 6/2/17	HR Office	Y	Man	
FB Store	N	to		Canteen	Y	Man	
HK Store	N	to		Car park P3 #1	Y	Man	
Kitchen Store	Y	to		Car park P3 #2	Y	Man	
Sever Room	Y	to		Car park P3 #3	Y	Man	
Main Kitchen#1	Y	to		Car park P3 #4	Y	Man	
Main Kitchen#2	Y	to		Car park P4 #1	Y	Man	
Generator room	N	to	6/2/17 6/2/17	Car park P4 #2	Y	Man	
MDB room 1	N	to	6/2/17 6/2/17	Car park P4 #3	Y	Man	
MDB room 2	Y	to		Car park P4 #4	Y	Man	

Checked By Supervisor

Date

15/2/16

Approve By Chief Engineer

Date

2/17/26



Travelodge

SUKHUMVIT 11

TRAVELODGE SUKHUMVIT11

ENGINEERING DEPARTMENT

EMERGENCY LIGHTING & EXIT LIGHT

Emergency light Tower B				Emergency light Tower A			
Locations	Test	Inspector	Remark	Locations	Test	Inspector	Remark
	Y/N				Y/N		
Exit Stair FL-B1	Y			Exit Stair FL-B1	Y		
Exit Stair FL-B2	Y			Exit Stair FL-B2	Y		W.M.B.O.S.J
Exit Stair FL-G	Y			Exit Stair FL-G	Y		
Exit Stair FL-2	Y			Exit Stair FL-2	Y		
Exit Stair FL-3	Y			Exit Stair FL-3	Y		
Exit Stair FL-4	Y			Exit Stair FL-4	Y		
Exit Stair FL-5	Y			Exit Stair FL-5	Y		
Exit Stair FL-6	Y			Exit Stair FL-6	Y		
Exit Stair FL-7	Y			Exit Stair FL-7	Y		
Exit Stair FL-8	Y			Exit Stair FL-8	Y		
Main Stair FL-B1#1	Y			Main Stair FL-B1#1	Y		
Main Stair FL-B1#2	Y			Main Stair FL-B1#2	Y		
Main Stair FL-B2	Y			Main Stair FL-B2	Y		
Main Stair FL-G	Y			Main Stair FL-G	Y		
Main Stair FL-2	Y			Main Stair FL-2	Y		
Main Stair FL-3	Y			Main Stair FL-3	Y		
Main Stair FL-4	Y			Main Stair FL-4	Y		
Main Stair FL-5	Y			Main Stair FL-5	Y		
Main Stair FL-6	Y			Main Stair FL-6	Y		
Main Stair FL-7	Y			Main Stair FL-7	Y		
Main Stair FL-8	Y			Main Stair FL-8	Y		
Hall lift staff FL-B1	Y			Owner Office	Y		
Hall lift staff FL-B2	Y			GM Office	Y		
Lift Hall tower A EL.B1	Y			FC Office	Y		
Lift hall tower A EL.B2	Y			AC Office	Y		
Car lift FL-B1	Y			HK Office	Y		
Fire pump room	Y			FO Office	Y		
Store Eng.	Y			HR Office	Y		
FB Store	Y			Canteen	Y		
HK Store	Y			Car park P3 #1	Y		
Kitchen Store	Y			Car park P3 #2	Y		
Sever Room	Y			Car park P3 #3	Y		
Main Kitchen#1	Y			Car park P3 #4	Y		
Main Kitchen#2	Y			Car park P4 #1	Y		
Generator room	N		6 N.J	Car park P4 #2	Y		
MDB room 1	N		6 N.J	Car park P4 #3	Y		
MDB room 2	N			Car park P4 #4	Y		

Checked By Supervisor

Date

3 / 6 / 26

Approve By Chief Engineer

Date

1 / 6 / 26