

DATE	ปริมาณน้ำใช้	น้ำเข้าบ่อ	ค่า DO (≥3)	SV30, (0)	PH บ่อ B ₀ (5.5-9)	PH บ่อเติมอากาศ, (5.5-9)	PH บ่อน้ำทิ้ง, (5.5-9)	Free Cl ₂ , (0.5-1) / OZONE	CL.คงเหลือ	ผู้บันทึก
01/01/2026	69	55.2	6.1	0	7.46	7.87	7.45	Ozone	-	
02/01/2026	0	0	6.5	0	7.34	7.36	7.51	Ozone	-	
03/01/2026	82	65.6	6.2	0	7.29	7.55	7.57	Ozone	-	
04/01/2026	0	0	6.6	0	7.37	7.45	7.41	Ozone	-	
05/01/2026	72	57.6	6	0	7.39	7.49	7.52	Ozone	-	
06/01/2026	0	0	6.1	0	7.48	7.81	7.33	Ozone	-	
07/01/2026	70	56	6.3	0	7.4	7.47	7.58	Ozone	-	
08/01/2026	69	55.2	6.2	0	7.46	7.52	7.63	Ozone	-	
09/01/2026	0	0	6	0	7.42	7.5	7.54	Ozone	-	
10/01/2026	69	55.2	6.1	0	7.46	7.61	7.57	Ozone	-	
11/01/2026	0	0	6.5	0	7.28	7.56	7.62	Ozone	-	
12/01/2026	75	60	6.2	0	7.45	7.62	7.52	Ozone	-	
13/01/2026	67	53.6	5.8	0	7.27	7.42	7.59	Ozone	-	
14/01/2026	0	0	5.9	0	7.49	7.54	7.65	Ozone	-	
15/01/2026	69	55.2	6.5	0	7.51	7.55	7.63	Ozone	-	
16/01/2026	22	17.6	5.8	0	7.56	7.49	7.57	Ozone	-	
17/01/2026	54	43.2	6.1	0	7.48	7.51	7.64	Ozone	-	
18/01/2026	70	56	5.4	0	7.62	7.54	7.58	Ozone	-	
19/01/2026	0	0	5.6	0	7.58	7.52	7.49	Ozone	-	
20/01/2026	67	53.6	5.3	0	7.6	7.54	7.59	Ozone	-	
21/01/2026	0	0	5.7	0	7.53	7.66	7.64	Ozone	-	
22/01/2026	120	96	5.9	0	7.35	7.51	7.62	Ozone	-	
23/01/2026	60	48	5.5	0	7.29	7.31	7.56	Ozone	-	
24/01/2026	0	0	5.7	0	7.34	7.39	7.6	Ozone	-	
25/01/2026	76	60.8	5.8	0	7.37	7.42	7.49	Ozone	-	
26/01/2026	0	0	5.7	0	7.39	7.52	7.72	Ozone	-	
27/01/2026	65	52	5.7	0	7.41	7.47	7.52	Ozone	-	
28/01/2026	75	60	5.5	0	7.37	7.49	7.57	Ozone	-	
29/01/2026	0	0	5.6	0	7.39	7.42	7.58	Ozone	-	
30/01/2026	70	56	5.4	0	7.28	7.41	7.62	Ozone	-	
31/01/2026	69	55.2	5.6	0	7.32	7.44	7.58	Ozone	-	
	1390	1112								
01/02/2026	0	0	5.5	0	7.37	7.42	7.47	Ozone	-	
02/02/2026	71	56.8	5.5	0	7.42	7.54	7.61	Ozone	-	
03/02/2026	71	56.8	5.2	0	7.39	7.52	7.68	Ozone	-	
04/02/2026	0	0	5.4	0	7.41	7.54	7.58	Ozone	-	
05/02/2026	73	58.4	5.6	0	7.38	7.45	7.57	Ozone	-	
06/02/2026	68	54.4	5.3	0	7.63	7.51	7.48	Ozone	-	
07/02/2026	0	0	5.4	0	7.46	7.52	7.57	Ozone	-	
08/02/2026	72	57.6	5.4	0	7.42	7.55	7.51	Ozone	-	
09/02/2026	18	14.4	5.6	0	7.45	7.54	7.63	Ozone	-	
10/02/2026	53	42.4	5.3	0	7.64	7.51	7.68	Ozone	-	
11/02/2026	70	56	5.2	0	7.52	7.65	7.62	Ozone	-	
12/02/2026	0	0	5.4	0	7.45	7.56	7.58	Ozone	-	
13/02/2026	90	72	5.1	0	7.41	7.63	7.61	Ozone	-	
14/02/2026	39	31.2	5.9	0	7.35	7.51	7.62	Ozone	-	
15/02/2026	30	24	5.4	0	7.37	7.45	7.54	Ozone	-	
16/02/2026	70	56	5.5	0	7.42	7.53	7.64	Ozone	-	
17/02/2026	0	0	5.3	0	7.39	7.54	7.67	Ozone	-	
18/02/2026	72	57.6	5.6	0	7.34	7.44	7.53	Ozone	-	
19/02/2026	70	56	5.4	0	7.38	7.46	7.51	Ozone	-	
20/02/2026	5	4	5.5	0	7.42	7.48	7.56	Ozone	-	
21/02/2026	72	57.6	5.6	0	7.45	7.65	7.52	Ozone	-	
22/02/2026	68	54.4	5.5	0	7.32	7.41	7.52	Ozone	-	
23/02/2026	-68	-54.4	5.5	0	7.46	7.55	7.61	Ozone	-	
24/02/2026	71	56.8	5.3	0	7.38	7.46	7.51	Ozone	-	
25/02/2026	23	18.4	5.2	0	7.44	7.47	7.58	Ozone	-	
26/02/2026	45	36	5.4	0	7.32	7.54	7.59	Ozone	-	
27/02/2026	71	56.8	5.4	0	7.46	7.57	7.62	Ozone	-	
28/02/2026	26	20.8	5.5	0	7.37	7.45	7.51	Ozone	-	
01/03/2026	46	36.8	5.6	0	7.39	7.55	7.48	Ozone	-	
02/03/2026	50	40	5.3	0	7.41	7.48	7.57	Ozone	-	
03/03/2026	19	15.2	6.6	0	7.31	6.23	6.22	Ozone	-	
04/03/2026	73	58.4	7.5	0	7.32	6.32	6.31	Ozone	-	
05/03/2026	68	54.4	7	0	7.26	6.23	6.25	Ozone	-	
06/03/2026	0	0	6.8	0	7.3	6.43	6.35	Ozone	-	
07/03/2026	5	4	6.9	0	7.37	6.46	7.27	Ozone	-	
08/03/2026	64	51.2	7.1	0	7.32	6.23	6.56	Ozone	-	
09/03/2026	4	3.2	6.7	0	7.35	6.29	6.39	Ozone	-	
10/03/2026	74	59.2	6.6	0	7.3	6.26	6.23	Ozone	-	
11/03/2026	0	0	6.6	0	7.31	6.23	6.25	Ozone	-	
12/03/2026	69	55.2	6.8	0	7.26	6.31	6.31	Ozone	-	
13/03/2026	0	0	6.7	0	7.34	6.28	6.24	Ozone	-	
14/03/2026	70	56	6.4	0	7.41	6.24	6.32	Ozone	-	
15/03/2026	0	0	6.7	0	7.39	6.65	6.39	Ozone	-	
16/03/2026	74	59.2	6.8	0	7.29	6.38	6.24	Ozone	-	

DATE	ปริมาณน้ำไหล	น้ำเข้าบ่อ	ค่า DO (≥3)	SV30, (0)	PH บ่อ B ₀ , (5.5-9)	PH บ่อเติมอากาศ, (5.5-9)	PH บ่อน้ำทิ้ง, (5.5-9)	Free Cl ₂ , (0.5-1) / OZONE	CL.คงเหลือ	ผู้บันทึก
17/03/2026	48	38.4	6.7	0	7.32	6.46	6.36	Ozone	-	
18/03/2026	20	16	6.5	0	7.34	6.49	6.33	Ozone	-	
19/03/2026	70	56	5	0	7.29	6.89	7.03	Ozone	-	
20/03/2026	0	0	5.3	0	7.23	6.96	6.98	Ozone	-	
21/03/2026	72	57.6	4.8	0	7.28	6.77	6.66	Ozone	-	
22/03/2026	0	0	4.7	0	7.31	6.71	6.69	Ozone	-	
23/03/2026	73	58.4	5.5	0	7.29	6.89	6.89	Ozone	-	
24/03/2026	0	0	5.1	0	7.22	7.11	7.15	Ozone	-	
25/03/2026	69	55.2	7.7	0	7.18	6.04	6.39	Ozone	-	
26/03/2026	0	0	5.8	0	7.2	7.14	6.6	Ozone	-	
27/03/2026	70	56	6.3	0	7.17	7.19	6.8	Ozone	-	
28/03/2026	0	0	6.2	0	7.22	7.2	6.82	Ozone	-	
29/03/2026	72	57.6	6.4	0	7.17	6.9	6.71	Ozone	-	
30/03/2026	32	25.6	6.3	0	7.27	6.93	6.79	Ozone	-	
31/03/2026	40	32	6.2	0	7.79	6.95	7.82	Ozone	-	
	1182	945.6								
01/04/2026	65	52	6.4	0	7.84	6.92	6.99	Ozone	-	
02/04/2026	0	0	6.2	0	7.72	6.95	6.73	Ozone	-	
03/04/2026	37	29.6	6.1	0	7.78	6.78	6.89	Ozone	-	
04/04/2026	32	25.6	6.2	0	7.75	6.86	6.95	Ozone	-	
05/04/2026	0	0	6.2	0	7.72	6.85	6.92	Ozone	-	
06/04/2026	70	56	6.9	0	7.29	7.13	7.12	Ozone	-	
07/04/2026	72	57.6	6.4	0	7.71	7.17	6.99	Ozone	-	
08/04/2026	30	24	6.7	0	7.72	7.15	7.01	Ozone	-	
09/04/2026	38	30.4	7.3	0	7.29	6.98	6.98	Ozone	-	
10/04/2026	71	56.8	6.8	0	7.64	6.86	6.74	Ozone	-	
11/04/2026	0	0	6.5	0	7.62	6.95	6.75	Ozone	-	
12/04/2026	69	55.2	6.5	0	7.75	6.79	6.81	Ozone	-	
13/04/2026	0	0	6.4	0	7.69	6.85	6.93	Ozone	-	
14/04/2026	40	32	6.5	0	7.71	6.78	6.95	Ozone	-	
15/04/2026	0	0	6.5	0	7.53	6.89	6.72	Ozone	-	
16/04/2026	68	54.4	6.7	0	7.32	6.78	6.78	Ozone	-	
17/04/2026	0	0	6.9	0	7.29	6.97	6.97	Ozone	-	
18/04/2026	0	0	6.8	0	7.29	6.98	6.98	Ozone	-	
19/04/2026	0	0	6.9	0	7.28	6.73	6.83	Ozone	-	
20/04/2026	0	0	6.7	0	7.29	6.68	6.96	Ozone	-	
21/04/2026	0	0	6.7	0	7.24	6.75	6.94	Ozone	-	
22/04/2026	0	0	6.5	0	7.28	6.73	6.92	Ozone	-	
23/04/2026	0	0	6.2	0	7.34	6.79	6.94	Ozone	-	
24/04/2026	0	0	6.4	0	7.31	6.75	6.92	Ozone	-	
25/04/2026	0	0	6.5	0	7.39	6.71	6.94	Ozone	-	
26/04/2026	0	0	6.4	0	7.34	6.73	6.91	Ozone	-	
27/04/2026	0	0	6.5	0	7.45	6.92	6.95	Ozone	-	
28/04/2026	0	0	6.5	0	7.41	6.94	6.89	Ozone	-	
29/04/2026	0	0	6.4	0	7.4	6.96	6.96	Ozone	-	
30/04/2026	0	0	6.5	0	7.51	6.94	6.99	Ozone	-	
1/พ.ค./2569	40	32	6.4	0	7.49	6.97	6.81	Ozone	-	
2/พ.ค./2569	40	32	6.6	0	7.47	6.91	6.83	Ozone	-	
3/พ.ค./2569	40	32	6.3	0	7.46	6.81	6.81	Ozone	-	
4/พ.ค./2569	40	32	6.3	0	7.28	6.83	6.73	Ozone	-	
5/พ.ค./2569	40	32	6.4	0	7.34	6.89	6.77	Ozone	-	
6/พ.ค./2569	40	32	6.2	0	7.38	6.79	6.92	Ozone	-	
7/พ.ค./2569	40	32	6.5	0	7.31	6.81	6.95	Ozone	-	
8/พ.ค./2569	40	32	6.5	0	7.32	6.79	6.99	Ozone	-	
9/พ.ค./2569	40	32	6.4	0	7.35	6.83	6.94	Ozone	-	
10/พ.ค./2569	40	32	6.3	0	7.38	6.89	6.91	Ozone	-	
11/พ.ค./2569	40	32	6.5	0	7.4	6.81	6.95	Ozone	-	
12/พ.ค./2569	40	32	6.4	0	7.35	6.84	6.97	Ozone	-	
13/พ.ค./2569	40	32	6.3	0	7.31	6.89	6.81	Ozone	-	
14/พ.ค./2569	40	32	6.2	0	7.34	6.81	6.43	Ozone	-	
15/พ.ค./2569	40	32	6.5	0	7.32	6.87	6.56	Ozone	-	
16/พ.ค./2569	40	32	6.4	0	7.37	6.81	6.61	Ozone	-	
17/พ.ค./2569	40	32	6.7	0	7.31	6.98	6.98	Ozone	-	
18/พ.ค./2569	40	32	6.8	0	7.29	6.98	6.97	Ozone	-	
19/พ.ค./2569	40	32	6.3	0	7.26	6.87	6.91	Ozone	-	
20/พ.ค./2569	40	32	6.1	0	7.27	6.96	6.94	Ozone	-	
21/พ.ค./2569	40	32	6.5	0	7.31	6.83	6.97	Ozone	-	
22/พ.ค./2569	40	32	6.7	0	7.33	6.81	6.95	Ozone	-	
23/พ.ค./2569	40	32	6.6	0	7.29	6.94	6.94	Ozone	-	
24/พ.ค./2569	40	32	6.5	0	7.34	6.81	6.91	Ozone	-	
25/พ.ค./2569	40	32	6.4	0	7.28	6.84	6.94	Ozone	-	
26/พ.ค./2569	40	32	6.3	0	7.31	6.81	6.91	Ozone	-	
27/พ.ค./2569	40	32	6.5	0	7.29	6.84	6.91	Ozone	-	
28/พ.ค./2569	40	32	6.2	0	7.34	6.95	6.97	Ozone	-	

DATE	ปริมาณน้ำใช้	น้ำเข้าบ่อ	ค่า DO (≥3)	SV30, (0)	PH บ่อ Bg, (5.5-9)	PH บ่อเติมอากาศ, (5.5-9)	PH บ่อน้ำทิ้ง, (5.5-9)	Free Cl ₂ , (0.5-1) / OZONE	CL.คงเหลือ	ผู้บันทึก
29/พ.ค./2569	40	32	6.3	0	7.29	6.91	6.95	Ozone	-	
30/พ.ค./2569	40	32	6.4	0	7.31	6.89	6.94	Ozone	-	
31/พ.ค./2569	40	32	6.3	0	7.32	6.81	6.92	Ozone	-	