

ภาคผนวก ก

ใบรับรองผลการตรวจวิเคราะห์

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: จุดเก็บน้ำก่อนเข้าสู่ระบบบำบัดน้ำเสียส่วนกลาง
Sampling Date	: January 6, 2026
Sampling Time	: 9.23 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Jaturong Bubpasang

Received Date	: January 8, 2026
Analytical Date	: January 8-27, 2026
Sample Condition	: Turbid Yellow, Little Sediment, Smell
Sample Code	: JAN26-018
Report No.	: LAB2601008
Report Date	: January 27, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.3	-
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	46	-
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	<10	-
4	Oil & Grease	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	-
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	40	-

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 7-289

กุลธิดา

(Miss Kullatida Jeenplangchat)

Scientist

7-289-ก-0017

Analyzed

กอร์ชสา

(Miss Kornchasa Boonprasopsom)

Technical Supervisor

7-289-ก-0004

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: จุดเก็บน้ำก่อนเข้าสู่ระบบบำบัดน้ำเสียส่วนกลาง (ค่อ)	Sampling Source	: Wastewater
Sampling Date	: January 6, 2026	Sampling By	: Mr. Jaturong Bubpasang
Sampling Time	: 9.23 น.		

Received Date	: January 8, 2026	Sample Code	: JAN26-018
Analytical Date	: January 8-27, 2026	Report No.	: LAB2601008
Sample Condition	: Turbid Yellow, Little Sediment, Smell	Report Date	: January 27, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	2,400,000	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 7-291



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: จุดเก็บน้ำหลังผ่านระบบบำบัดน้ำเสียส่วนกลาง
Sampling Date	: January 6, 2026
Sampling Time	: 9.16 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Jaturong Bubpasang

Received Date	: January 8, 2026
Analytical Date	: January 8-27, 2026
Sample Condition	: Clear, Little Sediment
Sample Code	: JAN26-019
Report No.	: LAB2601008
Report Date	: January 27, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard ⁽²⁾
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.7	5.5-9.0
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	3	≤20
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	<10	≤30
4	Oil & Grease	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	≤20
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	7	≤35

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 7-289

: ⁽²⁾ ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากที่ดินจัดสรร พ.ศ. 2564 (ประเภท ก)

กุลจิรา

(Miss Kullatida Jeenplangchat)

Scientist

7-289-ก-0017

Analyzed

กอร์ชสา

(Miss Kornchasa Boonprasopsom)

Technical Supervisor

7-289-ก-0004

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: จุดเก็บน้ำหลังผ่านระบบบำบัดน้ำเสียส่วนกลาง (ต่อ)	Sampling Source	: Wastewater
Sampling Date	: January 6, 2026	Sampling By	: Mr. Jaturong Bubpasang
Sampling Time	: 9.16 น.		

Received Date	: January 8, 2026	Sample Code	: JAN26-019
Analytical Date	: January 8-27, 2026	Report No.	: LAB2601008
Sample Condition	: Clear, Little Sediment	Report Date	: January 27, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	4.5	-
7	Nitrate ⁽¹⁾	mg/L	SMWW (2023) 4500 NO ₃ ⁻ E	<0.22	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 3-291



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: บ่อพักสุดท้ายก่อนระบายออกสู่แหล่งน้ำสาธารณะ
Sampling Date	: January 6, 2026
Sampling Time	: 9.36 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Jaturong Bubpasang

Received Date	: January 8, 2026
Analytical Date	: January 8-27, 2026
Sample Condition	: Turbid Yellow, Little Sediment
Sample Code	: JAN26-020
Report No.	: LAB2601008
Report Date	: January 27, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard ⁽²⁾
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.6	5.5-9.0
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	3	≤20
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	53	≤30
4	Oil & Grease	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	≤20
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	7	≤35

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 7-289

: ⁽²⁾ ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากที่ดินจัดสรร พ.ศ. 2564 (ประเภท ก)


(Miss Kullatida Jeenplangchat)

Scientist

7-289-ก-0017

Analyzed


(Miss Kornchasa Boonprasopsom)

Technical Supervisor

7-289-ก-0004

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ	
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240	
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)	
Sampling Location	: บ่อพักสุดท้ายก่อนระบายออกสู่แหล่งน้ำสาธารณะ (ต่อ)	Sampling Source : Wastewater
Sampling Date	: January 6, 2026	Sampling By : Mr. Jaturong Bubpasang
Sampling Time	: 9.36 น.	

Received Date	: January 8, 2026	Sample Code	: JAN26-020
Analytical Date	: January 8-27, 2026	Report No.	: LAB2601008
Sample Condition	: Turbid Yellow, Little Sediment	Report Date	: January 27, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	2.0	-
7	Nitrate ⁽¹⁾	mg/L	SMWW (2023) 4500 NO ₃ ⁻ E	3.46	-
8	Total Phosphorus ⁽¹⁾	mg/L	SMWW (2023) 4500-P C	4.01	-
9	Residual Chlorine ⁽¹⁾	mg/L	SMWW (2023) 4500 Cl B	<0.05	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 7-291



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

Reviewed and Approved

- End of The Analysis Report -

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: จุดเก็บน้ำก่อนเข้าสู่ระบบบำบัดน้ำเสียส่วนกลาง
Sampling Date	: February 3, 2026
Sampling Time	: 9.33 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Jaturong Bubpasang

Received Date	: February 6, 2026	Sample Code	: FEB26-024
Analytical Date	: February 6-25, 2026	Report No.	: LAB2602008
Sample Condition	: Turbid Yellow, Sediment, Smell	Report Date	: February 26, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.4	-
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	37	-
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	19	-
4	Oil & Grease	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	-
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	34	-

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 3-289


(Miss Kullatida Jeenplangchat)
Scientist
3-289-จ-0017
Analyzed


(Miss Kornchasa Boonprasopsom)
Technical Supervisor
3-289-ก-0004
Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: จุดเก็บน้ำก่อนเข้าสู่ระบบบำบัดน้ำเสียส่วนกลาง (ต่อ)	Sampling Source	: Wastewater
Sampling Date	: February 3, 2026	Sampling By	: Mr. Jaturong Bubpasang
Sampling Time	: 9.33 น.		

Received Date	: February 6, 2026	Sample Code	: FEB26-024
Analytical Date	: February 6-25, 2026	Report No.	: LAB2602008
Sample Condition	: Turbid Yellow, Sediment, Smell	Report Date	: February 26, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	160,000	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 3-291



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: จุดเก็บน้ำหลังผ่านระบบบำบัดน้ำเสียส่วนกลาง
Sampling Date	: February 3, 2026
Sampling Time	: 9.15 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Jaturong Bubpasang

Received Date	: February 6, 2026	Sample Code	: FEB26-025
Analytical Date	: February 6-25, 2026	Report No.	: LAB2602008
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: February 26, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard ⁽²⁾
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.2	5.5-9.0
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	3	≤20
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	<10	≤30
4	Oil & Grease	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	≤20
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	<4	≤35

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.
: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 7-289
: ⁽²⁾ ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากที่ดินจัดสรร พ.ศ. 2564 (ประเภท ก)


(Miss Kullatida Jeenplangchat)
Scientist
7-289-ก-0017
Analyzed


(Miss Kornchasa Boonprasopsom)
Technical Supervisor
7-289-ก-0004
Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: จุดเก็บน้ำหลังผ่านระบบบำบัดน้ำเสียส่วนกลาง (ต่อ)	Sampling Source	: Wastewater
Sampling Date	: February 3, 2026	Sampling By	: Mr. Jaturong Bubpasang
Sampling Time	: 9.15 น.		

Received Date	: February 6, 2026	Sample Code	: FEB26-025
Analytical Date	: February 6-25, 2026	Report No.	: LAB2602008
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: February 26, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	70	-
7	Nitrate ⁽¹⁾	mg/L	SMWW (2023) 4500 NO ₃ ⁻ E	0.48	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 3-291



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: บ่อพักสุดท้ายก่อนระบายออกสู่แหล่งน้ำสาธารณะ
Sampling Date	: February 3, 2026
Sampling Time	: 9.46 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Jaturong Bubpasang

Received Date	: February 6, 2026
Analytical Date	: February 6-25, 2026
Sample Condition	: Clear Yellow, Little Sediment
Sample Code	: FEB26-026
Report No.	: LAB2602008
Report Date	: February 26, 2026


Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard ⁽²⁾
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.4	5.5-9.0
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	4	≤20
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	46	≤30
4	Oil & Grease	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	≤20
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	<4	≤35

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 7-289

: ⁽²⁾ ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากที่ดินจัดสรร พ.ศ. 2564 (ประเภท ก)



(Miss Kullatida Jeenplangchat)

Scientist

7-289-จ-0017

Analyzed



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

7-289-ก-0004

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: บ่อพักสุดท้ายก่อนระบายออกสู่แหล่งน้ำสาธารณะ (ต่อ)	Sampling Source	: Wastewater
Sampling Date	: February 3, 2026	Sampling By	: Mr. Jaturong Bubpasang
Sampling Time	: 9.46 น.		

Received Date	: February 6, 2026	Sample Code	: FEB26-026
Analytical Date	: February 6-25, 2026	Report No.	: LAB2602008
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: February 26, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	540	-
7	Nitrate ⁽¹⁾	mg/L	SMWW (2023) 4500 NO ₃ ⁻ E	1.32	-
8	Total Phosphorus ⁽¹⁾	mg/L	SMWW (2023) 4500-P C	9.62	-
9	Residual Chlorine ⁽¹⁾	mg/L	SMWW (2023) 4500 Cl B	<0.05	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 7-291



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: จุดเก็บตัวอย่างน้ำลำเหมืองสาธารณะก่อนผ่านจุดระบายน้ำ ทิ้งของ โครงการ	Sampling Source	: Surface Water
Sampling Date	: February 3, 2026	Sampling By	: Mr. Jaturong Bubpasang
Sampling Time	: 9.52 น.		

Received Date	: February 6, 2026	Sample Code	: FEB26-027
Analytical Date	: February 6-25, 2026	Report No.	: LAB2602008
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: February 26, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	6.9	5.0-9.0 ⁽²⁾
2	Dissolved Oxygen*	mg/L	Dissolved Oxygen Meter	6.1	≥4.0 ⁽²⁾
3	Biochemical Oxygen Demand*	mg/L	MEMBRANE ELECTRODE METHOD (SM:PART 5210 B AND PART 4500-O G)	3	≤2 ⁽³⁾
4	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	19	-
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	<4	-

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co.Ltd. Registration No. 7-289

: ⁽²⁾ ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ ฉบับที่ 8 (พ.ศ. 2537) ออกตามความในพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. 2535 เรื่อง กำหนดมาตรฐานคุณภาพน้ำในแหล่งน้ำผิวดิน



(Miss Kullatida Jeenplangchat)

Scientist

7-289-0-0017

Analyzed



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

7-289-0-0004

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: จุดเก็บตัวอย่างน้ำลำเหมืองสาธารณะก่อนผ่านจุดระบายน้ำทิ้งของโครงการ (ต่อ)	Sampling Source	: Surface Water
Sampling Date	: February 3, 2026	Sampling By	: Mr. Jaturong Bubpasang
Sampling Time	: 9.52 น.		

Received Date	: February 6, 2026	Sample Code	: FEB26-027
Analytical Date	: February 6-25, 2026	Report No.	: LAB2602008
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: February 26, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	79	≤4,000 ⁽²⁾

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 7-291

: ⁽²⁾ ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ ฉบับที่ 8 (พ.ศ. 2537) ออกตามความในพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. 2535 เรื่อง กำหนดมาตรฐานคุณภาพน้ำในแหล่งน้ำผิวดิน



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: จุดเก็บตัวอย่างน้ำลำเหมืองสาธารณะหลังผ่านจุดระบายน้ำทิ้งของโครงการ	Sampling Source	: Surface Water
Sampling Date	: February 3, 2026	Sampling By	: Mr. Jaturong Bubpasang
Sampling Time	: 9.57 น.		

Received Date	: February 6, 2026	Sample Code	: FEB26-028
Analytical Date	: February 6-25, 2026	Report No.	: LAB2602008
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: February 26, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	6.9	5.0-9.0 ⁽²⁾
2	Dissolved Oxygen*	mg/L	Dissolved Oxygen Meter	6.2	≥4.0 ⁽²⁾
3	Biochemical Oxygen Demand*	mg/L	MEMBRANE ELECTRODE METHOD (SM:PART 5210 B AND PART 4500-O G)	3	≤2 ⁽²⁾
4	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	17	-
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{CRG} C.)	<4	-

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

⁽¹⁾ Analysis results by Skilltech and Environmental Co.Ltd. Registration No. 3-289

⁽²⁾ ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ ฉบับที่ 8 (พ.ศ. 2537) ออกตามความในพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. 2535 เรื่อง กำหนดมาตรฐานคุณภาพน้ำในแหล่งน้ำผิวดิน



(Miss Kullatida Jeenplangchat)

Scientist

3-289-0-0017

Analyzed



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

3-289-0-0004

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: จุดเก็บตัวอย่างน้ำลำเหมืองสาธารณะหลังผ่านจุดระบายน้ำทิ้งของโครงการ (ต่อ)	Sampling Source	: Surface Water
Sampling Date	: February 3, 2026	Sampling By	: Mr. Jaturong Bubpasang
Sampling Time	: 9.57 น.		

Received Date	: February 6, 2026	Sample Code	: FEB26-028
Analytical Date	: February 6-25, 2026	Report No.	: LAB2602008
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: February 26, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	23	≤4,000 ⁽²⁾

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 3-291

: ⁽²⁾ ประกาศคณะกรรมการสิ่งแวดล้อมแห่งชาติ ฉบับที่ 8 (พ.ศ. 2537) ออกตามความในพระราชบัญญัติส่งเสริมและรักษาคุณภาพสิ่งแวดล้อมแห่งชาติ พ.ศ. 2535 เรื่อง กำหนดมาตรฐานคุณภาพน้ำในแหล่งน้ำผิวดิน



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

Reviewed and Approved

- End of The Analysis Report -

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดลำปาง (พืช)
Sampling Location	: จุดเก็บน้ำก่อนเข้าสู่ระบบบำบัดน้ำเสียส่วนกลาง
Sampling Date	: March 1, 2026
Sampling Time	: 13.16 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Jaturong bubpasang

Received Date	: March 5, 2026
Analytical Date	: March 5-26, 2026
Sample Condition	: Turbid Grey, Very Sediment, Smell
Sample Code	: MAR26-011
Report No.	: LAB2603004
Report Date	: March 26, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.3	-
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	35	-
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	21	-
4	Oil & Grease	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	-
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	48	-

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 7-289

กุลจิต

(Miss Kullatida Jeenplangchat)

Scientist

7-289-0-0017

Analyzed

กอร์ชสา

(Miss Kornchasa Boonprasopsom)

Technical Supervisor

7-289-0-0004

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดลำปาง (พิชัย)		
Sampling Location	: จุดเก็บน้ำก่อนเข้าสู่ระบบบำบัดน้ำเสียส่วนกลาง (ต่อ)	Sampling Source	: Wastewater
Sampling Date	: March 1, 2026	Sampling By	: Mr. Jaturong bubpasang
Sampling Time	: 13.16 น.		

Received Date	: March 5, 2026	Sample Code	: MAR26-011
Analytical Date	: March 5-26, 2026	Report No.	: LAB2603004
Sample Condition	: Turbid Grey, Very Sediment, Smell	Report Date	: March 26, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	11,000	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 7-291



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดลำปาง (พิชัย)
Sampling Location	: จุดเก็บน้ำหลังผ่านระบบบำบัดน้ำเสียส่วนกลาง
Sampling Date	: March 1, 2026
Sampling Time	: 13.09 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Jaturong bubpasang

Received Date	: March 5, 2026
Analytical Date	: March 5-26, 2026
Sample Condition	: Clear Yellow, Little Sediment
Sample Code	: MAR26-012
Report No.	: LAB2603004
Report Date	: March 26, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard ⁽²⁾
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.3	5.5-9.0
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	6	≤20
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	<10	≤30
4	Oil & Grease	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	≤20
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	13	≤35

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 7-289

: ⁽²⁾ ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากที่ดินจัดสรร พ.ศ. 2564 (ประเภท ก)


(Miss Kullatida Jeenplangchat)

Scientist

7-289-0-0017

Analyzed


(Miss Kornchasa Boonprasopsom)

Technical Supervisor

7-289-0-0004

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดลำปาง (พิชัย)		
Sampling Location	: จุดเก็บน้ำหลังผ่านระบบบำบัดน้ำเสียส่วนกลาง (ต่อ)	Sampling Source	: Wastewater
Sampling Date	: March 1, 2026	Sampling By	: Mr. Jaturong bubpasang
Sampling Time	: 13.09 น.		

Received Date	: March 5, 2026	Sample Code	: MAR26-012
Analytical Date	: March 5-26, 2026	Report No.	: LAB2603004
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: March 26, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	5,400	-
7	Nitrate ⁽¹⁾	mg/L	SMWW (2023) 4500 NO ₃ ⁻ E	5.86	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 7-291



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

Reviewed and Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดลำปาง (พิชัย)
Sampling Location	: บ่อพักสุดท้ายก่อนระบายออกสู่แหล่งน้ำสาธารณะ
Sampling Date	: March 1, 2026
Sampling Time	: 13.27 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Jaturong bubpasang

Received Date	: March 5, 2026
Analytical Date	: March 5-26, 2026
Sample Condition	: Clear Yellow, Sediment
Sample Code	: MAR26-013
Report No.	: LAB2603004
Report Date	: March 26, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard ⁽²⁾
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.4	5.5-9.0
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	9	≤20
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	<10	≤30
4	Oil & Grease	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	≤20
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	18	≤35

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 7-289

: ⁽²⁾ ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากที่ดินจัดสรร พ.ศ. 2564 (ประเภท ก)



(Miss Kullatida Jeenplangchat)

Scientist

7-289-0-0017

Analyzed



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

7-289-0-0004

Reviewed and Approved

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL, REPORT ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ	
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240	
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดลำปาง (พิชัย)	
Sampling Location	: บ่อพักสุดท้ายก่อนระบายออกสู่แหล่งน้ำสาธารณะ (ต่อ)	Sampling Source : Wastewater
Sampling Date	: March 1, 2026	Sampling By : Mr. Jaturong bubpasang
Sampling Time	: 13.27 น.	

Received Date	: March 5, 2026	Sample Code	: MAR26-013
Analytical Date	: March 5-26, 2026	Report No.	: LAB2603004
Sample Condition	: Clear Yellow, Sediment	Report Date	: March 26, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	790	-
7	Nitrate ⁽¹⁾	mg/L	SMWW (2023) 4500 NO ₃ ⁻ E	1.11	-
8	Total Phosphorus ⁽¹⁾	mg/L	SMWW (2023) 4500-P C)	10.51	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 7-291



(Miss Kornchasa Boonprasopsom)

Technical Supervisor

Reviewed and Approved

- End of The Analysis Report -

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนวชิรธร แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: จุดเก็บน้ำก่อนเข้าสู่ระบบบำบัดน้ำเสียส่วนกลาง	Sampling Source	: Wastewater
Sampling Date	: April 1, 2026	Sampling By	: Mr. Jaturong Bubpasang
Sampling Time	: 11.32 น.		

Received Date	: April 2, 2026	Sample Code	: APR26-004
Analytical Date	: April 2-23, 2026	Report No.	: LAB2604002
Sample Condition	: Turbid Yellow, Sediment, Smell	Report Date	: April 27, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.3	-
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	26	-
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	24	-
4	Oil & Grease*	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	-
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	37	-

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 7-289

☒ Kornchasa Boonprasopsom (7-289-ก-0004)
☒ Nontharit Promtakaew (7-289-ก-0003)
☒ Kullatida Jeenplangchat (7-289-อ-0017)

Scientist

Analyzed


 (Miss Pranisa Kunsamut)
 Technical Supervisor

7-289-ก-0001

Approved

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL, REPORT ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: จุดเก็บน้ำก่อนเข้าสู่ระบบบำบัดน้ำเสียส่วนกลาง (ต่อ)
Sampling Date	: April 1, 2026
Sampling Time	: 11.32 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Jaturong Bubpasang

Received Date	: April 2, 2026
Analytical Date	: April 2-23, 2026
Sample Condition	: Turbid Yellow, Sediment, Smell
Sample Code	: APR26-004
Report No.	: LAB2604002
Report Date	: April 27, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	920	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 3-291



(Miss Pranisa Kunsamut)

Technical Supervisor

Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: จุดเก็บน้ำหลังผ่านระบบบำบัดน้ำเสียส่วนกลาง
Sampling Date	: April 1, 2026
Sampling Time	: 11.41 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Jaturong Bubpasang

Received Date	: April 2, 2026
Analytical Date	: April 2-23, 2026
Sample Condition	: Clear, Little Sediment
Sample Code	: APR26-005
Report No.	: LAB2604002
Report Date	: April 27, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard ⁽²⁾
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.4	5.5-9.0
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	2	≤20
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	<10	≤30
4	Oil & Grease*	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	≤20
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	<4	≤35

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 3-289

: ⁽²⁾ ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากที่ดินจัดสรร พ.ศ. 2564 (ประเภท ก)

☒ Kornchasa Boonprasopsom (3-289-ก-0004)

☒ Nontharit Promtakaew (3-289-ก-0003)

☒ Kullatida Jeenplangchat (3-289-ก-0017)

Scientist

Analyzed


(Miss Pranisa Kunsamut)

Technical Supervisor

3-289-ก-0001

Approved

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL, REPORT ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: จุดเก็บน้ำหลังผ่านระบบบำบัดน้ำเสียส่วนกลาง (ต่อ)
Sampling Date	: April 1, 2026
Sampling Time	: 11.41 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Jaturong Bubpasang

Received Date	: April 2, 2026
Analytical Date	: April 2-23, 2026
Sample Condition	: Clear, Little Sediment
Sample Code	: APR26-005
Report No.	: LAB2604002
Report Date	: April 27, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	13	-
7	Nitrate ⁽¹⁾	mg/L	SMWW (2023) 4500 NO ₃ ⁻ E	<0.22	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 7-291



(Miss Pranisa Kunsamut)

Technical Supervisor

Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ	
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240	
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)	
Sampling Location	: บ่อกักสูกั๊ยก่อนระบายออกสู่แหล่งน้ำสาธารณะ	Sampling Source : Wastewater
Sampling Date	: April 1, 2026	Sampling By : Mr. Jaturong Bubpasang
Sampling Time	: 11.50 น.	

Received Date	: April 2, 2026	Sample Code	: APR26-006
Analytical Date	: April 2-23, 2026	Report No.	: LAB2604002
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: April 27, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard ⁽²⁾
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.3	5.5-9.0
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	3	≤20
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	36	≤30
4	Oil & Grease*	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	≤20
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	<4	≤35

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 7-289

: ⁽²⁾ ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากที่ดินจัดสรร พ.ศ. 2564 (ประเภท ก)

☒ Kornchasa Boonprasopsom (7-289-ก-0004)

☒ Nontharit Promtakaew (7-289-ก-0003)

☒ Kullatida Jeenplangchat (7-289-ก-0017)

Scientist

Analyzed


(Miss Pranisa Kunsamut)

Technical Supervisor

7-289-ก-0001

Approved

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL, REPORT ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: บ่อพักสุดท้ายก่อนระบายออกสู่แหล่งน้ำสาธารณะ (ต่อ)
Sampling Date	: April 1, 2026
Sampling Time	: 11.50 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Jaturong Bubpasang

Received Date	: April 2, 2026	Sample Code	: APR26-006
Analytical Date	: April 2-23, 2026	Report No.	: LAB2604002
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: April 27, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	16,000	-
7	Nitrate ⁽¹⁾	mg/L	SMWW (2023) 4500 NO ₃ ⁻ E	1.85	-
8	Total Phosphorus ⁽¹⁾	mg/L	SMWW (2023) 4500-P C)	0.56	-
9	Residual Chlorine ⁽¹⁾	mg/L	SMWW (2023) 4500 Cl B	<0.05	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 7-291



(Miss Pranisa Kunsamut)

Technical Supervisor

Approved

- End of The Analysis Report -

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: จุดเก็บน้ำก่อนเข้าสู่ระบบบำบัดน้ำเสียส่วนกลาง
Sampling Date	: May 4, 2026
Sampling Time	: 10.21 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Pongpitsanu Jaitiang

Received Date	: May 6, 2026
Analytical Date	: May 6-26, 2026
Sample Condition	: Turbid Yellow, Little Sediment, Smell
Sample Code	: MAY26-016
Report No.	: LAB2605006
Report Date	: May 30, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.6	-
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	25	-
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	<10	-
4	Oil & Grease*	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	-
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	27	-

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 3-289

☒ Kornchasa Boonprasopsom (3-289-ก-0004)

☒ Nontharit Promtakaew (3-289-ก-0003)

☒ Kullatida Jeenplangchat (3-289-ก-0017)

Scientist

Analyzed



(Miss Pranisa Kunsamut)

Technical Supervisor

3-289-ก-0001

Approved

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL, REPORT ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: จุดเก็บน้ำก่อนเข้าสู่ระบบบำบัดน้ำเสียส่วนกลาง (ต่อ)
Sampling Date	: May 4, 2026
Sampling Time	: 10.21 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Pongpitsanu Jaitiang

Received Date	: May 6, 2026	Sample Code	: MAY26-016
Analytical Date	: May 6-26, 2026	Report No.	: LAB2605006
Sample Condition	: Turbid Yellow, Little Sediment, Smell	Report Date	: May 30, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	1,600,000	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 3-291



(Miss Pranisa Kunsamut)

Technical Supervisor

Approved

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL, REPORT ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: จุดเก็บน้ำหลังผ่านระบบบำบัดน้ำเสียส่วนกลาง
Sampling Date	: May 4, 2026
Sampling Time	: 10.15 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Pongpitsanu Jaitiang

Received Date	: May 6, 2026
Analytical Date	: May 6-26, 2026
Sample Condition	: Clear Yellow, Little Sediment
Sample Code	: MAY26-017
Report No.	: LAB2605006
Report Date	: May 30, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard ⁽²⁾
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.5	5.5-9.0
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	3	≤20
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	<10	≤30
4	Oil & Grease*	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	≤20
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{org} C.)	<4	≤35

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No.จ-289

: ⁽²⁾ ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากที่ดินจัดสรร พ.ศ. 2564 (ประเภท ก)

☒ Kornchasa Boonprasopsom (จ-289-ก-0004)

☒ Nontharit Promtakaew (จ-289-ก-0003)

☒ Kullatida Jeenplangchat (จ-289-ก-0017)

Scientist

Analyzed



(Miss Pranisa Kunsamut)

Technical Supervisor

จ-289-ก-0001

Approved

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL, REPORT ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: จุดเก็บน้ำหลังผ่านระบบบำบัดน้ำเสียส่วนกลาง (ต่อ)
Sampling Date	: May 4, 2026
Sampling Time	: 10.15 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Pongpitsanu Jaitiang

Received Date	: May 6, 2026
Analytical Date	: May 6-26, 2026
Sample Condition	: Clear Yellow, Little Sediment
Sample Code	: MAY26-017
Report No.	: LAB2605006
Report Date	: May 30, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	240	-
7	Nitrate ⁽¹⁾	mg/L	SMWW (2023) 4500 NO ₃ ⁻ E	<0.22	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 7-291



(Miss Pranisa Kunsamut)

Technical Supervisor

Approved

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL, REPORT ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: บ่อพักสุดท้ายก่อนระบายออกสู่แหล่งน้ำสาธารณะ	Sampling Source	: Wastewater
Sampling Date	: May 4, 2026	Sampling By	: Mr. Pongpitsanu Jaitiang
Sampling Time	: 10.01 น.		

Received Date	: May 6, 2026	Sample Code	: MAY26-018
Analytical Date	: May 6-26, 2026	Report No.	: LAB2605006
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: May 30, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard ⁽²⁾
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.6	5.5-9.0
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	2	≤20
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	<10	≤30
4	Oil & Grease*	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	≤20
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	<4	≤35

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No.จ-289

: ⁽²⁾ ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากที่ดินจัดสรร พ.ศ. 2564 (ประเภท ก)

☒ Kornchasa Boonprasopsom (จ-289-ก-0004)

☒ Nontharit Promtakaew (จ-289-ก-0003)

☒ Kullatida Jeenplangchat (จ-289-ก-0017)

Scientist

Analyzed


(Miss Pranisa Kunsamut)
Technical Supervisor
จ-289-ก-0001
Approved

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL, REPORT ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนวินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: บ่อพักสุดท้ายก่อนระบายออกสู่แหล่งน้ำสาธารณะ (ต่อ)	Sampling Source	: Wastewater
Sampling Date	: May 4, 2026	Sampling By	: Mr. Pongpitsanu Jaitiang
Sampling Time	: 10.01 น.		

Received Date	: May 6, 2026	Sample Code	: MAY26-018
Analytical Date	: May 6-26, 2026	Report No.	: LAB2605006
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: May 30, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	240	-
7	Nitrate ⁽¹⁾	mg/L	SMWW (2023) 4500 NO ₃ ⁻ E	0.61	-
8	Total Phosphorus ⁽¹⁾	mg/L	SMWW (2023) 4500-P C)	0.48	-
9	Residual Chlorine ⁽¹⁾	mg/L	SMWW (2023) 4500 Cl B	<0.05	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 7-291



(Miss Pranisa Kunsamut)

Technical Supervisor

Approved

- End of The Analysis Report -

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL, REPORT ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: จุดเก็บน้ำก่อนเข้าสู่ระบบบำบัดน้ำเสียส่วนกลาง
Sampling Date	: June 3, 2026
Sampling Time	: 13.42 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Nontharit Promtakaew

Received Date	: June 5, 2026
Analytical Date	: June 5-19, 2026
Sample Condition	: Turbid Yellow, Little Sediment, Smell
Sample Code	: JUN26-030
Report No.	: LAB2606011
Report Date	: June 19, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.1	-
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	22	-
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	8.25	-
4	Oil & Grease*	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	-
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	24	-

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.
: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 7-289

☒ Kornchasa Boonprasopsom (7-289-ก-0004)
☒ Nontharit Promtakaew (7-289-ก-0003)
☒ Kullatida Jeenplangchat (7-289-ก-0017)

Scientist

Analyzed


(Miss Pranisa Kunsamut)

Technical Supervisor

7-289-ก-0001

Approved

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL, REPORT ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: จุดเก็บน้ำก่อนเข้าสู่ระบบบำบัดน้ำเสียส่วนกลาง (ต่อ)
Sampling Date	: June 3, 2026
Sampling Time	: 13.42 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Nontharit Promtakaew

Received Date	: June 5, 2026	Sample Code	: JUN26-030
Analytical Date	: June 5-19, 2026	Report No.	: LAB2606011
Sample Condition	: Turbid Yellow, Little Sediment, Smell	Report Date	: June 19, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	1,600,000	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 3-291



(Miss Pranisa Kunsamut)

Technical Supervisor

Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: จุดเก็บน้ำหลังผ่านระบบบำบัดน้ำเสียส่วนกลาง	Sampling Source	: Wastewater
Sampling Date	: June 3, 2026	Sampling By	: Mr. Nontharit Promtakaew
Sampling Time	: 13.30 น.		

Received Date	: May 6, 2026	Sample Code	: JUN26-031
Analytical Date	: May 6-26, 2026	Report No.	: LAB2606011
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: June 19, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard ⁽²⁾
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.0	5.5-9.0
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	3	≤20
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	2.67	≤30
4	Oil & Grease*	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	≤20
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	<4	≤35

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.
: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.
: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 7-289
: ⁽²⁾ ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากที่ดินจัดสรร พ.ศ. 2564 (ประเภท ก)

☒ Kornchasa Boonprasopsom (7-289-ก-0004)
☒ Nontharit Promtakaew (7-289-ก-0003)
☒ Kullatida Jeenplangchat (7-289-ก-0017)

Scientist

Analyzed


(Miss Pranisa Kunsamut)

Technical Supervisor

7-289-ก-0001

Approved

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL, REPORT ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ		
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	: จุดเก็บน้ำหลังผ่านระบบบำบัดน้ำเสียส่วนกลาง (ต่อ)	Sampling Source	: Wastewater
Sampling Date	: June 3, 2026	Sampling By	: Mr. Nontharit Promtakaew
Sampling Time	: 13.30 น.		

Received Date	: May 6, 2026	Sample Code	: JUN26-031
Analytical Date	: May 6-26, 2026	Report No.	: LAB2606011
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: June 19, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	140	-
7	Nitrate ⁽¹⁾	mg/L	SMWW (2023) 4500 NO ₃ ⁻ E	<0.22	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 7-291



(Miss Pranisa Kunsamut)

Technical Supervisor

Approved

ANALYSIS REPORT

Customer Name	: การเคหะแห่งชาติ
Address	: 905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240
Project Name	: โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)
Sampling Location	: บ่อพักสุดท้ายก่อนระบายออกสู่แหล่งน้ำสาธารณะ
Sampling Date	: June 3, 2026
Sampling Time	: 13.58 น.
Sampling Source	: Wastewater
Sampling By	: Mr. Nontharit Promtakaew

Received Date	: May 6, 2026
Analytical Date	: May 6-26, 2026
Sample Condition	: Clear Yellow, Little Sediment
Sample Code	: JUN26-032
Report No.	: LAB2606011
Report Date	: June 19, 2026

Item	Parameter	Unit	Method of Analysis	Result ⁽¹⁾	Standard ⁽²⁾
1	pH at 25 °C	-	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 4500-H ⁺ B	7.0	5.5-9.0
2	Biochemical Oxygen Demand*	mg/L	5-Day BOD Test (5210 B), Azide Modification (4500-O C)	5	≤20
3	Total Suspended Solids	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 2540 D	12.75	≤30
4	Oil & Grease*	mg/L	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF 24 th edition, 2023, part 5520 B	<5	≤20
5	Total Kjeldahl Nitrogen*	mg/L	Semi-Micro Kjeldahl Method (4500-N _{ORG} C.)	<4	≤35

Remark : * The parameters are outside the scope of accreditation to ISO/IEC 17025:2017 by Thailand Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analysis results by Skilltech and Environmental Co., Ltd. Registration No. 7-289

: ⁽²⁾ ประกาศกระทรวงทรัพยากรธรรมชาติและสิ่งแวดล้อม เรื่อง กำหนดมาตรฐานควบคุมการระบายน้ำทิ้งจากที่ดินจัดสรร พ.ศ. 2564 (ประเภท ก)

☒ Kornchasa Boonprasopsom (7-289-ก-0004)
☒ Nontharit Promtakaew (7-289-ก-0003)
☒ Kullatida Jeenplangchat (7-289-ก-0017)

Scientist

Analyzed



(Miss Pranisa Kunsamut)

Technical Supervisor

7-289-ก-0001

Approved

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL, REPORT ANALYSIS REFERS TO SUBMITTED SAMPLE ONLY

ANALYSIS REPORT

Customer Name	:	การเคหะแห่งชาติ		
Address	:	905 ถนนนวมินทร์ แขวงคลองจั่น เขตบางกะปิ กรุงเทพฯ 10240		
Project Name	:	โครงการบ้านเอื้ออาทร จังหวัดเชียงราย (ริมกก)		
Sampling Location	:	บ่อกักสุดท้ายก่อนระบายออกสู่แหล่งน้ำสาธารณะ (ต่อ)	Sampling Source	: Wastewater
Sampling Date	:	June 3, 2026	Sampling By	: Mr. Nontharit Promtakaew
Sampling Time	:	13.58 น.		

Received Date	: May 6, 2026	Sample Code	: JUN26-032
Analytical Date	: May 6-26, 2026	Report No.	: LAB2606011
Sample Condition	: Clear Yellow, Little Sediment	Report Date	: June 19, 2026

Item	Parameter*	Unit	Method of Analysis	Result	Standard
6	Fecal Coliform Bacteria ⁽¹⁾	MPN/100 mL	SMWW (2023) 9221 E	920	-
7	Nitrate ⁽¹⁾	mg/L	SMWW (2023) 4500 NO ₃ ⁻ E	0.73	-
8	Total Phosphorus ⁽¹⁾	mg/L	SMWW (2023) 4500-P C	0.44	-
9	Residual Chlorine ⁽¹⁾	mg/L	SMWW (2023) 4500 Cl B	<0.05	-

Remark : * The parameters are out of the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: Sampling activities are outside the scope of accreditation to ISO/IEC 17025:2017 by Thai Industrial Standards Institute.

: ⁽¹⁾ Analyzed by South East Asian Laboratory Co., Ltd. Registration No. 3-291



(Miss Pranisa Kunsamut)

Technical Supervisor

Approved

- End of The Analysis Report -