คุณภาพน้ำสระว่ายน้ำ



TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673244 E 1519630 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3
Sample Type : Swimming pool Water
Sampling Date : 07 January 2026
Sampling Time : 09.31 a.m.
Received Date : 08 January 2026
Analytical Date : 08 - 13 January 2026
Report Date : 14 January 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673266 E 1519627 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4
Sample Type : Swimming pool Water
Sampling Date : 07 January 2026
Sampling Time : 09.30 a.m.
Received Date : 08 January 2026
Analytical Date : 08 - 13 January 2026
Report Date : 14 January 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name	:	โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project	:	เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนตื้น
GPS. Coordinate	:	47 P 673244 E 1519630 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Customer Code	:	W69098
Sample No	:	W69098/3-1
Sample Type	:	Swimming pool Water
Sampling Date	:	15 January 2026
Sampling Time	:	01.20 p.m.
Received Date	:	16 January 2026
Analytical Date	:	16 - 28 January 2026
Report Date	:	29 January 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

Miss Jarawee Aedee
Analyst

TNP ENVIRONMENT CO.,LTD.
บริษัท ทีเอ็นพี เอ็นไวรอนเมนท์ จำกัด

Miss Anusara Kaewkajorn
Laboratory Manager

DO NOT COPY PARTIAL OR
REPORTED RESULTS REFER

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name	:	โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project	:	เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนลึก
GPS. Coordinate	:	47 P 673266 E 1519627 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Customer Code	:	W69098
Sample No	:	W69098/4-1
Sample Type	:	Swimming pool Water
Sampling Date	:	15 January 2026
Sampling Time	:	01.20 p.m.
Received Date	:	16 January 2026
Analytical Date	:	16 - 28 January 2026
Report Date	:	29 January 2026

Parameter	Unit	Analytical Method [1/]	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark [1/] Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

[2/] Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name	:	โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project	:	เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนตื้น
GPS. Coordinate	:	47 P 673244 E 1519630 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Customer Code	:	W69098
Sample No	:	W69098/3-2
Sample Type	:	Swimming pool Water
Sampling Date	:	22 January 2026
Sampling Time	:	09.01 a.m.
Received Date	:	23 January 2026
Analytical Date	:	23 - 28 January 2026
Report Date	:	29 January 2026

Parameter	Unit	Analytical Method [1/]	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark [1/] Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

[2/] Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer			Data Provided by Laboratory		
Customer Name	:	นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย	Customer Code	:	W69098
Project Name	:	โครงการ เดอะ ทรี พัฒนาการ-เอกมัย	Sample No	:	W69098/4-2
Address Project	:	เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250	Sample Type	:	Swimming pool Water
			Sampling Date	:	22 January 2026
Sampling Point	:	สระว่ายน้ำส่วนลึก	Sampling Time	:	09.00 a.m.
GPS. Coordinate	:	47 P 673266 E 1519627 N	Received Date	:	23 January 2026
Sampling By	:	TNP ENVIRONMENT CO., LTD.	Analytical Date	:	23 - 28 January 2026
Sampling Method	:	Grab Sampling	Report Date	:	29 January 2026

Parameter	Unit	Analytical Method [1/]	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark [1/] Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

[2/] Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer			Data Provided by Laboratory		
Customer Name	:	นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย	Customer Code	:	W69098
Project Name	:	โครงการ เดอะ ทรี พัฒนาการ-เอกมัย	Sample No	:	W69098/3-3
Address Project	:	เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250	Sample Type	:	Swimming pool Water
			Sampling Date	:	28 January 2026
Sampling Point	:	สระว่ายน้ำส่วนตื้น	Sampling Time	:	10.02 a.m.
GPS. Coordinate	:	47 P 673244 E 1519630 N	Received Date	:	29 January 2026
Sampling By	:	TNP ENVIRONMENT CO., LTD.	Analytical Date	:	29 January - 04 February 2026
Sampling Method	:	Grab Sampling	Report Date	:	05 February 2026

Parameter	Unit	Analytical Method [1/]	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark [1/] Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

[2/] Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer			Data Provided by Laboratory		
Customer Name	:	นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย	Customer Code	:	W69098
Project Name	:	โครงการ เดอะ ทรี พัฒนาการ-เอกมัย	Sample No	:	W69098/4-3
Address Project	:	เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250	Sample Type	:	Swimming pool Water
			Sampling Date	:	28 January 2026
Sampling Point	:	สระว่ายน้ำส่วนลึก	Sampling Time	:	10.00 a.m.
GPS. Coordinate	:	47 P 673266 E 1519627 N	Received Date	:	29 January 2026
Sampling By	:	TNP ENVIRONMENT CO., LTD.	Analytical Date	:	29 January - 04 February 2026
Sampling Method	:	Grab Sampling	Report Date	:	05 February 2026

Parameter	Unit	Analytical Method [1/]	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark [1/] Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

[2/] Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673198 E 1519673 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3
Sample Type : Swimming pool Water
Sampling Date : 04 February 2026
Sampling Time : 10.03 a.m.
Received Date : 05 February 2026
Analytical Date : 05 - 11 February 2026
Report Date : 12 February 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673232 E 1519624 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4
Sample Type : Swimming pool Water
Sampling Date : 04 February 2026
Sampling Time : 10.01 a.m.
Received Date : 05 February 2026
Analytical Date : 05 - 11 February 2026
Report Date : 12 February 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673199 E 1519673 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3-1
Sample Type : Swimming pool Water
Sampling Date : 12 February 2026
Sampling Time : 02.00 p.m.
Received Date : 13 February 2026
Analytical Date : 13 - 25 February 2026
Report Date : 26 February 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673234 E 1519627 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-1
Sample Type : Swimming pool Water
Sampling Date : 12 February 2026
Sampling Time : 02.00 p.m.
Received Date : 13 February 2026
Analytical Date : 13 - 25 February 2026
Report Date : 26 February 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name	:	โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project	:	เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนตื้น
GPS. Coordinate	:	47 P 673244 E 1519677 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Customer Code	:	W69098
Sample No	:	W69098/3-2
Sample Type	:	Swimming pool Water
Sampling Date	:	18 February 2026
Sampling Time	:	09.02 a.m.
Received Date	:	19 February 2026
Analytical Date	:	19 - 25 February 2026
Report Date	:	26 February 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673266 E 1519622 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-2
Sample Type : Swimming pool Water
Sampling Date : 18 February 2026
Sampling Time : 09.00 a.m.
Received Date : 19 February 2026
Analytical Date : 19 - 25 February 2026
Report Date : 26 February 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th *Edition, 2023, Part 9213 B*	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name	:	โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project	:	เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนตื้น
GPS. Coordinate	:	47 P 673200 E 1519675 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Customer Code	:	W69098
Sample No	:	W69098/3-3
Sample Type	:	Swimming pool Water
Sampling Date	:	25 February 2026
Sampling Time	:	10.01 a.m.
Received Date	:	26 February 2026
Analytical Date	:	26 February - 05 March 2026
Report Date	:	06 March 2026

Parameter	Unit	Analytical Method [1/]	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark [1/] Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

[2/] Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673236 E 1519619 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-3
Sample Type : Swimming pool Water
Sampling Date : 25 February 2026
Sampling Time : 10.00 a.m.
Received Date : 26 February 2026
Analytical Date : 26 February - 05 March 2026
Report Date : 06 March 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673195 E 1519666 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3
Sample Type : Swimming pool Water
Sampling Date : 04 March 2026
Sampling Time : 11.01 a.m.
Received Date : 05 March 2026
Analytical Date : 05 - 11 March 2026
Report Date : 12 March 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673241 E 1519631 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4
Sample Type : Swimming pool Water
Sampling Date : 04 March 2026
Sampling Time : 11.00 a.m.
Received Date : 05 March 2026
Analytical Date : 05 - 11 March 2026
Report Date : 12 March 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673241 E 1519630 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3-1
Sample Type : Swimming pool Water
Sampling Date : 11 March 2026
Sampling Time : 09.31 a.m.
Received Date : 12 March 2026
Analytical Date : 12 - 18 March 2026
Report Date : 19 March 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673243 E 1519266 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-1
Sample Type : Swimming pool Water
Sampling Date : 11 March 2026
Sampling Time : 09.30 a.m.
Received Date : 12 March 2026
Analytical Date : 12 - 18 March 2026
Report Date : 19 March 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark
1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673192 E 1519667 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3-2
Sample Type : Swimming pool Water
Sampling Date : 17 March 2026
Sampling Time : 01.20 p.m.
Received Date : 18 March 2026
Analytical Date : 18 - 30 March 2026
Report Date : 31 March 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673232 E 1519629 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-2
Sample Type : Swimming pool Water
Sampling Date : 17 March 2026
Sampling Time : 01.20 p.m.
Received Date : 18 March 2026
Analytical Date : 18 - 30 March 2026
Report Date : 31 March 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673194 E 1519674 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3-3
Sample Type : Swimming pool Water
Sampling Date : 24 March 2026
Sampling Time : 09.31 a.m.
Received Date : 25 March 2026
Analytical Date : 25 - 31 March 2026
Report Date : 1 April 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673232 E 1519629 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-3
Sample Type : Swimming pool Water
Sampling Date : 24 March 2026
Sampling Time : 09.30 a.m.
Received Date : 25 March 2026
Analytical Date : 25 - 31 March 2026
Report Date : 1 April 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673241 E 1519614 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 09.30 a.m.
Received Date : 04 April 2026
Analytical Date : 04 - 10 April 2026
Report Date : 16 April 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark
1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673237 E 1519628 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 09.31 a.m.
Received Date : 04 April 2026
Analytical Date : 04 - 10 April 2026
Report Date : 16 April 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673240 E 1519610 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3-1
Sample Type : Swimming pool Water
Sampling Date : 08 April 2026
Sampling Time : 02.50 p.m.
Received Date : 09 April 2026
Analytical Date : 09 - 21 April 2026
Report Date : 22 April 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673233 E 1519627 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-1
Sample Type : Swimming pool Water
Sampling Date : 08 April 2026
Sampling Time : 02.50 p.m.
Received Date : 09 April 2026
Analytical Date : 09 - 21 April 2026
Report Date : 22 April 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673246 E 1519604 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3-2
Sample Type : Swimming pool Water
Sampling Date : 16 April 2026
Sampling Time : 09.00 a.m.
Received Date : 17 April 2026
Analytical Date : 17 - 22 April 2026
Report Date : 23 April 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673238 E 1519615 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-2
Sample Type : Swimming pool Water
Sampling Date : 16 April 2026
Sampling Time : 09.01 a.m.
Received Date : 17 April 2026
Analytical Date : 17 - 22 April 2026
Report Date : 23 April 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark
1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673239 E 1519631 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3-3
Sample Type : Swimming pool Water
Sampling Date : 23 April 2026
Sampling Time : 10.00 a.m.
Received Date : 24 April 2026
Analytical Date : 24 - 30 April 2026
Report Date : 04 May 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673233 E 1519630 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-3
Sample Type : Swimming pool Water
Sampling Date : 23 April 2026
Sampling Time : 10.01 a.m.
Received Date : 24 April 2026
Analytical Date : 24 - 30 April 2026
Report Date : 04 May 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673244 E 1519619 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3-4
Sample Type : Swimming pool Water
Sampling Date : 29 April 2026
Sampling Time : 10.30 a.m.
Received Date : 30 April 2026
Analytical Date : 30 April - 08 May 2026
Report Date : 11 May 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673239 E 151930 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-4
Sample Type : Swimming pool Water
Sampling Date : 29 April 2026
Sampling Time : 10.31 a.m.
Received Date : 30 April 2026
Analytical Date : 30 April - 08 May 2026
Report Date : 11 May 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673244 E 1519616 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3
Sample Type : Swimming pool Water
Sampling Date : 06 May 2026
Sampling Time : 10.30 a.m.
Received Date : 07 May 2026
Analytical Date : 07 - 13 May 2026
Report Date : 14 May 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673235 E 1519626 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4
Sample Type : Swimming pool Water
Sampling Date : 06 May 2026
Sampling Time : 10.31 a.m.
Received Date : 07 May 2026
Analytical Date : 07 - 13 May 2026
Report Date : 14 May 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th *Edition, 2023, Part 9213 B*	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name	:	โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project	:	เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนตื้น
GPS. Coordinate	:	47 P 673249 E 1519611 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Customer Code	:	W69098
Sample No	:	W69098/3-1
Sample Type	:	Swimming pool Water
Sampling Date	:	14 May 2026
Sampling Time	:	01.30 p.m.
Received Date	:	15 May 2026
Analytical Date	:	15 - 25 May 2026
Report Date	:	26 May 2026

Parameter	Unit	Analytical Method [1/]	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th *Edition, 2023, Part 9213 B*	Not Detected	Not Detected
Pseudomonas aeruginosa *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark [1/] Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

[2/] Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name	:	โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project	:	เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนลึก
GPS. Coordinate	:	47 P 673237 E 1519620 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Customer Code	:	W69098
Sample No	:	W69098/4-1
Sample Type	:	Swimming pool Water
Sampling Date	:	14 May 2026
Sampling Time	:	01.30 p.m.
Received Date	:	15 May 2026
Analytical Date	:	15 - 25 May 2026
Report Date	:	26 May 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th *Edition, 2023, Part 9213 B*	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name	:	โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project	:	เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนตื้น
GPS. Coordinate	:	47 P 673242 E 1519611 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Customer Code	:	W69098
Sample No	:	W69098/3-2
Sample Type	:	Swimming pool Water
Sampling Date	:	20 May 2026
Sampling Time	:	10.30 a.m.
Received Date	:	21 May 2026
Analytical Date	:	21 - 27 May 2026
Report Date	:	28 May 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name	:	โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project	:	เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนลึก
GPS. Coordinate	:	47 P 673238 E 1519620 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Customer Code	:	W69098
Sample No	:	W69098/4-2
Sample Type	:	Swimming pool Water
Sampling Date	:	20 May 2026
Sampling Time	:	10.31 a.m.
Received Date	:	21 May 2026
Analytical Date	:	21 - 27 May 2026
Report Date	:	28 May 2026

Parameter	Unit	Analytical Method [1/]	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, [2/]	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark
[1/] Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
[2/] Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name	:	นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name	:	โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project	:	เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point	:	สระว่ายน้ำส่วนตื้น
GPS. Coordinate	:	47 P 673246 E 1519619 N
Sampling By	:	TNP ENVIRONMENT CO., LTD.
Sampling Method	:	Grab Sampling

Data Provided by Laboratory

Customer Code	:	W69098
Sample No	:	W69098/3-3
Sample Type	:	Swimming pool Water
Sampling Date	:	27 May 2026
Sampling Time	:	10.30 a.m.
Received Date	:	28 May 2026
Analytical Date	:	28 May - 04 June 2026
Report Date	:	05 June 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673231 E 1519623 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-3
Sample Type : Swimming pool Water
Sampling Date : 27 May 2026
Sampling Time : 10.31 a.m.
Received Date : 28 May 2026
Analytical Date : 28 May - 04 June 2026
Report Date : 05 June 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673240 E 1519633 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3
Sample Type : Swimming pool Water
Sampling Date : 04 June 2026
Sampling Time : 01.30 p.m.
Received Date : 05 June 2026
Analytical Date : 05 - 11 June 2026
Report Date : 12 June 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673236 E 1519622 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4
Sample Type : Swimming pool Water
Sampling Date : 04 June 2026
Sampling Time : 01.30 p.m.
Received Date : 05 June 2026
Analytical Date : 05 - 11 June 2026
Report Date : 12 June 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673239 E 1519631 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3-1
Sample Type : Swimming pool Water
Sampling Date : 10 June 2026
Sampling Time : 02.04 p.m.
Received Date : 11 June 2026
Analytical Date : 11 - 17 June 2026
Report Date : 18 June 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673235 E 1519627 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-1
Sample Type : Swimming pool Water
Sampling Date : 10 June 2026
Sampling Time : 02.04 p.m.
Received Date : 11 June 2026
Analytical Date : 11 - 17 June 2026
Report Date : 18 June 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark
1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673247 E 1519635 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3-2
Sample Type : Swimming pool Water
Sampling Date : 17 June 2026
Sampling Time : 10.17 a.m.
Received Date : 18 June 2026
Analytical Date : 18 - 30 June 2026
Report Date : 01 July 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673234 E 1519621 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-2
Sample Type : Swimming pool Water
Sampling Date : 17 June 2026
Sampling Time : 10.17 a.m.
Received Date : 18 June 2026
Analytical Date : 18 - 30 June 2026
Report Date : 01 July 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนตื้น
GPS. Coordinate : 47 P 673248 E 1519635 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/3-3
Sample Type : Swimming pool Water
Sampling Date : 25 June 2026
Sampling Time : 01.03 p.m.
Received Date : 26 June 2026
Analytical Date : 26 June - 01 July 2026
Report Date : 02 July 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY

TNP ENVIRONMENT CO.,LTD.
เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273
E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่

NSC-TISI-TIS 17025
Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ทรี พัฒนาการ-เอกมัย
Project Name : โครงการ เดอะ ทรี พัฒนาการ-เอกมัย
Address Project : เลขที่ 89 ถนนพัฒนาการ (ตรงข้ามซอยพัฒนาการ 4) แขวงสวนหลวง เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47 P 673239 E 1519624 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69098
Sample No : W69098/4-3
Sample Type : Swimming pool Water
Sampling Date : 25 June 2026
Sampling Time : 01.03 p.m.
Received Date : 26 June 2026
Analytical Date : 26 June - 01 July 2026
Report Date : 02 July 2026

Parameter	Unit	Analytical Method 1/	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Escherichia coli *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Staphylococcus aureus *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 B	Not Detected	Not Detected
Pseudomonas aeruginosa *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.
Remark 1/ Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.
2/ Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.
* This item is out the scope ISO/IEC 17025:2017 Accreditation.

[redacted]

DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL
REPORTED RESULTS REFERS TO SUBMITTED SAMPLE(S) ONLY