

LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date: 31/01/2015

Month: 2/2026

Year 2026

BUILDING : Windshell Naradhiwas

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
8	Morning 06:00	1.5	7.2	10			
	Afternoon 14:00	1.4	7.0	10			
9	Morning 10:00	1.5	7.2	10			
	Afternoon 14:00	1.7	7.1	11			
10	Morning 14:00	1.3	7.2	10			
	Afternoon 14:00	1.3	7.2	10			
11	Morning 14:00	1.3	7.2	10			
	Afternoon 14:00	1.3	7.2	10			
12	Morning 14:00	1.3	7.2	10			
	Afternoon 14:00	1.3	7.2	10			
13	Morning 14:00	1.3	7.2	10			
	Afternoon 14:00	1.3	7.2	10			
14	Morning 14:00	1.3	7.2	10			
	Afternoon 14:00	1.3	7.2	10			

Comment: _____

BSE:

LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date: 31/01/2015

Month: 2/2026

Year 2026

BUILDING : Windshell Naradhiwas

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
22	Morning 06:00	1.3	7.5	16			
	Afternoon 14:00	1.2	7.5	10			
23	Morning 06:00	1.4	7.2	10			
	Afternoon 14:00	1.3	7.2	10			
24	Morning 06:00	1.3	7.2	10			
	Afternoon 14:00	1.3	7.2	10			
25	Morning 06:00	1.3	7.2	10			
	Afternoon 14:00	1.3	7.2	10			
26	Morning 06:00	1.3	7.2	10			
	Afternoon 14:00	1.3	7.2	10			
27	Morning 06:00	1.3	7.2	10			
	Afternoon 14:00	1.3	7.2	10			
28	Morning 06:00	1.3	7.2	10			
	Afternoon 14:00	1.3	7.2	10			

Comment: _____

BSE:

Note: pH: normal range 7.2 - 7.8

LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date: 31/01/2015

Month: 2/2026

Year 2026

BUILDING : Windshell Naradhiwas

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
1	Morning 06:00	4.5	7.4	10			
	Afternoon 14:00	4.5	7.4	10			
2	Morning 06:00	1.5	7.4	10			
	Afternoon 14:00	1.5	7.4	10			
3	Morning 06:00	1.5	7.4	10			
	Afternoon 14:00	1.5	7.4	10			
4	Morning 06:00	1.5	7.4	10			
	Afternoon 14:00	1.5	7.4	10			
5	Morning 06:00	1.5	7.4	10			
	Afternoon 14:00	1.5	7.4	10			
6	Morning 06:00	1.5	7.4	10			
	Afternoon 14:00	1.5	7.4	10			
7	Morning 06:00	1.5	7.4	10			
	Afternoon 14:00	1.5	7.4	10			

Comment: _____

BSE:

LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date: 31/01/2015

Month: 2/2026

Year 2026

BUILDING : Windshell Naradhiwas

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
15	Morning 06:00	1.5	7.4	10			
	Afternoon 14:00	1.5	7.4	10			
16	Morning 06:00	1.5	7.4	10			
	Afternoon 14:00	1.5	7.4	10			
17	Morning 06:00	1.5	7.4	10			
	Afternoon 14:00	1.5	7.4	10			
18	Morning 06:00	1.5	7.4	10			
	Afternoon 14:00	1.5	7.4	10			
19	Morning 06:00	1.5	7.4	10			
	Afternoon 14:00	1.5	7.4	10			
20	Morning 06:00	1.5	7.4	10			
	Afternoon 14:00	1.5	7.4	10			
21	Morning 06:00	1.5	7.4	10			
	Afternoon 14:00	1.5	7.4	10			

Comment: _____

BSE:

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLL-OP-SN-004/01
BUILDING : Windshell Nardhiwas						Rev. Date : 3/10/2015	Year 2026
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
29	Morning	1.00	7.2	19	[Redacted Signature]		
	Afternoon	1.44	7.2				
30	Morning	1.9	7.4	12			
	Afternoon	1.90	7.2	10			
31	Morning	1.5	7.2	10			
	Afternoon	1.91	7.4	11			
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						

Comment : _____

BSE : _____

[Redacted Signature]

Note: pH: normal range 7.2 - 7.8

LOG SHEET OF SWIMMING POOL / POND							Ref. No: JLL-OP-SW-00401
BUILDING : Windshell Naradhiwas							Rev. Date : 31/01/2015
Month : 15 / 1 / 19							Year : 2026
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (S. Technician)	Remark
		Chlorine (ppm)	pH				
15	Morning	1.0	7.4	12	[Redacted]		
	Afternoon	1.5	7.4	12			
16	Morning	1.5	7.4	12			
	Afternoon	1.5	7.4	12			
17	Morning	1.5	7.4	12			
	Afternoon	1.5	7.4	12			
18	Morning	1.5	7.4	12			
	Afternoon	1.5	7.4	12			
19	Morning	1.5	7.4	12			
	Afternoon	1.5	7.4	12			
20	Morning	1.5	7.4	12			
	Afternoon	1.5	7.4	12			
21	Morning	1.5	7.4	12			
	Afternoon	1.5	7.4	12			

Comment : _____
 BSE : _____

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLL-OP-SN-004101
BUILDING : Windshell Naradhiwas							Rev. Date : 31/01/2015
		Month : 4/1/19		Year 2026			
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
7	Morning	1.2	9.1	10	[Redacted]		
	Afternoon	1.2	9.2	10			
9	Morning	1.2	9.2	10			
	Afternoon	1.2	9.2	10			
10	Morning	1.2	9.1	10			
	Afternoon	1.2	9.1	10			
11	Morning	1.2	9.1	10			
	Afternoon	1.2	9.1	10			
12	Morning	1.2	9.1	10			
	Afternoon	1.2	9.1	10			
13	Morning	1.2	9.1	10			
	Afternoon	1.2	9.1	10			
14	Morning	1.2	9.1	10			
	Afternoon	1.2	9.1	10			

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm

BSE : [Redacted]



Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLT-OP-SN-004/01
BUILDING : Windshell Naradhivas							Rev. Date : 31/01/2015
							Month : Nov Year 2026
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
1	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
2	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
3	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
4	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
5	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
6	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
7	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
8	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
9	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLT-OP-SN-004/01
BUILDING : Windshell Naradhivas							Rev. Date : 31/01/2015
							Month : Nov Year 2026
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
12	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
13	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
14	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
15	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
16	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
17	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
18	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
19	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
20	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLT-OP-SN-004/01
BUILDING : Windshell Naradhivas							Rev. Date : 31/01/2015
							Month : Nov Year 2026
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
1	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
2	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
3	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
4	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
5	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
6	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
7	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
8	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
9	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLT-OP-SN-004/01
BUILDING : Windshell Naradhivas							Rev. Date : 31/01/2015
							Month : Nov Year 2026
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
10	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
11	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
12	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
13	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			
14	Morning	8.00	7.50	16			
	Afternoon	8.00	7.50	16			

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND

Ref No: JLT-OP-SN-004/01
Rev. Date: 31/01/2015
Month: March Year 2026

BUILDING : Windshell Naradhiwas

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
29	Morning	1.5	7.2	10	[Redacted]		
	Afternoon	1.5	7.2	10			
30	Morning	1.3	7.2	10			
	Afternoon	1.3	7.2	10			
31	Morning	1.5	7.2	10			
	Afternoon	1.5	7.2	10			
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						

Comment :
BSE : [Redacted]

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm

JLT

LOG SHEET OF SWIMMING POOL / POND

Ref No: JLT-OP-SN-004/01
Rev. Date: 31/01/2015
Month: March Year 2026

BUILDING : Windshell Naradhiwas

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
29	Morning	1.5	7.2	10	[Redacted]		
	Afternoon	1.5	7.2	10			
30	Morning	1.5	7.2	10			
	Afternoon	1.5	7.2	10			
31	Morning	1.5	7.2	10			
	Afternoon	1.5	7.2	10			
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						
	Morning						
	Afternoon						

Comment :
BSE : [Redacted]

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm

JLT

LOG SHEET OF SWIMMING POOL / POND

Ref No: JLT-OP-SN-004/01
Rev. Date: 31/01/2015
Month: March Year 2026

BUILDING : Windshell Naradhiwas

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
9	Morning	1.5	7.4	10	[Redacted]		
	Afternoon	1.5	7.2	10			
10	Morning	1.5	7.9	10			
	Afternoon	1.5	7.9	10			
11	Morning	1.5	7.2	10			
	Afternoon	1.5	7.2	10			
12	Morning	1.3	7.1	10			
	Afternoon	1.3	7.7	10			
13	Morning	1.5	7.2	10			
	Afternoon	1.5	7.2	10			

Comment :
BSE : [Redacted]

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm

JLT

LOG SHEET OF SWIMMING POOL / POND

Ref No: JLT-OP-SN-004/01
Rev. Date: 31/01/2015
Month: March Year 2026

BUILDING : Windshell Naradhiwas

Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
1	Morning	1.5	7.2	10	[Redacted]		
	Afternoon	1.5	7.2	10			
2	Morning	1.5	7.4	10			
	Afternoon	1.5	7.3	10			
3	Morning	1.5	7.3	10			
	Afternoon	1.5	7.2	10			
4	Morning	1.5	7.4	10			
	Afternoon	1.5	7.3	10			
5	Morning	1.5	7.3	10			
	Afternoon	1.5	7.3	10			
6	Morning	1.3	7.1	10			
	Afternoon	1.3	7.7	10			
7	Morning	1.5	7.2	10			
	Afternoon	1.5	7.2	10			

Comment :
BSE : [Redacted]

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm

JLT

LOG SHEET OF SWIMMING POOL / POND

Rev. Date : 31/01/2015

Month : March Year 2026

LOG SHEET OF SWIMMING POOL / POND

Ref No: JLL-OP-SN-004/01

Rev. Date : 31/01/2015

Year 2026

BUILDING : Windshell Naradhiwas		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
Date	Shift / Time	Chlorine (ppm)	pH				
23	Morning	1.0	7.2	10	[REDACTED]		
	Afternoon	1.5	7.7	10			
24	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
25	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
26	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
27	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
28	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



BUILDING : Windshell Naradhiwas		Ref No: JLL-OP-SN-004/01
		Rev. Date : 31/01/2015
		Month : March Year 2026

BUILDING : Windshell Naradhiwas		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
Date	Shift / Time	Chlorine (ppm)	pH				
29	Morning	1.0	7.2	10	[REDACTED]		
	Afternoon	1.5	7.7	10			
30	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
31	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
32	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
33	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
34	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



BUILDING : Windshell Naradhiwas		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
Date	Shift / Time	Chlorine (ppm)	pH				
35	Morning	1.0	7.2	10	[REDACTED]		
	Afternoon	1.5	7.7	10			
36	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
37	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
38	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
39	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
40	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



BUILDING : Windshell Naradhiwas		Ref No: JLL-OP-SN-004/01
		Rev. Date : 31/01/2015
		Month : March Year 2026

BUILDING : Windshell Naradhiwas		Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
Date	Shift / Time	Chlorine (ppm)	pH				
41	Morning	1.0	7.2	10	[REDACTED]		
	Afternoon	1.5	7.7	10			
42	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
43	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
44	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
45	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			
46	Morning	1.0	7.7	10			
	Afternoon	1.5	7.9	10			

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8

Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLL-OP-SN-004/01
BUILDING : Windshell Naradhiwas							Rev. Date : 31/01/2015
Month : May							Year 2026
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
15	Morning	16.00	7.5	25	[Redacted]		
	Afternoon	16.00	7.4	6			
16	Morning	17.00	7.5	10			
	Afternoon	17.00	7.6	10			
17	Morning	18.00	7.5	10			
	Afternoon	18.00	7.8	10			
18	Morning	19.00	7.5	10			
	Afternoon	19.00	7.4	16			
19	Morning	20.00	7.5	10			
	Afternoon	20.00	7.7	10			
20	Morning	21.00	7.5	10			
	Afternoon	21.00	7.5	10			
21	Morning	22.00	7.5	10			
	Afternoon	22.00	7.5	10			

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLL-OP-SN-004/01
BUILDING : Windshell Naradhiwas							Rev. Date : 31/01/2015
Month : May							Year 2026
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
1	Morning	1.00	7.5	10	[Redacted]		
	Afternoon	1.00	7.5	10			
2	Morning	2.00	7.4	10			
	Afternoon	2.00	7.4	10			
3	Morning	3.00	7.5	10			
	Afternoon	3.00	7.5	10			
4	Morning	4.00	7.5	10			
	Afternoon	4.00	7.5	10			
5	Morning	5.00	7.5	10			
	Afternoon	5.00	7.5	10			
6	Morning	6.00	7.5	10			
	Afternoon	6.00	7.5	10			
7	Morning	7.00	7.5	10			
	Afternoon	7.00	7.5	10			
8	Morning	8.00	7.5	10			
	Afternoon	8.00	7.5	10			
9	Morning	9.00	7.5	10			
	Afternoon	9.00	7.5	10			
10	Morning	10.00	7.5	10			
	Afternoon	10.00	7.5	10			
11	Morning	11.00	7.5	10			
	Afternoon	11.00	7.5	10			
12	Morning	12.00	7.5	10			
	Afternoon	12.00	7.5	10			
13	Morning	13.00	7.5	10			
	Afternoon	13.00	7.5	10			
14	Morning	14.00	7.5	10			
	Afternoon	14.00	7.5	10			

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLL-OP-SN-004/01
BUILDING : Windshell Naradhiwas							Rev. Date : 31/01/2015
Month : May							Year 2026
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
29	Morning	22:00	7.6	10	[Redacted]		
	Afternoon	22:00	7.6	10			
30	Morning	23:00	7.6	10			
	Afternoon	23:00	7.6	10			
31	Morning	00:00	7.6	10			
	Afternoon	00:00	7.6	10			
	Morning	01:00	7.6	10			
	Afternoon	01:00	7.6	10			
	Morning	02:00	7.6	10			
	Afternoon	02:00	7.6	10			
	Morning	03:00	7.6	10			
	Afternoon	03:00	7.6	10			

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLL-OP-SN-004/01
BUILDING : Windshell Naradhiwas							Rev. Date : 31/01/2015
Month : May							Year 2026
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
22	Morning	19:00	7.5	10	[Redacted]		
	Afternoon	19:00	7.5	10			
23	Morning	20:00	7.5	10			
	Afternoon	20:00	7.5	10			
24	Morning	21:00	7.5	10			
	Afternoon	21:00	7.5	10			
25	Morning	22:00	7.5	10			
	Afternoon	22:00	7.5	10			
26	Morning	23:00	7.5	10			
	Afternoon	23:00	7.5	10			
27	Morning	00:00	7.5	10			
	Afternoon	00:00	7.5	10			
28	Morning	01:00	7.5	10			
	Afternoon	01:00	7.5	10			

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLL-OP-SN-004/01	Rev. Date: 31/07/2015	Year 2026
BUILDING : Windshell Naradhiwas							Month: May		
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
29	Morning	1.3	7.6	10					
	Afternoon	22:00							
30	Morning	1.0	7.8	10					
	Afternoon	19:00	1.0	7.6	10				
31	Morning	1.0	7.6	10					
	Afternoon	19:00	1.0	7.6	10				
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
	Morning								
	Afternoon								
Comment :							BSE :		

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLL-OP-SN-004/01	Rev. Date: 31/07/2015	Year 2026
BUILDING : Windshell Naradhiwas							Month: May		
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
30	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
31	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
1	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
2	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
3	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
4	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
5	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
6	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
7	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
8	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
9	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
10	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
11	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
12	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
13	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
14	Morning	1.3	7.6	10					
	Afternoon	19:00	1.3	7.6	10				
Comment :							BSE :		

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLL-OP-SN-004/01	Rev. Date: 31/07/2015	Year 2026
BUILDING : Windshell Naradhiwas							Month: May		
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
8	Morning	1.5	7.6	8					
	Afternoon	17:00	1.5	7.6	8				
9	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
10	Morning	1.4	7.6	9					
	Afternoon	17:00	1.4	7.6	9				
11	Morning	1.3	7.6	10					
	Afternoon	17:00	1.3	7.6	10				
12	Morning	1.3	7.6	10					
	Afternoon	17:00	1.3	7.6	10				
13	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
14	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
Comment :							BSE :		

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLL-OP-SN-004/01	Rev. Date: 31/07/2015	Year 2026
BUILDING : Windshell Naradhiwas							Month: May		
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark		
		Chlorine (ppm)	pH						
1	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
2	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
3	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
4	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
5	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
6	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
7	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
8	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
9	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
10	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
11	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
12	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
13	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
14	Morning	1.5	7.6	10					
	Afternoon	17:00	1.5	7.6	10				
Comment :							BSE :		

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLL-OP-SN-004/01
BUILDING : Windshell Naradhiwas							Rev. Date : 31/01/2015
Month : <u>April</u> Year 2026							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
10-01	Morning	1.7	7.4	12			
	Afternoon	1.4	7.4	12			
10-02	Morning	1.3	7.4	10			
	Afternoon	1.4	7.4	10			
10-03	Morning	1.5	7.2	10			
	Afternoon	1.4	7.2	14			
10-04	Morning	1.5	7.2	8			
	Afternoon	1.4	7.2	8			
10-05	Morning	1.5	7.2	8			
	Afternoon	1.4	7.2	10			
10-06	Morning	1.3	7.4	10			
	Afternoon	1.3	7.4	10			
10-07	Morning						
	Afternoon						

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm



LOG SHEET OF SWIMMING POOL / POND							Ref No: JLL-OP-SN-004/01
BUILDING : Windshell Naradhiwas							Rev. Date : 31/01/2015
Month : <u>April</u> Year 2026							
Date	Shift / Time	Water Quality		Filter Pressure (psi)	Recorded By (Technician)	Verified By (Sr. Technician)	Remark
		Chlorine (ppm)	pH				
10-01	Morning	1.3	7.4	9			
	Afternoon	1.3	7.4	9			
10-02	Morning	1.5	7.4	10			
	Afternoon	1.3	7.4	10			
10-03	Morning	1.3	7.4	10			
	Afternoon	1.3	7.4	10			
10-04	Morning	1.3	7.4	10			
	Afternoon	1.3	7.4	10			
10-05	Morning	1.3	7.4	10			
	Afternoon	1.3	7.4	10			
10-06	Morning	1.3	7.4	10			
	Afternoon	1.3	7.4	10			
10-07	Morning	1.3	7.4	10			
	Afternoon	1.3	7.4	10			

Comment : _____

BSE : _____

Note: pH: normal range 7.2 - 7.8
Chlorine: normal range 1.0 - 3.0 ppm

