

ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : JANUARY 23, 2026
SAMPLING TIME : 14:20 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY :
ANALYZED BY :
RECEIVED DATE : JANUARY 23, 2026
ANALYTICAL DATE : JANUARY 23-30, 2026
ISSUE DATE : FEBRUARY 2, 2026
REPORT NO. : 2026-U007835
WORK NO. : 2026-000378
ANALYSIS NO. : T26AB381-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ผลการตรวจคุณภาพน้ำ T26AB381-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	6.7 (30.5°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	6.1	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	10.1	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	389	≤ 1,300	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	< 5.0	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/TURBID			
SEDIMENT			BROWN			


^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JANUARY 23, 2026
SAMPLING TIME : 14:15 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : JANUARY 23, 2026
ANALYTICAL DATE : JANUARY 23-28, 2026
ISSUE DATE : FEBRUARY 2, 2026
REPORT NO. : 2026-U007836
WORK NO. : 2026-000378
ANALYSIS NO. : T26AB381-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T26AB381-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JANUARY 23, 2026
SAMPLING TIME : 14:10 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : [REDACTED]
ANALYZED BY : [REDACTED]


RECEIVED DATE : JANUARY 23, 2026
ANALYTICAL DATE : JANUARY 23-28, 2026
ISSUE DATE : FEBRUARY 2, 2026
REPORT NO. : 2026-U007837
WORK NO. : 2026-000378
ANALYSIS NO. : T26AB381-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T26AB381-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : FEBRUARY 18, 2026
SAMPLING TIME : 14:20 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : FEBRUARY 18, 2026
ANALYTICAL DATE : FEBRUARY 18-25, 2026
ISSUE DATE : FEBRUARY 26, 2026
REPORT NO. : 2026-U015153
WORK NO. : 2026-000378
ANALYSIS NO. : T26AD291-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ผลการตรวจคุณภาพน้ำ T26AD291-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	6.6 (33.8°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	21.1	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	26.8	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	438	≤ 1,300	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	7.6	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/TURBID			
SEDIMENT			BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : FEBRUARY 18, 2026
SAMPLING TIME : 14:15 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : [REDACTED]
ANALYZED BY : [REDACTED]


RECEIVED DATE : FEBRUARY 18, 2026
ANALYTICAL DATE : FEBRUARY 18-21, 2026
ISSUE DATE : FEBRUARY 27, 2026
REPORT NO. : 2026-U015154
WORK NO. : 2026-000378
ANALYSIS NO. : T26AD291-0002

ANALYZED BY : _____				
PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T26AD291-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID			COLOURLESS/CLEAR	
SEDIMENT			-	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : FEBRUARY 18, 2026
SAMPLING TIME : 14:10 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : FEBRUARY 18, 2026
ANALYTICAL DATE : FEBRUARY 18-21, 2026
ISSUE DATE : FEBRUARY 27, 2026
REPORT NO. : 2026-U015155
WORK NO. : 2026-000378
ANALYSIS NO. : T26AD291-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T26AD291-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : MARCH 20, 2026
SAMPLING TIME : 12:30 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : MARCH 20, 2026
ANALYTICAL DATE : MARCH 20-30, 2026
ISSUE DATE : MARCH 30, 2026
REPORT NO. : 2026-U024721
WORK NO. : 2026-000378
ANALYSIS NO. : T26AF964-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			มาตรฐานคุณภาพน้ำ T26AF964-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	6.4 (32.1°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	8.6	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	11.9	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	415	≤ 1,300	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	< 5.0	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/TURBID BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MARCH 20, 2026
SAMPLING TIME : 12:20 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° :
ANALYZED BY :
RECEIVED DATE : MARCH 20, 2026
ANALYTICAL DATE : MARCH 20-25, 2026
ISSUE DATE : MARCH 31, 2026
REPORT NO. : 2026-U024724
WORK NO. : 2026-000378
ANALYSIS NO. : T26AF964-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T26AF964-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT


CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MARCH 20, 2026
SAMPLING TIME : 12:15 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° :
ANALYZED BY :
RECEIVED DATE : MARCH 20, 2026
ANALYTICAL DATE : MARCH 20-25, 2026
ISSUE DATE : MARCH 31, 2026
REPORT NO. : 2026-U024725
WORK NO. : 2026-000378
ANALYSIS NO. : T26AF964-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T26AF964-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : APRIL 24, 2026
SAMPLING TIME : 11:55 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : APRIL 24, 2026
ANALYTICAL DATE : APRIL 24-MAY 6, 2026
ISSUE DATE : MAY 6, 2026
REPORT NO. : 2026-U036113
WORK NO. : 2026-000378
ANALYSIS NO. : T26AI681-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			ผลการตรวจคุณภาพน้ำ T26AI681-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	7.8 (31.2°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	2.6	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	13.5	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	362	≤ 1,300	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	< 5.0	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION WATER'S COLOUR/TURBID SEDIMENT			YELLOW/CLEAR BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : APRIL 24, 2026
SAMPLING TIME : 11:50 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° :
ANALYZED BY :
RECEIVED DATE : APRIL 24, 2026
ANALYTICAL DATE : APRIL 24-29, 2026
ISSUE DATE : MAY 7, 2026
REPORT NO. : 2026-U036114
WORK NO. : 2026-000378
ANALYSIS NO. : T26AI681-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T26AI681-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : APRIL 24, 2026
SAMPLING TIME : 11:45 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° :
ANALYZED BY :
RECEIVED DATE : APRIL 24, 2026
ANALYTICAL DATE : APRIL 24-29, 2026
ISSUE DATE : MAY 7, 2026
REPORT NO. : 2026-U036115
WORK NO. : 2026-000378
ANALYSIS NO. : T26AI681-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T26AI681-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : MAY 22, 2026
SAMPLING TIME : 11:10 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : MAY 22, 2026
ANALYTICAL DATE : MAY 22-29, 2026
ISSUE DATE : JUNE 2, 2026
REPORT NO. : 2026-U046149
WORK NO. : 2026-000378
ANALYSIS NO. : T26AL196-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			มอดตรวจคุณภาพน้ำ T26AL196-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H ⁺ B AND 1060 B	6.7 (32.2°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	6.9	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	8.5	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	337	≤ 1,300	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ²⁻ F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^c	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	ND	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/CLEAR			
SEDIMENT			BROWN			

^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.

ND : NOT DETECTED.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 22, 2026
SAMPLING TIME : 11:05 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c :
ANALYZED BY :
RECEIVED DATE : MAY 22, 2026
ANALYTICAL DATE : MAY 22-26, 2026
ISSUE DATE : JUNE 2, 2026
REPORT NO. : 2026-U046150
WORK NO. : 2026-000378
ANALYSIS NO. : T26AL196-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T26AL196-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT


CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION :
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : MAY 22, 2026
SAMPLING TIME : 11:00 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° :
ANALYZED BY :
RECEIVED DATE : MAY 22, 2026
ANALYTICAL DATE : MAY 22-26, 2026
ISSUE DATE : JUNE 2, 2026
REPORT NO. : 2026-U046151
WORK NO. : 2026-000378
ANALYSIS NO. : T26AL196-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T26AL196-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION			COLOURLESS/CLEAR	
WATER'S COLOUR/TURBID SEDIMENT				

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : EFFLUENT
SAMPLING DATE : JUNE 19, 2026
SAMPLING TIME : 13:35 HOUR
SAMPLING METHOD : GRAB
SAMPLING BY : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : JUNE 19, 2026
ANALYTICAL DATE : JUNE 19-28, 2026
ISSUE DATE : JUNE 29, 2026
REPORT NO. : 2026-U056876
WORK NO. : 2026-000378
ANALYSIS NO. : T26AN978-0001

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	REGULATORY STANDARD	DETECTION LIMIT	LIMIT OF QUANTITATION (LOQ)
			בודตรวจคุณภาพน้ำ T26AN978-0001			
pH ^a	-	ELECTROMETRIC METHOD (AT SITE) SM: PART 4500-H* B AND 1060 B	6.4 (34.7°C)	5.5-9.0	-	-
BIOCHEMICAL OXYGEN DEMAND ^a	mg/L	MEMBRANE ELECTRODE METHOD (SM: PART 5210 B AND PART 4500-O G)	5.0	≤ 40	-	2.0
TOTAL SUSPENDED SOLIDS ^a	mg/L	TOTAL SUSPENDED SOLIDS DRIED FROM 103 TO 105 °C (SM: PART 2540 D)	11.7	≤ 50	-	5.0
TOTAL DISSOLVED SOLIDS ^b	mg/L	TOTAL DISSOLVED SOLIDS DRIED AT 180 °C (SM: PART 2540 C)	386	≤ 1,300	-	25
SETTLABLE SOLIDS ^c	mL/L	IMHOFF CONE (SM: PART 2540 F)	< 0.1	-	0.1	-
SULPHIDE ^b	mg/L	IODOMETRIC METHOD (SM: PART 4500-S ² -F)	< 0.50	≤ 1.0	-	0.50
TOTAL KJELDAHL NITROGEN ^b	mg/L	IN-HOUSE METHOD: UAE.TP.WAS.001 (KJELDAHL METHOD); SM: PART 4500-Norg C	< 5.0	≤ 40	1.5	5.0
OIL AND GREASE ^a	mg/L	LIQUID-LIQUID, PARTITION-GRAVIMETRIC METHOD (SM: PART 5520 B)	< 3	≤ 20	-	3
SAMPLE CONDITION						
WATER'S COLOUR/TURBID			YELLOW/TURBID			
SEDIMENT			BROWN			


^a : ISO/IEC 17025 ACCREDITED BY THAI INDUSTRIAL STANDARDS INSTITUTE (TISI)

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

REGULATORY STANDARD : RANGE OR MAXIMUM PERMITTED VALUE FOR BUILDING EFFLUENT STANDARDS CLASS C, NOTIFICATION OF THE MINISTRY OF RESOURCES AND ENVIRONMENT, PUBLISHED IN THE ROYAL GOVERNMENT GAZETTE, VOL 141, PART 233 D, DATED AUGUST 27, 2024.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JUNE 19, 2026
SAMPLING TIME : 13:30 HOUR
SAMPLING METHOD ° : GRAB AND STERILE TECHNIQUE
SAMPLING BY ° : [REDACTED]
ANALYZED BY : [REDACTED]


RECEIVED DATE : JUNE 19, 2026
ANALYTICAL DATE : JUNE 19-25, 2026
ISSUE DATE : JULY 1, 2026
REPORT NO. : 2026-U056877
WORK NO. : 2026-000378
ANALYSIS NO. : T26AN978-0002

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (SHALLOW ZONE) T26AN978-0002	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR -	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.



ANALYSIS REPORT

CUSTOMER NAME : WINDSHELL NARADHIWAS CONDOMINIUM JURISTIC PERSON
ADDRESS : 53 NARADHIWAS RAJANAGARINDRA ROAD THUNG MAHA MEK SATHON BANGKOK 10120
CONTACT INFORMATION : [REDACTED]
SAMPLING SOURCE : -
SAMPLE TYPE : WATER SAMPLE FROM SWIMMING POOL
SAMPLING DATE : JUNE 19, 2026
SAMPLING TIME : 13:25 HOUR
SAMPLING METHOD ^c : GRAB AND STERILE TECHNIQUE
SAMPLING BY ^c : [REDACTED]
ANALYZED BY : [REDACTED]

RECEIVED DATE : JUNE 19, 2026
ANALYTICAL DATE : JUNE 19-25, 2026
ISSUE DATE : JULY 1, 2026
REPORT NO. : 2026-U056879
WORK NO. : 2026-000378
ANALYSIS NO. : T26AN978-0003

PARAMETER	UNIT	METHOD OF ANALYSIS	RESULT	DETECTION LIMIT
			SWIMMING POOL (DEEP ZONE) T26AN978-0003	
MICROBIOLOGY				
TOTAL COLIFORMS ^b	MPN/100 mL	MULTIPLE-TUBE FERMENTATION TECHNIQUE (SM: PART 9221 B AND C)	< 1.1	1.1
<i>E. coli</i> ^b	/100 mL	FLUOROGENIC SUBSTRATE TEST (SM: PART 9221 D AND F)	NOT DETECTED	-
SAMPLE CONDITION				
WATER'S COLOUR/TURBID SEDIMENT			COLOURLESS/CLEAR	
			-	

^b : ISO/IEC 17025 ACCREDITED BY DEPARTMENT OF SCIENCE SERVICE (DSS)

^c : VERIFIED BY OWN LABORATORY QUALITY SYSTEM, BUT NOT IN SCOPE OF ACCREDITATION

SM : STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER, APHA, AWWA, WEF, 24th EDITION, 2023.

