

ภาคผนวก ง

ผลการติดตามตรวจสอบคุณภาพสิ่งแวดล้อม



คุณภาพน้ำทิ้ง



ANALYSIS REPORT

Data Provided by Customer

Customer Name : บริษัท เทอร์ติโน สวิส จำกัด
Project Name : โครงการ 39 Luxury Suites
Address Project : ซอยสุขุมวิท 39 (ซอยพร้อมจิตร์) ถนนสุขุมวิท
แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บริเวณบ่อตรวจคุณภาพน้ำก่อนระบายลงสู่
ท่อระบายน้ำสาธารณะ
GPS. Coordinate : 47 P 669858 E 1519195 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69003
Sample No. : W69003/1
Sample Type : Wastewater
Sampling Date : 16 January 2026
Sampling Time : 01.38 p.m.
Received Date : 17 January 2026
Analytical Date : 17 January – 02 February 2026
Report Date : 03 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.8 °C	-	Electrometric Method (4500-H ⁺ B)	7.1	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	34.3	≤ 50
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	391	≤ 1,300
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	23.2	≤ 40
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	3.0	-
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	22,000	-
Total Kjeldahl Nitrogen *, ^{3/}	mg/L	APHA:4500-Norg (B) ^{2/}	11	≤ 40
Sample Appearance		Yellow/Turbid/Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type C.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : บ่อพักน้ำทิ้งสุดท้ายก่อนปล่อยออกนอกโครงการ
GPS. Coordinate : 47 P 704619 E 1424978 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69007
Sample No. : W69007/1
Sample Type : Wastewater
Sampling Date : 04 February 2026
Sampling Time : 02.18 p.m.
Received Date : 05 February 2026
Analytical Date : 05 – 24 February 2026
Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.1 °C	-	Electrometric Method (4500-H ⁺ B)	7.5	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	24.6	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	343	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	58.6	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.4	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	1.10	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{*, 3/}	mg/L	APHA:4500-Norg (B) ^{2/}	72	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Smelly		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{3/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : บ่อน้ำทิ้งสุดท้ายก่อนปล่อยออกนอกโครงการ
GPS. Coordinate : 47P 704627 E 1424960 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69007
Sample No. : W69007/1
Sample Type : Wastewater
Sampling Date : 10 March 2026
Sampling Time : 09.35 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.7 °C	-	Electrometric Method (4500-H ⁺ B)	7.5	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	24.1	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	372	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	65.6	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	1.81	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{*, 3/}	mg/L	APHA:4500-Norg (B) ^{2/}	61	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Smelly		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{3/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : บ่อน้ำทิ้งสุดท้ายก่อนปล่อยออกนอกโครงการ
GPS. Coordinate : 47P 704617 E 1424953 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69007
Sample No. : W69007/1
Sample Type : Wastewater
Sampling Date : 03 April 2026
Sampling Time : 01.54 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 24 April 2026
Report Date : 27 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.7 °C	-	Electrometric Method (4500-H ⁺ B)	7.6	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	31.8	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	489	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	78.8	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	1.61	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	0.2	-
Total Kjeldahl Nitrogen *, 2/	mg/L	APHA:4500-Norg (B) ^{3/}	54	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Smelly		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : บริษัท เทอร์ติโน สวิสท์ จำกัด
Project Name : โครงการ 39 Luxury Suites
Address Project : ซอยสุขุมวิท 39 (ซอยพร้อมจิตร์) ถนนสุขุมวิท
แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บริเวณบ่อตรวจคุณภาพน้ำก่อนระบายลงสู่
ท่อระบายน้ำสาธารณะ
GPS. Coordinate : 47P 669853 E 1519195 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69003
Sample No. : W69003/1
Sample Type : Wastewater
Sampling Date : 20 May 2026
Sampling Time : 01.53 p.m.
Received Date : 21 May 2026
Analytical Date : 21 May - 05 June 2026
Report Date : 08 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.7 °C	-	Electrometric Method (4500-H ⁺ B)	8.0	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	< 5.0	≤ 50
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	371	≤ 1,300
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	< 2.0	≤ 40
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	540	-
Total Kjeldahl Nitrogen ^{*, 3/}	mg/L	APHA:4500-Norg (B) ^{2/}	< 0.28	≤ 40
Sample Appearance		Yellow/Clear/Little Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type C.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : บริษัท เทอร์ติโน สวิส จำกัด
Project Name : โครงการ 39 Luxury Suites
Address Project : ซอยสุขุมวิท 39 (ซอยพร้อมจิตร์) ถนนสุขุมวิท
แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : บริเวณบ่อตรวจคุณภาพน้ำก่อนระบายลงสู่
ท่อระบายน้ำสาธารณะ
GPS. Coordinate : 47P 669851 E 1519203 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69003
Sample No. : W69003/1
Sample Type : Wastewater
Sampling Date : 18 June 2026
Sampling Time : 02.20 p.m.
Received Date : 19 June 2026
Analytical Date : 19 June - 01 July 2026
Report Date : 02 July 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.4 °C	-	Electrometric Method (4500-H ⁺ B)	6.9	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	31.9	≤ 50
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	377	≤ 1,300
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	38.3	≤ 40
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.1	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	< 0.60	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	920	-
Total Kjeldahl Nitrogen *, ^{3/}	mg/L	APHA:4500-Norg (B) ^{2/}	33	≤ 40
Sample Appearance		Yellow/Turbid/Sediment/Odorless		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type C.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



คุณภาพน้ำสะอาด



ANALYSIS REPORT

Data Provided by Customer

Customer Name : บริษัท เทอร์ติโนน์ สวิสท์ จำกัด
Project Name : โครงการ 39 Luxury Suites
Address Project : ซอยสุขุมวิท 39 (ซอยพร้อมจิตร์) ถนนสุขุมวิท
แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนเล็ก
GPS. Coordinate : 47 P 669853 E 1519160 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69003
Sample No : W69003/2
Sample Type : Swimming pool Water
Sampling Date : 16 January 2026
Sampling Time : 01.41 p.m.
Received Date : 17 January 2026
Analytical Date : 17 January – 02 February 2026
Report Date : 03 February 2026


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : บริษัท เทอร์ติโน สวิส จำกัด
Project Name : โครงการ 39 Luxury Suites
Address Project : ซอยสุขุมวิท 39 (ซอยพร้อมจิตร์) ถนนสุขุมวิท
แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนต้น
GPS. Coordinate : 47 P 669851 E 1519177 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69003
Sample No : W69003/3
Sample Type : Swimming pool Water
Sampling Date : 16 January 2026
Sampling Time : 01.42 p.m.
Received Date : 17 January 2026
Analytical Date : 17 January – 02 February 2026
Report Date : 03 February 2026


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
 Project Name : โครงการ The Riviera Jomtien
 Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
 Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 1
 GPS. Coordinate : 47 P 704634 E 1424943 N
 Sampling By : TNP ENVIRONMENT CO.,LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
 Sample No : W69007/2
 Sample Type : Swimming pool Water
 Sampling Date : 04 February 2026
 Sampling Time : 02.16 p.m.
 Received Date : 05 February 2026
 Analytical Date : 05 – 24 February 2026
 Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยร์ จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 1
GPS. Coordinate : 47 P 704624 E 1424933 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/3
Sample Type : Swimming pool Water
Sampling Date : 04 February 2026
Sampling Time : 02.15 p.m.
Received Date : 05 February 2026
Analytical Date : 05 – 24 February 2026
Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 4
GPS. Coordinate : 47 P 704596 E 1424997 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/4
Sample Type : Swimming pool Water
Sampling Date : 04 February 2026
Sampling Time : 02.14 p.m.
Received Date : 05 February 2026
Analytical Date : 05 – 24 February 2026
Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
 Project Name : โครงการ The Riviera Jomtien
 Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
 Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 4
 GPS. Coordinate : 47 P 704599 E 1424995 N
 Sampling By : TNP ENVIRONMENT CO.,LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
 Sample No : W69007/5
 Sample Type : Swimming pool Water
 Sampling Date : 04 February 2026
 Sampling Time : 02.13 p.m.
 Received Date : 05 February 2026
 Analytical Date : 05 – 24 February 2026
 Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 37
GPS. Coordinate : 47 P 704620 E 1424962 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/6
Sample Type : Swimming pool Water
Sampling Date : 04 February 2026
Sampling Time : 02.09 p.m.
Received Date : 05 February 2026
Analytical Date : 05 – 24 February 2026
Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำสวนต้น ชั้นที่ 37
GPS. Coordinate : 47 P 704638 E 1424952 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/7
Sample Type : Swimming pool Water
Sampling Date : 04 February 2026
Sampling Time : 02.09 p.m.
Received Date : 05 February 2026
Analytical Date : 05 – 24 February 2026
Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^u	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^u Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
 Project Name : โครงการ The Riviera Jomtien
 Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
 Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 42
 GPS. Coordinate : 47 P 704634 E 1424924 N
 Sampling By : TNP ENVIRONMENT CO.,LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
 Sample No : W69007/8
 Sample Type : Swimming pool Water
 Sampling Date : 04 February 2026
 Sampling Time : 02.05 p.m.
 Received Date : 05 February 2026
 Analytical Date : 05 – 24 February 2026
 Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 42
GPS. Coordinate : 47 P 704617 E 1424895 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/9
Sample Type : Swimming pool Water
Sampling Date : 04 February 2026
Sampling Time : 02.04 p.m.
Received Date : 05 February 2026
Analytical Date : 05 – 24 February 2026
Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 1
GPS. Coordinate : 47P 704628 E 1424942 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/2
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.32 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 1
GPS. Coordinate : 47P 704586 E 1424998 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/3
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.31 a.m.
Received Date : 11 March 2026
Analytical Date : 11 - 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 4
GPS. Coordinate : 47P 704583 E 1424998 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/4
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.28 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
 Project Name : โครงการ The Riviera Jomtien
 Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
 Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 4
 GPS. Coordinate : 47P 704585 E 1424998 N
 Sampling By : TNP ENVIRONMENT CO.,LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
 Sample No : W69007/5
 Sample Type : Swimming pool Water
 Sampling Date : 10 March 2026
 Sampling Time : 09.27 a.m.
 Received Date : 11 March 2026
 Analytical Date : 11 – 27 March 2026
 Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิตินุคคณาการชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 37
GPS. Coordinate : 47P 704587 E 1424970 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/6
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.24 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 37
GPS. Coordinate : 47P 704492 E 1424983 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/7
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.24 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 42
GPS. Coordinate : 47P 704621 E 1424931 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/8
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.20 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 42
GPS. Coordinate : 47P 704633 E 1424891 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/9
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.20 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 1
GPS. Coordinate : 47P 704627 E 1424953 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/2
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.51 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยร์ จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 1
GPS. Coordinate : 47P 704620 E 1424945 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/3
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.51 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 4
GPS. Coordinate : 47P 704570 E 1424987 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/4
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.47 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 4
GPS. Coordinate : 47P 704569 E 1424988 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/5
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.46 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีแยร์ จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 37
GPS. Coordinate : 47P 704590 E 1424961 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/6
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.42 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 37
GPS. Coordinate : 47P 704598 E 1424964 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/7
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.41 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 42
GPS. Coordinate : 47P 704621 E 1424927 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/8
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.36 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 42
GPS. Coordinate : 47P 704642 E 1424923 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/9
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.36 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : ถังน้ำใช้รดน้ำต้นไม้
GPS. Coordinate : 47P 704645 E 1424879 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/10
Sample Type : Water Supply
Sampling Date : 03 April 2026
Sampling Time : 01.32 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 24 April 2026
Report Date : 27 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Color *	Pt-Co	Spectrophotometric Method (2120 C)	< 5	≤ 15
Turbidity *, ^{3/}	NTU	APHA : 2130 B ^{2/}	0.28	≤ 5.0
Odour *	-	Observation Method	Not Objectionability	-
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		


Standard : The Department of Health, Criterias of Supplied Drinkable Water Quality, B.E. 2563.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : สถาบันเทคโนโลยี ไทย-ญี่ปุ่น
Project Name : โครงการ สถาบันเทคโนโลยี ไทย-ญี่ปุ่น
Address Project : เลขที่ 1771/1 ถนนพัฒนาการ แขวงสวนหลวง
เขตสวนหลวง กรุงเทพมหานคร 10250
Sampling Point : ภายในพื้นที่โครงการ
GPS. Coordinate : 47P 676108 E 1519363 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling


Data Provided by Laboratory

Report No. : W69009
Sample No. : W69009/16
Sample Type : Water Supply
Sampling Date : 28 January 2026
Sampling Time : 01.01 p.m.
Received Date : 29 January 2026
Analytical Date : 29 January – 19 February 2026
Report Date : 20 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	118	≤ 500
Sample Appearance		Clear/Odorless		

Standard : The Department of Health, Criterias of Supplied Drinkable Water Quality, B.E. 2563.

Remark ^{1/} : Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : บริษัท เทอร์ดีเอ็นน์ สวีตส์ จำกัด
Project Name : โครงการ 39 Luxury Suites
Address Project : ซอยสุขุมวิท 39 (ซอยพร้อมจิตร์) ถนนสุขุมวิท
แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47P 669851 E 1519163 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69003
Sample No : W69003/2
Sample Type : Swimming pool Water
Sampling Date : 20 May 2026
Sampling Time : 01.49 p.m.
Received Date : 21 May 2026
Analytical Date : 21 May - 01 June 2026
Report Date : 02 June 2026


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : บริษัท เทอร์ดีเนน สวิส จำกัด
Project Name : โครงการ 39 Luxury Suites
Address Project : ซอยสุขุมวิท 39 (ซอยพร้อมจิตร์) ถนนสุขุมวิท
แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนต้น
GPS. Coordinate : 47P 669851 E 1519175 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69003
Sample No : W69003/3
Sample Type : Swimming pool Water
Sampling Date : 20 May 2026
Sampling Time : 01.50 p.m.
Received Date : 21 May 2026
Analytical Date : 21 May - 01 June 2026
Report Date : 02 June 2026


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *. ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *. ^{2/}	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : บริษัท เทอร์ติโน สวิสท์ จำกัด
Project Name : โครงการ 39 Luxury Suites
Address Project : ซอยสุขุมวิท 39 (ซอยพร้อมจิตร์) ถนนสุขุมวิท
แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
Sampling Point : สระว่ายน้ำส่วนลึก
GPS. Coordinate : 47P 669818 E 1519180 N
Sampling By : TNP ENVIRONMENT CO., LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69003
Sample No : W69003/2
Sample Type : Swimming pool Water
Sampling Date : 18 June 2026
Sampling Time : 02.17 p.m.
Received Date : 19 June 2026
Analytical Date : 19 - 29 June 2026
Report Date : 30 June 2026


Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : บริษัท เทอร์ติโน สวิสท์ จำกัด
 Project Name : โครงการ 39 Luxury Suites
 Address Project : ซอยสุขุมวิท 39 (ซอยพร้อมจิตร์) ถนนสุขุมวิท
 แขวงคลองตันเหนือ เขตวัฒนา กรุงเทพมหานคร 10110
 Sampling Point : สระว่ายน้ำส่วนต้น
 GPS. Coordinate : 47P 669868 E 1519182 N
 Sampling By : TNP ENVIRONMENT CO., LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69003
 Sample No : W69003/3
 Sample Type : Swimming pool Water
 Sampling Date : 18 June 2026
 Sampling Time : 02.18 p.m.
 Received Date : 19 June 2026
 Analytical Date : 19 - 29 June 2026
 Report Date : 30 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
<i>Staphylococcus aureus</i> *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 B	Not Detected	Not Detected
<i>Pseudomonas aeruginosa</i> *, 2/	/100 mL	Standard Methods for the Examination of Water and Wastewater, APHA, AWWA & WEF, 24 th Edition, 2023, Part 9213 E	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Analyzed by Bureau Veritas AQ Lab (Thailand) Limited registration number Wo.-313.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

