

ภาคผนวก ง

ผลการติดตามตรวจสอบคุณภาพสิ่งแวดล้อม

- ง1 คุณภาพน้ำทิ้ง
- ง2 คุณภาพน้ำระเหยน้ำ



ภาคผนวก ง1

คุณภาพน้ำทิ้ง



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยร์่า จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : บ่อพักน้ำทิ้งสุดท้ายก่อนปล่อยออกนอกโครงการ
GPS. Coordinate : 47 P 704635 E 1424954 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69007
Sample No. : W69007/1
Sample Type : Wastewater
Sampling Date : 29 January 2026
Sampling Time : 03.10 p.m.
Received Date : 30 January 2026
Analytical Date : 30 January – 19 February 2026
Report Date : 20 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.1 °C	-	Electrometric Method (4500-H ⁺ B)	7.5	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	69.5	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	289	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	68.1	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	1.22	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	0.1	-
Total Kjeldahl Nitrogen *, ^{3/}	mg/L	APHA:4500-Norg (B) ^{2/}	65	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Smelly		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{3/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : บ่อพักน้ำทิ้งสุดท้ายก่อนปล่อยออกนอกโครงการ
GPS. Coordinate : 47 P 704619 E 1424978 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69007
Sample No. : W69007/1
Sample Type : Wastewater
Sampling Date : 04 February 2026
Sampling Time : 02.18 p.m.
Received Date : 05 February 2026
Analytical Date : 05 – 24 February 2026
Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.1 °C	-	Electrometric Method (4500-H ⁺ B)	7.5	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	24.6	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	343	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	58.6	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.4	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	1.10	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{*, 3/}	mg/L	APHA:4500-Norg (B) ^{2/}	72	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Smelly		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{3/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง จังหวัดชลบุรี 20150
Sampling Point : บ่อน้ำทิ้งสุดท้ายก่อนปล่อยออกนอกโครงการ
GPS. Coordinate : 47P 704627 E 1424960 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69007
Sample No. : W69007/1
Sample Type : Wastewater
Sampling Date : 10 March 2026
Sampling Time : 09.35 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.7 °C	-	Electrometric Method (4500-H ⁺ B)	7.5	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	24.1	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	372	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	65.6	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	< 2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	1.81	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	< 0.1	-
Total Kjeldahl Nitrogen ^{*, 3/}	mg/L	APHA:4500-Norg (B) ^{2/}	61	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Smelly		

Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{3/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{2/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : บ่อน้ำทิ้งสุดท้ายก่อนปล่อยออกนอกโครงการ
GPS. Coordinate : 47P 704617 E 1424953 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69007
Sample No. : W69007/1
Sample Type : Wastewater
Sampling Date : 03 April 2026
Sampling Time : 01.54 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 24 April 2026
Report Date : 27 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.7 °C	-	Electrometric Method (4500-H ⁺ B)	7.6	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	31.8	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	489	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	78.8	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.0	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	1.61	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	0.2	-
Total Kjeldahl Nitrogen *, 2/	mg/L	APHA:4500-Norg (B) ^{3/}	54	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Smelly		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีร์รา จอมเทียน
 Project Name : โครงการ The Riviera Jomtien
 Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
 Sampling Point : บ่อน้ำทิ้งสุดท้ายก่อนปล่อยออกนอกโครงการ
 GPS. Coordinate : 47P 704615 E 1424968 N
 Sampling By : TNP ENVIRONMENT CO.,LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69007
 Sample No. : W69007/1
 Sample Type : Wastewater
 Sampling Date : 08 May 2026
 Sampling Time : 10.05 a.m.
 Received Date : 09 May 2026
 Analytical Date : 09 - 20 May 2026
 Report Date : 21 May 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.7 °C	-	Electrometric Method (4500-H ⁺ B)	7.2	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	37.4	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	378	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Azide Modification Method (4500-O C, 5210 B)	32.6	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.4	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	1.31	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	0.1	-
Total Kjeldahl Nitrogen *, ^{3/}	mg/L	APHA:4500-Norg (B) ^{2/}	50	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Smelly		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024), Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : บ่อน้ำทิ้งสุดท้ายก่อนปล่อยออกนอกโครงการ
GPS. Coordinate : 47P 704627 E 1424954 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Report No. : W69007
Sample No. : W69007/1
Sample Type : Wastewater
Sampling Date : 10 June 2026
Sampling Time : 11.21 a.m.
Received Date : 11 June 2026
Analytical Date : 11 - 25 June 2026
Report Date : 26 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
pH at 24.7 °C	-	Electrometric Method (4500-H ⁺ B)	8.8	5.5-9.0
Total Suspended Solids	mg/L	Dried at 103-105 °C (2540 D)	99.3	≤ 30
Total Dissolved Solids	mg/L	Dried at 180 °C (2540 C)	378	≤ 1,000
Biochemical Oxygen Demand *	mg/L	5-Day BOD Test, Membrane Electrode Method (4500-O G, 5210 B)	48.5	≤ 20
Oil and Grease *	mg/L	Liquid-Liquid Partition Gravimetric Method (5520 B)	2.9	≤ 20
Sulfide *	mg/L	Iodometric Method (4500-S ²⁻ F)	1.00	≤ 1.0
Settleable Solids *	mL/L	Imhoff Cone (2540 F)	1.2	-
Total Kjeldahl Nitrogen *, ^{3/}	mg/L	APHA:4500-Norg (B) ^{2/}	63	≤ 35
Sample Appearance		Yellow/Turbid/Sediment/Smelly		


Standard : Notification of the Ministry of Natural Resources and Environment, under Enhancement and Conservation of National Environmental Quality Act, B.E. 2567 (2024)., Building type A.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ภาคผนวก ง2

คุณภาพน้ำสระว่ายน้ำ



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำสวนลิก ชั้นที่ 1
GPS. Coordinate : 47 P 704630 E 1424942 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/2
Sample Type : Swimming pool Water
Sampling Date : 29 January 2026
Sampling Time : 03.08 p.m.
Received Date : 30 January 2026
Analytical Date : 30 January – 19 February 2026
Report Date : 20 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิตบุศคลอการชุด เดอะ ริวีเยร์ จอมเทียน
 Project Name : โครงการ The Riviera Jomtien
 Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
 Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 1
 GPS. Coordinate : 47 P 704625 E 1424941 N
 Sampling By : TNP ENVIRONMENT CO.,LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
 Sample No : W69007/3
 Sample Type : Swimming pool Water
 Sampling Date : 29 January 2026
 Sampling Time : 03.07 p0m.
 Received Date : 30 January 2026
 Analytical Date : 30 January – 19 February 2026
 Report Date : 20 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 4
GPS. Coordinate : 47 P 704584 E 1424995 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/4
Sample Type : Swimming pool Water
Sampling Date : 29 January 2026
Sampling Time : 03.05 p.m.
Received Date : 30 January 2026
Analytical Date : 30 January – 19 February 2026
Report Date : 20 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริเวียรา จอมเทียน
 Project Name : โครงการ The Riviera Jomtien
 Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
 Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 4
 GPS. Coordinate : 47 P 704584 E 1424993 N
 Sampling By : TNP ENVIRONMENT CO.,LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
 Sample No : W69007/5
 Sample Type : Swimming pool Water
 Sampling Date : 29 January 2026
 Sampling Time : 03.04 p.m.
 Received Date : 30 January 2026
 Analytical Date : 30 January – 19 February 2026
 Report Date : 20 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 37
GPS. Coordinate : 47 P 704489 E 1425005 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/6
Sample Type : Swimming pool Water
Sampling Date : 29 January 2026
Sampling Time : 02.58 p.m.
Received Date : 30 January 2026
Analytical Date : 30 January – 19 February 2026
Report Date : 20 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 37
GPS. Coordinate : 47 P 704559 E 1424958 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/7
Sample Type : Swimming pool Water
Sampling Date : 29 January 2026
Sampling Time : 02.58 p.m.
Received Date : 30 January 2026
Analytical Date : 30 January – 19 February 2026
Report Date : 20 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 42
GPS. Coordinate : 47 P 704616 E 1424923 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/8
Sample Type : Swimming pool Water
Sampling Date : 29 January 2026
Sampling Time : 02.54 p.m.
Received Date : 30 January 2026
Analytical Date : 30 January – 19 February 2026
Report Date : 20 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
 Project Name : โครงการ The Riviera Jomtien
 Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
 Sampling Point : สระว่ายน้ำสวนต้น ชั้นที่ 42
 GPS. Coordinate : 47 P 704707 E 1425136 N
 Sampling By : TNP ENVIRONMENT CO.,LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
 Sample No : W69007/9
 Sample Type : Swimming pool Water
 Sampling Date : 29 January 2026
 Sampling Time : 02.54 p.m.
 Received Date : 30 January 2026
 Analytical Date : 30 January – 19 February 2026
 Report Date : 20 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 1
GPS. Coordinate : 47 P 704634 E 1424943 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/2
Sample Type : Swimming pool Water
Sampling Date : 04 February 2026
Sampling Time : 02.16 p.m.
Received Date : 05 February 2026
Analytical Date : 05 – 24 February 2026
Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยร์่า จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 1
GPS. Coordinate : 47 P 704624 E 1424933 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/3
Sample Type : Swimming pool Water
Sampling Date : 04 February 2026
Sampling Time : 02.15 p.m.
Received Date : 05 February 2026
Analytical Date : 05 – 24 February 2026
Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 4
GPS. Coordinate : 47 P 704596 E 1424997 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/4
Sample Type : Swimming pool Water
Sampling Date : 04 February 2026
Sampling Time : 02.14 p.m.
Received Date : 05 February 2026
Analytical Date : 05 – 24 February 2026
Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
 Project Name : โครงการ The Riviera Jomtien
 Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
 Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 4
 GPS. Coordinate : 47 P 704599 E 1424995 N
 Sampling By : TNP ENVIRONMENT CO.,LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
 Sample No : W69007/5
 Sample Type : Swimming pool Water
 Sampling Date : 04 February 2026
 Sampling Time : 02.13 p.m.
 Received Date : 05 February 2026
 Analytical Date : 05 – 24 February 2026
 Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 37
GPS. Coordinate : 47 P 704620 E 1424962 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/6
Sample Type : Swimming pool Water
Sampling Date : 04 February 2026
Sampling Time : 02.09 p.m.
Received Date : 05 February 2026
Analytical Date : 05 – 24 February 2026
Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำสวนต้น ชั้นที่ 37
GPS. Coordinate : 47 P 704638 E 1424952 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/7
Sample Type : Swimming pool Water
Sampling Date : 04 February 2026
Sampling Time : 02.09 p.m.
Received Date : 05 February 2026
Analytical Date : 05 – 24 February 2026
Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^u	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^u Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
 Project Name : โครงการ The Riviera Jomtien
 Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
 Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 42
 GPS. Coordinate : 47 P 704634 E 1424924 N
 Sampling By : TNP ENVIRONMENT CO.,LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
 Sample No : W69007/8
 Sample Type : Swimming pool Water
 Sampling Date : 04 February 2026
 Sampling Time : 02.05 p.m.
 Received Date : 05 February 2026
 Analytical Date : 05 – 24 February 2026
 Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 42
GPS. Coordinate : 47 P 704617 E 1424895 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/9
Sample Type : Swimming pool Water
Sampling Date : 04 February 2026
Sampling Time : 02.04 p.m.
Received Date : 05 February 2026
Analytical Date : 05 – 24 February 2026
Report Date : 25 February 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 1
GPS. Coordinate : 47P 704628 E 1424942 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/2
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.32 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 1
GPS. Coordinate : 47P 704586 E 1424998 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/3
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.31 a.m.
Received Date : 11 March 2026
Analytical Date : 11 - 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 4
GPS. Coordinate : 47P 704583 E 1424998 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/4
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.28 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 4
GPS. Coordinate : 47P 704585 E 1424998 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/5
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.27 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 37
GPS. Coordinate : 47P 704587 E 1424970 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/6
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.24 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 37
GPS. Coordinate : 47P 704492 E 1424983 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/7
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.24 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 42
GPS. Coordinate : 47P 704621 E 1424931 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/8
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.20 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 42
GPS. Coordinate : 47P 704633 E 1424891 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/9
Sample Type : Swimming pool Water
Sampling Date : 10 March 2026
Sampling Time : 09.20 a.m.
Received Date : 11 March 2026
Analytical Date : 11 – 27 March 2026
Report Date : 30 March 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 1
GPS. Coordinate : 47P 704627 E 1424953 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/2
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.51 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยร์ จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 1
GPS. Coordinate : 47P 704620 E 1424945 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/3
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.51 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 4
GPS. Coordinate : 47P 704570 E 1424987 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/4
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.47 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 4
GPS. Coordinate : 47P 704569 E 1424988 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/5
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.46 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีแย่า จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 37
GPS. Coordinate : 47P 704590 E 1424961 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/6
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.42 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 37
GPS. Coordinate : 47P 704598 E 1424964 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/7
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.41 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 42
GPS. Coordinate : 47P 704621 E 1424927 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/8
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.36 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.





TNP ENVIRONMENT CO.,LTD.

เลขที่ 332/173 หมู่ 3 ตำบลบางรักพัฒนา อำเภอบางบัวทอง จังหวัดนนทบุรี 11110 โทรศัพท์: 02-156-8273

E-mail: tnp.envi@gmail.com เลขประจำตัวผู้เสียภาษี 0125560008957 สำนักงานใหญ่



NSC-TIS-TIS 17025

Testing 1679

ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 42
GPS. Coordinate : 47P 704642 E 1424923 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/9
Sample Type : Swimming pool Water
Sampling Date : 03 April 2026
Sampling Time : 01.36 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 20 April 2026
Report Date : 21 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
Sampling Point : ถังน้ำใช้รดน้ำต้นไม้
GPS. Coordinate : 47P 704645 E 1424879 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/10
Sample Type : Water Supply
Sampling Date : 03 April 2026
Sampling Time : 01.32 p.m.
Received Date : 04 April 2026
Analytical Date : 04 - 24 April 2026
Report Date : 27 April 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Color *	Pt-Co	Spectrophotometric Method (2120 C)	< 5	≤ 15
Turbidity *, ^{3/}	NTU	APHA : 2130 B ^{2/}	0.28	≤ 5.0
Odour *	-	Observation Method	Not Objectionability	-
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : The Department of Health, Criterias of Supplied Drinkable Water Quality, B.E. 2563.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 1
GPS. Coordinate : 47P 704636 E 1424939 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/2
Sample Type : Swimming pool Water
Sampling Date : 08 May 2026
Sampling Time : 10.03 a.m.
Received Date : 09 May 2026
Analytical Date : 09 - 20 May 2026
Report Date : 21 May 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 1
GPS. Coordinate : 47P 704627 E 1424931 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/3
Sample Type : Swimming pool Water
Sampling Date : 08 May 2026
Sampling Time : 10.03 a.m.
Received Date : 09 May 2026
Analytical Date : 09 - 20 May 2026
Report Date : 21 May 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 4
GPS. Coordinate : 47P 704591 E 1424997 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/4
Sample Type : Swimming pool Water
Sampling Date : 08 May 2026
Sampling Time : 10.01 a.m.
Received Date : 09 May 2026
Analytical Date : 09 - 20 May 2026
Report Date : 21 May 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 4
GPS. Coordinate : 47 P 704583 E 1425003 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/5
Sample Type : Swimming pool Water
Sampling Date : 08 May 2026
Sampling Time : 10.00 a.m.
Received Date : 09 May 2026
Analytical Date : 09 - 20 May 2026
Report Date : 21 May 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 37
GPS. Coordinate : 47P 704559 E 1424963 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/6
Sample Type : Swimming pool Water
Sampling Date : 08 May 2026
Sampling Time : 09.57 a.m.
Received Date : 09 May 2026
Analytical Date : 09 - 20 May 2026
Report Date : 21 May 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำสวนต้น ชั้นที่ 37
GPS. Coordinate : 47P 704511 E 1424933 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/7
Sample Type : Swimming pool Water
Sampling Date : 08 May 2026
Sampling Time : 09.57 a.m.
Received Date : 09 May 2026
Analytical Date : 09 - 20 May 2026
Report Date : 21 May 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
 Project Name : โครงการ The Riviera Jomtien
 Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
 จังหวัดชลบุรี 20150
 Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 42
 GPS. Coordinate : 47P 704632 E 1424939 N
 Sampling By : TNP ENVIRONMENT CO.,LTD.
 Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
 Sample No : W69007/8
 Sample Type : Swimming pool Water
 Sampling Date : 08 May 2026
 Sampling Time : 09.52 a.m.
 Received Date : 09 May 2026
 Analytical Date : 09 - 20 May 2026
 Report Date : 21 May 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 42
GPS. Coordinate : 47P 704595 E 1424948 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/9
Sample Type : Swimming pool Water
Sampling Date : 08 May 2026
Sampling Time : 09.52 a.m.
Received Date : 09 May 2026
Analytical Date : 09 - 20 May 2026
Report Date : 21 May 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 1
GPS. Coordinate : 47P 704632 E 1424952 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/2
Sample Type : Swimming pool Water
Sampling Date : 10 June 2026
Sampling Time : 11.19 a.m.
Received Date : 11 June 2026
Analytical Date : 11 - 25 June 2026
Report Date : 26 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 1
GPS. Coordinate : 47P 704625 E 1424942 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/3
Sample Type : Swimming pool Water
Sampling Date : 10 June 2026
Sampling Time : 11.18 a.m.
Received Date : 11 June 2026
Analytical Date : 11 - 25 June 2026
Report Date : 26 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 4
GPS. Coordinate : 47P 704588 E 1424968 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/4
Sample Type : Swimming pool Water
Sampling Date : 10 June 2026
Sampling Time : 11.16 a.m.
Received Date : 11 June 2026
Analytical Date : 11 - 25 June 2026
Report Date : 26 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 4
GPS. Coordinate : 47P 704581 E 1424987 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/5
Sample Type : Swimming pool Water
Sampling Date : 10 June 2026
Sampling Time : 11.16 a.m.
Received Date : 11 June 2026
Analytical Date : 11 - 25 June 2026
Report Date : 26 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 37
GPS. Coordinate : 47P 704590 E 1424963 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/6
Sample Type : Swimming pool Water
Sampling Date : 10 June 2026
Sampling Time : 11.12 a.m.
Received Date : 11 June 2026
Analytical Date : 11 - 25 June 2026
Report Date : 26 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิตบุคคณาการชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 37
GPS. Coordinate : 47P 704594 E 1424964 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/7
Sample Type : Swimming pool Water
Sampling Date : 10 June 2026
Sampling Time : 11.12 a.m.
Received Date : 11 June 2026
Analytical Date : 11 - 25 June 2026
Report Date : 26 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนลึก ชั้นที่ 42
GPS. Coordinate : 47P 704624 E 1424929 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/8
Sample Type : Swimming pool Water
Sampling Date : 10 June 2026
Sampling Time : 11.08 a.m.
Received Date : 11 June 2026
Analytical Date : 11 - 25 June 2026
Report Date : 26 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริเวียรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : สระว่ายน้ำส่วนต้น ชั้นที่ 42
GPS. Coordinate : 47P 704628 E 1424925 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory


Customer Code : W69007
Sample No : W69007/9
Sample Type : Swimming pool Water
Sampling Date : 10 June 2026
Sampling Time : 11.08 a.m.
Received Date : 11 June 2026
Analytical Date : 11 - 25 June 2026
Report Date : 26 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Total Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 B)	< 1.8	< 10
Fecal Coliform Bacteria *	MPN/100 mL	Multiple-Tube Fermentation Technique (9221 E)	Not Detected	Not Detected
Sample Appearance		Clear/Odorless		

Standard : Public Health Commission Recommendation (No. 1) B.E. 2550 (2007), on the control of the operation swimming pools or other.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.



ANALYSIS REPORT

Data Provided by Customer

Customer Name : นิติบุคคลอาคารชุด เดอะ ริวีเยรา จอมเทียน
Project Name : โครงการ The Riviera Jomtien
Address Project : เลขที่ 29/72 หมู่ที่ 12 ตำบลหนองปรือ อำเภอบางละมุง
จังหวัดชลบุรี 20150
Sampling Point : ถังน้ำใช้รดน้ำ
GPS. Coordinate : 47P 704642 E 1424897 N
Sampling By : TNP ENVIRONMENT CO.,LTD.
Sampling Method : Grab Sampling

Data Provided by Laboratory

Customer Code : W69007
Sample No : W69007/10
Sample Type : Water Supply
Sampling Date : 10 June 2026
Sampling Time : 11.03 a.m.
Received Date : 11 June 2026
Analytical Date : 11 - 25 June 2026
Report Date : 26 June 2026

Parameter	Unit	Analytical Method ^{1/}	Result	Standard
Color *	Pt-Co	Spectrophotometric Method (2120 C)	< 5	≤ 15
Odour *	-	Observation Method	Not Objectionability	-
<i>Escherichia coli</i> *	/100 mL	Multiple-Tube Fermentation Technique (9221 F)	Not Detected	Not Detected
Turbidity ^{2/}	NTU	APHA : 2130 B ^{2/}	0.37	≤ 5.0
Sample Appearance		Clear/Odorless		

Standard : The Department of Health, Criterias of Supplied Drinkable Water Quality, B.E. 2563.

Remark ^{1/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 24th edition 2023.

^{2/} Standard Methods for the Examination of Water and Wastewater., APHA, AWWA, WEF, 23rd edition 2017.

^{3/} Analyzed by Environment & Laboratory Co.,Ltd. Registration number Wo-029.

* This item is out the scope ISO/IEC 17025:2017 Accreditation.

